

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0204048  
APS ID 1008446  
Authorization ID 1300097

**Applicant and Facility Information**

Applicant Name	<u>Conemaugh Township Municipal Water &amp; Sewer Authority</u>	Facility Name	<u>Tunnelton STP</u>
Applicant Address	<u>16980 Route 286 Highway W</u> <u>Saltsburg, PA 15681-8023</u>	Facility Address	<u>Tunnelton Road (SR 3003)</u> <u>Tunnelton, PA 15725</u>
Applicant Contact	<u>Scott Corbin</u>	Facility Contact	<u>Chuck Ishman</u>
Applicant Phone	<u>(724) 639-9024</u>	Facility Phone	<u>(724) 801-8169 Ext. 12</u>
Client ID	<u>114983</u>	Site ID	<u>259187</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Conemaugh Township</u>
Connection Status	<u>No Connection Prohibitions</u>	County	<u>Indiana</u>
Date Application Received	<u>December 11, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 31, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an existing discharge to treated domestic sewage from a POTW.</u>		

**Summary of Review**

No changes to discharge quantity or quality were proposed as part of this permit renewal.

Permittee began using eDMR system for reporting in January 2016.

There are currently no open violations listed in EFACTS for this permittee (2/22/2021).

Chapter 94 reports have been incomplete or not submitted. The Department's permitting section will follow up with the compliance section prior to final permit issuance.

Sludge use and disposal description and location(s): Biosolids are land applied at Adam Skokut Farm, South Huntington Township, Westmoreland County under NPDES Permit PAG 09-6113

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam Pesek Adam J. Pesek, E.I.T. / Environmental Engineering Specialist	February 24, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	February 26, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0095</u>
Latitude	<u>40° 27' 19"</u>	Longitude	<u>-79° 23' 30"</u>
Quad Name	<u>Saltsburg</u>	Quad Code	<u>01510</u>
Wastewater Description: <u>Treated Sewage Effluent</u>			
Receiving Waters	<u>Conemaugh River</u>	Stream Code	<u>43832</u>
NHD Com ID	<u>123722194</u>	RMI	<u>5.57</u>
Drainage Area	<u>1358</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.2069</u>
Q <sub>7-10</sub> Flow (cfs)	<u>281</u>	Q <sub>7-10</sub> Basis	<u>USGS #03041500 ('92-'17)</u>
Elevation (ft)	<u>846</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>18-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>DEWATERING, FLOW REGIME MODIFICATION, METALS</u>		
Source(s) of Impairment	<u>ACID MINE DRAINAGE, DAM OR IMPOUNDMENT, IMPACTS FROM HYDROSTRUCTURE FLOW REGULATION/MODIFICATION</u>		
TMDL Status	<u>Final</u>	Name	<u>Kiskiminetas-Conemaugh River Watersheds TMDL</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.49</u>		<u>8/17/2020 stream sample at SR 3003 Bridge in Tunnelton</u>
Temperature (°C)	<u>25</u>		<u>Default WWF</u>
Hardness (mg/L)	<u>281</u>		<u>8/17/2020 stream sample at SR 3003 Bridge in Tunnelton</u>
Other: NH <sub>3</sub> -N	<u>0.04</u>		<u>8/17/2020 stream sample at SR 3003 Bridge in Tunnelton</u>
Nearest Downstream Public Water Supply Intake	<u>Buffalo Township Municipal Authority, Freeport, PA</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2,390</u>
PWS RMI	<u>29.4</u>	Distance from Outfall (mi)	<u>31.4</u>

Changes Since Last Permit Issuance: Stream yield rate was updated based on newer gage flow data. The Saltsburg Municipal WTP Plant PWS Intake is no longer operational.

Other Comments: As was previously implemented, only 5% of the total streamflow was allocated for this discharge as a conservative measure for modeling considerations. There the streamflow at the discharge point is 0.05 x 281 = 15.05 cfs.

Available dilution ratio is therefore 15.05 cfs : 0.0146 7 cfs (0.0095 MGD) = 956 to 1.

Past experience indicates a dilution ratio of 500:1 or greater, water quality modeling should indicate secondary limits are appropriate. WQM 7.0 modeling will still be conducted to verify this statement.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Tunnelton STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
3289406		11/20/1989		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Chlorination	0.0095
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0095	16	Unknown		Land Application

Changes Since Last Permit Issuance: N/A

Other Comments: Treatment system consists of an equalization basin, two aeration chambers, two clarifiers, sludge holding tank, chlorination, and chlorine contact tank.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	Permittee has been consistently meeting existing limits
<b>Summary of Inspections:</b>	No inspections conducted in the previous 5 years.

Other Comments: Status of Chapter 94 reports is unknown.

Compliance History

DMR Data for Outfall 001 (from January 1, 2020 to December 31, 2020)

Parameter	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20
Flow (MGD) Average Monthly	0.0049	0.00179 5	0.00229 7	0.00473 2	0.00458	0.00322	0.00275	0.00341	0.00557	0.00926 1	0.008	0.00460 6
pH (S.U.) Minimum	7.0	6.9	6.8	6.6	6.5	6.5	6.3	6.7	6.6	6.5	7.0	6.8
pH (S.U.) Maximum	7.3	7.4	7.6	7.5	7.6	7.4	7.4	7.4	7.6	7.4	7.4	7.5
DO (mg/L) Minimum	4.5	7.2	6.79	6.00	7.27	6.8	6.0	6.13	5.85	5.94	7.0	7.1
TRC (mg/L) Average Monthly	0.27	0.23	0.16	0.32	0.34	0.30	0.17	0.13	0.18	0.26	0.25	0.22
TRC (mg/L) Instantaneous Maximum	0.5	0.43	0.47	0.50	0.52	0.62	0.41	0.4	0.47	0.45	0.49	0.48
CBOD5 (mg/L) Average Monthly	< 3.0	4.25	< 4.01	< 5.7	< 3.0	< 9.4	3.7	< 3.92	6.11	< 3.0	3.38	< 3.0
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	5.12	5.01	8.39	< 3.0	15.7	4.3	4.83	9.01	< 3.0	3.68	< 3.0
TSS (mg/L) Average Monthly	3.8	2.6	2.4	< 1.6	< 3.4	< 3.0	4.0	< 1.2	< 3.0	< 2.1	4.71	6.2
TSS (mg/L) Instantaneous Maximum	6.8	3.8	3.2	< 1.6	6.0	4.4	6.00	< 1.6	4.4	3.4	8.22	6.8
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 2	< 1	< 1	< 1.0	< 1	< 1	< 2	9	29	97	3.0
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1	4.1	< 1	< 1	< 1.0	< 1	< 1	3.1	40.4	51.2	435	5.2
Ammonia (mg/L) Average Monthly	< 0.1	< 1.612	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	1.382	< 0.1	< 3	< 0.1
Ammonia (mg/L) Instantaneous Maximum	< 0.1	3.124	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	1.471	< 0.1	5.9	< 0.1

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.0095</u>
<b>Latitude</b> <u>40° 27' 19.00"</u>	<b>Longitude</b> <u>-79° 23' 31.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
N/A			

Comments: WQM 7.0 modeling and the TRC calc spreadsheet determined secondary treatment limits were protective of the receiving stream.

**Best Professional Judgment (BPJ) Limitations**

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l, a TRC IMAX limit of 1.6, and monitoring for ammonia nitrogen, total nitrogen and total phosphorus was placed in the permit in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.”

Influent monitoring for TSS and BOD<sub>5</sub> was placed in the permit in accordance with the Department’s SOP entitled “New and Reissuance of Sewage Individual NPDES Permit Applications (SOP No. BCW-PMT-002).”

The requirement to monitor Iron, Manganese and Aluminum once per year is being continued in this permit renewal in accordance with the Conemaugh River Basin TMDL.

Flow monitoring is being retained as authorized under Chapter 92a.61.

**Anti-Backsliding**

N/A

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	3/week	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	3/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	3/week	Grab
CBOD5	1.9	XXX	XXX	25.0	XXX	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS	2.3	XXX	XXX	30.0	XXX	60	2/month	Grab
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia May 1 - Oct 31	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Aluminum	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Iron	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Manganese	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments: As part of a permit amendment in the previous permit cycle, the Authority requested that the Department amend their NPDES Permit to decrease the monitoring frequency for dissolved oxygen, TRC and pH from 1/day to 3/week due to the additional cost of testing. The Authority had stated that it only has 37 customers and is a lower income community. The Authority further claimed that the additional cost will increase the customer's monthly bill to an unreasonable and unaffordable amount and will put its customers in hardship to pay for service. This may result in more delinquent payments and actually jeopardize funding to keep the plant operating. A review of the eDMR data for these three parameters since 2016 indicates they are meeting the existing limits. Therefore, 3/week sampling frequency for dissolved oxygen, TRC and pH will be retained in this permit renewal.



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43832	CONEMAUGH RIVER	5.570	846.00	1358.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.207	15.05	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.49	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Tunnelton STP	PA0204048	0.0095	0.0000	0.0000	0.000	20.00	6.80

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.04	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43832	CONEMAUGH RIVER	4.180	841.00	1370.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.207	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.49	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18C		43832				CONEMAUGH RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
5.570	15.05	0.00	15.05	.0147	0.00068	1.025	88.29	86.12	0.17	0.510	25.00	7.49
<b>Q1-10 Flow</b>												
5.570	9.63	0.00	9.63	.0147	0.00068	NA	NA	NA	0.13	0.655	24.99	7.49
<b>Q30-10 Flow</b>												
5.570	20.47	0.00	20.47	.0147	0.00068	NA	NA	NA	0.20	0.430	25.00	7.49

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

**SWP Basin**      **Stream Code**                      **Stream Name**  
18C                      43832                                      CONEMAUGH RIVER

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
5.570	Tunnelton STP	4.18	50	4.18	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
5.570	Tunnelton STP	1.01	25	1.01	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
5.57	Tunnelton STP	25	25	25	25	4	4	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18C	43832	CONEMAUGH RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
5.570	0.009	24.995	7.488	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
88.289	1.025	86.123	0.166	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.02	0.012	0.06	1.028	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.537	0.871	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.510	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.051	2.02	0.06	7.54
	0.102	2.02	0.06	7.54
	0.153	2.02	0.05	7.54
	0.204	2.02	0.05	7.54
	0.255	2.01	0.05	7.54
	0.306	2.01	0.05	7.54
	0.357	2.01	0.04	7.54
	0.408	2.01	0.04	7.54
	0.459	2.01	0.04	7.54
	0.510	2.01	0.04	7.54

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18C		43832		CONEMAUGH RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
5.570	Tunnelton STP	PA0204048	0.009	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

<b>TRC EVALUATION</b>		<b>Girard Boro STP - Outfall 001</b>	
Input appropriate values in B4:B8 and E4:E7			
281.00	= Q stream (cfs)	0.5	= CV Daily
0.010	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	0.066	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	0	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)	0	=Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference CFC Calculations
TRC PENTOXSD	1.3.2.iii 5.1a	WLA_afc = 0.643 LTAMULT	1.3.2.iii 5.1c WLA_cfc = 0.863 LTAMULT_cfc =
TRG PENTOXSD	5.1b	afc = 0.373	5.1d 0.581
TRG		LTA_afc = 0.240	LTA_cfc = 0.502
Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML_MULT = 1.231 AVG MON LIMIT (mg/l) =	AFC
PENTOXSD TRG	5.1g	0.295 INST MAX LIMIT (mg/l) =	0.964
WLA_afc	$\{0.019/e(-k*AFC\_tc)\} + \{[(AFC\_Yc*Qs*.019/Qd)*e(-k*AFC\_tc)]\} \dots$ $\dots + Xd + (AFC\_Yc*Qs*Xs/Qd) * (1-FOS/100) \text{ EXP}((0.5*LN(cvh^2+1)) - 2.326*LN(cvh^2+1)^{0.5})$ wla_afc*LTAMULT_afc		
LTAMULT_afc	$\{0.011/e(-k*CFC\_tc)\} + \{[(CFC\_Yc*Qs*.011/Qd)*e(-k*CFC\_tc)]\} \dots$ $\dots + Xd + (CFC\_Yc*Qs*Xs/Qd) * (1-FOS/100)$ EXP((0.5*LN(cvd^2/no_samples+1)) - 2.326*LN(cvd^2/no_samples+1)^{0.5}) wla_cfc*LTAMULT_cfc		
LTA_afc	EXP(2.326*LN((cvd^2/no_samples+1)^{0.5}) - 0.5*LN(cvd^2/no_samples+1))		
WLA_cfc	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc)*AML_MULT)		
LTAMULT_cfc	$1.5*((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)$		
LTA_cfc			
AML_MULT			
AVG MON LIMIT			
INST MAX LIMIT			



Tunnelton STP  
Conemaugh Township, Indiana County  
NPDES# PA0204048

Date	pH min	pH max	Ave (10^pH min			
			10^-pH min	10^-pH max	& pH max)	-Log (Ave pH)
Jul-18	6.1	7.2	7.94E-07	6.31E-08	4.29E-07	<b>6.4</b>
Aug-18	6.5	7.3	3.16E-07	5.01E-08	1.83E-07	<b>6.7</b>
Sep-18	6.8	7.7	1.58E-07	2E-08	8.92E-08	<b>7.0</b>
Jul-19	6.6	7.4	2.51E-07	3.98E-08	1.45E-07	<b>6.8</b>
Aug-19	6.5	7.5	3.16E-07	3.16E-08	1.74E-07	<b>6.8</b>
Sep-19	6.7	7.1	2E-07	7.94E-08	1.39E-07	<b>6.9</b>
Jul-20	6.5	7.4	3.16E-07	3.98E-08	1.78E-07	<b>6.7</b>
Aug-20	6.5	7.6	3.16E-07	2.51E-08	1.71E-07	<b>6.8</b>
Sep-20	6.6	7.5	2.51E-07	3.16E-08	1.41E-07	<b>6.8</b>
					Median:	<b>6.8</b>