

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0204498
 APS ID 1021932
 Authorization ID 1324250

Applicant and Facility Information

Applicant Name	<u>Marion Center School District</u>	Facility Name	<u>Rayne Township Elementary School</u>
Applicant Address	<u>22820 Route 403 Highway N, PO Box 156 Marion Center, PA 15759-0156</u>	Facility Address	<u>2535 US 119 Home, PA 15747-8801</u>
Applicant Contact	<u>Kenneth Kirkland</u>	Facility Contact	<u>Kenneth Kirkland</u>
Applicant Phone	<u>(724) 397-5551</u>	Facility Phone	<u>(724) 397-5551</u>
Client ID	<u>7896</u>	Site ID	<u>259346</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Rayne Township</u>
Connection Status		County	<u>Indiana</u>
Date Application Received	<u>August 11, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 27, 2020</u>	If No, Reason	
Purpose of Application	<u>Minor Sewage Treatment Facility NPDES Permit Renewal.</u>		

Summary of Review

Act 14 – Proof of notification were submitted and received.

There are no open violations for subject client no. 7896 as of 10/25/2021.

This facility is currently submitting eDMR reports.

There has been no change to the discharge or receiving stream since the last permit issuance.

Sludge use and disposal description and location(s): Septage must be pumped and hauled off-site by a septage hauler for land application under a general permit authorized by DEP or disposal at an STP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jon F. Bucha Jonathan F. Bucha / Civil Engineer General	October 25, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	October 29, 2021

Treatment Facility Summary				
Treatment Facility Name: Rayne Township Elementary School				
WQM Permit No.		Issuance Date		
362S23		September 20, 1962		
362S23 A-1		December 9, 1999		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia removal	Extended Aeration	Chlorine	0.00189
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0068	31.2	Not Overloaded	Holding Tank	

Changes Since Last Permit Issuance: None

Other Comments: Treatment consists of a grinder, aeration tank, clarifier, and chlorination.

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.00210		0.00180	0.00180	0.00180	0.00195	0.00105	0.00180	0.00190	0.00190	0.00197	0.00200
pH (S.U.) Minimum	7.17		7.50	6.37	7.34	7.29	7.33	7.40	7.44	7.34	7.36	7.22
pH (S.U.) Maximum	7.99		8.05	7.95	8.39	8.54	8.29	8.46	8.25	8.30	8.31	8.10
DO (mg/L) Minimum	6.86		8.10	8.01	8.48	7.29	10.24	11.05	10.30	9.89	9.05	8.02
TRC (mg/L) Average Monthly	0.30		0.23	0.23	0.35	0.30	0.39	0.36	0.32	0.30	0.25	0.44
TRC (mg/L) Instantaneous Maximum	0.74		0.55	0.40	0.91	0.69	0.98	1.01	0.69	0.56	0.67	1.17
CBOD5 (mg/L) Average Monthly	3.2		3.0	3.0	3.2	6.0	5.7	< 3.0	4.7	3.0	< 3.0	3
CBOD5 (mg/L) Instantaneous Maximum	3.4		3.0	3.0	3.4	7.6	6.2	< 3.0	6.4	3.0	< 3.0	3
TSS (mg/L) Average Monthly	8.5		9.0	8.5	13.0	23	27.5	15.5	12.5	18.5	10	17.5
TSS (mg/L) Instantaneous Maximum	9.0		11.0	12.0	14.0	25	34.0	18.0	13.0	19.0	10	20.0
Fecal Coliform (CFU/100 ml) Geometric Mean	133		23	8	1.0	38	50.0	10.0	25	9.0	14	11
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	981		489	11	1.0	1414	2420	43.0	613	16.0	192	11
Total Nitrogen (mg/L) Daily Maximum									96.4			
Ammonia (mg/L) Average Monthly	0.41		0.28	0.34	0.73	2.12	1.95	1.82	0.22	0.56	0.35	0.31
Ammonia (mg/L) Instantaneous Maximum	0.54		0.33	0.37	0.82	3.02	3.14	3.41	0.24	0.58	0.46	0.39
Total Phosphorus (mg/L) Daily Maximum									5.44			

Compliance History

Comments: A review of the past 3 years of eDMR data shows that this facility has had no effluent exceedances in that time period. This treatment system is in good operational condition.

Inspections: An inspection occurred on 11/20/2017, where no violations were noted.

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	.00676
Latitude	40° 42' 10.00"	Longitude	-79° 6' 9.00"
Wastewater Description: Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: TRC limits will remain at the technology-based limits of 0.5 mg/L average monthly and 1.6 mg/L imax, based on this facility being designed and constructed before the issuance of dry stream guidance, and significant dilution being available at Crooked Creek (WWF).

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD ₅	15.0	Average Monthly	WQM 7.0
Ammonia Nitrogen	4.5	Average Monthly	WQM 7.0

Comments: Modeling conditions for this treatment facility is a dry drainage swale leading into an intermittent stream. CBOD₅ limit is more stringent than the previous renewal, changing from the technology-based limit of 25 mg/L, to a water quality-based limit of 15 mg/L.

Ammonia Nitrogen has been calculated as $C_0 = C_t * e^{kt} = 3.62 * e^{(0.7)(0.295)} = 4.5$ mg/L. Ammonia Nitrogen limits will be carried over from the previous permit renewal based on current eDMR data, anti-backsliding considerations, and future protection of designated stream uses. Therefore, average monthly ammonia nitrogen limits will be 2.0 mg/L and 3.5 mg/L for summertime and wintertime respectively.

Best Professional Judgment (BPJ) Limitations

Comments: Once per year monitoring for Total Nitrogen, Total Phosphorus, and E. Coli monitoring is based on Ch. 92a.61 and the Departments SOP for Establishing Effluent Limitations for Individual Sewage Permits (SOP No. BPNPSM-PMT-033). E. Coli monitoring is a new addition to this permit renewal.

Monitoring frequency for DO, pH, and TRC will remain at 1/weekday due to the school being closed, and not staffed on weekends. Dissolved Oxygen limit will remain at 6 mg/L as specified in the dry stream guidance (Doc # 391-2000-014).

Anti-Backsliding

Anti-Backsliding considerations do not apply since the effluent limitations have not been relaxed from the previous permit renewal.

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/weekday	Grab
DO	XXX	XXX	6.0 Daily Min	XXX	XXX	XXX	1/weekday	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/weekday	Grab
CBOD5	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	3.5	XXX	7.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection.

Attachment A – eMAP Stream Designation




Attachment B – Streamstats Drainage Area (Discharge Point)



Attachment C – Streamstats Drainage Area (End of Drainage Swale)

Region ID: PA
Workspace ID: PA20211022182758224000
Clicked Point (Latitude, Longitude): 40.70374, -79.10819
Time: 2021-10-22 14:28:21 -0400


PA
 PA20211022182758224000
 40.70374, -79.10819
 2021-10-22 14:28:21 -0400



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.0362	squa
ELEV	Mean Basin Elevation	1282	feet


Attachment D – Streamstats Drainage Area (Intermittent Stream Confluence)

<p>Region ID:</p> <p>Workspace ID:</p> <p>Clicked Point (Latitude, Longitude):</p> <p>Time:</p>	<p>PA</p> <p>PA20211022185613652000</p> <p>40.70369, -79.10845</p> <p>2021-10-22 14:56:32 -0400</p>
---	---



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.32	square
ELEV	Mean Basin Elevation	1308	feet

Attachment E – Streamstats Drainage Area (End of Unnamed Trib 46832)



Attachment F – WQM 7.0 Modeling (Drainage Swale Reach)

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
17E	46832	Trib 46832 to Crooked Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.280	Rayne Twp Elem	PA0204498	0.000	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
17E	46832	Trib 46832 to Crooked Creek			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
0.280	0.007	20.000		7.500	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
0.584	0.321	1.817		0.058	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
24.15	1.500	24.15		0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
4.143	26.233	Owens		NA	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>				
0.295	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
	0.030	23.11	23.66	4.19	
	0.059	22.11	23.18	4.29	
	0.089	21.15	22.70	4.41	
	0.118	20.23	22.24	4.54	
	0.148	19.35	21.78	4.67	
	0.177	18.52	21.34	4.80	
	0.207	17.71	20.90	4.93	
	0.236	16.95	20.47	5.05	
	0.266	16.21	20.05	5.17	
	0.295	15.51	19.64	5.29	

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46832	Trib 46832 to Crooked Creek	0.280	1290.00	0.01	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.037	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Rayne Twp Elem	PA0204498	0.0000	0.0000	0.0068	0.000	20.00	7.50

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	0.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46832	Trib 46832 to Crooked Creek	0.001	1173.00	0.04	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.037	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
17E	46832	Trib 46832 to Crooked Creek										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
0.280	0.00	0.00	0.00	.0105	0.07942	.321	.58	1.82	0.06	0.295	20.00	7.50
Q1-10 Flow												
0.280	0.00	0.00	0.00	.0105	0.07942	NA	NA	NA	0.00	0.000	0.00	0.00
Q30-10 Flow												
0.280	0.00	0.00	0.00	.0105	0.07942	NA	NA	NA	0.00	0.000	0.00	0.00

WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17E	46832	Trib 46832 to Crooked Creek

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.28	Rayne Twp Elem	25	25	25	25	4	4	0	0

Attachment G – WQM 7.0 Modeling (Intermittent Reach)

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
17E	46832	Trib 46832 to Crooked Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.570	Rayne Twp Elem	PA0204498	0.000	CBOD5	15.51		
				NH3-N	3.62	7.24	
				Dissolved Oxygen			5.29

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
17E	46832	Trib 46832 to Crooked Creek			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>		<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
1.570	0.007		20.000		7.500
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>		<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
2.306	0.276		8.371		0.035
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>		<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
7.32	1.500		1.71		0.700
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>		<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.850	24.872		Owens		6
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>				
2.749	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.275	4.84	1.41	8.24	
	0.550	3.21	1.16	8.24	
	0.825	2.12	0.96	8.24	
	1.099	1.41	0.79	8.24	
	1.374	0.93	0.65	8.24	
	1.649	0.62	0.54	8.24	
	1.924	0.41	0.44	8.24	
	2.199	0.27	0.37	8.24	
	2.474	0.18	0.30	8.24	
	2.749	0.12	0.25	8.24	

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46832	Trib 46832 to Crooked Creek	1.570	1172.00	0.32	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.037	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Rayne Twp Elem	PA0204498	0.0000	0.0000	0.0068	0.000	20.00	7.50

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	15.51	0.00	0.00	1.50
Dissolved Oxygen	5.29	8.24	0.00	0.00
NH3-N	19.64	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46832	Trib 46832 to Crooked Creek	0.001	1054.00	1.63	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	(cfs)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.037	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
17E		46832		Trib 46832 to Crooked Creek								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.570	0.01	0.00	0.01	.0105	0.01424	.276	2.31	8.37	0.03	2.749	20.00	7.50
Q1-10 Flow												
1.570	0.01	0.00	0.01	.0105	0.01424	NA	NA	NA	0.03	3.093	20.00	7.50
Q30-10 Flow												
1.570	0.02	0.00	0.02	.0105	0.01424	NA	NA	NA	0.04	2.493	20.00	7.50

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17E	46832	Trib 46832 to Crooked Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.570	Rayne Twp Elem	5.85	10.05	5.85	10.05	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.570	Rayne Twp Elem	1.43	3.62	1.43	3.62	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.57	Rayne Twp Elem	15.51	15.51	3.62	3.62	5.29	5.29	0	0

Attachment H – Discharge pH

Rayne Twp Elem School							
Rayne Twp, Indiana County							
PA0204498							
Discharge pH							
Date	pH min	pH max	10 ⁻ pH min	10 ⁻ pH max	& pH max)	-Log (Ave pH)	
Aug-21	7.17	7.99	6.76083E-08	1.0233E-08	3.8921E-08	7.4	
Sep-20	7.22	8.1	6.0256E-08	7.9433E-09	3.41E-08	7.5	
Sep-19	7.5	8.6	3.16228E-08	2.5119E-09	1.7067E-08	7.8	
Aug-19	7.1	8.11	7.94328E-08	7.7625E-09	4.3598E-08	7.4	
Sep-18	7.19	8.38	6.45654E-08	4.1687E-09	3.4367E-08	7.5	
Aug-18	7.27	8.32	5.37032E-08	4.7863E-09	2.9245E-08	7.5	
Sep-17	7.15	8.3	7.07946E-08	5.0119E-09	3.7903E-08	7.4	
Sep-16	6.38	7.46	4.16869E-07	3.4674E-08	2.2577E-07	6.6	
Sep-15	7.42	8.46	3.80189E-08	3.4674E-09	2.0743E-08	7.7	
Aug-15	8.3	8.66	5.01187E-09	2.1878E-09	3.5998E-09	8.4	
					Median:	7.5	