

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0205257
APS ID 827945
Authorization ID 1272297

Applicant and Facility Information

Applicant Name	<u>Greensboro Monongahela Township Joint Sewer Authority</u>	Facility Name	<u>Greensboro Monongahela Township Joint Sewer Authority STP</u>
Applicant Address	<u>PO Box 342 Greensboro, PA 15338</u>	Facility Address	<u>Stony Hill Road Greensboro, PA 15338</u>
Applicant Contact	<u>Mr. William Monahan</u>	Facility Contact	<u>Mr. James Vance</u>
Applicant Phone	<u>(724) 943-3000</u>	Facility Phone	<u>(412) 965-4061</u>
Client ID	<u>87536</u>	Site ID	<u>443112</u>
Ch 94 Load Status	<u>Existing Hydraulic and Organic Overload</u>	Municipality	<u>Monongahela Township</u>
Connection Status	<u>Dept. Imposed Connection Prohibitions</u>	County	<u>Greene</u>
Date Application Received	<u>May 6, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 7, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for a renewal of an existing NPDES permit for the discharge of treated Sewage.</u>		

Summary of Review

The applicant has applied for a renewal of an existing NPDES Permit, Permit No. PA0205257, which was previously issued by the Department on May 1, 2014. That permit expired on May 31, 2019.

Latitude and Longitude information for this facility was updated to accurately reflect the location of the STP/Outfall # 001.

WQM Permit No. 3091402 A-2, issued on May 19, 2009, approved construction of a STP with a design flow rate of 0.165 MDG. The existing treatment process consists of a three train activated sludge STP with aerobic digestion and UV disinfection.

The receiving stream, Monongahela River, is classified as a WWF, and is located in State Watershed No. 19-G.

The applicant has complied with Act 14 Notifications and no comments were received.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		William C. Mitchell William C. Mitchell, E.I.T. / Project Manager	April 10, 2020
X		Christopher Kriley Christopher Kriley, P.E. / Program Manager	April 10, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.165</u>
Latitude	<u>39° 47' 58.00"</u>	Longitude	<u>-79° 54' 39.00"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99417488</u>	RMI	<u>83.4</u>
Drainage Area	<u>4,447</u>	Yield (cfs/mi ²)	<u>N/A</u>
Q ₇₋₁₀ Flow (cfs)	<u>480.0</u>	Q ₇₋₁₀ Basis	<u>US Army Corp of Engineers</u>
Elevation (ft)	<u>780</u>	Slope (ft/ft)	<u>N/A</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>PCB; Chlordane</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Dunkard Valley Joint Municipal Authority.</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI		Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance: NONE

Other Comments: The STP discharges indirectly to the Monongahela River which has an EPA Approved TMDL and is impaired by PCBs and Chlordane. No WLAs have been developed for this sewage discharge as neither PCB nor Chlordane is typically found in sewage, but instead found in legacy sediments. This sewage discharge is not expected to add to the impairment of the receiving stream.

Treatment Facility Summary				
Treatment Facility Name: Greensboro Monongahela Township Joint Sewer Authority STP				
WQM Permit No.	Issuance Date			
3091402 A-2	May 19, 2009			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge with Solids Removal	UV Disinfection	0.070 - 2018
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.165	280.0	Existing Hydraulic and Organic Overload	Aerobic Digestion	Hauled to Franklin Twp. WWTF, PA0046426

Changes Since Last Permit Issuance: NONE

Compliance History

Other Comments: An Operations Compliance Check Report for this facility was requested and will be included in the Fact Sheet Addendum.

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.165
 Latitude 39° 47' 58.00" Longitude -79° 54' 39.00"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Comments: The discharge was previously modeled using WQAM63 to evaluate the CBOD₅, Ammonia Nitrogen and Dissolved Oxygen parameters. Because there have been no changes to the discharge or the receiving stream, the modeling results for those parameters are based on the previously approved pollution report which is attached to this fact sheet. It was unnecessary to remodel those three parameters using the current WQM 7.0 model because the same effluent results are computed for a single discharge scenario. The modeling results show technology based effluent limitations for CBOD₅ are appropriate. The modeling results also confirm that Ammonia-Nitrogen and Dissolved Oxygen limitations are not necessary to meet in-stream water quality criterion. The Total Suspended Solids, pH, Fecal Coliform, are not evaluated using WQAM63. The basis for those limitations is listed in the above table.

Best Professional Judgment (BPJ) Limitations

Comments: A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment. This is applied for an activated sludge system.

Anti-Backsliding

N/A

Additional Considerations:

Ultraviolet (UV) disinfection is used therefore Total Residual Chlorine (TRC) limits are not applicable. Routine monitoring of UV intensity will be at the same monitoring frequency that is used for TRC.

For pH, Dissolved Oxygen (DO) and UV disinfection, a monitoring frequency 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days where monitoring is not required.

Nutrient monitoring is required to establish the nutrient load from the waste water treatment facility and the impacts that load may have on the quality of the receiving stream(s). A 1/year monitor and report requirement for Total N & Total P has been added to the permit as per Chapter 92.a.61.

For existing discharges, if an average monthly warm period limit of 25 mg/L is acceptable, a year-round monitoring requirement for ammonia-nitrogen, at a minimum should be established. The monitoring requirements for Ammonia Nitrogen are consistent with CBOD₅, TSS, and Fecal Coliform and Table 6-3 of the Permits Writers Manual.

Mass loading limits are applicable for publicly owned treatment works. Current policy requires average monthly and average weekly mass loading limits be established for CBOD₅ and TSS. Average monthly mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

Please note that changes were made to the Average Monthly & Average Weekly Mass Effluent Limitations for CBOD₅ and TSS. These changes were necessary to be consistent with rounding guidelines found in Chapter 5.C.2, Rounding-Off Mathematically Values, of the Department's Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001.

For POTWs with design flows greater than 2,000 GPD influent BOD₅ and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations.

Total Dissolved Solids (TDS) and its Major Constituents

Monitoring is not required for Chloride, Sulfate, and TDS, because the effluent concentration of TDS, as reported in the NPDES Permit application, does not exceed 1,000 mg/l.

Monitoring is required for Bromide, because the effluent concentration of Bromide, as reported in the NPDES Permit Application, exceeds 1 mg/l and the discharge flow exceeds 0.1 MGD.

Total Dissolved Solids (TDS) and its major constituents including sulfate, chloride, and bromide have emerged as pollutants of concern in several major watersheds in the Commonwealth. The conservative nature of these solids allows them to accumulate in surface waters and they may remain a concern even if the immediate downstream public water supply is not directly impacted. Bromide has been linked to formation of disinfection byproducts at increased levels in public water systems. As a consequence of actions associated with Triennial Review 13, the Environmental Quality Board has directed DEP to collect additional data. Facilities with design flows greater than or equal to 0.1 mgd are required to report at least one sample analyzed for these parameters with the NPDES Permit renewal application.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
CBOD5	34.0	51.0	XXX	25.0	37.5	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	41.0	60.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Bromide	Report	XXX	XXX	Report	Report Daily Max	XXX	1/week	8-Hr Composite

Compliance Sampling Location: Outfall # 001

Monongahela River
PA0205257
Discharge location is point of 1st
use

HEADWATER DATA

$Q_{7-10} = 480$ cfs
TEMP = 25° C
pH = 7
D.O. = 7.12 mg/l
CBOD₅ = 2 mg/l
NH₃-N = 0.1 mg/l
 $K_c = 0$

DISCHARGE DATA - STP Expansion Flow

$Q_p = 0.165$ mgd
CBOD₅ = 25 mg/l
NH₃-N = 25 mg/l
D.O. = 2 mg/l
TEMP = 20° C
pH = 7
 $K_c = 1.5$


$Q_t = 0$ cfs
TEMP = 25° C
pH = 7
D.O. = 7.12 mg/l
CBOD₅ = 2 mg/l
NH₃-N = 0.1 mg/l

REACH DATA



DO = 5.0 mg/l
 $K_c = 0.6$
Slope = 0.00001 ft/ft
Length = 6,864 ft
DA = 4455 mi²
W/D = 22.9

Grays landing Lock and Dam - End of Reach


Significant RMI's - Monongahela River 2



Note: Jacobs Creek enters the Mon. River at mp 83.16. The DA of Jacobs Creek was subtracted from the DA of the Mon R. at the Dunkard Valley Intake to determine the DA at the proposed outfall.



MONONGAHELA RIVER MAIN STEM
 NAVIGATION SYSTEM
 GENERAL PLAN AND PROFILE



Velocity Calculations

From the Monongahela River Main Stem Navigation System General Plan and Profile (enclosed), the depth of the river from the proposed outfall to the Grays landing Lock and Dam, once constructed is approximately 24 feet. According to the Masontown, PA topographic map, the average width of the river is approximately 550 feet.

Data from the Army Corp of Engineers indicates the Q_{7-10} flow at L&D No. 7 is 480 cfs.

The equation $Q=AV$ will determine the velocity at Q_{7-10} conditions:

For existing plant:

$$\text{Total } Q = \text{Stream Flow} + \text{Waste Flow} = 480 \text{ cfs} + 0.170 \text{ cfs} = 480.17 \text{ cfs}$$

$$480.17 \text{ cfs} = (24 \text{ ft} \times 550 \text{ ft})V$$

$$V = 0.036 \text{ fps}$$

For proposed plant expansion:

$$\text{Total } Q = \text{Stream Flow} + \text{Waste Flow} = 480 \text{ cfs} + 0.256 \text{ cfs} = 480.26 \text{ cfs}$$

$$480.26 \text{ cfs} = (24 \text{ ft} \times 550 \text{ ft}) \times V$$

$$V = 0.036 \text{ fps}$$

Compute Travel Time From Point of Discharge to End of Reach

Travel time = distance/velocity

$$\text{Travel time} = 6864 \text{ ft} / 0.036 \text{ ft per sec} = 190,667 \text{ seconds} = 2.21 \text{ days}$$

Width to Depth Ratio Calculation:

Width ~ 550 feet

Depth ~ 24 feet

Width / Depth = $550 / 24 = 22.9$

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

Default Data

- a. Stream Values
 - 1 Q1-10/Q7-10 ratio.....: .64
 - 2 Q30-10/Q7-10 ratio.....: 1.36
 - 3 Temperature.....: 25
 - 4 pH.....: 7
 - 5 C-BOD5.....: 2
 - 6 NH3-N.....: .1
 - 7 D.O. Saturation (%).....: .85
 - 8 D.O. Goal.....: 5
 - 9 Width/Depth ratio.....: 22.9
 - 10 KC...(Headwaters only!).....: 0
 - 11 KN.....: .6
- b. Discharge Values (30-day avgs.)
 - 12 C-BOD5.....: 25
 - 13 NH3-N.....: 25
 - 14 Effluent D.O.....: 3
 - 15 Effluent Temp.....: 20
 - 16 KC.....: 1.5
 - 17 Balanced Technology(1=y 0=no).....: 0

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

REACH # 1
Headwaters and Tributary data

No. of Reaches : 1

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
HW	480.0000	25	7	7.12	2	.1
1	0.0000					

FILE: c:\wqam63\untitled.wqm
 Greensboro-Monongahela STP Warm Period STP Expansion

Stream Characteristics

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
1	480	25	7	7.12	2	.1

Q 1-10/Q 7-10 = .64
 Q 30-10/Q 7-10 = 1.36

FILE: c:\wqam63\untitled.wqm
 Greensboro-Monongahela STP Warm Period STP Expansion

DISCHARGE # 1
 Discharger Data
 Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/days)
1	0.1650	20	7	3	25	25	1.5

(WQAM63.EXE) Release 1.2 07-09-2008 12:54:42

FILE: c:\wqam63\untitled.wqm
 Greensboro-Monongahela STP Warm Period STP Expansion

REACH # 1						
Reach Characteristics						
Rh	D.O. GOAL	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
---	---	---	---	---	---	---
1	5	.6	0.00001	6864	4455	22.9

FILE: c:\wqam63\untitled.wqm
 Greensboro-Monongahela STP Warm Period STP Expansion

REACH # 1		
Reach Characteristics		
Rh	KR (/D)	TT (Days)
---	---	---
1	0	2.21

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

NH3-N Discharge Allocations at Q30-10 (Uniform)

DIS	Q (mgd)	BASE. CONC. (mg/l)	MULT. CONC. (mg/l)	CRIT. RCH.	PCT. RED. (%)	NH3-N CRIT. (mg/l)
1	0.1650	25.00	25.00	0	0	1.34

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

NH3-N Discharge Allocations at Q1-10 (Uniform)

DIS	Q (mgd)	BASE. CONC. (mg/l)	MULT. CONC. (mg/l)	CRIT. RCH.	PCT. RED. (%)	NH3-N CRIT. (mg/l)
1	0.1650	50.00	50.00	0	0	6.77

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

D.O. Allocations (Uniform)

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT. RCH.	PCT. REM. (%)
		IND. Conc. (mg/l)	CUM. Conc. (mg/l)	IND. Conc. (mg/l)	CUM. Conc. (mg/l)		
1	0.1650	25	25	25	25	0	0

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

(Total) Discharge = .165 MGD
 Temp = 25 pH = 7 Width = 553.12
 CBOD-5 = 2.01 NH3-N = .11 Depth = 24.15
 D.O. = 7.12 D.O. Goal = 5 Velocity = 0.036
 KC' = .002 KN = .6 W/D RATIO = 22.9
 KR = .021 (O'CONNOR)
 Dis. 1 Rch. 1 Trvl Time: 2.21

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.221	2.01	0.10	7.03
0.442	2.01	0.10	6.95
0.663	2.01	0.10	6.88
0.884	2.01	0.10	6.80
1.105	2.01	0.10	6.73
1.326	2.00	0.10	6.65
1.547	2.00	0.10	6.58
1.768	2.00	0.10	6.50
1.989	2.00	0.10	6.43
2.210	2.00	0.10	6.35

Turbulent mixing at Grays Landing Lock & Dam (end of reach) will ensure D.O. recovers.

(WQAM63.EXE) Release 1.2 07-09-2008 12:56:38

*JAP
7-9-08*

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

DISCHARGE CHARACTERISTICS

END OF REACH 1

(TOTAL) FLOW-MGD.....: .165
 TEMPERATURE.....: 20
 pH.....: 7
 DISSOLVED OXYGEN (mg/l).....: -1432.2 ?
 C-BOD5 (mg/l).....: 2
 NH3-N (mg/l).....: .1
 KC (1/Day).....: .9

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

D.O. Allocations (Uniform)

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		---CRIT. RCH.	PCT. REM. (%)
		IND. Conc. (mg/l)	CUM. Conc. (mg/l)	IND. Conc. (mg/l)	CUM. Conc. (mg/l)		
1	0.1650	25	25	25	25	0	0

FILE: c:\wqam63\untitled.wqm
Greensboro-Monongahela STP Warm Period STP Expansion

Effluent Limitations Display

DIS #	Q MGD	NH3-N TOX.		DISS. OXYGEN		
		1 DAY	30 DAY	C-BOD5 30-DAY	NH3-N 30-DAY	EFF. D.O.
1	.165	50	25	25	25	3

(WQAM63.EXE) Release 1.2 07-09-2008 12:57:03

STORET RETRIEVAL DATE 91/03/21 PGM=INVENT PAGE: 8

WQ00703 ABMS0703 03072550
39 47 15.0 079 55 15.0 1
LOCK-DAM #7 AT GREENSBORO
42059 PENNSYLVANIA GREENE
OHIO RIVER O50200
MONONGAHELA RIVER HQ 05020005038 0000.100 OFF.
21PA 770419
0000 FEET DEPTH

PARAMETER	CENT	MEDIUM	RMK	NUMBER	MEAN	VARIANCE	STAN DEV	MAXIMUM	MINIMUM	BEG DATE	END DATE
00010 WATER	TEMP	TEMP		24	15.39200	69.61500	8.343500	28.5	1.5	86/03/26	88/06/14
00011 WATER	FAHN	WATER	\$	24	59.70500	229.5500	15.01800	83.3	34.7	86/03/26	88/06/14
00060 STREAM	FLOW	CFS		9	8583.300	1690E+05	13000.00	42400	1610	86/01/07	86/09/10
00061 STREAM	INST-CFS	WATER		12	7284.200	34748000	5894.700	18800	300	86/10/07	87/09/28
00065 STREAM	STAGE	FEET		21	12.07100	2.624400	1.620000	15.60	9.40	86/01/07	87/09/28
00095 CONDUCTIV	AT 25C	MICROMHO		25	292.2400	10869.00	104.2600	520	120	86/01/07	88/06/14
00300 DO		MG/L		20	9.575000	3.735700	1.932800	12.7	6.5	86/04/30	88/06/14
00301 DO	SATUR	PERCENT	\$	20	92.75500	27.40800	5.235300	103.1	82.3	86/04/30	88/06/14
00400 PH		SU		24	7.010400	1686700	4106900	7.80	6.30	86/03/26	88/06/14
00403 PH	LAB	SU		27	6.303700	1027200	3205000	7.2	5.8	86/01/07	88/06/14
00410 T ALK	CAC03	MG/L		27	18.92600	43.61000	6.603800	40	8	86/01/07	88/06/14
00515 RESIDUE	DISS-105 C	MG/L		24	213.8300	7282.800	85.34000	368	92	86/01/07	87/12/03
00530 RESIDUE	TOT NFLT	MG/L		2	8.000000	.0000000	.0000000	8	2	88/01/19	88/02/10
			K	1	2.000000			2		88/06/14	88/06/14
			TOT	3	6.000000	12.00000	3.464100	8	2	88/01/19	88/06/14
00610 NH3+NH4-N	TOTAL	MG/L		27	1.122200	.0024334	.0493300	.230	.040	86/01/07	88/06/14
00612 UN-IONZD	NH3-N	MG/L	\$	24	.0005491	.0000003	.0006317	.002	.00004	86/03/26	88/06/14
00615 ND2-N	TOTAL	MG/L		26	.0083846	.00000182	.0042716	.024	.004	86/01/07	88/06/14
			K	1	.0040000			.004	.004	87/08/17	87/08/17
			TOT	27	.0082222	.00000182	.0042728	.024	.004	86/01/07	88/06/14
00619 UN-IONZD	NH3-NH3	MG/L		24	.0006676	.0000005	.0007680	.003	.00004	86/03/26	88/06/14
00620 ND3-N	TOTAL	MG/L	\$	27	.5896300	.0155190	.1245800	.950	.350	86/01/07	88/06/14
00665 PHOS-TOT		MG/L P		27	.0522220	.0006256	.0250130	.120	.020	86/01/07	88/06/14
00680 T ORG C		MG/L		3	1.600000	.0100010	.1000100	1.7	1.5	88/01/19	88/06/14
00719 CN FREE	HGB METH	UG/L		2	1.000000	.0000000	.0000000	1.000	1.000	86/07/10	86/11/04
			K	23	1.000000	.0000000	.0000000	1.000	1.000	86/01/07	88/01/19
			TOT	25	1.000000	.0000000	.0000000	1.000	1.000	86/01/07	88/01/19
00720 CYANIDE	CN-TOT	MG/L		4	.0010000	.0000000	.0000000	.001	.001	86/03/26	86/11/04
			K	21	.0010000	.0000000	.0000000	.001	.001	86/01/07	88/01/19
			TOT	25	.0010000	.0000000	.0000000	.001	.001	86/01/07	88/01/19
00900 TOT HARD	CAC03	MG/L		27	99.74100	1248.700	35.33800	175	38	86/01/07	88/06/14
00916 CALCIUM	CA-TOT	MG/L		24	28.78200	106.9100	10.34000	48.1	12.0	86/01/07	87/12/03
00927 MGSNIUM	MG,TOT	MG/L		24	7.355000	8.092900	2.844800	13.8	2.7	86/01/07	87/12/03
00940 CHLORIDE	TOTAL	MG/L		24	7.845800	6.709500	2.590300	16	4	86/01/07	87/12/03
00945 SULFATE	S04-TOT	MG/L		27	106.6300	2286.900	47.82200	224	39	86/01/07	88/06/14
00951 FLUORIDE	F.TOTAL	MG/L		9	19.22200	.0037195	.0609880	.28	.10	86/04/30	87/09/28
			K	14	1.000000	.0000000	.0000000	.10	.10	86/01/07	88/01/19
			TOT	23	1360900	.0034704	.0589100	.28	.10	86/01/07	88/01/19
01002 ARSENIC	AS.TOT	UG/L		1	4.000000			4	4	86/08/05	86/08/05

STORRETRIEVAL DATE 91/03/21

PGM-INVENT

MONO703 ABMS0703 03072550

PAGE: 9

39.47 15.0 0.79 55 15.0 1
LOCK-DAM #7 AT GREENSBORO
42059 PENNSYLVANIA GREENE
OHIO RIVER 050200
MONONGAHELA RIVER
21PA 770419 HQ 05020005038 0000.100 OFF
0000 FEET DEPTH

/TYPA/AMBNT/STREAM

PARAMETER	MEDIUM	RMK	NUMBER	MEAN	VARIANCE	STAN DEV	MAXIMUM	MINIMUM	BEG DATE	END DATE
01027 CADMIUM CD.TOT	WATER	K	1	.3200000			.3	.3	87/08/17	87/08/17
TOT			1	.2000000			.2	.2	86/08/05	86/08/05
01034 CHROMIUM CR.TOT	WATER	K	2	.2600000	.0072000	.0848530	.3	.2	86/08/05	87/08/17
01042 COPPER CU.TOT	WATER	K	2	4.0000000	.0000000	.0000000	4	4	86/08/05	87/08/17
			1	14.00000			14	14	88/06/14	88/06/14
01045 IRON FE.TOT	WATER	K	4	30.00000	533.3300	23.09400	50	10	86/08/05	88/02/10
01051 LEAD PB.TOT	WATER	TOT	5	26.80000	451.2000	21.24200	50	10	86/08/05	85/06/14
01055 MANGNESE MN	WATER	K	28	1004.700	512170.0	715.6600	4080	290	86/01/07	88/06/14
01067 NICKEL NI.TOTAL	WATER	K	5	4.020000	.0020332	.0450910	4	4	86/08/05	88/06/14
			5	239.6000	9828.800	99.14100	318.0	90.0	86/08/05	88/06/14
			2	59.50000	840.5000	28.99100	80	39	86/08/05	88/06/14
01092 ZINC ZN.TOT	WATER	K	3	33.33300	208.3300	14.43400	50	25	87/08/17	88/02/10
			5	43.80000	519.7000	22.79700	80	25	86/08/05	88/06/14
			3	32.00000	372.0000	19.28700	46	10	86/08/05	88/02/10
01105 ALUMINUM AL.TOT	WATER	K	2	10.00000	.0000000	.0000000	10	10	88/01/19	88/06/14
31616 FEC COLI MFM-FCBR	WATER	TOT	5	23.20000	331.2000	18.19900	46	10	86/08/05	88/06/14
			5	580.8000	180600.0	424.9700	1310	200	86/08/05	88/06/14
			17	365.8800	262740.0	512.5800	1700	20	86/02/20	88/01/19
32730 PHENDLS TOTAL	WATER	K	8	30.00000	800.0000	28.28400	100	20	86/01/07	87/11/19
46014 HIRUD LEECH	NO/FT2	TOT	25	258.4000	200970.0	448.2900	1700	20	86/01/07	88/01/19
46018 GAMMAR SCUD	NO/FT2		24	.0000000	.0000000	.0000000	0	0	86/01/07	88/01/19
46037 COENAG DAMSEL	NO/FT2		3	1.333300	.3333400	.5773500	2	1	86/11/21	87/11/03
46087 TENTIPED FLY	NO/FT2		3	3.333300	4.333400	2.081700	5	1	86/11/21	87/11/03
46095 PHYSID SNAIL	NO/FT2		3	2.000000	1.000000	1.000000	3	1	86/11/21	87/11/03
46106 OLIGOCHT AQ E WRM	NO/FT2		3	504.3300	71525.00	267.4400	710	202	86/11/21	87/11/03
			2	640.0000	26.33300	5.131600	11	1	86/11/21	87/11/03
			1	1000.000	55778.00	236.1700	807	473	87/11/03	87/11/03
46142 POLYCENT CADDIS	NO/FT2	K	1	1000.000	71089.00	266.6300	1000	1000	86/11/21	86/11/21
46570 CAL HARD CA MG	MG/L	TOT	3	6.333300	9.333400	3.095100	9	473	86/11/21	87/11/03
70508 T ACIDITY HOT-MG/L	CAC03	\$	24	102.1600	1385.000	37.21500	173	41	86/01/07	87/12/03
71900 MERCURY HG.TOTAL	UG/L	K	24	10.08300	617.2100	24.84400	118	0	86/01/07	87/12/03
74041 WOF SAMPLE UPDATED	WATER		1	1.000000			1.0	1.0	86/08/05	86/08/05
82079 TURBIDTY LAB NTU	WATER	K	33	883410.0	35127000	5926.800	890103	870721	86/01/07	88/06/14
			23	13.32600	380.8300	19.51500	94.0	1.0	86/01/07	87/12/03
			1	1.000000			1.0	1.0	87/02/11	87/02/11
TOT			24	12.81300	370.6100	19.25100	94.0	1.0	86/01/07	87/12/03