

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0205559
APS ID 999778
Authorization ID 1284543

Applicant and Facility Information

Applicant Name	<u>Jonathan Clark & Thomas Loughry d/b/a WFT Enterprises</u>	Facility Name	<u>Crystal Waters PCH</u>
Applicant Address	<u>4639 Route 119 Highway N Home, PA 15747</u>	Facility Address	<u>4639 Route 119 Highway N Home, PA 15747</u>
Applicant Contact	<u>Thomas Loughry</u>	Facility Contact	<u>Charles Ishman, Operator</u>
Applicant Phone	<u>(724) 465-6454</u>	Facility Phone	<u>(724) 801-8169, ext. 12</u>
Client ID	<u>111972</u>	Site ID	<u>242745</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Rayne Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Indiana County</u>
Date Application Received	<u>June 3, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 27, 2019</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater.</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.
A Part II Water Quality Management permit is not required at this time.
The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization

II. SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in efacts associated with the subject Client ID (111972) as of 11/23/2021.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	11/23/2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	11/24/2021

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0029</u>
Latitude	<u>40° 43' 40.00"</u>	Longitude	<u>-79° 06' 10.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Pine Run (CWF)</u>	Stream Code	<u>46843</u>
NHD Com ID	<u>123854944</u>	RMI	<u>0.42</u>
Drainage Area	<u>9.78</u>	Yield (cfs/mi ²)	<u>0.037 (Bulletin 12)</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.36</u>	Q ₇₋₁₀ Basis	<u>calculated</u>
Elevation (ft)	<u>1095</u>	Slope (ft/ft)	<u>0.0075</u>
Watershed No.	<u>17-E</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>Final, 8/15/2015</u>	Name	<u>Crooked Creek Watershed*</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>New Kensington City Municipal Authority</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2,300</u>
PWS RMI	<u>21.0</u>	Distance from Outfall (mi)	<u>65.0</u>

* - This discharge was assigned a WLA for solids of 530 lbs/year (1.45 lbs/day) in the Crooked Creek TMDL. With a permitted flow of 0.0029 MGD and an instantaneous maximum TSS limit of 60.0 mg/l, the maximum solid loading from this site would be 1.45 lbs/day. Therefore, the TSS instantaneous maximum is protective of the WLA in the TMDL. No additional limits or monitoring for solids will be included with this renewal.

Sludge use and disposal description and location(s): All sludge is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.0029 MGD of treated sewage from a personal care home in Rayne Township, Indiana County.

Treatment permitted under Water Quality Management Permit No. 3295403 consists of the following: A grease trap, four septic tanks, a dosing tank, two intermittently dosed sand filters, tablet chlorine disinfection with a contact tank, and dechlorination.

1. Streamflow:

Crooked Creek at Gaibleton, PA - USGS Stream Gage 03036800 (1945-1958):

Drainage Area:	<u>37.3</u>	sq. mi.	(USGS StreamStats)
Q ₇₋₁₀ :	<u>1.4</u>	cfs	(USGS StreamStats)
Yieldrate:	<u>0.037</u>	cfsm	calculated

Pine Run at Outfall 001:

Yieldrate:	<u>0.037</u>	cfsm	calculated above
Drainage Area:	<u>9.78</u>	sq. mi.	(USGS StreamStats)
Q ₇₋₁₀ :	<u>0.36</u>	cfs	calculated

% of stream allocated: 100% Basis: No nearby discharges

2. Wasteflow:

Maximum discharge: 0.0029 MGD = 0.0044 cfs

Runoff flow period: 16 hours Basis: Runoff flow used in previous permits

24 hour flow: 0.0029 MGD x 24/16 = 0.0043 MGD = 0.0066 cfs

There is greater than 3 parts stream flow (Q₇₋₁₀) to 1 part effluent (design flow). Therefore, the standards in DEP guidance (391-2000-014) will not be applied.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits. The measurement frequency was previously set to 1/weekday as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Phosphorus

- Limit necessary due to:
- Discharge to lake, pond, or impoundment
 - Discharge to stream

Basis: N/A

- Limit not necessary

Basis: Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value

Calculated NH₃-N Summer limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. Since the calculated limits are the same as in the previous permit, they will be retained. Since this is an existing discharge, the year-round monitoring requirement for ammonia-nitrogen will be retained, per the SOP.

h. CBOD₅

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ Summer limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Calculated CBOD₅ Winter limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. Since the calculated limits are the same as in the previous permit, they will be retained. Since the summer and winter limits are technology-based, the year-round limit of 25.0 mg/l monthly average and 50.0 mg/l instantaneous maximum will be retained with this renewal.

i. Dissolved Oxygen (DO)

- 4.0 mg/l - minimum desired in effluent to protect all aquatic life
- 5.0 mg/l - desired in effluent for CWF, WWF, or TSF
- 6.0 mg/l - minimum required due to discharge falling under guidance document 391-2000-014
- 8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. The measurement frequency was previously set to 1/weekday as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

j. Total Residual Chlorine (TRC)

- No limit necessary

Basis: N/A

- TRC limits: 0.5 mg/l (monthly average)
1.6 mg/l (instantaneous maximum)

Basis: The technology-based limits for TRC were calculated by the TRC_Calc spreadsheet (see Attachment 2). The calculated limits are less restrictive than the previous permit. Since the previous, more restrictive limits are being attained, they will be retained. The measurement frequency was previously set to 1/weekday as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

4. Anti-Backsliding

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

5. Reasonable Potential Analysis for Receiving Stream:

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 by the Department's Toxics Management Spreadsheet since no data was required to be collected for the renewal application.

Result: N/A

6. Reasonable Potential for Downstream Public Water Supply (PWS):

The Reasonable Potential Analysis performed above does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no data was provided, mass-balance calculations were not able to be performed.

Nearest Downstream potable water supply (PWS): New Kensington City Municipal Authority

Distance downstream from the point of discharge: 65.0 miles (approximate)

- No limits necessary
 Limits needed

Basis: Significant dilution available

7. Attachment List:

Attachment 1 - WQ Modeling Printouts

Attachment 2 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from October 1, 2020 to September 30, 2021)

Parameter	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20
Flow (MGD) Average Monthly	0.0022	0.0023	0.0018	0.0022	0.0022	0.0024	0.0026	0.0021	0.0019	0.0017	0.0021	0.0017
pH (S.U.) Minimum	6.5	6.8	6.7	6.81	6.9	6.88	6.81	7.0	7.0	6.9	7.0	6.87
pH (S.U.) Maximum	7.1	7.1	7.1	7.15	7.11	7.15	7.3	7.4	7.4	7.4	7.3	7.3
TRC (mg/L) Average Monthly	0.36	0.4	0.40	0.4	0.36	0.36	0.37	0.34	0.34	0.37	0.4	0.39
TRC (mg/L) Instantaneous Maximum	0.50	0.5	0.5	0.4	0.5	0.5	0.5	0.5	0.50	0.50	0.5	0.5
CBOD5 (mg/L) Average Monthly	< 3.3	5.59	< 4.42	< 4.35	7.88	4.7	< 8.8	< 3.54	< 4.91	17.29	< 3.0	< 4.15
CBOD5 (mg/L) Instantaneous Maximum	4.5	6.11	6.84	6.69	13.3	5.72	< 12	5.07	6.81	45	< 3.0	5.29
TSS (mg/L) Average Monthly	9	13	10	13	10	11	12	12	8	44	11	12
TSS (mg/L) Instantaneous Maximum	10	14	10	13	13	12	14	15	8	305	11	13
Fecal Coliform (CFU/100 ml) Geometric Mean	< 5	< 5	< 5	< 2	< 5	138	< 5	< 5	< 5	< 5	< 2	< 2
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 5	< 5	< 5	< 5	< 5	386	5	< 5	< 5	< 5	< 5	< 5
Total Nitrogen (mg/L) Daily Maximum										0.350		
Ammonia (mg/L) Average Monthly	13.5	16.7	13.8	13.1	17	15.5	13.9	12.4	10.18	18.2	16.1	9.47
Ammonia (mg/L) Instantaneous Maximum	14.4	17	15	16.2	18.4	15.5	15.1	14.3	10.80	18.9	16.4	15.5
Total Phosphorus (mg/L) Daily Maximum										2.5		

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/weekday	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/weekday	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.4	1/weekday	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limit is technology-based on Chapter 92a.48. The limits for CBOD₅, Total Suspended Solids, Dissolved Oxygen, and Fecal Coliform are technology based on Chapter 92a.47. Monitoring for E. Coli, Ammonia-Nitrogen, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17E		46843		PINE RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.420	Crystal Waters	PA0205559	0.004	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17E	46843	PINE RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.420	0.004	20.090		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
11.072	0.446	24.813		0.075
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.42	0.227	0.45		0.705
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.166	16.997	Owens		6
<u>Reach Travel Time (days)</u>	Subreach Results			
0.344	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.034	2.40	0.44	8.23
	0.069	2.38	0.43	8.23
	0.103	2.36	0.42	8.23
	0.138	2.34	0.41	8.23
	0.172	2.32	0.40	8.23
	0.206	2.30	0.39	8.23
	0.241	2.29	0.38	8.23
	0.275	2.27	0.37	8.23
	0.310	2.25	0.36	8.23
	0.344	2.23	0.35	8.23

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46843	PINE RUN	0.420	1095.00	9.78	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.037	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Crystal Waters	PA0205559	0.0043	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46843	PINE RUN	0.000	1080.00	9.87	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.037	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17E		46843				PINE RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
0.420	0.36	0.00	0.36	.0067	0.00676	.446	11.07	24.81	0.07	0.344	20.09	7.00
Q1-10 Flow												
0.420	0.23	0.00	0.23	.0067	0.00676	NA	NA	NA	0.06	0.439	20.14	7.00
Q30-10 Flow												
0.420	0.49	0.00	0.49	.0067	0.00676	NA	NA	NA	0.09	0.290	20.07	7.00

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17E	46843	PINE RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.420	Crystal Waters	16.57	50	16.57	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.420	Crystal Waters	1.88	25	1.88	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.42	Crystal Waters	25	25	25	25	4	4	0	0

Attachment 2

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.151	= Q stream (cfs)			0.5	= CV Daily
0.015	= Q discharge (MGD)			0.5	= CV Hourly
30	= no. samples			1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream			1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge			15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value			720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			0	= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 2.095		1.3.2.iii	WLA_cfc = 2.035
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.781		5.1d	LTA_cfc = 1.183
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$				