

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0205915**
APS ID **1103918**
Authorization ID **1467613**

Applicant and Facility Information

Applicant Name	<u>Dayton Borough</u>	Facility Name	<u>Dayton Borough STP</u>
Applicant Address	<u>PO Box 396</u>	Facility Address	<u>207 Mechanic Street</u>
	<u>Dayton, PA 16222-0396</u>		<u>Dayton, PA 16222</u>
Applicant Contact	<u>James Marshall</u>	Facility Contact	<u>James Marshall</u>
Applicant Phone	<u>(814) 257-9826</u>	Facility Phone	<u>(814) 257-9826</u>
Client ID	<u>66321</u>	Site ID	<u>241699</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Dayton Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Armstrong</u>
Date Application Received	<u>December 26, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 11, 2024</u>	If No, Reason	
Purpose of Application	<u>Renewal of Existing NPDES Permit</u>		

Summary of Review

Dayton Borough has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Eldred Township STP. The permit was originally issued on July 24, 2019, with an effective date of August 1, 2019. The permit expired on July 31, 2024, but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Sludge use and disposal description and location(s): Evergreen Landfill (Blairsville, PA)

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		Aaron Baar Aaron Baar / Project Manager	July 5, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	July 10, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.1
Latitude	40° 52' 45.92"	Longitude	-79° 14' 48.52"
Quad Name	Dayton	Quad Code	1112
Wastewater Description:	Sewage Effluent		
Receiving Waters	Glade Run (CWF)	Stream Code	47407
NHD Com ID	123856234	RMI	2.91
Drainage Area	5.62 sq. mi.	Yield (cfs/mi ²)	0.0411
Q ₇₋₁₀ Flow (cfs)	0.231	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1311.57	Slope (ft/ft)	
Watershed No.	17-D	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	ORGANICS, ORGANICS, ORGANICS, ORGANICS, SILTATION, SILTATION, SILTATION, SILTATION		
Source(s) of Impairment	AGRICULTURE, AGRICULTURE, AGRICULTURE, AGRICULTURE, AGRICULTURE, AGRICULTURE, AGRICULTURE, AGRICULTURE, AGRICULTURE		
TMDL Status	Name _____		
Background/Ambient Data		Data Source	
pH (SU)	7.0	Assumed, default value	
Temperature (°F)	20	CWF, default value	
Hardness (mg/L)	100	Assumed, default value	
Other:	0.1	Assumed, default value	
Nearest Downstream Public Water Supply Intake	Kittanning Suburban JT Water Authority		
PWS Waters	Allegany River	Flow at Intake (cfs)	
PWS RMI	~48.5	Distance from Outfall (mi)	~34 miles

Drainage Area

The discharge is to Glade Run at RMI 2.91. A drainage area upstream of the discharge is determined to be 5.62 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the watershed has a Q₇₋₁₀ of 0.231 cfs and a Q₃₀₋₁₀ of 0.427 cfs. This information was used to obtain a Low Flow Yield (LFY), and a chronic Q₃₀₋₁₀:Q₇₋₁₀ ratio for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 0.231 \text{ cfs} \\
 Q_{30-10} &= 0.427 \text{ cfs} \\
 Q_{30-10}:Q_{7-10} &= 0.427 \text{ cfs} / 0.231 \text{ cfs} = 1.4329 \\
 \text{LFY} &= 0.231 \text{ cfs}/5.62 \text{ mi}^2 = 0.0411 \text{ cfs/mi}^2
 \end{aligned}$$

For WQM modelling purposes, the default acute (Q₁₋₁₀) exposure stream value of 0.64 cfs was utilized in the absence of other information.

Glade Run

25 Pa Code §93.9 classifies the receiving water, Glade Run, with a Cold-Water Fishery (CWF) Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as not fully attaining uses.

Local Watershed Total Maximum Daily Loads (TMDLs)

According to PA's 2024 integrated water quality monitoring and assessment report, Glade Run in the vicinity of the proposed point of discharge is currently assessed for aquatic life; the most recent assessment found aquatic life in the waterway to be impaired by agricultural organics and siltation. The impairments are listed as Category 5 in the 2024 integrated report, indicating that Glade Run may be impaired for one or more uses by a pollutant that requires the development of a TMDL.

No TMDL has been developed for Glade Run to date, so no local watershed TMDL has been taken into consideration during this review.

Public Water Supply Intake

The nearest downstream public water supply intake is the Kittanning Suburban JT Water Authority intake, located on Alleghany River approximately 34 miles from the point of discharge. Considering the distance and nature, the discharge is not expected to affect the water supply.

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Other Comments

The location of Outfall 001 in eFACTS was not matching other Department records. Based on information provided by the operator, updated coordinates have been entered into eFACTS that better coordinate with the as-built system. See the appendix materials at the end of this report for the existing and proposed locations.

Treatment Facility Summary				
Treatment Facility Name: Dayton Borough STP				
WQM Permit No.	Issuance Date			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	Chlorine With Dechlorination	0.1
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.1		Not Overloaded		

Dayton Borough owns and operates the wastewater treatment facility located at 207 Mechanic Street (Dayton Borough, Armstrong County); the facility only serves Dayton Borough. With an annual average design flow and hydraulic design capacity of 0.10 MGD, the treatment process, as described in the application, is configured as follows:

Grinder → Aeration Tank → Secondary Clarification (2) → Chlorine Contact → Dechlorination → Outfall 001

The application does not identify any chemicals used to facilitate treatment. Solids handling is facilitated by a sludge holding tank and drying beds.

Compliance History	
Summary of DMRs:	DMR results for the past year are presented below.
Summary of Inspections:	Since the last renewal of the facility's NPDES permit, the following inspections have been logged: July 10, 2024: A routine CEI was conducted by Clinton Stonesifer. No new violations were noted, but the following unresolved violations were listed: 1. 25 Pa. Code 92a.41(a)(12): Failure to submit monitoring reports or properly complete monitoring reports. The inspection was prompted by a call from the operator requesting assistance with Supplemental Submission Forms.

A CACP was entered into on April 16, 2025 for discharge violations at the facility.

Existing Permit Limits

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.095	XXX	0.3	1/day	Grab
CBOD5 Nov 1 - Apr 30	21.0	31.3	XXX	25	38	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	12.5	18.8	XXX	15	23	30	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS	25.0	37.0	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	7.5	11.2	XXX	9.0	13.5	18	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	2.5	3.7	XXX	3.0	4.5	6	1/week	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from June 1, 2024 to May 31, 2025)

Parameter	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24
Flow (MGD) Average Monthly	0.0685	0.067	0.0428	0.0791	0.0267	0.0469	0.0357	0.0246	0.0234	0.0656	0.0232	0.0243
Flow (MGD) Daily Maximum	0.1552	0.2474	0.0964	0.2230	0.07970	0.1491	0.1052	0.4098	0.0318	0.2496	0.0478	0.0373
pH (S.U.) Instantaneous Minimum	7.4	7.3	7.1	7.3	7.4	7.2	7.3	7.2	7.2	7.2	7.2	7.1
pH (S.U.) Instantaneous Maximum	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
DO (mg/L) Instantaneous Minimum	5.21	5.2	5.32	5.52	5.06	5.3	5.35	5.12	5.14	5.17	5.17	5.21
TRC (mg/L) Average Monthly	0.025	0.024	0.0125	0.013	0.014	0.020	0.023	0.020	0.0275	0.0125	0.016	0.015
TRC (mg/L) Instantaneous Maximum	0.04	0.03	0.02	0.02	0.03	0.030	0.04	0.04	0.05	0.02	0.03	0.02
CBOD5 (lbs/day) Average Monthly	3.9930	5.398	1.063	4.318	1.201	1.567	0.910	0.8959	1.3787	1.1863	0.5007	1.0226
CBOD5 (lbs/day) Weekly Average	13.1951	4.253	3.213	19.327	6.270	8.101	4.050	3.1834	2.6735	5.5328	1.3703	3.0120
CBOD5 (mg/L) Average Monthly	6.995	9.668	2.98	6.55	5.398	4.01	3.06	4.37	7.07	2.17	2.59	5.05
CBOD5 (mg/L) Weekly Average	10.2	15.9	4.0	10.4	9.40	6.52	4.62	9.3	10.1	2.70	3.4	9.7
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	84.951	178.220	50.379	70.102	36.891	41.843	61.806	42.517	53.138	96.541	40.561	42.981
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	250.965	1822.513	120.500	284.325	139.475	222.408	245.467	88.958	106.409	590.720	127.068	103.508
BOD5 (mg/L) Raw Sewage Influent Average Monthly	148.82	319.2	141.25	106.35	165.8	107.06	207.75	207.4	272.5	176.6	209.8	212.25
BOD5 (mg/L) Raw Sewage Influent Weekly Average	194.0	884	150.0	153.0	210.0	179	280.0	261.0	402	284.0	319.0	333

NPDES Permit Fact Sheet
Dayton Borough STP

NPDES Permit No. PA0205915

TSS (lbs/day) Average Monthly	7.1925	6.1752	3.3883	13.6448	2.4475	6.0579	4.2394	1.8450	1.6575	2.7333	1.0440	2.8350
TSS (lbs/day) Raw Sewage Influent Average Monthly	58.2250	68.1167	30.0492	63.6096	26.4330	47.4863	41.5013	24.2720	21.3525	78.4467	18.6373	25.9200
TSS (lbs/day) Raw Sewage Influent Daily Maximum	175.9341	527.7867	85.1533	293.6167	92.9833	293.2300	185.8533	69.5300	40.7638	436.8000	55.7667	52.2200
TSS (lbs/day) Weekly Average	28.2750	28.8633	13.6567	11.2750	10.6267	32.3050	21.0400	4.7717	3.9705	10.4000	2.7883	6.5275
TSS (mg/L) Average Monthly	12.6	11.06	9.5	20.7	11	15.5	14.25	9	8.5	5	5.40	14
TSS (mg/L) Raw Sewage Influent Average Monthly	102	122	84	96.5	119	122	140	118	110	144	96	128
TSS (mg/L) Raw Sewage Influent Weekly Average	136	256	106	158	140	236	212	204	154	210	140	168
TSS (mg/L) Weekly Average	29	14	17	30	16	26	24	14	15	5	7	21
Fecal Coliform (No./100 ml) Geometric Mean	5.47	2.62	1.86	500	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10
Fecal Coliform (No./100 ml) Instantaneous Maximum	14	62	5	200	< 10	< 10	< 10	< 10	10	< 10	< 10	< 10
Total Nitrogen (mg/L) Daily Maximum						14.59						
Ammonia (lbs/day) Average Monthly	0.0856	0.0838	0.0556	0.0989	0.0356	0.0586	0.0595	0.0410	0.0390	0.1093	0.0425	0.0450
Ammonia (mg/L) Average Monthly	< 0.150	< 0.150	0.156	< 0.15	0.16	< 0.15	< 0.2	< 0.20	< 0.20	< 0.20	0.22	< 0.20
Ammonia (mg/L) Weekly Average	< 0.150	< 0.150	0.175	< 0.15	0.20	< 0.15	< 0.20	< 0.20	< 0.20	< 0.20	0.33	< 0.20
Total Phosphorus (mg/L) Daily Maximum						1.33						

Compliance History

As of July 5, 2025, there are two Safe Drinking Water open violations associated with this facility.

CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	PF STATUS	INSP PROGRAM	PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION	PF INSPECTOR	INSP REGION
66321	DAYTON BORO ARMSTRONG CNTY	287129	DAYTON MUNI WATER DEPT	Community	Active	Safe Drinking Water	6030002	3537451	991334	PF	04/13/2023	C7	FAILURE TO COMPLY WITH A PERMIT CONDITION	CROW,MELISSA	NWRO
66321	DAYTON BORO ARMSTRONG CNTY	287129	DAYTON MUNI WATER DEPT	Community	Active	Safe Drinking Water	6030002	3946792	8226838	PF	03/28/2025	B5A	FAILURE OF A PUBLIC WATER SYSTEM TO OBTAIN A PERMIT	CROW,MELISSA	NWRO

The draft permit letter will indicate that the permit may not be finalized until all pending violations are resolved or closed.

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 52' 50.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .1
Longitude -79° 14' 40.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

Water Quality-Based Limitations

CBOD5, NH3-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized using data derived by USGS StreamStats and the model output indicated that existing WQBELs for DO, ammonia and CBOD5 are still protective of water quality

Due to the fact that the facility is a POTW, weekly average mass limits calculated from the facility's weekly average ammonia concentration limits are proposed in this permit as follows:

May 1 – Oct 31 : 4.5 mg/L ammonia x 0.10 mgd x 8.34 = 3.7 lbs/day ammonia (weekly average)
Nov 1 – Apr 30: 13.5 mg/L ammonia x 0.10 mgd x 8.34 = 11.2 lbs/day ammonia (weekly average)

The Department notes that the new weekly average ammonia mass limits require no additional sampling.

See attached for model inputs and outputs.

Toxics

A reasonable potential (RP) analysis was done for Total Copper, Total Lead and Total Zinc using the sampling results provided with the application. The Department's Toxics Management Spreadsheet (Version 1.4) was used to perform the RP analysis for these parameters at a pH of 7.3 and a discharge hardness of 100 mg/L. The sample sizes for all analyzed parameters were less than 10, so the maximum reported effluent concentration was utilized in the analysis.

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Zinc	Report	Report	Report	Report	Report	mg/L	0.19	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Copper	0.022	mg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	7.93	µg/L	Discharge Conc ≤ 10% WQBEL

In conformity with the Department's SOP for Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers (SOP No. BCW-PMT-037), the Department proposes to establish monitoring requirements in the draft permit for Total Zinc due to effluent concentrations exceeding 10% of the WQBEL (i.e., RP is demonstrated). In conformity with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (PA Doc No. 362-0400-001), Table 6-3 (plant design flow = 0.4 mgd.), weekly monitoring of Total Zinc is proposed.

The full TMS report is presented at the end of this report.

E. Coli Monitoring

In conformity with the Department's *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, quarterly E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

Best Professional Judgment (BPJ) Limitations

Total Residual Chlorine

Since chlorine is used for disinfection, Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC_CALC worksheet is utilized to determine if the existing BAT TBEL is still appropriate. The worksheet indicates that the existing limits of 0.095 mg/L (average monthly) and 0.3 mg/L (IMAX) are still protective of water quality.

The Department's TRC_CALC worksheet is presented at the end of this report.

Total Phosphorus & Total Nitrogen

DEP's SOP no. BPNPSM-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits) recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for Total Phosphorus and Total Nitrogen are recommended to be continued in this permit. Sampling frequency for TP and TN is currently required 1/year. No change to the sampling frequency is proposed.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Anti-backsliding Requirement

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal unless noted otherwise above. This approach is in accordance with 40 CFR §122.44(l)(1).

Annual Fees

An annual fee clause is continued in the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor Sewage Facility ≥ 0.05 and < 1 MGD fee category, which has an annual fee of \$1000.

Mass Loading Limitations

Unless stated otherwise in this fact sheet, mass loading effluent limits are calculated based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.095	XXX	0.3	1/day	Grab
CBOD5 Nov 1 - Apr 30	21.0	31.3	XXX	25	38	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	12.5	18.8	XXX	15	23	30	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS	25.0	37.0	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	7.5	11.2	XXX	9.0	13.5	18	1/week	8-Hr Composite


Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	2.5	3.7	XXX	3.0	4.5	6	1/week	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Total Zinc	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Existing Discharge Point in eFACTS:



Updated Location in eFACTS:




StreamStats Report

Region ID: PA

Workspace ID: PA20250705120325265000

Clicked Point (Latitude, Longitude): 40.88057, -79.24741

Time: 2025-07-05 08:03:45 -0400



[Collapse All](#)

» Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	5.62	square miles
ELEV	Mean Basin Elevation	1417	feet
PRECIP	Mean Annual Precipitation	43	inches

» Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	5.62	square miles	2.33	1720
ELEV	Mean Basin Elevation	1417	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.544	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.791	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.231	ft ³ /s	54	54

Statistic	Value	Unit	SE	ASEp
30 Day 10 Year Low Flow	0.331	ft ³ /s	49	49
90 Day 10 Year Low Flow	0.492	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


StreamStats Report

Region ID: PA

Workspace ID: PA20250705124234391000

Clicked Point (Latitude, Longitude): 40.89987, -79.25621

Time: 2025-07-05 08:42:53 -0400



[Collapse All](#)

» Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	7.17	square miles
ELEV	Mean Basin Elevation	1411	feet
PRECIP	Mean Annual Precipitation	43	inches

» Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	7.17	square miles	2.33	1720
ELEV	Mean Basin Elevation	1411	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.696	ft ³ /s	43	43
30 Day 2 Year Low Flow	1.01	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.299	ft ³ /s	54	54
30 Day 10 Year Low Flow	0.427	ft ³ /s	49	49
90 Day 10 Year Low Flow	0.632	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.


USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



WQM 7.0 Effluent Limits

SWP Basin 17D	Stream Code 47407	Stream Name GLADE RUN					
		Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.910	Dayton Boro STP	PA0205915	0.100	CBOD5	15		
				NH3-N	3	6	
				Dissolved Oxygen			5

WQM 7.0 Wasteload Allocations

SWP Basin		Stream Code	Stream Name				
17D	47407	GLADE RUN					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.910	Dayton Boro STP	12	6	12	6	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.910	Dayton Boro STP	1.65	3	1.65	3	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen	
2.91	Dayton Boro STP	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
		15	15	3	3	5	5
						0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
17D	47407	GLADE RUN	
<u>RMI</u>	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
2.910	0.100	22.005	7.097
<u>Reach Width (ft)</u>	Reach Depth (ft)	Reach WDRatio	Reach Velocity (fps)
11.176	0.460	24.280	0.075
<u>Reach CBOD5 (mg/L)</u>	Reach Kc (1/days)	Reach NH3-N (mg/L)	Reach Kn (1/days)
7.21	0.920	1.26	0.817
<u>Reach DO (mg/L)</u>	Reach Kr (1/days)	Kr Equation	Reach DO Goal (mg/L)
6.942	16.854	Owens	6
<u>Reach Travel Time (days)</u>	Subreach Results		
1.271	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.127	6.35
		0.254	5.58
		0.381	4.91
		0.509	4.32
		0.636	3.80
		0.763	3.34
		0.890	2.94
		1.017	2.59
		1.144	2.27
		1.271	2.00
			0.45
			7.85
			7.95
			7.95
			7.95
			7.95
			7.95
			7.95
			7.95
			7.95
			7.95
			7.95
			7.95

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.4329	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
17D			47407			GLADE RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.910	0.23	0.00	0.23	.1547	0.00122	.46	11.18	24.28	0.07	1.271	22.01	7.10
Q1-10 Flow												
2.910	0.15	0.00	0.15	.1547	0.00122	NA	NA	NA	0.07	1.457	22.56	7.13
Q30-10 Flow												
2.910	0.33	0.00	0.33	.1547	0.00122	NA	NA	NA	0.09	1.118	21.59	7.08

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
			(ft)	(ft)	(sq mi)	(ft/ft)	(mgd)				
17D	47407	GLADE RUN	2.910	1311.57	5.62	0.00000	0.00	<input checked="" type="checkbox"/>			
Stream Data											
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.000	0.23	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
Dayton Boro STP	PA0205915	0.1000	0.1000	0.1000	0.000	25.00	7.30				
Parameter Data											
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
CBOD5	15.00	2.00	0.00	1.50							
Dissolved Oxygen	5.00	8.24	0.00	0.00							
NH3-N	3.00	0.10	0.00	0.70							

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17D	47407	GLADE RUN			1.350	1301.52	7.17	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.000	0.30	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					0.00
Q30-10		0.00	0.00	0.000	0.000					0.00
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	3.00	8.24	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

TRC_CALC

1A	B	C	D	E	F	G				
2 TRC EVALUATION										
3 Input appropriate values in B4:B8 and E4:E7										
4	0.231	= Q stream (cfs)		0.5	= CV Daily					
5	0.1	= Q discharge (MGD)		0.5	= CV Hourly					
6	30	= no. samples		1	= AFC_Partial Mix Factor					
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor					
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)					
9	0.095	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)					
	0	= % Factor of Safety (FOS)			=Decay Coefficient (K)					
10	Source	Reference	AFC Calculations	Reference	CFC Calculations					
11	TRC	1.3.2.iii	WLA_afc = 0.495	1.3.2.iii	WLA_cfc = 0.475					
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581					
13	PENTOXSD TRG	5.1b	LTA_afc = 0.185	5.1d	LTA_cfc = 0.276					
14										
15	Source	Effluent Limit Calculations								
16	PENTOXSD TRG	5.1f	AML MULT = 1.231							
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.095			BAT/BPJ				
18			INST MAX LIMIT (mg/l) = 0.311							
19										
20	WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
21	LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$								
22	LTA_afc	$wla_afc*LTAMULT_afc$								
23	WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
24	LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$								
25	LTA_cfc	$wla_cfc*LTAMULT_cfc$								
26	AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$								
27	AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$								
28	INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$								



Toxics Management Spreadsheet
Version 1.4, May 2023

Discharge Information

Instructions Discharge Stream

Facility: Dayton Boro STP

NPDES Permit No.: **PA0205915**

Outfall No.: 001

Evaluation Type: **Custom / Additives**

Wastewater Description: **Sewage**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.1	100	7.3						



Stream / Surface Water Information

Instructions Discharge Stream

Dayton Boro STP, NPDES Permit No. PA0205915, Outfall 001

Receiving Surface Water Name: **Glade Run**

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	047407	2.91	1311.57	5.62			Yes
End of Reach 1	047407	1.35	1301.52	7.17			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
			Stream	Tributary					Hardness	pH	Hardness
Point of Discharge	2.91	0.231									
End of Reach 1	1.35	0.299									

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
			Stream	Tributary					Hardness	pH	Hardness
Point of Discharge	2.91										
End of Reach 1	1.35										



Model Results

<input type="button" value="Instructions"/>	<input checked="" type="button" value="Results"/>	<input type="button" value="RETURN TO INPUTS"/>	<input type="button" value="SAVE AS PDF"/>	<input type="button" value="PRINT"/>	<input checked="" type="radio"/> All	<input type="radio"/> Inputs	<input type="radio"/> Results	<input type="radio"/> Limits
---	---	---	--	--------------------------------------	--------------------------------------	------------------------------	-------------------------------	------------------------------

Dayton Boro STP, NPDES Permit No. PA0205915, Outfall 001

Hydrodynamics

Wasteload Allocations

AFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (\mu g/L)	Stream CV	Trib Conc (\mu g/L)	Fate Coef	WQC (µg/L)	WQ Obj (\mu g/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	13.439	14.0	34.9	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	64.581	81.6	204	Chem Translator of 0.791 applied
Total Zinc	0	0	0	0	117.180	120	299	Chem Translator of 0.978 applied

CFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (\mu g/L)	Stream CV	Trib Conc (\mu g/L)	Fate Coef	WQC (µg/L)	WQ Obj (\mu g/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	8.956	9.33	23.3	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	2.517	3.18	7.93	Chem Translator of 0.791 applied
Total Zinc	0	0	0	0	118.139	120	299	Chem Translator of 0.986 applied

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (\mu g/L)	Stream CV	Trib Conc (\mu g/L)	Fate Coef	WQC (µg/L)	WQ Obj (\mu g/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A	N/A

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (\mu g/L)	Stream CV	Trib Conc (\mu g/L)	Fate Coef	WQC (µg/L)	WQ Obj (\mu g/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A	N/A

Total Lead	0	0	0	N/A	N/A
Total Zinc	0	0	0	N/A	N/A

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits				Concentration Limits				Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Governing WQBEL	WQBEL Basis	
Total Zinc	Report	Report	Report	Report	Report	mg/L	0.19	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., < Target QL).