

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0208647  
APS ID 1041023  
Authorization ID 1358116

**Applicant and Facility Information**

Applicant Name	<u>Kratzer Run Sewer Authority</u>	Facility Name	<u>Kratzer Run Sewer Authority WWTP</u>
Applicant Address	<u>PO Box 253</u> <u>Grampian, PA 16838-0253</u>	Facility Address	<u>1265 Stronach Road</u> <u>Grampian, PA 16838-7911</u>
Applicant Contact	<u>Betty Jo Sutika, Secretary</u>	Facility Contact	<u>Betty Jo Sutika, Secretary</u>
Applicant Phone	<u>(814) 236-8346</u>	Facility Phone	<u>(814) 236-8346</u>
Client ID	<u>159928</u>	Site ID	<u>482999</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Penn Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Clearfield</u>
Date Application Received	<u>June 8, 2021</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>June 21, 2021</u>	If No, Reason	<u>Discharge with Wasteload Allocation in a EPA-approved TMDL</u>
Purpose of Application	<u>Renewal of NPDES Permit</u>		

**Summary of Review**

The subject facility is a municipal sewage treatment plant serving Grampian Borough and Penn Township in Clearfield County. A map indicating the discharge location is attached (Attachment A).

Sludge use and disposal description and location(s): The facility's dried sludge is disposed by landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	October 21, 2021
✓		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	October 22, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.08</u>
Latitude	<u>40° 58' 2.67"</u>	Longitude	<u>-78° 35' 12.20"</u>
Quad Name	<u>Curwensville, PA</u>	Quad Code	<u>1117</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Kratzer Run (CWF)</u>	Stream Code	<u>26659</u>
NHD Com ID	<u>61831557</u>	RMI	<u>2.6</u>
Drainage Area	<u>5.77 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0886</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.54</u>	Q <sub>7-10</sub> Basis	<u>USGS Gage 01541000, W. Branch Susquehanna River at Bower, PA (1915-2008)</u>
Elevation (ft)	<u>1480</u>	Slope (ft/ft)	<u>0.2178</u>
Watershed No.	<u>8-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>METALS, NUTRIENTS, PH</u>		
Source(s) of Impairment	<u>ACID MINE DRAINAGE, ACID MINE DRAINAGE, ON-SITE TREATMENT SYSTEMS (SEPTIC SYSTEMS AND SIMILAR DECENTRALIZED SYSTEMS)</u>		
TMDL Status	<u>Final</u>	Name	<u>Anderson Creek</u>
Nearest Downstream Public Water Supply Intake	<u>PA-American Water Company at Milton, PA</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Distance from Outfall (mi)	<u>Approx. 153</u>

Changes Since Last Permit Issuance: None. The above discharge and drainage characteristics are from the previous review and remain adequate.

Other Comments:

The above-listed Anderson Creek TMDL is primarily for pH and metals from Abandoned Mine Drainage (AMD) but also includes nutrient impairment for the Kratzer Run sub-watershed. This facility was included as a source of pollution and has received a wasteload allocation for phosphorus in an amendment to the TMDL in 2014 of 1.34 lbs/day and 487.35 lbs/year from a concentration of 2.0 mg/L. The daily waste load allocation of 1.34 lbs/day from the TMDL will be included at this time in addition to the concentration and annual load limits already included.

Due to the AMD-related impairments monitoring was included in the previous permit for the metals typically associated with AMD – Aluminum, Iron, and Manganese. This monitoring for the past permit term found the levels for all three of these parameters to be below their respective instream criteria and therefore, the monitor will not continue at this time. It is noted that the facility also meets its pH limits. Per the TMDL, Kratzer Run is meeting criteria related to AMD near the discharge point (site KR2).

The discharge is not expected to affect any downstream water supply at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Kratzer Run Sewer Authority WWTP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
1793407		May 2, 1994		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	UV	0.08
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.08	167	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: UV disinfection was installed during the past permit term without permit approval.

Other Comments: The treatment plant consists of a comminutor, bar screen, 13,200-gallon aerated equalization tank, two 40,000-gallon aeration tanks, one 7,500-gallon clarifier, UV disinfection, aerobic digester and sludge drying beds. Per the application the permittee retains the capability to disinfect with sodium hypochlorite.

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.0309	0.0299	0.0237	0.029	0.0273	0.0362	0.0258	0.0263	0.0265	0.0233	0.019	0.018
Flow (MGD) Daily Maximum	0.0667	0.0537	0.0368	0.0399	0.0357	0.0453	0.0648	0.0488	0.0550	0.0452	0.0359	0.0249
pH (S.U.) Minimum	6.9	6.9	6.9	6.9	6.7	6.7	6.8	6.9	6.7	7.0	6.6	6.5
pH (S.U.) Maximum	7.2	7.2	7.3	7.2	7.2	7.2	7.1	7.3	7.4	7.4	7.3	7.5
DO (mg/L) Minimum	3.6	3.5	3.4	3.4	3.4	3.6	3.4	3.3	3.3	3.2	3.2	3.2
TRC (mg/L) Average Monthly	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG
TRC (mg/L) Instantaneous Maximum	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG	GG
CBOD5 (lbs/day) Average Monthly	< 0.5	< 0.7	< 0.5	1.0	0.7	0.8	1.0	1.0	1.0	1.0	0.5	0.3
CBOD5 (lbs/day) Weekly Average	0.5	1.0	0.8	2.7	0.6	1.5	1.6	2.3	1.5	1.4	0.8	0.4
CBOD5 (mg/L) Average Monthly	< 2	< 3	< 3	< 3	2	< 2	6	5	7	5	4	< 2
CBOD5 (mg/L) Weekly Average	2	4	5	7	3	3	8	12	5	7	6	3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	16	11	17	15	34	27	23	22	23	20	18	11
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	24	13	24	18	73	44	29	32	30	22	23	14
BOD5 (mg/L) Raw Sewage Influent Average Monthly	72	49	92	65	134	94	136	103	109	106	118	77
TSS (lbs/day) Average Monthly	< 0.7	< 0.6	< 0.7	< 1.5	0.7	1.7	2.3	1.9	3.4	2.1	0.6	0.6
TSS (lbs/day) Raw Sewage Influent Average Monthly	20	10	12	16	16	30	12	21	28	18	15	11

**NPDES Permit Fact Sheet  
Kratzer Run Sewer Authority WWTP**

**NPDES Permit No. PA0208647**

TSS (lbs/day) Raw Sewage Influent Daily Maximum	27	14	16	28	27	47	19	28	34	23	21	15
TSS (lbs/day) Weekly Average	0.8	0.8	1.2	4.2	1.0	4.1	3.9	2.1	7.3	4.1	1.1	1.1
TSS (mg/L) Average Monthly	< 3	< 3	< 4	< 5	3	5	13	9	17	11	4	< 4
TSS (mg/L) Raw Sewage Influent Average Monthly	86	45	66	65	67	99	67	94	134	96	98	79
TSS (mg/L) Weekly Average	4	3	6	10	4	12	24	11	33	21	7	8
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 2	< 1	< 1	< 2	< 1	116	< 2	< 7	< 1	29	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	2	9.6	< 1	< 1	7.4	1	579.4	16	2419.6	5.2	217.8	1
Ammonia (lbs/day) Average Monthly	0.1	0.08	< 0.2	< 0.02	0.02	0.1	0.5	0.8	0.52	0.05	0.07	0.5
Ammonia (mg/L) Average Monthly	0.504	0.364	< 1.154	< 0.1	0.1	0.3	3.06	3.28	2.41	0.84	0.51	0.5
Total Phosphorus (lbs/day) Average Monthly	0.6	0.3	0.3	0.2	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.3
Total Phosphorus (mg/L) Average Monthly	2.62	1.33	1.64	1.09	1.33	0.658	2.0	0.87	1.44	1.49	2.01	1.86

**Compliance History, Cont'd**

**Effluent Violations for Outfall 001, from: September 1, 2020 To: August 31, 2021**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	9/30/21	Inst. Max	2419.6	CFU/100 ml	1000	CFU/100 ml
Total Phosphorus	08/31/21	Avg Mo	2.62	mg/L	2.0	mg/L
Total Phosphorus	10/31/20	Avg Mo	2.01	mg/L	2.0	mg/L

**Compliance History, Cont'd**

<b>Summary of Inspections:</b>		The facility was inspected most recently by the Department on November 12, 2020. This inspection identified violations including failure to obtain WQM permit approval, failure to notify DEP of physical changes, effluent violations, and failure to comply with terms of a WQM permit.
<b>Other Comments:</b>		A query in WMS found the open violations listed below for Kratzer Run Sewer Authority in eFACTS.

**Open violations in eFACTS for Kratzer Run Sewer Authority**

CLIENT ID	CLIENT	PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	VIOLATION DATE	VIOLATION CODE	VIOLATION
159928	KRATZER RUN SEW AUTH	PA0208647	3126571	903212	11/12/2020	92A.44	NPDES - Violation of effluent limits in Part A of permit
159928	KRATZER RUN SEW AUTH	PA0208647	3126571	903213	11/12/2020	CSL611	CSL - Failure to comply with terms and conditions of a WQM permit
159928	KRATZER RUN SEW AUTH	PA0208647	3126571	903214	11/12/2020	92A.41(A)12A	NPDES - Failure to notify DEP of planned physical changes to a facility
159928	KRATZER RUN SEW AUTH	PA0208647	3126571	903215	11/12/2020	91.21	CSL - Failure to apply for and/or obtain a WQM permit for the construction of sewage or industrial waste facilities

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	16.7	26.7	XXX	25	40	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	20.0	30.0	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	10.6	XXX	XXX	16	XXX	32	2/month	8-Hr Composite
Total Phosphorus (lbs/year)	XXX	487.35 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus	Report	XXX	XXX	2.0	XXX	XXX	2/month	8-Hr Composite
Total Aluminum	Report	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite
Total Iron	Report	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite
Total Manganese	Report	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.08</u>
<b>Latitude</b> <u>40° 58' 2.60"</u>	<b>Longitude</b> <u>-78° 35' 12.20"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and included in the existing permit. Due to the addition of e. coli bacteria criteria to Chapter 93 of the Department's regulations in 2021, monitoring for e. coli will now be included in the permit.

**Water Quality-Based Limitations**

**CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. The facility has an existing water quality-based limitation for ammonia-nitrogen of 16 mg/L as a monthly average.

WQM7.0 modeling was performed at this time (see Attachment B) for the discharge to Kratzer Run and indicated that the existing secondary limits for CBOD<sub>5</sub> are adequate to protect the receiving stream but a more stringent May through October Monthly Average limitation for ammonia-nitrogen of 11.94 mg/l will be necessary. The more stringent limitation is due to changes in 2021 to the Department's ammonia-nitrogen criteria in Chapter 93. Based on the data for the facility listed on page 5 of this Fact Sheet, the facility should be capable of meeting the limit. No November through April limit is necessary due to typically higher flows and lower temperatures during this period. The existing DO monitoring will continue.

**Disinfection/Total Residual Chlorine**

The facility has an existing BAT monthly average limit of 0.5 mg/l with the typical instantaneous maximum limit of 1.6 mg/l. The attached modeling shows that the limit of 0.5 mg/l is adequate to protect the receiving stream. While chlorine is no longer used at the facility TRC monitoring will be included in the draft permit while chlorine is still the only WQM permit-approval disinfection method and the permittee retains the ability to use chlorination.

Due to the actual use of UV disinfection at the facility monitoring will be included in the draft permit for UV Light Intensity. The permittee will be asked to clarify the actual monitoring capabilities for UV in the draft cover letter so that the monitoring can be altered, if necessary.



**Toxics Management**

No further "Reasonable Potential Analysis" was performed to determine additional parameters of concern for this minor municipal treatment plant with no significant industrial users.

**Chesapeake Bay/Nutrient Requirements**

As noted above the facility has received Wasteload Allocations for Total Phosphorus under the Anderson Creek TMDL which will be included in the draft permit.

In addition, according to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is considered a Phase 5 Chesapeake Bay sewage discharger, and as such requires no nutrient loading limits. Per the application the Total Nitrogen has averaged 13.2 mg/L and the Total Phosphorus has averaged 1.80 mg/L. Regular Total Phosphorus monitoring will continue due to the existing effluent limitation. The existing annual monitoring for Total Nitrogen will also remain.

**Best Professional Judgment (BPJ) Limitations**

Comments: No BPJ limits are necessary beyond the technology-based limits noted above.

**Anti-Backsliding**

No proposed limitations have been made less stringent consistent with the antidegradation requirements of the Clean Water Act and 40 CFR 122.44(l).

**Additional Considerations**

None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	16.7	26.7	XXX	25	40	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	20.0	30.0	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	7.97	XXX	XXX	11.94	XXX	23.88	2/month	8-Hr Composite
Total Phosphorus (lbs/year)	XXX	487.35 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

**Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	Report	1.34 Daily Max	XXX	2.0	XXX	XXX	2/month	8-Hr Composite
e. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab
UV Light Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured

Compliance Sampling Location: Outfall 001


Other Comments: Fecal Coliform monitoring units has been more accurately changed to No./100 ml from CFU/100 ml. Quarterly e. Coli monitoring is now included consistent with Department policy and recent changes to Chapter 93 of the Department's regulations. Monitoring for Total Aluminum, Total iron, and Total Manganese has been removed as noted above. A more stringent ammonia-nitrogen limitation is included as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 3/24/21
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model





Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
08B	26659	KRATZER RUN	2.600	1480.00	5.77	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.089	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Kratzer Run	PA0208647	0.0800	0.0000	0.0000	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	16.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
08B	26659	KRATZER RUN	0.000	1181.00	15.40	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.089	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0208647

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>									
08B		26659		KRATZER RUN									
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH	
<b>Q7-10 Flow</b>													
2.600	0.51	0.00	0.51	.1238	0.02178	.486	10.45	21.48	0.13	1.267	20.97	7.00	
<b>Q1-10 Flow</b>													
2.600	0.33	0.00	0.33	.1238	0.02178	NA	NA	NA	0.10	1.535	21.37	7.00	
<b>Q30-10 Flow</b>													
2.600	0.70	0.00	0.70	.1238	0.02178	NA	NA	NA	0.14	1.098	20.75	7.00	

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>									
08B		26659		KRATZER RUN									
RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)		Analysis pH									
2.600	0.080	20.971		7.000									
Reach Width (ft)	Reach Depth (ft)	Reach WDRatio		Reach Velocity (fps)									
10.447	0.486	21.483		0.125									
Reach CBOD5 (mg/L)	Reach Kc (1/days)	Reach NH3-N (mg/L)		Reach Kn (1/days)									
6.47	0.788	2.32		0.754									
Reach DO (mg/L)	Reach Kr (1/days)	Kr Equation		Reach DO Goal (mg/L)									
7.225	20.972	Owens		6									
Reach Travel Time (days)	Subreach Results												
1.267	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)									
	0.127	5.83	2.11	8.10									
	0.253	5.25	1.92	8.10									
	0.380	4.73	1.74	8.10									
	0.507	4.26	1.58	8.10									
	0.633	3.84	1.44	8.10									
	0.760	3.46	1.31	8.10									
	0.887	3.11	1.19	8.10									
	1.013	2.81	1.08	8.10									
	1.140	2.53	0.98	8.10									
	1.267	2.28	0.89	8.10									

Permit No. PA0208647

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
08B	26659	KRATZER RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.600	Kratzer Run	14.96	32	14.96	32	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.600	Kratzer Run	1.8	11.94	1.8	11.94	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.600	Kratzer Run	25	25	11.94	11.94	3	3	0	0

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
08B	26659	KRATZER RUN

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
2.600	Kratzer Run	PA0208647	0.080	CBOD5	25		
				NH3-N	11.94	23.88	
				Dissolved Oxygen			3



TRC\_CALC

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.54	= Q stream (cfs)	0.5	= CV Daily	
0.08	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)	
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 1.411	1.3.2.iii	WLA_cfc = 1.368
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.526	5.1d	LTA_cfc = 0.795
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1) \cdot 0.5)$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1) \cdot 0.5)$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1) \cdot 0.5) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$			