

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0209031
APS ID 1031083
Authorization ID 1340771

Applicant and Facility Information

Applicant Name	<u>Loganton Borough Authority, Clinton County</u>	Facility Name	<u>Loganton Borough Authority Sewer System STP</u>
Applicant Address	<u>PO Box 203 Loganton, PA 17747-0203</u>	Facility Address	<u>298 S. Mill Street Loganton, PA 17747-9301</u>
Applicant Contact	<u>Earl Weaver, Chairman</u>	Facility Contact	<u>Earl Weaver, Chairman</u>
Applicant Phone	<u>(570) 660-3665</u>	Facility Phone	<u>(570) 660-3665</u>
Client ID	<u>139977</u>	Site ID	<u>252459</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Loganton Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Clinton</u>
Date Application Received	<u>January 28, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 28, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit.</u>		

Summary of Review

The subject facility is a Publicly Owned Treatment Works (POTW) serving Loganton Borough, Clinton County. A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge is transferred to other WWTPs for further processing. Per the application 6.79 Dry Tons were removed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	August 30, 2021
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	August 30, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.05</u>
Latitude	<u>41° 1' 41.09"</u>	Longitude	<u>-77° 18' 26.85"</u>
Quad Name	<u>Loganton, PA</u>	Quad Code	<u>1027</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Fishing Creek (HQ-CWF, MF)</u>	Stream Code	<u>22416</u>
NHD Com ID	<u>67176532</u>	RMI	<u>31.22</u>
Drainage Area	<u>29.03 mi²</u>	Yield (cfs/mi ²)	<u>0.1128</u>
Q ₇₋₁₀ Flow (cfs)	<u>3.27</u>	Q ₇₋₁₀ Basis	<u>USGS Gage 01565000, Kichacoquillas Creek @ Reedsville, PA</u>
Elevation (ft)	<u>1204</u>	Slope (ft/ft)	<u>0.00124</u>
Watershed No.	<u>9-C</u>	Chapter 93 Class.	<u>HQ-CWF, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>NUTRIENTS, SILTATION</u>		
Source(s) of Impairment	<u>CROP PRODUCTION (CROP LAND OR DRY LAND), ON-SITE TREATMENT SYSTEMS (SEPTIC SYSTEMS AND SIMILAR DECENTRALIZED SYSTEMS)</u>		
TMDL Status	Name _____		
Nearest Downstream Public Water Supply Intake	<u>PA American Water Company @ Milton, PA</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Flow at Intake (cfs)	<u>752</u>
PWS RMI	<u>10.66</u>	Distance from Outfall (mi)	<u>103</u>

Changes Since Last Permit Issuance: None

Other Comments: Fishing Creek, due to the underlying geology, has gaining and losing sections. Previous reviews indicate that the stream enters a sink hole approximately 0.75 miles downstream.

No TMDL has been performed for the listed impairment to Fishing Creek. A stream assessment was conducted in 2012 to determine whether this discharge specifically was affecting the receiving stream. That assessment concluded that the discharge does not appear to be impacting the biological integrity in Fishing Creek.

Treatment Facility Summary				
Treatment Facility Name: Loganton Borough Authority				
WQM Permit No.	Issuance Date	Permit For:		
1894401	A-1 – 11/5/09	20,000-gallon sludge Tank		
	Original 12/27/94	Treatment Plant		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Sequencing Batch Reactor	UV	0.05
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.05	86.0	Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: The treatment facility, as permitted under WQM Permit No. 1894401 Amendment No.1, consists of pump station, comminutor, bar screen, 10,000-gallon surge tank, two 31,400-gallon SBR tanks, 10,400-gallon decant equalization tank, tertiary filter, UV disinfection, and 20,000-gallon aerated sludge holding tank.

Hauled in Waste
Per the application the applicant has not received any hauled in waste over the past three years and does not anticipate receiving any over the next permit term.

Compliance History

DMR Data for Outfall 001 (from July 1, 2020 to June 30, 2021)

Parameter	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20
Flow (MGD) Average Monthly	0.016	0.018	0.018	0.022	0.021	0.019	0.020	0.017	0.015	0.014	0.014	0.013
Flow (MGD) Weekly Average	0.017	0.020	0.023	0.027	0.024	0.020	0.033	0.017	0.018	0.015	0.014	0.014
pH (S.U.) Minimum	6.96	6.94	6.95	6.96	6.91	6.91	6.94	6.97	6.98	6.88	7.01	6.97
pH (S.U.) Instantaneous Maximum	7.05	7.30	7.12	7.15	7.07	7.07	7.14	7.08	7.09	7.29	7.19	7.14
DO (mg/L) Minimum	1.87	1.41	2.92	4.11	2.61	3.08	2.87	2.15	2.6	2.36	1.8	2.86
CBOD5 (lbs/day) Average Monthly	< 0.40	< 0.4	< 0.5	0.9	1.7	< 0.4	< 0.3	< 0.3	< 0.4	0.4	0.3	< 0.4
CBOD5 (lbs/day) Weekly Average	< 0.40	< 0.5	< 0.6	1.0	2.0	0.6	< 0.4	< 0.4	0.5	0.5	0.3	0.6
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.1	4.8	12.8	< 3.1	< 3.0	< 3.0	< 3.1	3.9	3.4	< 3.5
CBOD5 (mg/L) Weekly Average	< 3.0	3.1	3.3	5.5	18.2	3.3	< 3.0	< 3.0	3.2	4.0	3.4	4.0
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	3.1	3.29	5.5	18.2	3.3	< 3.0	< 3.0	3.23	4.0	3.44	4.01
BOD5 (mg/L) Influent Average Monthly	273	254	222	175	261	199	298	212	152	189	320	236
BOD5 (mg/L) Influent Instantaneous Maximum	310	280	238	231	276	225	310	241	229	228	387	268
TSS (lbs/day) Average Monthly	0.30	2.5	0.8	< 0.9	1.0	0.5	0.4	1.1	< 0.3	< 0.2	0.5	0.3
TSS (lbs/day) Weekly Average	0.40	4.0	1.0	1.0	1.0	0.7	0.4	2.0	0.5	< 0.3	0.6	0.3
TSS (mg/L) Average Monthly	2.60	15.8	5.0	< 4.8	8.4	3.6	3.4	9.2	< 2.6	< 2.2	5.0	2.2
TSS (mg/L) Influent Average Monthly	120	114	96	63	148	194	388	78	115	114	127	91

**NPDES Permit Fact Sheet
Loganton Borough Authority Sewer System STP**

NPDES Permit No. PA0209031

TSS (mg/L) Weekly Average	3.20	26.0	7.2	8.0	14.0	4.0	4.0	16.0	3.6	2.4	6.4	2.4
TSS (mg/L) Influent Instantaneous Maximum	168	190	118	76	152	286	660	86	126	162	172	98
TSS (mg/L) Instantaneous Maximum	3.20	26.0	7.2	8.0	14.0	4.0	4.0	16.0	3.6	2.4	6.4	2.4
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1.0	< 1	< 1.0	5	< 1	< 1	< 31	< 1	< 10.0	< 10	< 3
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	< 1.0	< 1	< 1.0	5.2	1	< 1	960	1	< 10.0	< 10	< 10
UV Transmittance (%) Minimum	100	100	100	100	100	100	100	100	100	100	100	100
Total Nitrogen (mg/L) Average Monthly	4.559	4.4	3.89	7.445	5.547	4.864	7.34	4.879	6.176	3.069	3.454	< 1.7
Ammonia (lbs/day) Average Monthly	< 0.20	0.3	0.2	1.1	0.10	0.03	< 0.01	0.1	< 0.07	< 0.01	< 0.01	< 0.01
Ammonia (lbs/day) Weekly Average	< 0.30	0.4	0.3	1.3	0.20	0.05	< 0.01	0.2	0.1	< 0.01	< 0.01	< 0.01
Ammonia (mg/L) Average Monthly	< 1.60	2.0	1.6	5.7	0.90	< 0.3	< 0.1	1.3	< 0.5	< 0.1	< 0.1	< 0.1
Ammonia (mg/L) Weekly Average	2.60	2.8	2.3	7.6	0.90	0.5	< 0.1	1.8	0.9	< 0.1	< 0.1	< 0.1
Ammonia (mg/L) Instantaneous Maximum	2.60	2.8	2.3	7.629	0.901	0.5	< 0.1	1.8	0.937	< 0.1	< 0.1	< 0.1

Compliance History, cont'd

Summary of Inspections:		The facility has been inspected at least annually by the Department over the past permit term. The most recent inspection on April 15, 2021 identified no violations at the time of inspection.
Other Comments:		A query in WMS found no open violations in eFACTS for Loganton Borough Authority.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	8.4	13	20.0	30.0	XXX	40.0	2/month	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	4.2	6.3	10.0	15.0	XXX	20.0	2/month	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Influent	XXX	XXX	Report	XXX	XXX	Report	2/month	8-Hr Composite
Total Suspended Solids Nov 1 - Apr 30	8.4	13	20.0	30.0	XXX	40.0	2/month	8-Hr Composite
Total Suspended Solids May 1 - Oct 31	4.2	6.3	10.0	15.0	XXX	20.0	2/month	8-Hr Composite
Total Suspended Solids Influent	XXX	XXX	Report	XXX	XXX	Report	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ultraviolet light transmittance (%)	XXX	XXX	Report Min	XXX	XXX	XXX	1/day	Metered
Nitrate-Nitrite as N	XXX	XXX	Report	XXX	XXX	Report	1/year	8-Hr Composite
Total Nitrogen	XXX	XXX	10	XXX	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - May 31	3.8	5.6	9.0	13.5	XXX	18.0	2/month	8-Hr Composite
Ammonia-Nitrogen Jun 1 - Oct 31	1.3	1.9	3.0	4.5	XXX	6.0	2/month	8-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Maximum	Instant. Maximum		
Total Kjeldahl Nitrogen	XXX	XXX	Report	XXX	XXX	Report	1/year	8-Hr Composite
Total Phosphorus	XXX	XXX	Report	XXX	XXX	Report	1/year	8-Hr Composite
Copper, Total	XXX	XXX	Report	XXX	XXX	Report	1/quarter	8-Hr Composite

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.05</u>
Latitude <u>41° 1' 39.50"</u>	Longitude <u>-77° 18' 30.10"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

Comments: The above limitations are applicable and included in the existing permit except for more stringent existing limits for TSS and CBOD₅ as discussed below. Due to the addition of e. coli bacteria criteria to Chapter 93, monitoring for e. coli will now be included in the permit.

Water Quality-Based Limitations

Antidegradation

Social and economic justification (SEJ) for the discharge to a special protection watershed was approved in June 1993 with the inclusion of the dry stream limitations discussed below. Therefore, the discharge has not received the Antidegradation Best Available Combination of Technologies (ABACT) requirements as listed in the Department's *Water Quality Antidegradation Implementation Guidance*.

Discharge to Dry or Intermittent Stream

The existing limitations for CBOD₅, TSS, and Total Nitrogen were based on a prior version of the Department's *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales and Storm Sewers* guidance document (391-2000-014). The current version of the guidance prescribes additional and more stringent limitations for new or expanded discharges including a TN limit of 5 mg/L, DO maximum of 6 mg/L and TP limit of 0.5 mg/L. These additional limitations will not be required at this time for this existing discharge to a unique stream situation.

CBOD₅, NH₃-N & DO

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed (see Attachment B) for the discharge to Fishing Creek and indicated that the existing CBOD₅ limit mentioned above and the existing Water Quality-based NH₃-N limits, should be adequate to protect the receiving stream.

Toxics Management

Copper – The existing permit includes quarterly copper monitoring due to an application sample having been greater than 10% of the water quality-based effluent limit (WQBEL).

The Department's Toxics Management Spreadsheet is a mass-balance water quality analysis model that includes consideration for mixing and other factors to determine recommended water quality-based effluent limits. The spreadsheet incorporates the water quality criteria of 25 Pa. Code §93. The calculated WQBEL for Total Copper for the discharge is 0.198 mg/L. See the attached Toxics Management Spreadsheet (Attachment C).

Because copper levels since Fall 2017 (the period available in eDMR) have ranged from 0.0091 to 0.0298 mg/L with an average of 0.0173 mg/L, the current quarterly monitoring will be changed to annually because although they have been greater than 10% of the WQBEL the levels seen have been consistently remained under the limit.

No further "Reasonable Potential Analysis" was conducted for this minor sewage treatment facility with no industrial users to determine additional parameters as candidates for limitations or monitoring.

Chesapeake Bay/Nutrient Requirements

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is considered a Phase 5 Chesapeake Bay sewage discharger, and as such requires no nutrient loading limits. Per a review of the facility eDMR data over the past two years the Total Nitrogen has averaged 3.26 mg/L and the Total Phosphorus has averaged 1.67 mg/L. Regular Total Nitrogen monitoring will continue due to the existing effluent limitation. The existing annual monitoring for Total Phosphorus, TKN, and Nitrate-Nitrite will also remain due to the unique stream condition.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limits are necessary at this time beyond the water quality and technology-based limits noted above.

Anti-Backsliding

Consistent with the anti-backsliding provisions of the Clean Water Act and 40 CFR 122.44(l), no proposed limits have been made less stringent.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	8.4	13	20.0	30.0	XXX	40.0	2/month	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	4.2	6.3	10.0	15.0	XXX	20.0	2/month	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Influent	XXX	XXX	Report	XXX	XXX	Report	2/month	8-Hr Composite
Total Suspended Solids Nov 1 - Apr 30	8.4	13	20.0	30.0	XXX	40.0	2/month	8-Hr Composite
Total Suspended Solids May 1 - Oct 31	4.2	6.3	10.0	15.0	XXX	20.0	2/month	8-Hr Composite
Total Suspended Solids Influent	XXX	XXX	Report	XXX	XXX	Report	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Maximum	Instant. Maximum		
Ultraviolet light transmittance (%)	XXX	XXX	Report Min	XXX	XXX	XXX	1/day	Metered
Nitrate-Nitrite as N	XXX	XXX	Report	XXX	XXX	Report	1/year	8-Hr Composite
Total Nitrogen	XXX	XXX	10	XXX	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - May 31	3.8	5.6	9.0	13.5	XXX	18.0	2/month	8-Hr Composite
Ammonia-Nitrogen Jun 1 - Oct 31	1.3	1.9	3.0	4.5	XXX	6.0	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	XXX	Report	XXX	XXX	Report	1/year	8-Hr Composite
Total Phosphorus	XXX	XXX	Report	XXX	XXX	Report	1/year	8-Hr Composite
Copper, Total	XXX	XXX	XXX	Report Daily Max	XXX	Report	1/year	8-Hr Composite

Compliance Sampling Location: Outfall 001


Other Comments: Copper monitoring has been reduced from quarterly to annually as noted above. Quarterly e. Coli monitoring is now included consistent with Department policy and recent changes to Chapter 93 of the Department's regulations.

It is noted that the TRC monitoring data listed on page 5 of this Fact Sheet are consistently at a value of 100. This is not a typically expected value for UV Light Transmittance monitoring and therefore, the permittee will be asked to verify what parameters their UV units can monitor during the draft comment period. The monitoring units will then be altered as necessary in the final permit.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment C)
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 3/24/21
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. Toxics Management Spreadsheet



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
09C	22416	FISHING CREEK	31.220	1204.00	29.03	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.113	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Loganton	PA0209031	0.0500	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	10.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	3.00	0.00	0.00	0.70

Permit No. PA0209031

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
09C	22416	FISHING CREEK	26.790	1175.00	33.73	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.113	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Filter

Permit No. PA0209031

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
09C		22416		FISHING CREEK								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
31.220	3.27	0.00	3.27	.0773	0.00124	.651	29.33	45.06	0.18	1.542	20.12	7.00
Q1-10 Flow												
31.220	2.10	0.00	2.10	.0773	0.00124	NA	NA	NA	0.14	1.965	20.18	7.00
Q30-10 Flow												
31.220	4.45	0.00	4.45	.0773	0.00124	NA	NA	NA	0.21	1.302	20.09	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Permit No. PA0209031

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
09C	22416	FISHING CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
31.220	0.050	20.115		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
29.328	0.651	45.057		0.176
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.18	0.057	0.07		0.706
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.122	2.074	Tsivoglou		6
<u>Reach Travel Time (days)</u>	Subreach Results			
1.542	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.154	2.17	0.06	8.23
	0.308	2.15	0.06	8.23
	0.463	2.13	0.05	8.23
	0.617	2.11	0.04	8.23
	0.771	2.09	0.04	8.23
	0.925	2.07	0.04	8.23
	1.079	2.05	0.03	8.23
	1.233	2.04	0.03	8.23
	1.388	2.02	0.03	8.23
	1.542	2.00	0.02	8.23

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>							
09C	22416	FISHING CREEK							
<hr/>									
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
31.220	Loganton	16.51	6	16.51	6	0	0		
<hr/>									
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
31.220	Loganton	1.88	3	1.88	3	0	0		
<hr/>									
Dissolved Oxygen Allocations									
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
31.22	Loganton	10	10	3	3	3	3	0	0

Permit No. PA0209031

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
09C		22416		FISHING CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	E fl. Limit 30-day Ave. (mg/L)	E fl. Limit Maximum (mg/L)	E fl. Limit Minimum (mg/L)
31.220	Loganton	PA0209031	0.050	CBOD5	10		
				NH3-N	3	6	
				Dissolved Oxygen			3



Model Results

Loganton Borough, NPDES Permit No. PA0209031, Outfall 001

Instructions
 Results

 All
 Inputs
 Results
 Limits

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
31.22	3.27		3.27	0.077	0.001	0.851	29.328	45.057	0.178	1.542	60.848
26.79	3.80		3.804744								

Q_b

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
31.22	20.95		20.95	0.077	0.001	1.46	29.328	20.084	0.491	0.551	18.834
26.79	23.889		23.89								

Wasteload Allocations

AFC
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	13.439	14.0	308	Chem Translator of 0.96 applied

CFC
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	8.956	9.33	404	Chem Translator of 0.96 applied

THH
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	

CRL
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	Report	Report	Report	Report	Report	µg/L	198	AFC	Discharge Conc > 10% WQBEL (no RP)