

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0209236
 APS ID 1152245
 Authorization ID 1552136

Applicant and Facility Information

Applicant Name	<u>Tioga Borough Tioga County</u>	Facility Name	<u>Tioga Borough Sanitary Sewer STP</u>
Applicant Address	<u>PO Box 158</u> <u>Tioga, PA 16946-0158</u>	Facility Address	<u>Krieger Lane</u> <u>Tioga, PA 16946</u>
Applicant Contact	<u>Donald Warriner</u>	Facility Contact	<u>Donald Warriner</u>
Applicant Phone	<u>(570) 835-5226</u>	Facility Phone	<u>(570) 835-5226</u>
Client ID	<u>44851</u>	Site ID	<u>257615</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Tioga Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Tioga</u>
Date Application Received	<u>December 8, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 16, 2025</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an NPDES Permit</u>		



Summary of Review

The subject facility is a minor Publicly Owned Treatment Works (POTW) serving Tioga Borough and Tioga Township in Tioga County.

Sludge use and disposal description and location(s): The facility's dewatered sludge is disposed by landfill. Per the application 11.85 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	March 24, 2026
✓		 for Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	March 24, 2026

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.06</u>
Latitude	<u>41° 54' 49.74"</u>	Longitude	<u>-77° 7' 50.72"</u>
Quad Name	<u>Jackson Summit, PA</u>	Quad Code	<u>0329</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Tioga River (CWF)</u>	Stream Code	<u>30990</u>
NHD Com ID	<u>57350483</u>	RMI	<u>21.0</u>
Drainage Area	<u>280 mi²</u>	Yield (cfs/mi ²)	<u>0.0858</u>
Q ₇₋₁₀ Flow (cfs)	<u>24.3</u>	Q ₇₋₁₀ Basis	<u>USGS Gage 0151800, Tioga River @ Tioga, PA</u>
Elevation (ft)	<u>1020</u>	Slope (ft/ft)	<u>0.001388</u>
Watershed No.	<u>4-A</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>SILTATION</u>		
Source(s) of Impairment	<u>DAM OR IMPOUNDMENT</u>		
TMDL Status	<u>None</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>PA-NY State Line</u>		
PWS Waters	<u>Tioga River</u>	Flow at Intake (cfs)	<u>N/A</u>
PWS RMI	<u>13.0</u>	Distance from Outfall (mi)	<u>8.0</u>

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics determined for previous reviews remain adequate.

Other Comments: The facility is not expected to be a significant contributor to the above-listed impairments to the Tioga River. The facility's generally meets its TSS limitations. The TSS data for the past permit term was reviewed and the effluent violation noted for TSS from April 2025 was the only exceedance in the permit term.

The Tioga River TMDL addresses upstream impairments from AMD. The existing permit includes monitoring for Aluminum, Iron, and Manganese. Monitoring for these was consistently at 0.1 for Total Aluminum, mg/L, 0.2 mg/L for Total Iron, and 0.02 mg/L for Total Manganese which are all below their respective instream criteria. Therefore, because the load of the metals from the discharge has been adequately characterized and the discharge is not expected to contribute to the upstream impairments, no further monitoring for these will be included at this time.

No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed. The Department considers the PA/NY state line to the closest water supply due to no closer intakes.

Treatment Facility Summary				
Treatment Facility Name: Tioga Borough				
WQM Permit No.		Issuance Date		
5995405		11/20/1995		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Hypochlorite	0.06
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.06	110	Not Overloaded	Drying	Landfill

Changes Since Last Permit Issuance: None

Other Comments: The treatment facilities as permitted under WQM Permit 5995405 consists of a grinder pump, two sequencing batch reactors (SBRs), sodium hypochlorite disinfection, and chlorine contact tank.

Industrial Users
The facility receives flows from one industrial user, Tyoga Container.

Hauled-In-Waste
The facility receives no hauled in waste.

Compliance History

DMR Data for Outfall 001 (from February 1, 2025 to January 31, 2026)

Parameter	JAN-26	DEC-25	NOV-25	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25
Flow (MGD) Average Monthly	0.0255	0.0221	0.0212	0.0206	0.0208	0.0229	0.0274	0.0325	0.0338	0.0254	0.0247	0.0223
Flow (MGD) Daily Maximum	0.0375	0.0323	0.031	0.029	0.0293	0.037	0.0364	0.0472	0.0544	0.0327	0.0349	0.0302
pH (S.U.) Instantaneous Minimum	7.46	7.50	7.43	7.18	7.09	7.14	7.13	7.12	7.21	7.51	7.40	7.48
pH (S.U.) Instantaneous Maximum	7.64	7.62	7.59	7.47	7.32	7.37	7.30	7.32	7.58	7.61	7.58	7.78
DO (mg/L) Instantaneous Minimum	5.1	4.9	4.6	4.1	3.7	2.3	2.3	2.8	3.5	4.9	4.5	5.8
TRC (mg/L) Average Monthly	0.38	0.29	0.32	0.35	0.28	0.34	0.31	0.43	0.46	0.38	0.39	0.46
TRC (mg/L) Instantaneous Maximum	0.98	0.88	0.87	0.66	0.74	1.15	0.84	1.02	1.04	0.83	0.90	1.48
CBOD5 (lbs/day) Average Monthly	2.4	2.8	2.2	1	1.3	1.4	2.0	2	3.3	4.1	3.4	2.4
CBOD5 (lbs/day) Weekly Average	2.9	2.9	2.6	1.2	14	1.7	2.2	2.2	4.7	5.7	4.2	3.7
CBOD5 (mg/L) Average Monthly	13	17	14	6	9	9	9	8	13	22	16	12
CBOD5 (mg/L) Weekly Average	16	18	16	7	10	11	10	9	17	30	20	18
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	52	81	55	59	61	38	57	48	49	46	43	49
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	53	97	61	61	82	45	77	60	50	47	48	51
BOD5 (mg/L) Raw Sewage Influent Average Monthly	273	481	349	375	401	228	237	194	194	237	205	270
TSS (lbs/day) Average Monthly	2.1	2.8	2.7	1	1.7	0.9	1.7	2	4.4	6.5	4.2	2.1
TSS (lbs/day) Raw Sewage Influent Average Monthly	39	41	32	41	52	21	44	35	42	31	31	31
TSS (lbs/day) Raw Sewage Influent Daily Maximum	49	41	35	42	56	25	53	45	53	39	35	33

**NPDES Permit Fact Sheet
Tioga Borough Sanitary Sewer STP**

NPDES Permit No. PA0209236

TSS (lbs/day) Weekly Average	2.1	2.9	3.1	1	2.0	0.9	2.4	2.2	5.5	7.4	4.9	2.9
TSS (mg/L) Average Monthly	11	17	17	6	12	6	8	8	17	34	20	11
TSS (mg/L) Raw Sewage Influent Average Monthly	205	246	202	259	342	122	184	142	162	162	145	170
TSS (mg/L) Weekly Average	12	19	19	6	13	6	11	9	20	39	23	14
Fecal Coliform (No./100 ml) Geometric Mean	28	202	125	190	133	109	46	10	6	27	227	30
Fecal Coliform (No./100 ml) Instantaneous Maximum	98	426	1553	225	411	109	345	11	11	141	1120	308
E. Coli (No./100 ml) Instantaneous Maximum		68			124				649		2420	
Ammonia (lbs/day) Average Monthly	7.5	7.9	6.5	4.4	2.1	3.2	5.6	4.6	4.2	9.5	8.5	7.5
Ammonia (mg/L) Average Monthly	40	48	41	28	14	19	24	19	15	49	41	41

Compliance History, Continued

Effluent Violations for Outfall 001, from: February 1, 2025 to: January 31, 2026

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	04/30/25	Avg Mo	34	mg/L	30	mg/L

Compliance History, Continued

Summary of Inspections:	The most recent inspection by the Department of the facility on January 22, 2025, identified NPDES effluent violations.
Other Comments:	There are no open violations in eFACTS for Tioga Borough, Tioga County.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	13	20	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	15	23	XXX	30	45	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Aluminum	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Iron	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Manganese	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.06</u>
Latitude <u>41° 54' 50.10"</u>	Longitude <u>-77° 7' 49.60"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and are included in the existing permit.

Water Quality-Based Limitations

DO, CBOD₅ and NH₃-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed (see Attachment B) for the discharge to the Tioga River and showed that no more stringent limitations are necessary beyond the existing technology based limits noted above.

Total Residual Chlorine

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet (see Attachment C) show that the existing technology-based limit of 0.5 mg/l is adequate to protect the receiving stream.

Water Quality Toxics Management

No "Reasonable Potential Analysis" was performed to determine additional parameters with the reasonable potential to violate water quality standards for this minor STP discharge with no significant industrial influent.

Chesapeake Bay/Nutrient Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania in order to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. Tioga Borough is considered a Phase 5, Significant Chesapeake Bay discharger. Therefore, no Nutrient cap loads have been established for this facility pursuant to the Phase III Watershed Implementation Plan. Monitoring under a previous issuance found the Total Nitrogen and Total Phosphorus to average 22.1 mg/L and 1.65 mg/L, respectively. Therefore, because the Total Nitrogen and Total Phosphorus loads from the facility have been characterized, no additional nutrient monitoring will be required at this time.

E. Coli Monitoring

Quarterly E. Coli monitoring is included in the existing permit consistent with recent changes to Chapter 93 of the Department's regulations and Departmental policy and will remain.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limitations are necessary at this time beyond the technology and water quality-based limitations noted above.

Anti-Backsliding

No proposed technology or BPJ-based limitations have been made less stringent consistent with the Anti-degradation requirements of The Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	13	20	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	15	23	XXX	30	45	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia-Nitrogen	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

**NPDES Permit Fact Sheet
Tioga Borough Sanitary Sewer STP**



NPDES Permit No. PA0209236

Other Comments: The above limitations and monitoring are unchanged from the existing permit except for the removal of Total Aluminum, Total Iron, and Total Manganese monitoring as noted above..

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment)
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP:
<input type="checkbox"/>	Other:

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model



Outfall 001

Google Earth



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30990	TIOGA RIVER	21.000	1020.00	280.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)						Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.086	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Tioga Borough	PA0209236	0.0600	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30990	TIOGA RIVER	18.300	1000.00	285.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)	(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH	
Q7-10	0.086	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
04A		30990				TIOGA RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
21.000	24.02	0.00	24.02	.0928	0.00140	.911	81.41	89.4	0.33	0.507	20.02	7.00
Q1-10 Flow												
21.000	15.38	0.00	15.38	.0928	0.00140	NA	NA	NA	0.25	0.650	20.03	7.00
Q30-10 Flow												
21.000	32.67	0.00	32.67	.0928	0.00140	NA	NA	NA	0.39	0.427	20.01	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
04A	30990	TIOGA RIVER

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
21.000	0.060	20.019	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
81.405	0.911	89.395	0.325
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.09	0.049	0.10	0.701
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.223	3.116	Tsivoglou	6
<u>Reach Travel Time (days)</u>	Subreach Results		
0.507	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.051	2.08	0.09
	0.101	2.08	0.09
	0.152	2.07	0.09
	0.203	2.07	0.08
	0.254	2.06	0.08
	0.304	2.06	0.08
	0.355	2.05	0.08
	0.406	2.05	0.07
	0.456	2.04	0.07
	0.507	2.04	0.07

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
04A	30990	TIOGA RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
21.000	Tioga Borough	16.72	50	16.72	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
21.000	Tioga Borough	1.89	25	1.89	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
21.00	Tioga Borough	25	25	25	25	3	3	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
04A		30990		TIOGA RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
21.000	Tioga Borough	PA0209236	0.060	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
24.3	= Q stream (cfs)		0.5	= CV Daily
0.06	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 83.532	1.3.2.iii	WLA_cfc = 81.430
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 31.126	5.1d	LTA_cfc = 47.340
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$			
LTA_afc	wla_afc*LTAMULT_afc			
WLA_cfc	$(.011/e(-k*CFC_tc) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$			
LTA_cfc	wla_cfc*LTAMULT_cfc			
AML_MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$			
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)			
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)			