

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0209261  
APS ID 1010557  
Authorization ID 1304010

**Applicant and Facility Information**

Applicant Name	<u>Liberty Township, Montour County</u>	Facility Name	<u>Liberty Township Mooresburg Village WWTP</u>
Applicant Address	<u>197 Mooresburg Road</u> <u>Danville, PA 17821-7030</u>	Facility Address	<u>1316 Bald Top Road</u> <u>Danville, PA 17821</u>
Applicant Contact	<u>Linda Llewellyn, Twp Sec.</u>	Facility Contact	<u>Gary Krick, Supervisor</u>
Applicant Phone	<u>(570) 275-2211</u>	Facility Phone	<u>(570) 275-2211</u>
Client ID	<u>25304</u>	Site ID	<u>257852</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Liberty Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Montour</u>
Date Application Received	<u>January 31, 2020</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>February 4, 2020</u>	If No, Reason	<u>Discharge is subject to an EPA-approved TMDL</u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

**Summary of Review**

The subject facility is a Publicly Owned Treatment Work (POTW) serving Liberty Township, Montour County in the vicinity of the village of Mooresburg.

A map of the discharge location is attached.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	April 21, 2020
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	April 22, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.013</u>
Latitude	<u>40° 58' 54.26"</u>	Longitude	<u>-76° 42' 10.42"</u>
Quad Name	<u>Riverside, PA</u>	Quad Code	<u>1132</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Mausus Creek (CWF)</u>	Stream Code	<u>27331</u>
NHD Com ID	<u>65641597</u>	RMI	<u>4.97</u>
Drainage Area	<u>0.30 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.168</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.05</u>	Q <sub>7-10</sub> Basis	<u>Streamgage No. 01420500</u>
Elevation (ft)	<u>620</u>	Slope (ft/ft)	<u>0.00758</u>
Watershed No.	<u>5-E</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>SILTATION,</u>		
Source(s) of Impairment	<u>AGRICULTURE</u>		
TMDL Status	<u>Final</u>	Name	<u>Mahoning Creek Watershed TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>Cherokee Pharmaceuticals, LLC</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>5,000,000</u>
PWS RMI	<u>135.7</u>	Distance from Outfall (mi)	<u>8.6</u>

Changes Since Last Permit Issuance: None. The above discharge and drainage characteristics were determined for the previous review and remain adequate.

Other Comments:

The discharge has received wasteload allocations for Total Phosphorus and Sediment under the Mahoning Creek Watershed TMDL, which are further discussed in the Development of Effluent Limitations section below.

No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Mooresburg Wastewater Treatment Plant				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
4796402	6/13/96	Original permit for treatment system		
Amendment A-1	10/12/18	Phosphorus Removal		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Phosphorus Reduction	Septic Tank Sand Filter	Hypochlorite	0.013
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.013		Not Overloaded		

Changes Since Last Permit Issuance: 4796402 Amendment No. 1 was issued in 2018 but the Township has not installed the phosphorus removal yet because the TP limits have been met.

Other Comments: The treatment facility, as approved by WQM Permit No. 4796402 consists receipt of septic tank effluent from individual homes, a dosing tank, two sand filters, and chlorination with a contact tank.

Hauled in Waste
Per the application, the permittee has not accepted any trucked in waste in the past three years and does not anticipate receiving any over the next permit term.

Sludge/Biosolids Disposal
Septic tank septage is removed to a permitted facility for ultimate disposal or beneficial reuse. No sludge is typically produced from the main facility due to the nature of the treatment.

Compliance History

DMR Data for Outfall 001 (from February 1, 2019 to January 31, 2020)

Parameter	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19
Flow (MGD) Average Monthly	0.0034	0.0035	0.0039	0.0039	0.0036	0.0038	0.0036	0.0038	0.0041	0.0040	0.0036	0.0036
Flow (MGD) Daily Maximum	0.0036	0.0039	0.0043	0.0043	0.0039	0.0040	0.0039	0.0041	0.0043	0.0042	0.0041	0.0040
pH (S.U.) Daily Minimum	6.2	6.4	6.2	6.2	6.3	6.3	6.3	6.2	6.2	6.2	6.2	6.2
pH (S.U.) Instantaneous Maximum	6.5	6.7	6.7	6.5	6.6	6.7	6.6	6.5	6.5	6.6	6.5	6.6
DO (mg/L) Minimum	8.0	8.0	8.0	7.0	6.0	6.0	6.0	6.0	7.0	8.0	8.0	8.0
TRC (mg/L) Average Monthly	0.32	0.33	0.35	0.31	0.34	0.32	0.33	0.33	0.29	0.29	0.31	0.32
TRC (mg/L) Instantaneous Maximum	0.51	0.47	0.62	0.61	0.59	0.48	0.63	0.64	0.56	0.50	0.74	0.61
CBOD5 (lbs/day) Average Monthly	0.12	0.07	0.07	0.069	0.1	0.07	0.066	0.074	0.08	0.08	0.11	0.10
CBOD5 (lbs/day) Weekly Average	0.18	0.07	0.07	0.075	0.123	0.07	0.070	0.075	0.08	0.09	0.12	0.12
CBOD5 (mg/L) Average Monthly	5.0	2.2	2.2	2.2	2.2	2.3	2.2	2.2	2.2	3.0	4.0	4.0
CBOD5 (mg/L) Weekly Average	7.0	2.2	2.2	2.2	2.2	2.4	2.2	2.2	2.2	3.0	4.0	4.0
TSS (lbs/day) Daily Maximum	0.11	0.13	0.14	0.13	0.12	0.13	0.15	0.14	0.14	0.13	0.12	0.19
TSS (mg/L) Average Monthly	4.0	4.0	4.0	4.0	4.0	4.0	5.0	4.0	4.0	4.0	4.0	7.0
TSS (mg/L) Weekly Average	4.0	4.0	4.0	4.0	4.0	4.0	5.0	4.0	4.0	4.0	4.0	8.0
Fecal Coliform (No./100 ml) Average Monthly	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0

**NPDES Permit Fact Sheet**  
**Liberty Township Mooresburg Village Sanitary Sewer STP**

**NPDES Permit No. PA0209261**

Total Nitrogen (lbs/day) Annual Average		0.04										
Total Nitrogen (mg/L) Annual Average		1.3										
Ammonia (lbs/day) Average Monthly	0.009	0.003	0.003	0.003	0.003	0.003	0.0003	0.003	0.0035	0.10	0.22	0.084
Ammonia (lbs/day) Weekly Average	0.011	0.003	0.003	0.003	0.003	0.003	0.0003	0.003	0.0035	0.16	0.22	0.088
Ammonia (mg/L) Average Monthly	0.26	0.10	0.10	0.10	0.10	0.10	0.01	0.10	0.10	3.3	7.9	2.8
Ammonia (mg/L) Weekly Average	0.42	0.10	0.10	0.10	0.10	0.10	0.01	0.10	0.10	5.3	8.2	3.0
Total Phosphorus (lbs/day) Daily Maximum	0.075	0.069	0.051	0.079	0.068	0.063	0.057	0.048	0.042	0.067	0.034	0.032
Total Phosphorus (mg/L) Average Monthly	2.1	2.0	1.5	2.1	2.2	1.9	1.6	1.3	1.07	1.4	1.3	1.0
Total Phosphorus (mg/L) Daily Maximum	2.8	2.3	1.6	2.3	2.2	1.9	1.8	1.4	1.2	2.0	1.5	1.1

**Compliance History, Cont'd**

<b>Summary of Inspections:</b>	The facility has been inspected annually by the Department over the past permit term. The most recent inspection on February 7, 2020 identified no violations.
<b>Other Comments:</b>	A query in WMS found no open violations in eFACTS for Liberty Township, Montour County.

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.37	XXX	1.21	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	2.7	4.3 Wkly Avg	XXX	25.0	40.0	50	2/month	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Suspended Solids	XXX	3.25	XXX	30	45	60	2/month	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen Nov 1 - May 31	2.0	2.9 Wkly Avg	XXX	18.0	27.0	36	2/month	8-Hr Composite
Ammonia-Nitrogen Jun 1 - Oct 31	0.7	1.0 Wkly Avg	XXX	6.0	9.0	12	2/month	8-Hr Composite
Total Phosphorus	XXX	0.08	XXX	Report	Report Daily Max	XXX	2/month	8-Hr Composite

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.013</u>
<b>Latitude</b> <u>40° 58' 54.40"</u>	<b>Longitude</b> <u>-76° 42' 10.20"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are applicable and already included in the existing permit except for a more stringent water quality-based TRC limit which will remain.

**Water Quality-Based Limitations**

**CBOD<sub>5</sub>, NH<sub>3</sub>-N & DO**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. The facility has existing water quality-based limits for ammonia-nitrogen and Dissolved Oxygen.

WQM7.0 modeling performed for the discharge to Mause Creek for the previous review (see Attachment B) indicated that the existing CBOD<sub>5</sub>, DO, and NH<sub>3</sub> limits are adequate to protect the receiving stream.

**Total Residual Chlorine**

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's Total Residual Chlorine (TRC) in a receiving stream. The attached modeling shows that the existing water quality-based limit of 0.37 mg/L is adequate to protect the receiving stream.

**Toxics Management**

No further "Reasonable Potential Analysis" was conducted to determine additional parameters as candidates for limitations or monitoring for this minor sewage treatment facility with no industrial users.

**Mahoning Creek TMDL/Chesapeake Bay/ Nutrient Requirements**

Pursuant to the Mahoning Creek Watershed TMDL, the Liberty Township facility has received a daily maximum loading limitation for Total Phosphorus of 0.8 lbs/day. In addition, the discharge has received a daily maximum loading limitation for TSS. These limitations were included in the previous permit renewal with a compliance schedule for meeting the Total Phosphorus loading.

In addition, according to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is considered a Phase 5 Chesapeake Bay sewage discharger, and as such requires no nutrient loading limits. Per a review of the facility DMRs over the past two years the Total Nitrogen has averaged 14.8 mg/L while the Total Phosphorus over the past year has averaged 1.5 mg/L. Because the total nitrogen levels in the discharge have adequately been characterized, existing annual Total Nitrogen monitoring will be removed from this proposed draft permit consistent with the Phase III WIP wastewater supplement. Total Phosphorus monitoring will remain due to the TMDL limitation.

**Best Professional Judgment (BPJ) Limitations**

Comments: No additional BPJ limits are necessary for this discharge at this time beyond the technology and water quality-based limitations noted above.

**Anti-Backsliding**

No proposed limitations were made less stringent consistent with the anti-degradation requirements of the Clean Water Act and 40 CFR 122.44(l).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.37	XXX	1.21	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	2.7	4.3 Wkly Avg	XXX	25.0	40.0	50	2/month	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Suspended Solids	XXX	3.25	XXX	30	45	60	2/month	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
Ammonia-Nitrogen Nov 1 - May 31	2.0	2.9 Wkly Avg	XXX	18.0	27.0	36	2/month	8-Hr Composite
Ammonia-Nitrogen Jun 1 - Oct 31	0.7	1.0 Wkly Avg	XXX	6.0	9.0	12	2/month	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	0.08	XXX	Report	Report Daily Max	XXX	2/month	8-Hr Composite


Compliance Sampling Location: Outfall 001

Other Comments: The only proposed change from the existing limitations and monitoring requirements is the removal of Total Nitrogen monitoring as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits
<input type="checkbox"/>	Other: [redacted]

**Attachments:**

- A. Discharge Location Map
- B. WQM7.0 Modeling
- C. TRC Model



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05E	27331	MAUSES CREEK	4.970	620.00	0.30	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.168	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
MooresburgWWTP	PA0209261	0.0130	0.0130	0.0130	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	6.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05E	27331	MAUSES CREEK	3.970	580.00	1.76	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.168	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	6.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
05E		27331			MAUSES CREEK							
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
4.970	0.05	0.00	0.05	.0201	0.00758	.341	3.22	9.45	0.06	0.952	21.43	6.59
<b>Q1-10 Flow</b>												
4.970	0.05	0.00	0.05	.0201	0.00758	NA	NA	NA	0.06	0.980	21.50	6.60
<b>Q30-10 Flow</b>												
4.970	0.06	0.00	0.06	.0201	0.00758	NA	NA	NA	0.07	0.862	21.20	6.58

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.93	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.27	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

SWP Basin    Stream Code                      Stream Name  
 05E                      27331                                      MAUSES CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.970	MooresburgWWT	10.46	12	10.46	12	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.970	MooresburgWWT	2.26	6	2.26	6	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
4.97	MooresburgWWTP	25	25	6	6	3	3	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
05E	27331	MAUSES CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
4.970	0.013	21.426		6.594
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
3.221	0.341	9.446		0.064
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
8.56	1.037	1.71		0.781
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.748	26.092	Owens		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.952	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.095	7.70	1.59	8.03
	0.190	6.93	1.47	8.03
	0.286	6.24	1.37	8.03
	0.381	5.61	1.27	8.03
	0.476	5.05	1.18	8.03
	0.571	4.55	1.10	8.03
	0.666	4.09	1.02	8.03
	0.762	3.68	0.94	8.03
	0.857	3.31	0.88	8.03
	0.952	2.98	0.81	8.03

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
05E		27331		MAUSES CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.970	MooresburgWWTP	PA0209261	0.013	CBOD5	25		
				NH3-N	6	12	
				Dissolved Oxygen			3

TRC\_CALC

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Mooresburg Wastewater Treatment Plant					
4	0.05	= Q stream (cfs)		0.5	= CV Daily	
5	0.013	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	1	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 0.812	1.3.2.iii	WLA_cfc = 0.784	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 0.303	5.1d	LTA_cfc = 0.456	
14			WQBEL_afc = 0.372		WQBEL_cfc = 0.561	
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.372		AFC	
18			INST MAX LIMIT (mg/l) = 1.218			
	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
	LTA_afc	wla_afc * LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
	LTA_cfc	wla_cfc * LTAMULT_cfc				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
	AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
	INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				