



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0209317**

APS ID

**1075968**

Authorization ID

**1418073**


**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<u>Eagle Ridge Personal Care Home LLC</u>	Facility Name	<u>Eagle Ridge Personal Care Home</u>
Applicant Address	<u>2997 Renovo Road</u>	Facility Address	<u>2997 Renovo Road</u>
	<u>Mill Hall, PA 17751-8537</u>		<u>Mill Hall, PA 17751-8537</u>
Applicant Contact	<u>Tyler Penland</u>	Facility Contact	<u>Tyler Penland</u>
Applicant Phone	<u>(814) 574-4686</u>	Facility Phone	<u>(814) 574-4686</u>
Client ID	<u>294667</u>	Site ID	<u>238401</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Colebrook Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Clinton</u>
Date Application Received	<u>November 14, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>Application for the renewal of the existing individual NPDES permit.</u>		

**Summary of Review**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Jonathan P. Peterman / Project Manager	October 22, 2024
X		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	October 23, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.005
Latitude	41° 10' 34.00"	Longitude	-77° 32' 59.00"
Quad Name	Farrandsville	Quad Code	0925
Wastewater Description:	Sewage Effluent		
Receiving Waters	Tangascootack Creek	Stream Code	23332
NHD Com ID	61116653	RMI	0.038
Drainage Area	36.701	Yield (cfs/mi <sup>2</sup> )	
Q <sub>7-10</sub> Flow (cfs)	0.54	Q <sub>7-10</sub> Basis	Gage No. 1547700
Elevation (ft)	663	Slope (ft/ft)	
Watershed No.	9-B	Chapter 93 Class.	CWF
Existing Use	CWF	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, Metals		
Source(s) of Impairment	Abandoned Mine Drainage, Abandoned Mine Drainage		
TMDL Status	Final	Name	Tangascootack Creek Watershed
Nearest Downstream Public Water Supply Intake	West Branch of Susquehanna	PA American Water White Deer	
PWS Waters	River	Flow at Intake (cfs)	682
PWS RMI	10.5	Distance from Outfall (mi)	72

Changes Since Last Permit Issuance: A Q<sub>7-10</sub> analysis was previously conducted using a comparable stream gage (1547700) to approximate the Q<sub>7-10</sub> stream flow at the discharge point. The updated Q<sub>7-10</sub> data was obtained from the updated stream gage information obtained from *Stuckey, M.H., and Roland, M.A., 2011, Selected Streamflow Statistics for Streamgage Locations In and Near Pennsylvania*. The Q<sub>7-10</sub> calculations, which are attached in Appendix A, indicate that the Q<sub>7-10</sub> is 0.54 cfs.

Other Comments: None.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Eagle Ridge Personal Care Home				
WQM Permit No.	Issuance Date	Notes:		
1895405 T-1	10/3/16	Transfer from Oakridge PCA to Eagle Ridge PCA.		
1895405	3/18/96	Original construction.		
Waste Type	Degree of Treatment	Process Type	Disinfection	Design Flow (MGD)
Sewage	Primary	Septic Tank	Hypochlorite	0.005
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.005	--	Not Overloaded	None.	Other WWTP.

**Treatment System Components for Outfall 001:**

- Six (6) 1,500-gallon primary settling tanks.
- One (1) 1,000-gallon intermediate settling tank.
- One (1) dosing tank.
- Two (2) intermittent sand filters.
- An EES Tablet Feeder Model 100 Chlorination system is utilized for disinfection.
- One (1) chlorine contact tank.
- One (1) Outfall 001 to Tangascootack Creek.

Changes Since Last Permit Issuance: None.

Other Comments: None.

**Chesapeake Bay Requirements**

Facilities that are designed based on a flow of less than 2,000 GPD are not a part of Pennsylvania's Chesapeake Bay Tributary Strategy. The permittee has certified, by letter with documentation, that the facility is routinely operating with a discharge below 2,000 gallons per day (0.002 MGD). However, the permitted annual average design flow was not amended in the WQM permit. Therefore, the permitted design flow remains 5,000 gpd. Previously, the permittee was required to monitor and report TN and TP throughout the permit term at a frequency no less than annually in accordance with the Phase III WIP Chesapeake Bay Strategy for Phase V facilities (0.002 MGD to 0.2 MGD) since it did not have at least two of years of monitoring completed. Monitoring for these parameters was conducted over the previous permit term and the yearly monitoring requirements for nutrients will be removed accordingly. No further monitoring is required at this time. The monitoring results are attached in the Appendix D.

**Existing Effluent Limitations and Monitoring Requirements**

**Existing Limits – Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report SEMI AVG	XXX	Report	1/6 months	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

\*The existing effluent limits for Outfall 001 were based on a design flow of 0.005 MGD.

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 41° 10' 34.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .005  
Longitude -77° 32' 59.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for CBOD<sub>5</sub>, ammonia-N and dissolved oxygen, the Department utilizes the WQM 7.0 v1.0b model and in order to determine limitations for toxics, the Department utilizes the Toxic Management Spreadsheet

**WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen**

The model was run using the Q7-10 stream flow, background water quality, average annual design flow, and other discharge characteristics. The existing technology based effluent limit for CBOD<sub>5</sub> (25 mg/l) and NH<sub>3</sub>-N (25 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (5.0 mg/L for CWF) was used for the in-stream objective for the model. The summary of the output is as follows:

Parameter	Effluent Limit		
	30 Day Average	Maximum	Minimum
CBOD5	25	N/A	N/A
Ammonia-N	25	50	N/A
Dissolved Oxygen	N/A	N/A	3

The model did not recommend water-quality based effluent limitations with regards to CBOD<sub>5</sub>, ammonia-nitrogen, and dissolved oxygen. Refer to the Appendix for the previous WQM 7.0 inputs and results. The existing effluent limits will remain.

**Best Professional Judgment (BPJ) Limitations**

See NH<sub>3</sub>-N and monitoring frequency sections below.

Comments: None.

**Anti-Backsliding**

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

**Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	5/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report SEMI AVG	XXX	Report	1/6 months	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

\*The proposed effluent limits for Outfall 001 were based on a design flow of 0.005 MGD.

**Effluent Limit Determination for Outfall 001**

**General Information**

All of the limits proposed above are consistent with other permits issued for major wastewater treatment plants in the region. The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001), Chapter 5 - Specifying Effluent Limitations in NPDES Permits.

**Flow**

Reporting of the average monthly flow and daily maximum is consistent with monitoring requirements for other treatment plants of this size.

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>)**

The results of the WQM 7.0 model show that the previously applied secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for CBOD<sub>5</sub> are protective of water quality.

**Total Suspended Solids (TSS)**

The previously applied technology based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

**pH**

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH. The existing limits will remain.

**Fecal Coliforms**

The existing fecal coliform limits with I-max limits were updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5).

**Dissolved Oxygen (DO)**

Monitoring for Dissolved Oxygen will not be required for this anaerobic system with significant in-stream dilution (>100:1).

**Ammonia-Nitrogen (NH3-N)**

The results of the WQM 7.0 model show that water quality based effluent limits for ammonia-nitrogen are not required. Based on BPJ, monitoring for NH3-N is proposed. However, since it is anticipated that the treatment method utilized at this facility will consistently meet the technology based effluent limits, a monitoring frequency of 1/ 6 months is adequate and will remain.

**E. Coli**

25 PA Code § 92a.61 provide the basis of monitoring requirements for E. Coli. Yearly monitoring will be required going forward.

**Monitoring Frequencies (TRC, pH, CBOD<sub>5</sub>, TSS, and Fecal Coliforms)**

Previous reviews established a monitoring frequency of 5/ Week for pH and TRC and 1/ Month for CBOD<sub>5</sub>, TSS, and Fecal Coliforms. However, these monitoring frequencies do not correspond with the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) Table 6-3 which calls for daily monitoring and 2/ month samples accordingly. Based on BPJ and given that there is no history of non-compliance with effluent limitations over the past two years of DMR data, the existing frequencies will be continued in the renewed permit. This facility routinely operates at an annual average flow of less than 2,000 gpd. Although a rerate of the WQM has not been conducted, the monitoring frequency of 1/ month corresponds with the guidance (Table 6-3) for facilities that discharge less than 2,000 gpd and is acceptable. Given that this facility utilizes a septic / sand filter system in lieu of a traditional aeration system, a 5/ week sampling frequency is acceptable. It is expected that the effluent quality would not differ drastically on days when monitoring is not conducted given that there is a lesser potential for a system malfunction with a sand filter system.

Compliance History

**Summary of Inspections** - The last inspection of the facilities was conducted by the Department on 7/23/24 which reveals the facility was operating normally. Two operational violations were noted.

**WMS Query Summary** - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed two open violations in the SDW program. See below. These programs will be notified of the open violations.

CLIENT	PF STATUS	INSP PROGRAM	PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	VIOLATION DATE	VIOLATION CODE	VIOLATION	INSP REGION
EAGLE RIDGE PERSONAL CARE HOME LLC	Active	Water Planning and Conservation	100858-001	3652583	8166785	11/30/2023	110.301	Reporting for all water withdrawals and usage	NCRO
EAGLE RIDGE PERSONAL CARE HOME LLC	Active	Safe Drinking Water	4180071	3798001	8194568	07/18/2024	B6G	FAILURE TO MAINTAIN AN APPROPRIATELY CERTIFIED OPERATOR	NCRO

Compliance History

DMR Data for Outfall 001 (from September 1, 2023 to August 31, 2024)

Parameter	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23
Flow (MGD) Average Monthly							0.00156	0.0018	0.00143	0.00132	0.0014	0.00163
pH (S.U.) Instantaneous Minimum							6.85	6.76	6.67	6.52	6.64	6.67
pH (S.U.) Instantaneous Maximum							7.00	6.93	6.82	6.88	7.01	6.91
TRC (mg/L) Average Monthly							0.29	0.37	0.35	0.40	0.28	0.38
TRC (mg/L) Instantaneous Maximum							0.64	1.05	1.04	1.08	0.62	1.06
CBOD5 (mg/L) Average Monthly							6.39	10.34	9.215	< 8.05	< 4.63	< 5.32
CBOD5 (mg/L) Instantaneous Maximum							7.98	12.2	13.0	13.1	6.26	7.64
TSS (mg/L) Average Monthly							6.60	8.6	5.40	6.20	< 3.80	4.00
TSS (mg/L) Instantaneous Maximum							6.80	12.8	6.00	7.20	6.00	4.00
Fecal Coliform (No./100 ml) Geometric Mean							< 1.0	7.4	< 1.0	< 1.0	< 1.0	1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum							< 1.0	7.4	< 1.0	< 1.0	< 1.0	1.0
Total Nitrogen (mg/L) Daily Maximum									31.11			
Ammonia (mg/L) Semi-Annual Average			0.8395						< 0.1000			
Ammonia (mg/L) Instantaneous Maximum			0.8395						< 0.1000			
Total Phosphorus (mg/L) Daily Maximum									1.45			

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <b>B</b> )
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment <b>C</b> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

# **APPENDIX A**

## **Q7-10 ANALYSIS AND STREAM DATA**

### Q<sub>7-10</sub> Calculations

#### Comparative Analysis

Stream Name	Comparative Analysis
Stream Name	Beech Creek
Reference Gage	1547950
Station Name	Beech Creek at Monument, PA
Gage Drainage Area (sq. mi.)	152
Q <sub>7-10</sub> at gage (cfs)	15.9
Drainage Area at site (sq. mi.)	36.701
Q <sub>7-10</sub> at discharge site (cfs)	3.8391
Q <sub>7-10</sub> at discharge site (mgd)	2.4313

Low Flow Yield Ratio of 0.1 cfs/mi<sup>2</sup>

Q <sub>7-10</sub> at discharge site (cfs)
3.6701

Q <sub>7-10</sub> at discharge site (cfs)
3.6701

Q <sub>7-10</sub> at discharge site (mgd)
2.3720

### Q<sub>7-10</sub> Calculations

#### Comparative Analysis

Stream Name	Comparative Analysis
Stream Name	Marsh Creek
Reference Gage	1547700
Station Name	Marsh Creek at Blanchard, PA
Gage Drainage Area (sq. mi.)	44.1
Q <sub>7-10</sub> at gage (cfs)	0.63
Drainage Area at site (sq. mi.)	36.701
Q <sub>7-10</sub> at discharge site (cfs)	0.5743
Q <sub>7-10</sub> at discharge site (mgd)	0.3389

Use this flow. More representative and conservative

Check Dilution Ratio		
	sf (cfs)	wf (cfs)
Dilution Ratio = sf/wf	0.5243	0.007736143
Dilution Ratio = 67.77279 to 1		

## Basin Characteristics Report

Date: Thu Sep 29 2011 09:50:35 Mountain Daylight Time

NAD27 Latitude: 41.1760 (41 10 34)

NAD27 Longitude: -77.5502 (-77 33 01)

NAD83 Latitude: 41.1761 (41 10 34)

NAD83 Longitude: -77.5499 (-77 32 60)

Parameter	Value
Stream density (miles/square mile)	2.11
Depth to rock, in feet	4,766
Percent of area covered by forest	89.0065
Total stream length, in miles	77.3
Area in square miles	36.701
Unadjusted basin slope, in degrees	10.1664
Mean annual precipitation in inches	40.423
Percent of area covered by lakes, ponds, reservoirs and wetlands	0.0341
Percent of area covered by glacial activity	0.0000
Mean Basin Elevation in feet	1340
Percent of area covered by urban bedrock	0.0513
Adjusted basin slope, in degrees	9.93

# **APPENDIX B**

## **PREVIOUS WQM 7.0 MODEL INPUT/OUTPUT**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
09B	23332	TANGASCOOTACK CREEK	0.038	663.00	36.70	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)				(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.52	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Eagle Ridge PCH	PA0209317	0.0050	0.0050	0.0050	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
09B		23332		TANGASCOOTACK CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.038	0.52	0.00	0.52	.0077	0.01495	.513	14.14	27.58	0.07	0.032	20.07	7.00
<b>Q1-10 Flow</b>												
0.038	0.50	0.00	0.50	.0077	0.01495	NA	NA	NA	0.07	0.032	20.08	7.00
<b>Q30-10 Flow</b>												
0.038	0.62	0.00	0.62	.0077	0.01495	NA	NA	NA	0.08	0.029	20.06	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.97	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.2	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
09B	23332	TANGASCOOTACK CREEK

### **NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.038	Eagle Ridge PCH	16.66	50	16.66	50	0	0

### **NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.038	Eagle Ridge PCH	1.88	25	1.88	25	0	0

### **Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.04	Eagle Ridge PCH	25	25	25	25	3	3	0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
09B	23332	TANGASCOOTACK CREEK		
<u>RMI</u> 0.038	<u>Total Discharge Flow (mgd)</u> 0.005	<u>Analysis Temperature (°C)</u> 20.073	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 14.139	<u>Reach Depth (ft)</u> 0.513	<u>Reach WDRatio</u> 27.582	<u>Reach Velocity (fps)</u> 0.073	
<u>Reach CBOD5 (mg/L)</u> 2.34	<u>Reach Kc (1/days)</u> 0.230	<u>Reach NH3-N (mg/L)</u> 0.37	<u>Reach Kn (1/days)</u> 0.704	
<u>Reach DO (mg/L)</u> 8.166	<u>Reach Kr (1/days)</u> 12.937	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.032	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.003	2.34	0.37	8.20
	0.006	2.33	0.36	8.23
	0.010	2.33	0.36	8.23
	0.013	2.33	0.36	8.23
	0.016	2.33	0.36	8.23
	0.019	2.33	0.36	8.23
	0.022	2.33	0.36	8.23
	0.026	2.32	0.36	8.23
	0.029	2.32	0.36	8.23
	0.032	2.32	0.36	8.23

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
09B	23332	TANGASCOOTACK CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.038	Eagle Ridge PCH	PA0209317	0.005	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

# **APPENDIX C**

## **TRC ANALYSIS**



# **APPENDIX E**

## **NITROGEN AND PHOSPHORUS SAMPLING RESULTS**

**NPDES Permit Fact Sheet**  
**Eagle Ridge Personal Care Home**

**NPDES Permit No. PA0209317**

PERMIT	PF NAME	MONITORING START DATE	OUTFALL	PARAMETER	CONC 3 VALUE	CONC 3 LIMIT	CONC 3 SBC	SAMPLE FREQUENCY	SAMPLE TYPE
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2019	001	Total Nitrogen	47.22	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2020	001	Total Nitrogen	52.20	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2021	001	Total Nitrogen	25.89	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2022	001	Total Nitrogen	< 87.61	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2023	001	Total Nitrogen	31.11	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2019	001	Total Phosphorus	3.69	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2020	001	Total Phosphorus	2.68	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2021	001	Total Phosphorus	2.66	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2022	001	Total Phosphorus	2.40	Monitor and Report	Daily Maximum	1/year	Grab
PA0209317	EAGLE RIDGE PERSONAL CARE HOME LLC	01/01/2023	001	Total Phosphorus	1.45	Monitor and Report	Daily Maximum	1/year	Grab