

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0209384
 APS ID 1128239
 Authorization ID 1511104

Applicant and Facility Information

Applicant Name	<u>Lawrence Township Municipal Authority Tioga County</u>	Facility Name	<u>Lawrence Township Municipal Authority Sewer System</u>
Applicant Address	<u>173 School Road</u>	Facility Address	<u>173 School Road</u>
	<u>Tioga, PA 16946-8402</u>		<u>Tioga, PA 16946-8402</u>
Applicant Contact	<u>Nathan Rundell</u>	Facility Contact	<u>Nathan Rundell</u>
Applicant Phone	<u>(570) 827-0970</u>	Facility Phone	<u>(570) 827-0970</u>
Client ID	<u>91556</u>	Site ID	<u>464425</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Lawrence Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Tioga</u>
Date Application Received	<u>January 2, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 2, 2025</u>	If No, Reason	
Purpose of Application	<u>Renewal of a NPDES Permit</u>		


Summary of Review

The subject facility is a POTW serving the area of Tioga Junction in Lawrence Township, Tioga County. A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge disposed by landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	June 16, 2025
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	June 16, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.13
Latitude	41° 57' 21.34"	Longitude	-77° 6' 56.16"
Quad Name	Jackson Summit, PA	Quad Code	0329
Wastewater Description: Sewage Effluent			
Receiving Waters	Tioga River (WWF)	Stream Code	30990
NHD Com ID	133069764	RMI	16.51
Drainage Area	442.06 mi ²	Yield (cfs/mi ²)	0.068
Q ₇₋₁₀ Flow (cfs)	30.3	Q ₇₋₁₀ Basis	USGS Stream Gage
Elevation (ft)	1000	Slope (ft/ft)	Undetermined
Watershed No.	4-A	Chapter 93 Class.	WWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Impaired		
Cause(s) of Impairment	MERCURY		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	PA-NY Border		
PWS Waters	Tioga River	Distance from Outfall (mi)	16.51

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics were determined for previous reviews and remain adequate.

Other Comments: There is no expectation that the discharge is contributing to the impairment to the Tioga River by Mercury.

The Department considers the Pennsylvania-New York state line to be the nearest downstream water supply when no other nearer water supply exists.

Treatment Facility Summary				
Treatment Facility Name: Lawrence Township Munic Authority Sewer System				
WQM Permit No.	Issuance Date	Permit Coverage:		
5996404	Original - 7/30/96 A-1 – 10/22/12	Original Plant Design Amendments including fine screen, fine bubble diffusers in digester, and other minor modifications.		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	No Disinfection	0.13
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.13	470	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None.

Other Comments: The treatment as permitted under WQM Permit No. 5996404 Amendment No. 1 consists of grit removal, extended aeration, clarification, chlorination, aerobic digestion, and sludge press.

Compliance History

DMR Data for Outfall 001 (from May 1, 2024 to April 30, 2025)

Parameter	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24
Flow (MGD) Average Monthly	0.0711	0.0759	0.0753	0.0708	0.0703	0.064	0.0635	0.0558	0.0626	0.0565	0.0547	0.0596
Flow (MGD) Daily Maximum	0.1014	0.1051	0.1115	0.0959	0.1079	0.0930	0.085	0.0906	0.0965	0.0872	0.0665	0.0856
pH (S.U.) Instantaneous Minimum	6.63	6.51	6.63	6.56	6.69	6.59	6.82	6.68	6.78	6.81	6.80	6.77
pH (S.U.) Instantaneous Maximum	7.13	7.85	7.36	7.17	7.10	7.12	7.33	7.24	7.16	7.04	7.20	7.13
DO (mg/L) Instantaneous Minimum	6.1	6.0	6.5	5.7	6.4	4.9	4.4	3.4	3.7	3.6	3.7	4.0
TRC (mg/L) Average Monthly	0.21	0.35	0.49	0.45	0.27	0.37	0.33	0.39	0.44	0.22	0.36	0.34
TRC (mg/L) Instantaneous Maximum	0.48	0.91	0.96	0.97	0.47	0.59	0.75	0.70	0.83	0.52	0.91	0.61
CBOD5 (lbs/day) Average Monthly	2.7	3.0	2.3	1.9	2.2	2.4	1.9	1.6	1.8	1.9	2.4	2.3
CBOD5 (lbs/day) Weekly Average	3.5	< 6.9	3.0	2.3	2.9	3.7	3.2	2.8	3.2	2.8	3.1	3.7
CBOD5 (mg/L) Average Monthly	4.4	5.2	3.8	3.3	3.7	5.1	3.5	2.9	3.3	3.7	5.2	4.5
CBOD5 (mg/L) Weekly Average	7.0	< 12.4	4.8	4.0	5.3	8.8	5.1	4.1	4.9	5.7	6.2	6.6
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	60	74	88	63	84	34	53	53	56	57	71	99
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	71	107	116	85	137	52	142	79	65	85	96	126
BOD5 (mg/L) Raw Sewage Influent Average Monthly	98	121	142	104	132	67	102	101	108	103	154	185
TSS (lbs/day) Average Monthly	3.1	4.2	6.1	6.0	3.8	3.9	3.4	5.2	6.8	2.6	3.4	3.9
TSS (lbs/day) Raw Sewage Influent Average Monthly	49	85	86	70	69	72	86	78	64	64	75	98
TSS (lbs/day) Raw Sewage Influent Daily Maximum	71	121	95	85	82	91	156	104	86	103	91	133

NPDES Permit Fact Sheet

Lawrence Township Municipal Authority Sewer System

NPDES Permit No. PA0209384

TSS (lbs/day) Weekly Average	4.7	6.6	8.8	8.5	4.0	3.8	6.3	8.5	11.4	3.9	6.7	4.6
TSS (mg/L) Average Monthly	5.0	7.0	10.0	10.0	6.0	7.2	6.2	9.8	12.6	5.0	8.0	7.4
TSS (mg/L) Raw Sewage Influent Average Monthly	82	138	138	118	111	127	149	150	126	115	154	185
TSS (mg/L) Weekly Average	6.0	10.0	14.0	15.0	7.0	11.0	9.0	1.3	20.0	8.0	14.0	9.0
Fecal Coliform (No./100 ml) Geometric Mean	77.7	81	28	181	124	2.0	1.14	22	72	124	2.2	5.7
Fecal Coliform (No./100 ml) Instantaneous Maximum	816	2420	1203	2421	2420	2.0	2.0	2420	68	2420	5.2	49
Ammonia (lbs/day) Average Monthly	0.05	0.066	< 0.06	0.05	E	0.06	< 0.05	0.040	0.065	0.04	0.05	0.04
Ammonia (mg/L) Average Monthly	< 0.10	< 0.10	< 0.10	0.10	E	0.1	< 0.10	0.10	0.10	< 0.10	0.10	0.10

Compliance History

Effluent Violations for Outfall 001, from: May 1, 2024 to: April 30, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	09/30/24	IMAX	2420	No./100 ml	1000	No./100 ml
Fecal Coliform	07/31/24	IMAX	2420	No./100 ml	1000	No./100 ml

Compliance History

Summary of Inspections:	The most recent inspection of the facility by the Department on May 9, 2025 noted eDMR effluent violations but no operational violations at the time of inspection.
Other Comments:	A query in WMS found open violations in eFACTS for Lawrence Township Municipal Authority for effluent violations.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	27	43	XXX	25.0	40.0	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	32	48	XXX	30.0	45.0	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Ammonia	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
 Latitude 41° 57' 21.30"
 Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.13
 Longitude -77° 6' 55.20"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and are included in the existing permit.

Water Quality-Based Limitations**DO, CBOD₅ and NH₃-N**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N.

WQM7.0 modeling was performed for the discharge to the Tioga River (see Attachment B) and showed that no limitations are necessary for these parameters beyond the existing technology-based limits.

Total Residual Chlorine

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet (see Attachment C) show that the technology-based limit of 0.5 mg/l is adequate to protect the receiving stream.

Chesapeake Bay/Nutrient Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. The Lawrence Township Municipal Authority facility is considered a Phase V, non-significant Chesapeake Bay discharger and as such no nutrient cap loadings have been established for the facility pursuant to the Phase III Watershed Implementation Plan. Sampling for a previous permit term found Total Nitrogen and Total Phosphorus concentrations to average 24 and 6 mg/L, respectively. Because the permittee has adequately characterized the nutrient load from the facility no additional monitoring for these nutrients will be required at this time.

Water Quality Toxics Management

No "Reasonable Potential Analysis" was performed to determine additional parameters with the reasonable potential to violate water quality standards for this minor STP discharge with no industrial influent.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limitations are necessary at this time beyond the technology and water quality-based limitations noted above.

E. Coli

Quarterly e. coli monitoring will be included in the permit for this 0.13 MGD facility consistent with recent changes to Chapter 93 of the Department's regulations and Department policy.

Anti-Backsliding

No proposed limitations have been made less stringent consistent with the Anti-degradation requirements of The Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	27	43	XXX	25.0	40.0	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	32	48	XXX	30.0	45.0	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Ammonia	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab


Compliance Sampling Location: Outfall 001

Other Comments: E. Coli is new as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachments:

- Discharge Location Map
- WQM7.0 Model
- TRC Model



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30990	TIOGA RIVER	16.510	1000.00	442.06	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.068	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Lawrence Twp MA	PA0209384	0.1300	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30990	TIOGA RIVER	16.000	999.00	443.40	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	Stream pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.068	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000			
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>				<u>Stream Name</u>					
04A			30990				TIOGA RIVER					
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
16.510	30.06	0.00	30.06	.2011	0.00037	1.002	100.95	100.77	0.30	0.104	20.03	7.00
Q1-10 Flow												
16.510	19.24	0.00	19.24	.2011	0.00037	NA	NA	NA	0.23	0.133	20.05	7.00
Q30-10 Flow												
16.510	40.88	0.00	40.88	.2011	0.00037	NA	NA	NA	0.36	0.088	20.02	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
04A	30990	TIOGA RIVER	
<u>RMI</u> 16.510	<u>Total Discharge Flow (mgd)</u> 0.130	<u>Analysis Temperature (°C)</u> 20.033	<u>Analysis pH</u> 7.000
<u>Reach Width (ft)</u> 100.952	<u>Reach Depth (ft)</u> 1.002	<u>Reach WDRatio</u> 100.770	<u>Reach Velocity (fps)</u> 0.299
<u>Reach CBOD5 (mg/L)</u> 2.15	<u>Reach Kc (1/days)</u> 0.108	<u>Reach NH3-N (mg/L)</u> 0.17	<u>Reach Kn (1/days)</u> 0.702
<u>Reach DO (mg/L)</u> 8.208	<u>Reach Kr (1/days)</u> 0.519	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5
<u>Reach Travel Time (days)</u> 0.104	Subreach Results		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.010	2.15
		0.021	2.15
		0.031	2.15
		0.042	2.14
		0.052	2.14
		0.062	2.14
		0.073	2.14
		0.083	2.13
		0.094	2.13
		0.104	2.13
			0.16
			8.20
			0.16
			8.20
			0.16
			8.20
			0.16
			8.19
			0.16
			8.19
			0.16
			8.18
			0.16
			8.18
			0.16
			8.18
			0.16
			8.17
			0.15
			8.17

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
04A	30990	TIOGA RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
16.510	Lawrence Twp M	16.69	50	16.69	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
16.510	Lawrence Twp M	1.88	25	1.88	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
16.51	Lawrence Twp MA	25	25	25	25	3	3	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
04A	30990	TIOGA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
16.510	Lawrence Twp MA	PA0209384	0.130	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 48.081		1.3.2.iii	WLA_cfc = 46.867
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 17.916		5.1d	LTA_cfc = 27.247
Source					
Effluent Limit Calculations					
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ		
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc		$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$			
LTA_afc		wla_afc*LTAMULT_afc			
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc		$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$			
LTA_cfc		wla_cfc*LTAMULT_cfc			
AML MULT		$\text{EXP}(2.326*\text{LN}(cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1))$			
AVG MON LIMIT		$\text{MIN}(\text{BAT_BPJ},\text{MIN}(\text{LTA_afc},\text{LTA_cfc})*\text{AML_MULT})$			
INST MAX LIMIT		$1.5*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$			