

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**


Application No. PA0209511  
APS ID 1085943  
Authorization ID 1435217

**Applicant and Facility Information**

|                           |   |                  |                              |
|---------------------------|---|------------------|------------------------------|
| Applicant Name            | <u>Sullivan Township</u>  | Facility Name    | <u>Sullivan Township STP</u> |
| Applicant Address         | PO Box 84   | Facility Address | State Route 6                |
|                           | Mainesburg, PA 16932-0084   |                  | Mainesburg, PA 16932-0084    |
| Applicant Contact         | <u>Andrew Tice</u>  | Facility Contact | <u>Andrew Tice</u>           |
| Applicant Phone           | <u>(570) 549-7051</u>   | Facility Phone   | <u>(570) 549-7051</u>        |
| Client ID                 | <u>110560</u>   | Site ID          | <u>465886</u>                |
| Ch 94 Load Status         | <u>Not Overloaded</u>   | Municipality     | <u>Sullivan Township</u>     |
| Connection Status         | <u>No Limitations</u>   | County           | <u>Tioga</u>                 |
| Date Application Received | <u>April 3, 2023</u>  | EPA Waived?      | <u>Yes</u>                   |
| Date Application Accepted | <u>April 18, 2023</u>   | If No, Reason    |                              |
| Purpose of Application    | <u>Application for the renewal of the existing individual NPDES permit.</u> |                  |                              |

**Summary of Review**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures  | Date            |
|---------|------|---|-----------------|
| X       |      | <br>Jonathan P. Peterman / Project Manager                       | January 8, 2025 |
| X       |      | <br>Nicholas W. Hartranft, P.E. / Environmental Engineer Manager | January 9, 2025 |

| Discharge, Receiving Waters and Water Supply Information |                      |                              |                  |
|--|----------------------|------------------------------|------------------|
| Outfall No.  | 001                  | Design Flow (MGD)            | 0.015            |
| Latitude   | 41° 47' 8.56"        | Longitude                    | -77° 0' 14.61"   |
| Quad Name  | Mansfield            | Quad Code                    | 0429             |
| Wastewater Description:                                  | Sewage Effluent      |                              |                  |
| Receiving Waters   | Corey Creek (CWF)    | Stream Code                  | 31329            |
| NHD Com ID   | 57351711             | RMI                          | 5.34             |
| Drainage Area  | 10.8                 | Yield (cfs/mi <sup>2</sup> ) | N/A              |
| Q <sub>7-10</sub> Flow (cfs)                             | 0.0203               | Q <sub>7-10</sub> Basis      | Gage No. 1516500 |
| Elevation (ft)   | 1375                 | Slope (ft/ft)                | N/A              |
| Watershed No.  | 4-A                  | Chapter 93 Class.            | CWF              |
| Existing Use   | CWF                  | Existing Use Qualifier       | N/A              |
| Exceptions to Use  | None                 | Exceptions to Criteria       | None             |
| Assessment Status  | Attaining Use(s)     |                              |                  |
| Cause(s) of Impairment                                   | N/A                  |                              |                  |
| Source(s) of Impairment                                  | N/A                  |                              |                  |
| TMDL Status  | Final                | Name                         | Tioga River      |
| Nearest Downstream Public Water Supply Intake            | Mansfield University |                              |                  |
| PWS Waters   | Corey Creek          | Flow at Intake (cfs)         | 0.16             |
| PWS RMI  | 0.86                 | Distance from Outfall (mi)   | 4                |

Changes Since Last Permit Issuance: None.

**Other Comments:** In order to determine the Q<sub>7-10</sub> low flow for Corey Creek, a comparative stream analysis was conducted using a downstream gage. The results of this analysis are attached in Appendix A. This stream gage was used in the analysis and indicates that the Q<sub>7-10</sub> for Corey's Creek is 0.0885 cfs.

| Treatment Facility Summary                            |                                   |                         |                            |                               |
|---|-----------------------------------|-------------------------|----------------------------|-------------------------------|
| <b>Treatment Facility Name:</b> Sullivan Township STP |                                   |                         |                            |                               |
| <b>WQM Permit No.</b>                                 | <b>Issuance Date</b>              | <b>Notes:</b>           |                            |                               |
| 5997406   | 2/13/98                           | Initial construction.   |                            |                               |
| <b>Waste Type</b>                                     | <b>Degree of Treatment</b>        | <b>Process Type</b>     | <b>Disinfection</b>        | <b>Design Flow (MGD)</b>      |
| Sewage  | Secondary                         | Septic Tank Sand Filter | Hypochlorite               | 0.015                         |
| <b>Hydraulic Capacity (MGD)</b>                       | <b>Organic Capacity (lbs/day)</b> | <b>Load Status</b>      | <b>Biosolids Treatment</b> | <b>Biosolids Use/Disposal</b> |
| 0.015   | 31                                | Not Overloaded          | Anaerobic Digestion        | Other WWTP                    |

Changes Since Last Permit Issuance: None.

Other Comments: None.

**Treatment System Components for Outfall 001:**

- One (1) Influent wet well and flow meter.
- Two (2) Lift pumps.
- One (1) Aeration tank.
  - Two (2) Aeration blowers lowers.
- One (1) Settling tank.
- One (1) Dosing tank.
  - Two (2) Dosing tank pumps.
- Two (2) Sand filter beds.
- One (1) Erosion chlorinator.
- One (1) Chlorine contact tank.
- One (1) Outfall.

Changes Since Last Permit Issuance: None.

Other Comments: None.

**TMDL Impairment**

The Department's Geographic Information System (GIS) shows that the Corey's Creek (Tioga River Watershed) is attaining its use but a TMDL does exist for the watershed. High levels of metals caused these impairments (iron, manganese, aluminum) as well as pH. All impairments resulted from acid mine drainage. The TMDL addresses the three primary metals associated with acid mine drainage (iron, manganese, aluminum). There is currently no industrial waste being discharged into the treatment plant and this discharge is not expected to contribute to the level of metals in the stream. Given the regulations contained in 40 CFR §122.44(d)(1)(ii)&(iii), it can be determined that the type of effluent from this facility has no "Reasonable potential to cause, or contributes to an in-stream excursion above the allowable ambient concentration of a State numeric criteria within a State water quality standard for an individual pollutant." However, monitoring requirements for metals (iron, manganese and aluminum) will be placed in the permit because point sources in the segment where the TMDL does not assign any wasteload allocations are not authorized to discharge these metals of concern. The result from the monitoring that was conducted over the previous permit cycles demonstrates that the facility is not contributing to this impairment and no further monitoring is required. The monitoring requirements will be removed. The monitoring results for these metals are attached in the Appendix E.

**Chesapeake Bay Requirements**

Previously, the permittee was required to monitor and report TN and TP throughout the permit term at a frequency no less than annually in accordance with the Phase III WIP Chesapeake Bay Strategy for Phase V facilities (0.002 MGD to 0.2 MGD) since it did not have at least two of years of monitoring completed at that time. Monitoring for these parameters was conducted over the next permit term and the yearly monitoring requirements for nutrients were previously removed accordingly. No further monitoring is required at this time. The monitoring results, which will be preserved in the fact sheets, are listed below:

| Date (Mo.-Yr.) | Flow (MGD) | Total Nitrogen |             |           | Total Phosphorus |             |           |
|----------------|------------|----------------|-------------|-----------|------------------|-------------|-----------|
|                |            | TN (lbs/day)   | TN (lbs/yr) | TN (mg/L) | TP (lbs/day)     | TP (lbs/yr) | TP (mg/L) |
| Mar-18         | 0.0163     | 2.24           | 817.6       | 16.5      | 0.26             | 94.9        | 1.92      |
| Feb-17         | 0.0088     | 1.39           | 509         | 19        | 0.16             | 38.4        | 2.15      |
| Jan-16         | 0.0081     | 1.95           | 712         | 28.9      | 0.185            | 67.5        | 2.75      |
| Nov-15         | 0.0108     | 2.41           | 881         | 26.8      | 0.225            | 82.12       | 2.53      |
| Jan-15         | 0.0073     | 2.4            | 876         | 39.65     | 0.29             | 105.9       | 4.7       |
| Jan-14         | 0.0089     | 2.56           | 934.6       | 34.45     | 0.26             | 94.9        | 3.54      |
| Dec-13         | 0.0106     | 2.87           | 105         | 32.5      | 0.34             | 124         | 4.05      |

**Existing Effluent Limitations and Monitoring Requirements**

**Existing Limits – Outfall 001**

| Parameter   | Effluent Limitations                |                 |                       |                    |                     |                  | Monitoring Requirements                      |                      |
|---|-------------------------------------|-----------------|-----------------------|--------------------|---------------------|------------------|--|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                 | Concentrations (mg/L) |                    |                     |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Daily Maximum   | Minimum               | Average Monthly    | Weekly Average      | Instant. Maximum |  |                      |
| Flow (MGD)  | Report                              | Report          | XXX                   | XXX                | XXX                 | XXX              | 1/week                                       | Weir                 |
| pH (S.U.)   | XXX                                 | XXX             | 6.0<br>Inst Min       | XXX                | XXX                 | 9.0              | 6/week                                       | Grab                 |
| Dissolved Oxygen  | XXX                                 | XXX             | Report<br>Daily Min   | XXX                | XXX                 | XXX              | 6/week                                       | Grab                 |
| Total Residual Chlorine (TRC)                           | XXX                                 | XXX             | XXX                   | 0.27               | XXX                 | 0.89             | 6/week                                       | Grab                 |
| Carbonaceous Biochemical Oxygen Demand (CBOD5)          | 3.1                                 | 5.0             | XXX                   | 25.0               | 40.0                | 50               | 2/month                                      | Grab                 |
| Biochemical Oxygen Demand (BOD5)<br>Raw Sewage Influent | Report                              | Report          | XXX                   | Report             | XXX                 | XXX              | 2/month                                      | Grab                 |
| Total Suspended Solids                                  | 3.8                                 | 5.6<br>Wkly Avg | XXX                   | 30.0               | 45.0                | 60               | 2/month                                      | Grab                 |
| Total Suspended Solids<br>Raw Sewage Influent           | Report                              | Report          | XXX                   | Report             | XXX                 | XXX              | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30           | XXX                                 | XXX             | XXX                   | 2000<br>Geo Mean   | XXX                 | 10000            | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30           | XXX                                 | XXX             | XXX                   | 200<br>Geo Mean    | XXX                 | 1000             | 2/month                                      | Grab                 |
| Ammonia-Nitrogen<br>Nov 1 - Apr 30                      | 0.65                                | XXX             | XXX                   | 5.2                | XXX                 | 10               | 2/month                                      | Grab                 |
| Ammonia-Nitrogen<br>May 1 - Oct 31                      | 1.8                                 | XXX             | XXX                   | 15.0               | XXX                 | 30               | 2/month                                      | Grab                 |
| Aluminum, Total   | XXX                                 | XXX             | XXX                   | Report<br>Annl Avg | Report<br>Daily Max | XXX              | 1/year                                       | Grab                 |
| Iron, Total   | XXX                                 | XXX             | XXX                   | Report<br>Annl Avg | Report<br>Daily Max | XXX              | 1/year                                       | Grab                 |
| Manganese, Total  | XXX                                 | XXX             | XXX                   | Report<br>Annl Avg | Report<br>Daily Max | XXX              | 1/year                                       | Grab                 |

\*The existing effluent limits for Outfall 001 were based on a design flow of 0.015 MGD.

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 41° 47' 8.20"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.015  
Longitude -77° 0' 15.30"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant                    | Limit (mg/l)    | SBC             | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD <sub>5</sub>            | 25              | Average Monthly | 133.102(a)(4)(i)   | 92a.47(a)(1)     |
|                              | 40              | Average Weekly  | 133.102(a)(4)(ii)  | 92a.47(a)(2)     |
| Total Suspended Solids       | 30              | Average Monthly | 133.102(b)(1)      | 92a.47(a)(1)     |
|                              | 45              | Average Weekly  | 133.102(b)(2)      | 92a.47(a)(2)     |
| pH                           | 6.0 – 9.0 S.U.  | Min – Max       | 133.102(c)         | 95.2(1)          |
| Fecal Coliform (5/1 – 9/30)  | 200 / 100 ml    | Geo Mean        | -                  | 92a.47(a)(4)     |
| Fecal Coliform (5/1 – 9/30)  | 1,000 / 100 ml  | IMAX            | -                  | 92a.47(a)(4)     |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml  | Geo Mean        | -                  | 92a.47(a)(5)     |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX            | -                  | 92a.47(a)(5)     |
| Total Residual Chlorine      | 0.5             | Average Monthly | -                  | 92a.48(b)(2)     |

Comments: None.

**Water Quality-Based Limitations**

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for CBOD<sub>5</sub>, ammonia-N and dissolved oxygen, the Department utilizes the WQM 7.0 v1.0b model and in order to determine limitations for toxics, the Department utilizes Toxics Management Spreadsheet (TMS). The TMS was not utilized or this review.

**WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen**  
Since there have been no changes to the watershed or the facility, the previous modeling results shall be utilized. The model was previously run using the Q7-10 stream flow, background water quality, average annual design flow, and other discharge characteristics. The technology-based effluent limits for CBOD<sub>5</sub> (25 mg/l) and NH<sub>3</sub>-N (25.0 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (5.0 mg/L for CWF) was used for the in-stream objective for the model. The summary of the output is as follows:

| Parameter         | Effluent Limit |         |         |
|-------------------|----------------|---------|---------|
|                   | 30 Day Average | Maximum | Minimum |
| CBOD <sub>5</sub> | 25             | N/A     | N/A     |
| Ammonia-N         | 5.19           | 10.38   | N/A     |
| Dissolved Oxygen  | N/A            | N/A     | 3       |

The previous model did not recommend water-quality based effluent limitations with regards to CBOD<sub>5</sub> and dissolved oxygen. The model did recommend water-quality based effluent limitations for ammonia-nitrogen, which were applied in the permit. Refer to the Appendix B for the previous WQM 7.0 inputs and results. The existing effluent limits will remain.

**Best Professional Judgment (BPJ) Limitations**

See the D.O. section below.

Comments: None.

**Anti-Backsliding**

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

**Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date**

| Parameter   | Effluent Limitations                |                 |                       |                  |                |                  | Monitoring Requirements                      |                      |
|---|-------------------------------------|-----------------|-----------------------|------------------|----------------|------------------|--|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                 | Concentrations (mg/L) |                  |                |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Daily Maximum   | Minimum               | Average Monthly  | Weekly Average | Instant. Maximum |  |                      |
| Flow (MGD)  | Report                              | Report          | XXX                   | XXX              | XXX            | XXX              | 1/week                                       | Weir                 |
| pH (S.U.)   | XXX                                 | XXX             | 6.0<br>Inst Min       | XXX              | XXX            | 9.0              | 6/week                                       | Grab                 |
| Dissolved Oxygen  | XXX                                 | XXX             | Report Daily Min      | XXX              | XXX            | XXX              | 6/week                                       | Grab                 |
| Total Residual Chlorine (TRC)                           | XXX                                 | XXX             | XXX                   | 0.27             | XXX            | 0.89             | 6/week                                       | Grab                 |
| Carbonaceous Biochemical Oxygen Demand (CBOD5)          | 3.1                                 | 5.0             | XXX                   | 25.0             | 40.0           | 50               | 2/month                                      | Grab                 |
| Biochemical Oxygen Demand (BOD5)<br>Raw Sewage Influent | Report                              | Report          | XXX                   | Report           | XXX            | XXX              | 2/month                                      | Grab                 |
| Total Suspended Solids                                  | 3.8                                 | 5.6<br>Wkly Avg | XXX                   | 30.0             | 45.0           | 60               | 2/month                                      | Grab                 |
| Total Suspended Solids<br>Raw Sewage Influent           | Report                              | Report          | XXX                   | Report           | XXX            | XXX              | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30           | XXX                                 | XXX             | XXX                   | 2000<br>Geo Mean | XXX            | 10000            | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30           | XXX                                 | XXX             | XXX                   | 200<br>Geo Mean  | XXX            | 1000             | 2/month                                      | Grab                 |
| Ammonia-Nitrogen<br>Nov 1 - Apr 30                      | 0.65                                | XXX             | XXX                   | 5.2              | XXX            | 10               | 2/month                                      | Grab                 |
| Ammonia-Nitrogen<br>May 1 - Oct 31                      | 1.8                                 | XXX             | XXX                   | 15.0             | XXX            | 30               | 2/month                                      | Grab                 |
| E. Coli (No./100 ml)                                    | XXX                                 | XXX             | XXX                   | XXX              | XXX            | Report           | 1/year                                       | Grab                 |

\*The proposed effluent limits for Outfall 001 were based on a design flow of 0.015 MGD.

### Effluent Limit Determination for Outfall 001

#### **General Information**

All of the limits proposed above are consistent with other permits issued for wastewater treatment plants in the region. The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001), Chapter 5 - Specifying Effluent Limitations in NPDES Permits.

#### **Flow**

Reporting of the average monthly and daily maximum flow is consistent with monitoring requirements for other treatment plants of this size.

#### **Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>)**

The results of the WQM 7.0 model show that the previously applied secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for CBOD<sub>5</sub> are protective of water quality.

#### **Total Suspended Solids (TSS)**

The previously applied technology based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

#### **pH**

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH. The existing limits will remain.

#### **TRC**

In accordance with 25 Pa. Code 92a.48(b)(2), a best available technology (BAT) value of 0.5 mg/l was used in lieu of the existing effluent limit (1.0 mg/L) in the TRC Spreadsheet. The attached TRC model indicates that the existing water quality-based effluent limits of 0.27 mg/L (Average Monthly) and 0.89 mg/L (Instantaneous Maximum) are still adequate to protect water quality.

#### **Fecal Coliforms**

The existing fecal coliform limits with I-max limits were previously updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5).

#### **Ammonia-Nitrogen (NH3-N)**

The results of the WQM 7.0 model show that a discharge of ammonia-nitrogen at the water quality-based effluent limit (0.65 mg/L) is still adequate to protect water quality. Additionally, seasonal limits have been applied in accordance with the *Implementation Guidance of Section 93.7 Ammonia Criteria* (391-2000-013).

#### **Dissolved Oxygen (DO)**

Based on BPJ, monitoring of the minimum Dissolved Oxygen (DO) standard found in Chapter 93 for cold water fishes will be established. This will ensure that the discharge does not contributes to an in-stream excursion above the allowable ambient concentration of State numeric criteria within a State water quality standard for an individual pollutant. Discharges of concentrations less than this value (5.0 mg/L) could contribute to an impairment of D.O. in this segment.

#### **Influent BOD<sub>5</sub> and TSS**

The Department requires the reporting of raw sewage influent monitoring for BOD<sub>5</sub> and TSS in all POTW permits. This provides the Department with the ability to monitor the percent removal of each parameter as stipulated in section 2 of the Part A conditions and maintain records of the BOD<sub>5</sub> loading as required by 25 Pa. Code Chapter 94. The monitoring frequencies and sample types are identical to the effluent sampling.

#### **E. Coli**

25 PA Code § 92a.61 provide the basis of monitoring requirements for E. Coli. Yearly monitoring will be required going forward.

**Monitoring Frequencies (TRC, pH, and D.O.)**

Previous reviews established a monitoring frequency of 6/ Week for pH, D.O., and TRC. However, these monitoring frequencies do not correspond with the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) Table 6-3 which calls for daily monitoring and 2/ month samples accordingly. Based on BPJ and given that there is no history of significant non-compliance with effluent limitations over the past two years of DMR data, the existing frequencies will be continued in the renewed permit. Given that this facility utilizes a septic / sand filter system in lieu of a traditional aeration system, a 6/ week sampling frequency is acceptable. It is expected that the effluent quality would not differ drastically on days when monitoring is not conducted given that there is a lesser potential for a system malfunction with a sand filter system.

**Compliance History**

**Summary of Inspections** -The last inspection of the facilities was conducted by the Department on 10/31/24 which reveals the facility was operating normally. Some effluent limit exceedances were noted.

**WMS Query Summary** - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed that there were no unresolved violations.

**DMRs Summary** - Upon review of the last year of DMR's, the facility appears to be generally operating within the given concentration limits with the exception of Ammonia-Nitrogen and fecal coliforms.

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

| Parameter   | NOV-24 | OCT-24 | SEP-24 | AUG-24 | JUL-24 | JUN-24 | MAY-24 | APR-24 | MAR-24 | FEB-24 | JAN-24 | DEC-23 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD)<br>Average Monthly                                     | 0.0087 | 0.0075 | 0.0072 | 0.0186 | 0.0105 | 0.0123 | 0.0167 | 0.0175 | 0.0205 | 0.0164 | 0.0100 | 0.0104 |
| Flow (MGD)<br>Daily Maximum                                       | 0.0138 | 0.007  | 0.0073 | 0.0294 | 0.0114 | 0.0128 | 0.0220 | 0.0320 | 0.0294 | 0.0301 | 0.0155 | 0.0126 |
| pH (S.U.)<br>Instantaneous<br>Minimum                             | 7.25   | 6.99   | 7.20   | 6.99   | 7.01   | 7.01   | 6.86   | 6.99   | 7.09   | 6.99   | 7.01   | 7.00   |
| pH (S.U.)<br>Instantaneous<br>Maximum                             | 7.44   | 7.37   | 7.26   | 7.26   | 7.31   | 7.26   | 7.33   | 7.34   | 7.26   | 7.24   | 7.26   | 7.24   |
| DO (mg/L)<br>Daily Minimum  | 9.2    | 8.9    | 9.2    | 9.3    | 9.3    | 9.8    | 9.1    | 9.8    | 8.3    | 8.3    | 8.9    | 8.3    |
| TRC (mg/L)<br>Average Monthly                                     | 0.22   | 0.19   | 0.18   | 0.20   | 0.21   | 0.16   | 0.22   | 0.19   | 0.21   | 0.19   | 0.20   | 0.19   |
| TRC (mg/L)<br>Instantaneous<br>Maximum                            | 0.31   | 0.27   | 0.29   | 0.27   | 0.31   | 0.27   | 0.31   | 0.30   | 0.31   | 0.26   | 0.31   | 0.26   |
| CBOD5 (lbs/day)<br>Average Monthly                                | 0.63   | 1.1    | 0.39   | 0.31   | 0.14   | 0.56   | 0.25   | 0.50   | < 0.27 | 0.36   | 0.21   | 0.17   |
| CBOD5 (lbs/day)<br>Daily Maximum                                  | 0.69   | 1.8    | 0.65   | 0.31   | 0.15   | 0.74   | 0.25   | 0.85   | < 0.32 | 0.39   | 0.28   | 0.23   |
| CBOD5 (mg/L)<br>Average Monthly                                   | 9.83   | 20.0   | 7.7    | < 3.0  | 1.6    | 5.8    | < 1.8  | 4.9    | < 1.8  | 2.9    | 2.8    | 2.3    |
| CBOD5 (mg/L)<br>Weekly Average                                    | 9.83   | 20.0   | 12.6   | < 3.0  | 1.7    | 7.17   | < 1.8  | 8.2    | < 1.8  | 3.2    | 3.6    | 2.7    |
| BOD5 (lbs/day)<br>Raw Sewage Influent<br><br/> Average<br>Monthly | 3.74   | 3.2    | 1.3    | 5.1    | 4.9    | 4.8    | 1.97   | 3.7    | 4.39   | 7.1    | 2.7    | 3.0    |
| BOD5 (lbs/day)<br>Raw Sewage Influent<br><br/> Daily Maximum      | 4.35   | 4.5    | 1.4    | 5.1    | 5.0    | 5.2    | 2.1    | 4.8    | 4.44   | 8.6    | 3.1    | 3.1    |
| BOD5 (mg/L)<br>Raw Sewage Influent<br><br/> Average<br>Monthly    | 58.3   | 51.8   | 27.9   | 49.2   | 52.5   | 49.8   | 14.2   | 36.8   | 31.5   | 55.8   | 36.7   | 43.1   |

NPDES Permit Fact Sheet  
Sullivan Township STP

NPDES Permit No. PA0209511

|  |       |       |        |        |        |        |        |        |       |      |        |        |
|--|-------|-------|--------|--------|--------|--------|--------|--------|-------|------|--------|--------|
| TSS (lbs/day)<br>Average Monthly                                 | 0.46  | 0.78  | 0.24   | < 0.42 | 0.37   | < 0.38 | < 0.55 | 0.45   | 0.54  | 0.71 | 0.29   | < 0.33 |
| TSS (lbs/day)<br>Raw Sewage Influent<br><br/> Average<br>Monthly | 0.93  | 1.2   | 0.83   | 1.5    | 2.6    | 1.1    | 6.35   | 1.3    | 1.87  | 0.36 | 0.58   | 1.6    |
| TSS (lbs/day)<br>Raw Sewage Influent<br><br/> Daily Maximum      | 1.29  | 1.9   | 0.88   | 1.5    | 2.8    | 1.4    | 9.2    | 1.8    | 2.13  | 0.53 | 0.70   | 1.9    |
| TSS (lbs/day)<br>Weekly Average                                  | 0.57  | 0.78  | 0.31   | < 0.42 | 0.37   | < 0.38 | < 0.55 | 0.52   | 0.62  | 0.93 | 0.30   | < 0.44 |
| TSS (mg/L)<br>Average Monthly                                    | 7.0   | 13.5  | 5.0    | < 4.0  | < 4.0  | < 4.0  | < 4.0  | < 4.5  | 5.0   | 5.5  | < 4.0  | < 4.0  |
| TSS (mg/L)<br>Raw Sewage Influent<br><br/> Average<br>Monthly    | 16.0  | 19    | 17.0   | 14     | 27.5   | 12     | 45.8   | 13     | 13    | 9.5  | 8.0    | 22     |
| TSS (mg/L)<br>Weekly Average                                     | 9.66  | 13.5  | 5.0    | < 4.0  | < 4.0  | < 4.0  | < 4.0  | 5.0    | 6.0   | 7.0  | < 4.0  | < 4.5  |
| Fecal Coliform<br>(No./100 ml)<br>Geometric Mean                 | 11.1  | 131.2 | 44.9   | 2.0    | 2.02   | 178.3  | 1.4    | 52.8   | 15.12 | 18   | 150    | 320    |
| Fecal Coliform<br>(No./100 ml)<br>Instantaneous<br>Maximum       | 123.9 | 140.8 | 1011.2 | 2.0    | 4.1    | 185    | 2.0    | 1011.2 | 114.3 | 42   | 5654.4 | 960.6  |
| Ammonia (lbs/day)<br>Average Monthly                             | 0.76  | 0.69  | 0.50   | 0.04   | < 0.01 | < 0.01 | 0.09   | 0.52   | 0.65  | 0.22 | 0.50   | 0.03   |
| Ammonia (mg/L)<br>Average Monthly                                | 11.9  | 11.5  | 10.6   | 0.43   | < 0.10 | < 0.10 | 0.65   | 5.2    | 6.1   | 1.7  | 0.75   | 0.33   |
| Total Aluminum<br>(mg/L)<br>Annual Average                       |       |       |        |        |        |        |        |        |       |      |        | 0.07   |
| Total Aluminum<br>(mg/L)<br>Daily Maximum                        |       |       |        |        |        |        |        |        |       |      |        | 0.07   |
| Total Iron (mg/L)<br>Annual Average                              |       |       |        |        |        |        |        |        |       |      |        | 0.086  |
| Total Iron (mg/L)<br>Daily Maximum                               |       |       |        |        |        |        |        |        |       |      |        | 0.086  |
| Total Manganese<br>(mg/L)<br>Annual Average                      |       |       |        |        |        |        |        |        |       |      |        | 0.009  |

|  |  |  |  |  |  |  |  |  |  |  |  |  |       |
|--|--|--|--|--|--|--|--|--|--|--|--|--|-------|
| Total Manganese<br>(mg/L)<br>Daily Maximum |  |  |  |  |  |  |  |  |  |  |  |  | 0.009 |
|--|--|--|--|--|--|--|--|--|--|--|--|--|-------|

### Compliance History

#### Effluent Violations for Outfall 001, from: January 1, 2024 To: November 30, 2024

| Parameter      | Date     | SBC    | DMR Value | Units      | Limit Value | Units      |
|----------------|----------|--------|-----------|------------|-------------|------------|
| Fecal Coliform | 09/30/24 | IMAX   | 1011.2    | No./100 ml | 1000        | No./100 ml |
| Ammonia        | 11/30/24 | Avg Mo | 0.76      | lbs/day    | .65         | lbs/day    |
| Ammonia        | 11/30/24 | Avg Mo | 11.9      | mg/L       | 5.2         | mg/L       |
| Ammonia        | 03/31/24 | Avg Mo | 6.1       | mg/L       | 5.2         | mg/L       |

| Tools and References Used to Develop Permit |  |
|---|--|
| <input checked="" type="checkbox"/>         | WQM for Windows Model (see Attachment <b>B</b> )   |
| <input type="checkbox"/>                    | Toxics Management Spreadsheet (see Attachment [REDACTED])  |
| <input checked="" type="checkbox"/>         | TRC Model Spreadsheet (see Attachment <b>C</b> )   |
| <input type="checkbox"/>                    | Temperature Model Spreadsheet (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | Water Quality Toxics Management Strategy, 361-0100-003, 4/06.  |
| <input checked="" type="checkbox"/>         | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.   |
| <input type="checkbox"/>                    | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.  |
| <input checked="" type="checkbox"/>         | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.  |
| <input type="checkbox"/>                    | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.   |
| <input type="checkbox"/>                    | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.  |
| <input type="checkbox"/>                    | Pennsylvania CSO Policy, 386-2000-002, 9/08.   |
| <input type="checkbox"/>                    | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.  |
| <input type="checkbox"/>                    | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.   |
| <input checked="" type="checkbox"/>         | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.  |
| <input type="checkbox"/>                    | Implementation Guidance Design Conditions, 386-2000-007, 9/97.   |
| <input checked="" type="checkbox"/>         | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.  |
| <input type="checkbox"/>                    | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.   |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.  |
| <input checked="" type="checkbox"/>         | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.  |
| <input type="checkbox"/>                    | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.   |
| <input checked="" type="checkbox"/>         | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.   |
| <input type="checkbox"/>                    | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.   |
| <input type="checkbox"/>                    | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.       |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.   |
| <input type="checkbox"/>                    | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input checked="" type="checkbox"/>         | Design Stream Flows, 386-2000-003, 9/98.   |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.                                     |
| <input type="checkbox"/>                    | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.   |
| <input checked="" type="checkbox"/>         | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.   |
| <input type="checkbox"/>                    | SOP: [REDACTED]  |
| <input type="checkbox"/>                    | Other: [REDACTED]  |

# **APPENDIX A**

## **Q7-10 ANALYSIS AND STREAM DATA**

## Q<sub>7-10</sub> Analysis

# Q<sub>7-10</sub> Analysis

Facility: Sullivan Township  
Outfall: 001

NPDES Permit No.: PA0209511  
RMI at Outfall: 5.34  
Elev. 1375

## Reference Stream Gage Information

|                                    |                                 |
|------------------------------------|---------------------------------|
| Stream Name                        | Corey Creek                     |
| Reference Gage                     | 1518500                         |
| Station Name                       | Corey Creek near Mainesburg, PA |
| Gage Drainage Area (sq. mi.)       | 12.2                            |
| Q <sub>7-10</sub> at gage (cfs)    | 0.1                             |
| Yield Ratio (cfs/mi <sup>2</sup> ) | 0.0082                          |

## Q<sub>7-10</sub> at Outfall

|   |        |
|---|--------|
| Drainage Area at site (sq. mi.)   | 10.8   |
| Q <sub>7-10</sub> at discharge site (cfs)                                     | 0.0885 |
| Q <sub>7-10</sub> at discharge site (mgd)                                     | 0.0572 |
| Low Flow Yield Ratio of 0.1 cfs/mi <sup>2</sup> (For Approx. Comparison Only) |        |
| Q <sub>7-10</sub> at discharge site (cfs)                                     | 1.0800 |
| Q <sub>7-10</sub> at discharge site (mgd)                                     | 0.6980 |

## Q<sub>7-10</sub> at Downstream Reach #1

|                                  |                          |
|----------------------------------|--------------------------|
| Drainage Area at Reach (sq. mi.) | Drainage Area @ Reach #1 |
| RMI                              | [RMI @ Reach #1]         |
| Q <sub>7-10</sub> at reach (cfs) | #VALUE!                  |
| Q <sub>7-10</sub> at reach (mgd) | #VALUE!                  |

## Was Ecoflows Used?

No

Correlation From Ecoflows

## Check Dilution Ratio

|                                  |             |
|----------------------------------|-------------|
| Discharge at Outfall (wft) (mgd) | 0.015       |
| sf (cfs)                         | wf (cfs)    |
| Dilution Ratio = sf/wf           | 0.0885      |
| Dilution Ratio =                 | 0.023208431 |

## Q<sub>7-10</sub> at Downstream Reach #1

|                                  |                          |
|----------------------------------|--------------------------|
| Drainage Area at Reach (sq. mi.) | Drainage Area @ Reach #1 |
| RMI                              | [RMI @ Reach #1]         |
| Q <sub>7-10</sub> at reach (cfs) | #VALUE!                  |
| Q <sub>7-10</sub> at reach (mgd) | #VALUE!                  |

Elev. [Reach #1]

## Q<sub>7-10</sub> at Downstream Reach #3

|                                  |                          |
|----------------------------------|--------------------------|
| Drainage Area at Reach (sq. mi.) | Drainage Area @ Reach #3 |
| RMI                              | [RMI @ Reach #3]         |
| Q <sub>7-10</sub> at reach (cfs) | #VALUE!                  |
| Q <sub>7-10</sub> at reach (mgd) | #VALUE!                  |

## Basin Characteristics Report at [Site / Reach]

## Basin Map at Outfall

[Insert Drainage Area Map from Stream Stats]

# **APPENDIX B**

## **PREVIOUS WQM 7.0 MODEL INPUT/OUTPUT**

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI   | Elevation<br>(ft) | Drainage Area<br>(sq mi) | Slope<br>(ft/ft) | PWS Withdrawal<br>(mgd) | Apply FC                            |
|-----------|-------------|-------------|-------|-------------------|--------------------------|------------------|-------------------------|-------------------------------------|
| 04A       | 31329       | COREY CREEK | 5,340 | 1380.00           | 10.80                    | 0.00910          | 0.00                    | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY    | Trb Flow | Stream Flow | Rch Trav Time<br>(days) | Rch Velocity<br>(fps) | WD Ratio | Rch Width<br>(ft) | Rch Depth<br>(ft) | Tributary Temp<br>(°C) | Stream Temp<br>(°C) | Stream pH |
|--------------|--------|----------|-------------|-------------------------|-----------------------|----------|-------------------|-------------------|------------------------|---------------------|-----------|
|              | (cfsm) | (cfs)    | (cfs)       |                         |                       |          |                   |                   |                        |                     |           |
| Q7-10        | 0.002  | 0.00     | 0.00        | 0.000                   | 0.000                 | 0.0      | 0.00              | 0.00              | 20.00                  | 7.00                | 0.00      |
| Q1-10        |        | 0.00     | 0.00        | 0.000                   | 0.000                 |          |                   |                   |                        |                     |           |
| Q30-10       |        | 0.00     | 0.00        | 0.000                   | 0.000                 |          |                   |                   |                        |                     |           |

Discharge Data

| Name                  | Permit Number | Existing Disc Flow<br>(mgd) | Permitted Disc Flow<br>(mgd) | Design Disc Flow<br>(mgd) | Reserve Factor        | Disc Temp<br>(°C) | Disc pH |
|-----------------------|---------------|-----------------------------|------------------------------|---------------------------|-----------------------|-------------------|---------|
|                       |               |                             |                              |                           |                       |                   |         |
| Malnesburg            | PA0209511     | 0.0150                      | 0.0150                       | 0.0150                    | 0.000                 | 25.00             | 7.00    |
| <b>Parameter Data</b> |               |                             |                              |                           |                       |                   |         |
| Parameter Name        |               | Disc Conc<br>(mg/L)         | Trib Conc<br>(mg/L)          | Stream Conc<br>(mg/L)     | Fate Coef<br>(1/days) |                   |         |
| CBOD5                 |               | 26.00                       | 2.00                         | 0.00                      | 1.50                  |                   |         |
| Dissolved Oxygen      |               | 3.00                        | 8.24                         | 0.00                      | 0.00                  |                   |         |
| NH3-N                 |               | 25.00                       | 0.00                         | 0.00                      | 0.70                  |                   |         |

Input Data WQM 7.0

| SWP<br>Basin | Stream<br>Code | Stream Name | RML   | Elevation<br>(ft) | Drainage<br>Area<br>(sq mi) | Slope<br>(ft/ft) | PWS<br>Withdrawal<br>(mgd) | Apply<br>FC                         |
|--------------|----------------|-------------|-------|-------------------|-----------------------------|------------------|----------------------------|-------------------------------------|
| 04A          | 31329          | COREY CREEK | 4.510 | 1340.00           | 12.20                       | 0.00910          | 0.00                       | <input checked="" type="checkbox"/> |

Stream Data

| Design<br>Cond. | LFY    | Trib<br>Flow | Stream<br>Flow | Rch<br>Trav<br>Time | Rch<br>Velocity | WD | Rch<br>Ratio | Rch<br>Width | Rch<br>Depth | Tributary<br>Temp | pH   | Stream<br>Temp | pH   |
|-----------------|--------|--------------|----------------|---------------------|-----------------|----|--------------|--------------|--------------|-------------------|------|----------------|------|
|                 | (cfsm) | (cfs)        | (cfs)          | (days)              | (fps)           |    | (ft)         | (ft)         | (ft)         | (°C)              |      | (°C)           |      |
| 27-10           | 0.002  | 0.00         | 0.00           | 0.000               | 0.000           |    | 0.0          | 0.00         | 0.00         | 20.00             | 7.00 | 0.00           | 0.00 |
| 21-10           |        | 0.00         | 0.00           | 0.000               | 0.000           |    |              |              |              |                   |      |                |      |
| 130-10          |        | 0.00         | 0.00           | 0.000               | 0.000           |    |              |              |              |                   |      |                |      |

Discharge Data

| Name                  | Permit Number | Existing<br>Disc<br>Flow<br>(mgd) | Permitted<br>Disc<br>Flow<br>(mgd) | Design<br>Disc<br>Flow<br>(mgd) | Reserve<br>Factor        | Disc<br>Temp<br>(°C) | Disc<br>pH |
|-----------------------|---------------|-----------------------------------|------------------------------------|---------------------------------|--------------------------|----------------------|------------|
|                       |               | 0.0000                            | 0.0000                             | 0.0000                          |                          |                      |            |
| <b>Parameter Data</b> |               |                                   |                                    |                                 |                          |                      |            |
| Parameter Name        |               | Disc<br>Conc<br>(mg/L)            | Trib<br>Conc<br>(mg/L)             | Stream<br>Conc<br>(mg/L)        | Fate<br>Coef<br>(1/days) |                      |            |
| CBOD5                 |               | 25.00                             | 2.00                               | 0.00                            | 1.50                     |                      |            |
| Dissolved Oxygen      |               | 3.00                              | 8.24                               | 0.00                            | 0.00                     |                      |            |
| NH3-N                 |               | 25.00                             | 0.00                               | 0.00                            | 0.70                     |                      |            |

**Input Data WQM 7.0**

| SWP Basin | Stream Code | Stream Name | RMI   | Elevation | Drainage Area | Slope   | PWS Withdrawal | Apply FC                            |
|-----------|-------------|-------------|-------|-----------|---------------|---------|----------------|-------------------------------------|
|           |             |             |       | (ft)      | (sq mi)       | (ft/ft) | (mgd)          |                                     |
| 04A       | 31329       | COREY CREEK | 1.870 | 1190.00   | 15.70         | 0.00870 | 0.00           | <input checked="" type="checkbox"/> |

**Stream Data**

| Design Cond. | LFY    | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Stream pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|-----------|-------------|-----------|
|              | (cfsm) | (cfs)     | (cfs)       | (days)        | (fps)        |          | (ft)      | (ft)      | (°C)           |           | (°C)        |           |
| Q7-10        | 0.002  | 0.00      | 0.00        | 0.000         | 0.000        | 0.0      | 0.00      | 0.00      | 20.00          | 7.00      | 0.00        | 0.00      |
| Q1-10        |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |           |             |           |
| Q30-10       |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |           |             |           |

**Discharge Data**

| Name                  | Permit Number | Existing Disc Flow | Permitted Disc Flow | Design Disc Flow | Reserve Factor | Disc Temp | Disc pH |
|-----------------------|---------------|--------------------|---------------------|------------------|----------------|-----------|---------|
|                       |               | (mgd)              | (mgd)               | (mgd)            |                |           |         |
|                       |               | 0.0000             | 0.0000              | 0.0000           | 0.000          | 25.00     | 7.00    |
| <b>Parameter Data</b> |               |                    |                     |                  |                |           |         |
| Parameter Name        |               | Disc Conc          | Trib Conc           | Stream Conc      | Rate Coef      |           |         |
|                       |               | (mg/L)             | (mg/L)              | (mg/L)           | (1/days)       |           |         |
| CBOD5                 |               | 25.00              | 2.00                | 0.00             | 1.50           |           |         |
| Dissolved Oxygen      |               | 3.00               | 8.24                | 0.00             | 0.00           |           |         |
| NH3-N                 |               | 25.00              | 0.00                | 0.00             | 0.70           |           |         |

**WQM 7.0 Hydrodynamic Outputs**

| <u>SWP Basin</u>   |             |         | <u>Stream Code</u> |                    |             | <u>Stream Name</u> |       |           |          |                 |               |             |  |  |
|--------------------|-------------|---------|--------------------|--------------------|-------------|--------------------|-------|-----------|----------|-----------------|---------------|-------------|--|--|
| 04A                |             |         | 31329              |                    |             | COREY CREEK        |       |           |          |                 |               |             |  |  |
| RM                 | Stream Flow | PWS Wth | Net Stream Flow    | Disc Analysis Flow | Reach Slope | Depth              | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |  |  |
|                    | (cfs)       | (cfs)   | (cfs)              | (cfs)              | (ft/ft)     | (ft)               | (ft)  |           | (fps)    | (days)          | (°C)          |             |  |  |
| <b>Q7-10 Flow</b>  |             |         |                    |                    |             |                    |       |           |          |                 |               |             |  |  |
| 5.340              | 0.02        | 0.00    | 0.02               | .0232              | 0.00910     | .327               | 5.75  | 17.58     | 0.02     | 2.315           | 22.82         | 7.00        |  |  |
| 4.510              | 0.02        | 0.00    | 0.02               | .0232              | 0.00910     | .332               | 5.95  | 17.93     | 0.02     | 7.336           | 22.67         | 7.00        |  |  |
| <b>Q1-10 Flow</b>  |             |         |                    |                    |             |                    |       |           |          |                 |               |             |  |  |
| 5.340              | 0.01        | 0.00    | 0.01               | .0232              | 0.00910     | NA                 | NA    | NA        | 0.02     | 2.547           | 23.35         | 7.00        |  |  |
| 4.510              | 0.01        | 0.00    | 0.01               | .0232              | 0.00910     | NA                 | NA    | NA        | 0.02     | 8.129           | 23.21         | 7.00        |  |  |
| <b>Q30-10 Flow</b> |             |         |                    |                    |             |                    |       |           |          |                 |               |             |  |  |
| 5.340              | 0.11        | 0.00    | 0.11               | .0232              | 0.00910     | NA                 | NA    | NA        | 0.04     | 1.176           | 20.84         | 7.00        |  |  |
| 4.510              | 0.13        | 0.00    | 0.13               | .0232              | 0.00910     | NA                 | NA    | NA        | 0.04     | 3.627           | 20.76         | 7.00        |  |  |

### WQM 7.0 Modeling Specifications

|                    |                   |                                     |                                     |
|--------------------|-------------------|-------------------------------------|-------------------------------------|
| Parameters         | Both              | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method         | Uniform Treatment | Use Inputted W/D Ratio              | <input checked="" type="checkbox"/> |
| Q1-10/Q7-10 Ratio  | 0.64              | Use Inputted Reach Travel Times     | <input type="checkbox"/>            |
| Q30-10/Q7-10 Ratio | 6.4               | Temperature Adjust Kr               | <input checked="" type="checkbox"/> |
| D.O. Saturation    | 90.00%            | Use Balanced Technology             | <input checked="" type="checkbox"/> |
| D.O. Goal          | 6                 |                                     |                                     |

**WQM 7.0 Wasteload Allocations**

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
|------------------|--------------------|--------------------|
| 04A              | 31328              | COREY CREEK        |

**NH3-N Acute Allocations**

| RMI              | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|------------------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 5.340 Mainesburg |                | NA                        | 50                  | 7.6                       | 11.36               | 1              | 77                |
| 4.510            |                | NA                        | NA                  | 7.68                      | NA                  | NA             | NA                |

**NH3-N Chronic Allocations**

| RMI              | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|------------------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 5.340 Mainesburg |                | NA                        | 26                  | 1.8                       | 10.72               | 1              | 57                |
| 4.510            |                | NA                        | NA                  | 1.81                      | NA                  | NA             | NA                |

**Dissolved Oxygen Allocations**

| RMI             | Discharge Name | CBOD5           |                 | NH3-N           |                 | Dissolved Oxygen |                 | Critical Reach | Percent Reduction |
|-----------------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
|                 |                | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L)  | Multiple (mg/L) |                |                   |
| 5.34 Mainesburg |                | 26              | 25              | 11.36           | 10.38           | 3                | 5               | 1              | 5                 |
| 4.51            |                | NA              | NA              | NA              | NA              | NA               | NA              | NA             | NA                |

### WQM 7.0 D.O.Simulation

| <u>SWP Basin</u>                | <u>Stream Code</u>                | <u>Stream Name</u>               |                             |             |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|-------------|
| 04A                             | 31329                             | COREY CREEK                      |                             |             |
| <u>RMI</u>                      | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u>          |             |
| 5.340                           | 0.015                             | 22.821                           | 7.000                       |             |
| <u>Reach Width (ft)</u>         | <u>Reach Depth (ft)</u>           | <u>Reach WDRatio</u>             | <u>Reach Velocity (fps)</u> |             |
| 5.745                           | 0.327                             | 17.580                           | 0.022                       |             |
| <u>Reach CBOD5 (mg/L)</u>       | <u>Reach Kc (1/days)</u>          | <u>Reach NH3-N (mg/L)</u>        | <u>Reach Kn (1/days)</u>    |             |
| 14.98                           | 0.764                             | 5.86                             | 0.870                       |             |
| <u>Reach DO (mg/L)</u>          | <u>Reach Kr (1/days)</u>          | <u>Kr Equation</u>               | <u>Reach DO Goal (mg/L)</u> |             |
| 6.413                           | 14.200                            | Owens                            | 6                           |             |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u>           |                                  |                             |             |
| 2.315                           | TravTime (days)                   | CBOD5 (mg/L)                     | NH3-N (mg/L)                | D.O. (mg/L) |
|                                 | 0.232                             | 12.24                            | 4.79                        | 6.11        |
|                                 | 0.463                             | 10.01                            | 3.92                        | 6.55        |
|                                 | 0.695                             | 8.19                             | 3.20                        | 6.94        |
|                                 | 0.926                             | 6.69                             | 2.62                        | 7.26        |
|                                 | 1.158                             | 5.47                             | 2.14                        | 7.53        |
|                                 | 1.389                             | 4.47                             | 1.75                        | 7.74        |
|                                 | 1.621                             | 3.66                             | 1.43                        | 7.83        |
|                                 | 1.852                             | 2.99                             | 1.17                        | 7.83        |
|                                 | 2.084                             | 2.45                             | 0.96                        | 7.83        |
|                                 | 2.315                             | 2.00                             | 0.78                        | 7.83        |
| <u>RMI</u>                      | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u>          |             |
| 4.510                           | 0.015                             | 22.670                           | 7.000                       |             |
| <u>Reach Width (ft)</u>         | <u>Reach Depth (ft)</u>           | <u>Reach WDRatio</u>             | <u>Reach Velocity (fps)</u> |             |
| 5.953                           | 0.332                             | 17.934                           | 0.022                       |             |
| <u>Reach CBOD5 (mg/L)</u>       | <u>Reach Kc (1/days)</u>          | <u>Reach NH3-N (mg/L)</u>        | <u>Reach Kn (1/days)</u>    |             |
| 2.00                            | 0.000                             | 0.74                             | 0.860                       |             |
| <u>Reach DO (mg/L)</u>          | <u>Reach Kr (1/days)</u>          | <u>Kr Equation</u>               | <u>Reach DO Goal (mg/L)</u> |             |
| 7.852                           | 13.785                            | Owens                            | 6                           |             |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u>           |                                  |                             |             |
| 7.335                           | TravTime (days)                   | CBOD5 (mg/L)                     | NH3-N (mg/L)                | D.O. (mg/L) |
|                                 | 0.733                             | 2.00                             | 0.39                        | 7.85        |
|                                 | 1.467                             | 2.00                             | 0.21                        | 7.85        |
|                                 | 2.200                             | 2.00                             | 0.11                        | 7.85        |
|                                 | 2.934                             | 2.00                             | 0.06                        | 7.85        |
|                                 | 3.667                             | 2.00                             | 0.03                        | 7.85        |
|                                 | 4.401                             | 2.00                             | 0.02                        | 7.85        |
|                                 | 5.134                             | 2.00                             | 0.01                        | 7.85        |
|                                 | 5.868                             | 2.00                             | 0.00                        | 7.85        |
|                                 | 6.601                             | 2.00                             | 0.00                        | 7.85        |
|                                 | 7.335                             | 2.00                             | 0.00                        | 7.85        |

**WQM 7.0 Effluent Limits**

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |                 |                  |                               |                           |                           |
|------------------|--------------------|--------------------|-----------------|------------------|-------------------------------|---------------------------|---------------------------|
| 04A              | 31329              | COREY CREEK        |                 |                  |                               |                           |                           |
| RMF              | Name               | Permit Number      | Disc Flow (mgd) | Parameter        | Eff. Limit 30-day Ave. (mg/L) | Eff. Limit Maximum (mg/L) | Eff. Limit Minimum (mg/L) |
| 5.340            | Malnesburg         | PA0209511          | 0.015           | CBOD5            | 25                            |                           |                           |
|                  |                    |                    |                 | NH3-N            | 5.19                          | 10.38                     |                           |
|                  |                    |                    |                 | Dissolved Oxygen |                               |                           | 5                         |

# **APPENDIX C**

## **TRC ANALYSIS**

| 1A | B   | C                              | D  | E         | F                                    | G |
|----|---|--------------------------------|--|-----------|--------------------------------------|---|
| 2  | <b>TRC EVALUATION</b>                       | Sullivan Township              |  |           |                                      |   |
| 3  | Input appropriate values in B4:B8 and E4:E7 |                                |  |           |                                      |   |
| 4  | 0.0885                                      | = Q stream (cfs)               |  | 0.5       | = CV Daily                           |   |
| 5  | 0.015                                       | = Q discharge (MGD)            |  | 0.5       | = CV Hourly                          |   |
| 6  | 30  | = no. samples                  |  | 1         | = AFC_Partial Mix Factor             |   |
| 7  | 0.3   | = Chlorine Demand of Stream    |  | 1         | = CFC_Partial Mix Factor             |   |
| 8  | 0   | = Chlorine Demand of Discharge |  | 15        | = AFC_Criteria Compliance Time (min) |   |
| 9  | 0.5   | = BAT/BPJ Value                |  | 720       | = CFC_Criteria Compliance Time (min) |   |
|    | 0   | = % Factor of Safety (FOS)     |  | 0         | = Decay Coefficient (K)              |   |
| 10 | Source                                      | Reference                      | AFC Calculations   | Reference | CFC Calculations                     |   |
| 11 | TRC   | 1.3.2.III                      | WLA_afc = 1.236  | 1.3.2.III | WLA_cfc = 1.197                      |   |
| 12 | PENTOXSD TRG                                | 5.1a                           | LTAMULT_afc = 0.373  | 5.1c      | LTAMULT_cfc = 0.581                  |   |
| 13 | PENTOXSD TRG                                | 5.1b                           | LTA_afc = 0.460  | 5.1d      | LTA_cfc = 0.696                      |   |
| 14 |   |                                |  |           |                                      |   |
| 15 | Source                                      |                                | Effluent Limit Calculations  |           |                                      |   |
| 16 | PENTOXSD TRG                                | 5.1f                           | AML MULT = 1.231   |           |                                      |   |
| 17 | PENTOXSD TRG                                | 5.1g                           | AVG MON LIMIT (mg/l) = 0.500   |           | BAT/BPJ                              |   |
| 18 |   |                                | INST MAX LIMIT (mg/l) = 1.635  |           |                                      |   |
|    |   |                                |  |           |                                      |   |
|    | WLA_afc                                     |                                | (.018/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.018/Qd*e(-k*AFC_tc))...<br>...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) |           |                                      |   |
|    | LTAMULT_afc                                 |                                | EXP((0.5^LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)   |           |                                      |   |
|    | LTA_afc                                     |                                | wla_afc*LTAMULT_afc  |           |                                      |   |
|    | WLA_cfc                                     |                                | (.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...<br>...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) |           |                                      |   |
|    | LTAMULT_cfc                                 |                                | EXP((0.5^LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)                                     |           |                                      |   |
|    | LTA_cfc                                     |                                | wla_cfc*LTAMULT_cfc  |           |                                      |   |
|    | AML MULT                                    |                                | EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))                                     |           |                                      |   |
|    | AVG MON LIMIT                               |                                | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)   |           |                                      |   |
|    | INST MAX LIMIT                              |                                | 1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)  |           |                                      |   |

# **APPENDIX D**

## **FACILITY MAP**

# **APPENDIX E**

## **METALS SAMPLING RESULTS**

NPDES Permit Fact Sheet  
Sullivan Township STP

NPDES Permit No. PA0209511

| PERMIT    | PF NAME                          | DUE DATE   | OUTFALL | PARAMETER        | CONC UNITS | CONC 2 VALUE | CONC 2 SBC     | CONC 3 VALUE | CONC 3 SBC    | SAMPLE FREQUENCY | SAMPLE TYPE |
|-----------|----------------------------------|------------|---------|------------------|------------|--------------|----------------|--------------|---------------|------------------|-------------|
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2020 | 001     | Aluminum, Total  | mg/L       | 0.06         | Annual Average | 0.06         | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2021 | 001     | Aluminum, Total  | mg/L       | < 0.050      | Annual Average | < 0.050      | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2022 | 001     | Aluminum, Total  | mg/L       | < 0.05       | Annual Average | < 0.05       | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2023 | 001     | Aluminum, Total  | mg/L       | 0.03         | Annual Average | 0.03         | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2024 | 001     | Aluminum, Total  | mg/L       | 0.07         | Annual Average | 0.07         | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2025 | 001     | Aluminum, Total  | mg/L       | 0.051        | Annual Average | 0.051        | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2020 | 001     | Iron, Total      | mg/L       | 0.07         | Annual Average | 0.07         | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2021 | 001     | Iron, Total      | mg/L       | < 0.070      | Annual Average | < 0.070      | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2022 | 001     | Iron, Total      | mg/L       | < 0.07       | Annual Average | < 0.07       | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2023 | 001     | Iron, Total      | mg/L       | 0.05         | Annual Average | 0.05         | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2024 | 001     | Iron, Total      | mg/L       | 0.086        | Annual Average | 0.086        | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2025 | 001     | Iron, Total      | mg/L       | 0.092        | Annual Average | 0.092        | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2020 | 001     | Manganese, Total | mg/L       | 0.28         | Annual Average | 0.28         | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2021 | 001     | Manganese, Total | mg/L       | 0.036        | Annual Average | 0.036        | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2022 | 001     | Manganese, Total | mg/L       | 0.075        | Annual Average | 0.075        | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2023 | 001     | Manganese, Total | mg/L       | 0.05         | Annual Average | 0.05         | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2024 | 001     | Manganese, Total | mg/L       | 0.009        | Annual Average | 0.009        | Daily Maximum | 1/year           | Grab        |
| PA0209511 | MAINESBURG STP/COLLECTION SYSTEM | 01/28/2025 | 001     | Manganese, Total | mg/L       | 0.13         | Annual Average | 0.13         | Daily Maximum | 1/year           | Grab        |