

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0216071**

APS ID

**1108049**

Authorization ID

**1474312**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>Univar Solutions USA LLC</b>	Facility Name	<b>Univar Solutions USA Bunola Branch</b>
Applicant Address	328 Bunola River Road	Facility Address	328 Bunola River Road
	Bunola, PA 15020		Bunola, PA 15020
Applicant Contact	Scott Heath	Facility Contact	Scott Heath
Applicant Phone	(215) 428-5511	Facility Phone	215-428-5511
Client ID	32864	Site ID	258699
Ch 94 Load Status	Not Overloaded	Municipality	Forward Township
Connection Status	No Limitations	County	Allegheny
Date Application Received	January 30, 2024	EPA Waived?	Yes
Date Application Accepted	May 14, 2024	If No, Reason	
Purpose of Application	Renewal of NPDES sewage permit		

**Summary of Review**

The applicant has applied for the renewal of NPDES Permit PA0216071. The previous permit was issued on January 1, 2020 and expired on December 31, 2024.



Sewage from this plant is treated with a Wet Well, Pumps, Grinder, Aeration Tanks, Clarifier, Chlorinator, Contact Tank, Dechlor Feeder, RAS, Skimmer, Three Blowers, and a Sludge Holding Tank

The applicant is currently enrolled in and will continue to use eDMR.

The Act 14 notification letters were provided dated January 16, 2024 and no comments were received.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
		 Jordan Coldsmith / Environmental Engineering Specialist	February 11, 2025
		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	February 28, 2025

**Discharge, Receiving Waters and Water Supply Information**

Outfall No. 001

Design Flow (MGD) .003

Latitude 40° 14' 15"

Longitude -79° 56' 46"

Quad Name Monongahela

Quad Code 40079B8

Wastewater Description: Sewage Effluent

Receiving Waters Monongahela River (WWF)

Stream Code 37185

NHD Com ID 99408958

RMI 27.8

Drainage Area 5320

Yield (cfs/mi<sup>2</sup>) 0.1

Q<sub>7-10</sub> Flow (cfs) 550

Q<sub>7-10</sub> Basis Army Corp of Engineers

Elevation (ft) 1826

Slope (ft/ft)

Watershed No. 19-C

Chapter 93 Class. WWF

Existing Use

Existing Use Qualifier

Exceptions to Use

Exceptions to Criteria

Assessment Status Attaining Use(s)

Cause(s) of Impairment

Source(s) of Impairment

TMDL Status

Name

Background/Ambient Data

Data Source

pH (SU)

Temperature (°F)

Hardness (mg/L)

Other:

Nearest Downstream Public Water Supply Intake

PA AMER WATER CO-PITTSBURGH

PWS Waters Monongahela River (WWF)

Flow at Intake (cfs)

PWS RMI

Distance from Outfall (mi) 1.61

Changes Since Last Permit Issuance: None

Other Comments: N/A

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Bonola PA Facility				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
0294405	08/09/1994			
0294405 A-1	06/07/2001			
0294405 A-2	01/08/2003			
0294405 A-3	03/01/2021			
0294405 A-5	04/12/2024			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.003
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.003		Not Overloaded	Holding Tank	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: the current treatment process consists of:

- Wet Well
- Pumps
- Grinder
- Aeration Tanks
- Clarifier
- Chlorinator
- Contact Tank
- Dechlor Feeder
- RAS
- Skimmer
- Three Blowers
- Sludge Holding Tank

**Compliance History**

### Operations Compliance Check Summary Report

Facility: UNIVAR SOLUTIONS USA BUNOLA BRANCH

NPDES Permit No.: PA0216071

Compliance Review Period: 2/1/20-2/20/25

Inspection Summary:

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
08/31/2023	Compliance Evaluation	County Health Dept	Violation(s) Noted
07/27/2022	Compliance Evaluation	County Health Dept	Violation(s) Noted
06/23/2021	Compliance Evaluation	County Health Dept	Violation(s) Noted
07/16/2020	Incident- Response to Accident or Event	PA Dept of Environmental Protection	Administratively Closed
06/17/2020	Compliance Evaluation	County Health Dept	Violation(s) Noted

Violation Summary:

VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE
08/31/2023	92A.44	NPDES - Violation of effluent limits in Part A of permit	08/12/2023
07/27/2022	92A.44	NPDES - Violation of effluent limits in Part A of permit	08/19/2022
06/23/2021	92A.44	NPDES - Violation of effluent limits in Part A of permit	01/26/2023
06/17/2020	92A.44	NPDES - Violation of effluent limits in Part A of permit	08/05/2020
06/17/2020	92A.61(C)	NPDES - Failure to monitor pollutants as required by the NPDES permit	08/05/2020

Open Violations by Client ID:

No open violations for Client ID 32864 with Clean Water Program. The following two open violations exist with Storage Tanks program in Southwest Region and Southeast Region.

FACILITY	INSPI PROGRAM	PROGRAM SPECIFIC ID			VIOLATION ID	VIOLATION DATE	VIOLATION CODE	VIOLATION	INSPI REGION
		INSPI ID	INSPI ID	INSPI ID					
UNIVAR SOLUTIONS USA LLC BUNOLA BRANCH	Storage Tanks	02-32636	3918536	8217277	02/05/2025	245.533	Failure to meet aboveground storage tank system exterior coating requirements	SWRO	
UNIVAR SOLUTIONS USA MV BRANCH	Storage Tanks	09-37816	3878730	8209856	12/04/2024	245.41(A)	Failure to register a storage tank and/or failure to pay the registration fee prior to registration certificate expiration	SERO	

Enforcement Summary:

ENF TYPE	ENF TYPE DESC	EXECUTED DATE	VIOLATION#	ENF FINAL STATUS	ENF CLOSED DATE
NOV	Notice of Violation	09/12/2023	92A.44	Administrative Close Out	09/12/2023
NOV	Notice of Violation	08/03/2022	92A.44	Administrative Close Out	01/02/2024
NOV	Notice of Violation	07/16/2021	92A.44	Administrative Close Out	01/02/2024
NOV	Notice of Violation	07/01/2020	92A.44; 92A.61(C)	Administrative Close Out	12/29/2023

Effluent Violation Summary:

MON PD	PARAMETER	REPORTED VALUE	PERMIT LIMIT	UNIT	STAT BASE CODE	FACILITY COMMENTS
May-24	Fecal Coliform	< 491	200	ml	No./100 Geometric Mean	High grab lab result increased monthly average.
May-24	Fecal Coliform	2420	1000	ml	No./100 Instantaneous Maximum	
Apr-24	pH	9.47	9.0	S.U.	Instantaneous Maximum	
Feb-24	pH	9.39	9.0	S.U.	Instantaneous Maximum	
Dec-23	Total Suspended Solids	42	30	mg/L	Average Monthly	
Jul-22	Fecal Coliform	< 393	200	ml	No./100 Geometric Mean	One high sample value raised average value.
Jul-22	Fecal Coliform	1554	1000	ml	No./100 Instantaneous Maximum	
May-22	Carbonaceous Biochemical Oxygen Demand (CBOD5)	70.8	50	mg/L	Instantaneous Maximum	
May-22	Fecal Coliform	< 606	200	ml	No./100 Geometric Mean	
May-22	Fecal Coliform	2420	1000	ml	No./100 Instantaneous Maximum	
Jul-21	Total Residual Chlorine (TRC)	2.1	1.6	mg/L	Instantaneous Maximum	equipment was adjusted when operator visited the facility to check on the system.
May-21	Fecal Coliform	< 339	200	ml	No./100 Geometric Mean	The increased fecal result happened in May. The operator has increase the chlorine dosage and all results have been below

						the effluent limitations since.
						The increased fecal result happened in May. The operator has <u>increase</u> the chlorine dosage and all results have been below the effluent limitations since.
May-21	Fecal Coliform	1204	1000	No./100 ml	Instantaneous Maximum	Instantaneous Maximum
Oct-20	Total Residual Chlorine (TRC)	1.66	1.6	mg/L	Instantaneous Maximum	Instantaneous Maximum
Sep-20	Total Residual Chlorine (TRC)	2.06	1.6	mg/L	Instantaneous Maximum	Instantaneous Maximum
Jul-20	Total Residual Chlorine (TRC)	2.2	1.6	mg/L	Instantaneous Maximum	Instantaneous Maximum
Jun-20	Total Residual Chlorine (TRC)	1.84	1.6	mg/L	Instantaneous Maximum	Instantaneous Maximum

**Compliance Status:** Facility is in general compliance; There are currently no open violations or pending enforcements for Clean Water Program in Southwest Region. Open violations exist with Storage Tanks Program in Southwest and Southeast Regions.

**Completed by:** Amanda Illar **Completed date:** 2/20/25

Compliance History

DMR Data for Outfall 001 (from January 1, 2024 to December 31, 2024)

Parameter	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24
Flow (MGD) Average Monthly	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.01	0.001
pH (S.U.) Instantaneous Minimum	6.88	7.09	7.15	7.21	6.92	7.08	7.02	7.01	7.11	7.2	6.81	7.2
pH (S.U.) Instantaneous Maximum	7.63	7.56	7.74	7.89	7.48	7.78	7.99	7.62	9.47	8.5	9.39	7.8
DO (mg/L) Instantaneous Minimum	9.87	8.75	8.358	8.122	8.2	8.07	8.49	8.16	9.7	10.0	10.41	9.87
TRC (mg/L) Average Monthly	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.02	< 0.01	< 0.01	< 0.01
TRC (mg/L) Instantaneous Maximum	0.04	0.04	< 0.03	0.06	0.03	0.04	0.04	0.03	< 0.1	0.03	0.04	0.03
CBOD5 (mg/L) Average Monthly	6.3	< 3.0	< 3	< 3	< 3	< 4	< 3	< 3	5.6	3.9	< 4	< 4.2
CBOD5 (mg/L) Instantaneous Maximum	6.9	< 3.0	3	3	3	4	< 3	< 3	6.3	4.4	5	5.4
TSS (mg/L) Average Monthly	< 0.1	14	12	7	28	< 1	< 7	< 3	24	15	19	27
TSS (mg/L) Instantaneous Maximum	0.04	16	29	8	34	< 1	11	3	47	22	21	34
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	1	< 1	< 1	< 1	< 1	< 491	< 1	< 116	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	1	17	4	< 1	< 1	1	2420	< 1	462	921	2
Ammonia (mg/L) Average Monthly	0.41	< 0.6	< 0.10	< 0.10	< 0.1	0.33	0.36	< 0.93	2.21	1.52	< 2.24	2.94

NPDES Permit Fact Sheet  
Univar Solutions USA Bunola Branch

NPDES Permit No. PA0216071

Ammonia (mg/L) Instantaneous Maximum	1.54	2.15	< 0.10	0.30	< 0.1	0.56	0.56	1.76	2.96	2.72	4.38	3.38
--	------	------	--------	------	-------	------	------	------	------	------	------	------

Compliance History

Effluent Violations for Outfall 001, from: February 1, 2024 To: December 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
pH	04/30/24	IMAX	9.47	S.U.	9.0	S.U.
pH	02/29/24	IMAX	9.39	S.U.	9.0	S.U.
Fecal Coliform	05/31/24	Geo Mean	< 491	No./100 ml	200	No./100 ml
Fecal Coliform	05/31/24	IMAX	2420	No./100 ml	1000	No./100 ml

Summary of Inspections: [REDACTED]

Other Comments: [REDACTED]

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 14' 15.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .003  
Longitude -79° 56' 46.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The discharge was evaluated using WQM7.0 to determine the CBOD<sub>5</sub>, ammonia nitrogen, and dissolved oxygen parameters. The model results show the limits for CBOD<sub>5</sub>, ammonia and DO will not change.

TRC was calculated using the TRC Spreadsheet. The spreadsheet shows TRC will not change.

Parameter	Limit (mg/l)	SBC	Model
CBOD <sub>5</sub>	25 50	Average Monthly IMAX	WQM7.0
Dissolved Oxygen	4	Minimum	WQM7.0
Ammonia-Nitrogen	25 50	Average Monthly IMAX	WQM7.0
TRC	0.5 1.6	Average Monthly IMAX	TRC Spreadsheet

**Anti-Backsliding**

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (1) **Reissued permits.** (1) Except as provided in paragraph (1)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to

contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

**The facility is not seeking to revise the previously permitted effluent limits.**

**Additional Considerations**

Sewage discharges will include monitoring, at a minimum, for *E. coli*, in new and reissued permits, with a monitoring frequency of 1/year for design flows of 0.002 - 0.05 MGD.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Department's "Technical Guidance for the Development and Specification of Effluent Limitations".

An annual sampling frequency for total phosphorus and total nitrogen will again be imposed per 25 PA Code §92a.61.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	25	XXX	50	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: none



## Attachment 1 TRC Calculation



TRC\_CALC (1)

TRC EVALUATION																																	
Input appropriate values in A3:A9 and D3:D9																																	
<table><tr><td>550</td><td>= Q stream (cfs)</td></tr><tr><td>0.003</td><td>= Q discharge (MGD)</td></tr><tr><td>30</td><td>= no. samples</td></tr><tr><td>0.3</td><td>= Chlorine Demand of Stream</td></tr><tr><td>0</td><td>= Chlorine Demand of Discharge</td></tr><tr><td>0.5</td><td>= BAT/BPJ Value</td></tr><tr><td>0</td><td>= % Factor of Safety (FOS)</td></tr></table>			550	= Q stream (cfs)	0.003	= Q discharge (MGD)	30	= no. samples	0.3	= Chlorine Demand of Stream	0	= Chlorine Demand of Discharge	0.5	= BAT/BPJ Value	0	= % Factor of Safety (FOS)	<table><tr><td>0.5</td><td>= CV Daily</td></tr><tr><td>0.5</td><td>= CV Hourly</td></tr><tr><td>1</td><td>= AFC_Partial Mix Factor</td></tr><tr><td>1</td><td>= CFC_Partial Mix Factor</td></tr><tr><td>15</td><td>= AFC_Criteria Compliance Time (min)</td></tr><tr><td>720</td><td>= CFC_Criteria Compliance Time (min)</td></tr><tr><td></td><td>= Decay Coefficient (K)</td></tr></table>			0.5	= CV Daily	0.5	= CV Hourly	1	= AFC_Partial Mix Factor	1	= CFC_Partial Mix Factor	15	= AFC_Criteria Compliance Time (min)	720	= CFC_Criteria Compliance Time (min)		= Decay Coefficient (K)
550	= Q stream (cfs)																																
0.003	= Q discharge (MGD)																																
30	= no. samples																																
0.3	= Chlorine Demand of Stream																																
0	= Chlorine Demand of Discharge																																
0.5	= BAT/BPJ Value																																
0	= % Factor of Safety (FOS)																																
0.5	= CV Daily																																
0.5	= CV Hourly																																
1	= AFC_Partial Mix Factor																																
1	= CFC_Partial Mix Factor																																
15	= AFC_Criteria Compliance Time (min)																																
720	= CFC_Criteria Compliance Time (min)																																
	= Decay Coefficient (K)																																
Source	Reference	AFC Calculations	Reference	CFC Calculations																													
TRC	1.3.2.iii	WLA_afc = 37804.372	1.3.2.iii	WLA_cfc = #####																													
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581																													
PENTOXSD TRG	5.1b	LTA_afc = 14086.811	5.1d	LTA_cfc = #####																													
Effluent Limit Calculations																																	
PENTOXSD TRG	5.1f	AML MULT = 1.231																															
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ																													
		INST MAX LIMIT (mg/l) = 1.635																															
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$																															
LTAMULT_afc		$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$																															
LTA_afc		wla_afc*LTAMULT_afc																															
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$																															
LTAMULT_cfc		$\text{EXP}((0.5*\text{LN}(cvd^2/no\_samples+1))-2.326*\text{LN}(cvd^2/no\_samples+1)^0.5)$																															
LTA_cfc		wla_cfc*LTAMULT_cfc																															
AML MULT		$\text{EXP}(2.326*\text{LN}((cvd^2/no\_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no\_samples+1))$																															
AVG MON LIMIT		$\text{MIN}(\text{BAT\_BPJ},\text{MIN}(\text{LTA}_\text{afc},\text{LTA}_\text{cfc})*\text{AML\_MULT})$																															
INST MAX LIMIT		$1.5*((\text{av\_mon\_limit}/\text{AML\_MULT})/\text{LTAMULT}_\text{afc})$																															



**Attachment 2  
Upstream USGS StreamStat**



Pennsylvania  
**Department of**  
Environmental Protection

## StreamStats Report

Region ID: PA

Workspace ID: PA20250224225121957000

Clicked Point (Latitude, Longitude): 40.24090, -79.94719

Time: 2025-02-24 17:51:52 -0500



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	5320	square miles
ELEV	Mean Basin Elevation	1826	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	5320	square miles	2.26	1400
ELEV	Mean Basin Elevation	1826	feet	1050	2580

## Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

## Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	700	ft^3/s
30 Day 2 Year Low Flow	928	ft^3/s
7 Day 10 Year Low Flow	410	ft^3/s
30 Day 10 Year Low Flow	478	ft^3/s
90 Day 10 Year Low Flow	709	ft^3/s

### *Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.**  
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.27.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



**Attachment 3**  
**Downstream USGS StreamStat**

## StreamStats Report

Region ID: PA

Workspace ID: PA20250225151854410000

Clicked Point (Latitude, Longitude): 40.24485, -79.92601

Time: 2025-02-25 10:19:29 -0500



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	5330	square miles
ELEV	Mean Basin Elevation	1826	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	5330	square miles	2.26	1400
ELEV	Mean Basin Elevation	1826	feet	1050	2580

#### Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	702	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	930	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	411	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	479	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	710	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.27.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



## Attachment 4 Summer WQM7 Modeling



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
						(ft)	(sq mi)	(ft/ft)	(mgd)	
19A	37185	MONONGAHELA RIVER			27.800	1826.00	5320.00	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Tributary Temp (°C)	Stream pH (°C)	Temp pH
Q7-10	0.100	550.00	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
	Univar Bunola	PA0216071		0.0030	0.0000	0.0000	0.000	20.00	7.00	
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)		Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5	25.00		2.00	0.00	1.50				
	Dissolved Oxygen	4.00		8.24	0.00	0.00				
	NH3-N	25.00		0.00	0.00	0.70				

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name										
19A	37185	MONONGAHELA RIVER										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)	(fps)	(ft/s)	(days)	(°C)	
<b>Q7-10 Flow</b>												
27.800	550.00	0.00	550.00	.0046	0.00019	1.208	480.61	398.02	0.95	0.064	25.00	7.00
<b>Q1-10 Flow</b>												
27.800	352.00	0.00	352.00	.0046	0.00019	NA	NA	NA	0.74	0.083	25.00	7.00
<b>Q30-10 Flow</b>												
27.800	748.00	0.00	748.00	.0046	0.00019	NA	NA	NA	1.13	0.054	25.00	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19A	37185	MONONGAHELA RIVER

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
27.800	Univar Bunola	11.07	50	11.07	50	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
27.800	Univar Bunola	1.37	25	1.37	25	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
27.80	Univar Bunola	25	25	25	25	4	4	0	0

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
19A	37185	MONONGAHELA RIVER			
<u>RMI</u> 27.800	<u>Total Discharge Flow (mgd)</u> 0.003	<u>Analysis Temperature (°C)</u> 25.000	<u>Analysis pH</u> 7.000		
<u>Reach Width (ft)</u> 480.612	<u>Reach Depth (ft)</u> 1.208	<u>Reach WDRatio</u> 398.022	<u>Reach Velocity (fps)</u> 0.948		
<u>Reach CBOD5 (mg/L)</u> 2.00	<u>Reach Kc (1/days)</u> 0.000	<u>Reach NH3-N (mg/L)</u> 0.00	<u>Reach Kn (1/days)</u> 1.029		
<u>Reach DO (mg/L)</u> 8.243	<u>Reach Kr (1/days)</u> 0.943	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5		
<u>Reach Travel Time (days)</u> 0.064	<u>Subreach Results</u>				
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
	0.006	2.00	0.00	7.54	
	0.013	2.00	0.00	7.54	
	0.019	2.00	0.00	7.54	
	0.026	2.00	0.00	7.54	
	0.032	2.00	0.00	7.54	
	0.039	2.00	0.00	7.54	
	0.045	2.00	0.00	7.54	
	0.052	2.00	0.00	7.54	
	0.058	2.00	0.00	7.54	
	0.064	2.00	0.00	7.54	

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19A	37185	MONONGAHELA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
27.800	Univar Bunola	PA0216071	0.003	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4



## Attachment 5 Winter WQM7 Modeling



### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37185	MONONGAHELA RIVER			27.800	1826.00	5320.00	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.200	550.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Univar Bunola	PA0216071	0.0030	0.0000	0.0000	0.000	15.00	7.00		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	4.00	12.51	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

### WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
19A	37185	MONONGAHELA RIVER										
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio (fps)	Velocity (ft/ft)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
27.800	550.00	0.00	550.00	.0046	0.00019	1.208	480.61	398.02	0.95	0.064	5.00	7.00
<b>Q1-10 Flow</b>												
27.800	352.00	0.00	352.00	.0046	0.00019	NA	NA	NA	0.74	0.083	5.00	7.00
<b>Q30-10 Flow</b>												
27.800	748.00	0.00	748.00	.0046	0.00019	NA	NA	NA	1.13	0.054	5.00	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19A	37185	MONONGAHELA RIVER

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
27.800	Univar Bunola	24.1	50	24.1	50	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
27.800	Univar Bunola	4.36	25	4.36	25	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
27.80	Univar Bunola	25	25	25	25	4	4	0	0

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
19A	37185	MONONGAHELA RIVER			
<u>RMI</u> 27.800	<u>Total Discharge Flow (mgd)</u> 0.003	<u>Analysis Temperature (°C)</u> 5.000	<u>Analysis pH</u> 7.000		
<u>Reach Width (ft)</u> 480.612	<u>Reach Depth (ft)</u> 1.208	<u>Reach WDRatio</u> 398.022	<u>Reach Velocity (fps)</u> 0.948		
<u>Reach CBOD5 (mg/L)</u> 2.00	<u>Reach Kc (1/days)</u> 0.000	<u>Reach NH3-N (mg/L)</u> 0.00	<u>Reach Kn (1/days)</u> 0.221		
<u>Reach DO (mg/L)</u> 12.510	<u>Reach Kr (1/days)</u> 0.587	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5		
<u>Reach Travel Time (days)</u> 0.064	<u>Subreach Results</u>				
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
	0.006	2.00	0.00	11.45	
	0.013	2.00	0.00	11.45	
	0.019	2.00	0.00	11.45	
	0.026	2.00	0.00	11.45	
	0.032	2.00	0.00	11.45	
	0.039	2.00	0.00	11.45	
	0.045	2.00	0.00	11.45	
	0.052	2.00	0.00	11.45	
	0.058	2.00	0.00	11.45	
	0.064	2.00	0.00	11.45	

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
19A	37185	MONONGAHELA RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)
27.800	Univar Bunola	PA0216071	0.003	CBOD5	25
				NH3-N	25
				Dissolved Oxygen	50
					4