

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0216186
APS ID 1012592
Authorization ID 1307584

Applicant and Facility Information

Applicant Name	<u>United Mine Workers Of America Career Centers Inc.</u>	Facility Name	<u>Mining Tech & Training Center STP</u>
Applicant Address	<u>197 Dunn Station Road Prosperity, PA 15329-1625</u>	Facility Address	<u>197 Dunn Station Road Prosperity, PA 15329-1625</u>
Applicant Contact	<u>Clemmy Allen</u>	Facility Contact	<u>Clemmy Allen</u>
Applicant Phone	<u>(724) 627-0988</u>	Facility Phone	<u>(724) 627-0988</u>
Client ID	<u>270920</u>	Site ID	<u>237768</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Washington Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Greene</u>
Date Application Received	<u>March 4, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 1, 2021</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Minor Sewage Treatment Facility Renewal.</u>		

Summary of Review

This application is for a renewal of an NPDES permit, for an existing Minor discharge of treated sewage from a Non-Municipal STP.

Act 14 – Proof of Notification was submitted and received.

There are no open violations for subject client ID (200265) as of 3/25/2021.

There has been no change to the discharge or the receiving stream since the last permit issuance.

A part 2 WQM permit is not required at this time.

Treatment consist of (WQM Permit No. 3081405): The existing treatment process consists of flow EQ, extended aeration, clarification, tertiary filters and chlorination for disinfection. The treated sewage then discharges into Ruff Creek (WWF).

Sludge use and disposal description and location(s): Septage must be pumped and hauled off-site by a septage hauler for land application under a general permit authorized by DEP or disposal at an STP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jon F. Bucha Jonathan F. Bucha / Civil Engineer Trainee	March 24, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	April 7, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.025</u>
Latitude	<u>39° 57' 44"</u>	Longitude	<u>-80° 10' 33"</u>
Quad Name	<u>Waynesburg</u>	Quad Code	<u>1904</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Ruff Creek (WWF)</u>	Stream Code	<u>40345</u>
NHD Com ID	<u>99414406</u>	RMI	<u>8.7</u>
Drainage Area	<u>7.25 mi²</u>	Yield (cfs/mi ²)	<u>0.0017</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.01214</u>	Q ₇₋₁₀ Basis	<u>Storet Sta. No. 03073000, S. Fork Tenmile Creek, Jefferson PA, Period of Record 1933-1988.</u>
Elevation (ft)	<u>989 (Google Earth)</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>19-B</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Tri-County Joint Municipal Authority</u>		
PWS Waters	<u>MONONGAHELA RIVER</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance: River mile index's, elevations, and drainage areas were revised using streamstats and google earth for modeling purposes.

Other Comments: N/A

Treatment Facility Summary				
Treatment Facility Name: Mining Tech & Training Center STP				
WQM Permit No.		Issuance Date		
3081405		12/29/1981		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine	0.004
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.025		Not Overloaded		

Compliance History	
Summary of DMRs:	Review of the past 3 years of DMR reports indicates one effluent violation for Average Monthly TRC. No other effluent violations were indicated on the DMRs.
Summary of Inspections:	An inspection occurred on 7/22/2020, where no violations were noted and the plant is being properly maintained.

Compliance History

DMR Data for Outfall 001 (from February 1, 2020 to January 31, 2021)

Parameter	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20
Flow (MGD) Average Monthly	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.002
pH (S.U.) Minimum	6.6	6.6	6.8	6.5	6.6	6.8	6.5	6.8	6.6	6.6	6.8	6.8
pH (S.U.) Maximum	7.4	7.5	7.5	7.4	7.4	7.6	7.4	7.3	7.4	7.7	7.6	7.5
DO (mg/L) Minimum	7.8	7.6	7.6	7.6	7.6	7.6	7.4	7.4	6.7	6.5	6.7	6.7
TRC (mg/L) Average Monthly	0.05	0.04	0.04	0.04	0.05	0.04	0.04	0.04	0.05	0.04	0.05	0.05
TRC (mg/L) Instantaneous Maximum	0.07	0.08	0.08	0.09	0.09	0.09	0.09	0.08	0.09	0.09	0.09	0.09
CBOD5 (mg/L) Average Monthly	2.7	< 2.0	4.2	2.3	< 2.0	< 2.0	2.1	2.0	< 2.0	< 2.0	< 2.0	< 2.0
CBOD5 (mg/L) Instantaneous Maximum	3.5	< 2.0	6.4	2.6	< 2.0	< 2.0	2.1	2.1	< 2.0	< 2.0	< 2.0	< 2.0
TSS (mg/L) Average Monthly	11.5	10	10	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	5.5	8.5	17.5	< 5.0
TSS (mg/L) Instantaneous Maximum	18.0	15	15	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	6.0	12	25.0	< 5.0
Fecal Coliform (CFU/100 ml) Geometric Mean	2.4	72.1	< 1	1.4	12.9	73.4	< 1	2.0	< 1	< 2.0	8.4	< 1.0
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	6.0	193	< 1	2.0	84	> 200	< 1	4.0	< 2	< 2.0	72	< 1.0
Total Nitrogen (mg/L) Daily Maximum		35.5										
Ammonia (mg/L) Average Monthly	0.9	0.09	0.2	0.9	0.2	0.5	0.5	0.7	1.0	0.3	0.3	1.1
Ammonia (mg/L) Instantaneous Maximum	1.4	0.09	0.3	1.3	0.2	0.8	0.5	0.9	1.2	0.3	0.3	1.4
Total Phosphorus (mg/L) Daily Maximum		5.9										

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.025</u>
Latitude <u>39° 57' 44.00"</u>	Longitude <u>-80° 10' 33.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (May 1 – October 31)	2.0	Average Monthly	WQM 7.0
Ammonia Nitrogen (November 1 – April 30)	6.0	Average Monthly	WQM7.0
Dissolved Oxygen	4.0	Average Monthly	WQM 7.0
Total Residual Chlorine	0.07	Average Monthly	TRC_CALC

Comments: The winter seasonal ammonia nitrogen limit of 6.0 mg/L is based upon 3 times the summer seasonal limit, which is based upon the Department's Implementation Guidance of Section 93.7 Ammonia Criteria. Dissolved Oxygen modeling results show that the present limits of 5 mg/L are more stringent than the Water Quality-Based Limitations required to protect water quality. Upon review of past eDMR data demonstrating the treatment facilities ability to meet the current Dissolved Oxygen limit of 5 mg/L, It is recommended that the current limit of 5 mg/L for Dissolved Oxygen be re-imposed to help protect the stream.

Best Professional Judgment (BPJ) Limitations

Comments: Total Nitrogen, Total Phosphorus, and Flow monitoring is based on Ch. 92a.61 and the Departments SOP for Establishing Effluent Limitations for Individual Sewage Permits (SOP No. BPNPSM-PMT-033). Total Nitrogen and Total Phosphorus monitoring will remain at the 1/year sampling frequency on the current permit renewal. However, the Total Nitrogen and Total Phosphorus monitoring will be changed to an "annual average" reporting rather than a "daily maximum" reporting based on the Department's SOP for Establishing Effluent Limitations for Individual Sewage Permits. Monitoring for flow has been increased to 1/week

Additional Considerations

E. Coli monitoring of 1/year has been added based on Ch. 92a.61(11)(12).

Anti-Backsliding

The WQBEL calculation using WQM 7.0, resulting effluent limit for CBOD5 did not require a more stringent limit than the Technology-Based Limitation of 25 mg/L Average Monthly. However, backsliding is not appropriate in this case and the existing effluent limitation of 20 mg/L will remain in the current renewal. The permittee is able to consistently meet this limitation. There is no WLA or TMDL to consider for the receiving stream.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.055	XXX	0.179	1/day	Grab
CBOD5 (May through October)	XXX	XXX	XXX	20.0	XXX	40.0	2/month	Grab
CBOD5 (November through April)	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Annual Avg	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.0	XXX	12.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Annual Avg	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment)
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits (SOP No. BPNPSM-PMT-033) dated November 9, 2012, Revised August 23, 2013).


ATTACHMENT A

eMAP – Stream Designation



ATTACHMENT B


StreamStats REPORT – RMI 8.7 ON Ruff Creek



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	7.25	square miles
ELEV	Mean Basin Elevation	1239	feet

ATTACHMENT C

StreamStats REPORT – RMI 8.3 ON Ruff Creek



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	7.4	square miles
ELEV	Mean Basin Elevation	1236	feet

Permit No. PA0216186

ATTACHMENT D WQM 7.0 MODEL OUTPUT FILE

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19B	40345	RUFF CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
8.700	United Mine	PA0216186	0.025	CBOD5	25		
				NH3-N	2.42	4.84	
				Dissolved Oxygen			4

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
19B	40345	RUFF CREEK			
RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)		Analysis pH	
8.700	0.025	21.208		7.000	
Reach Width (ft)	Reach Depth (ft)	Reach WDRatio		Reach Velocity (fps)	
6.030	0.334	18.059		0.025	
Reach CBOD5 (mg/L)	Reach Kc (1/days)	Reach NH3-N (mg/L)		Reach Kn (1/days)	
19.44	1.416	1.86		0.768	
Reach DO (mg/L)	Reach Kr (1/days)	Kr Equation		Reach DO Goal (mg/L)	
5.025	14.475	Owens		5	
Reach Travel Time (days)	Subreach Results				
0.965	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
	0.097	16.83	1.73	5.58	
	0.193	14.56	1.60	6.02	
	0.290	12.61	1.49	6.39	
	0.386	10.91	1.38	6.72	
	0.483	9.44	1.28	6.99	
	0.579	8.17	1.19	7.24	
	0.676	7.08	1.11	7.45	
	0.772	6.12	1.03	7.63	
	0.869	5.30	0.95	7.80	
	0.965	4.59	0.89	7.94	

Permit No. PA0216186

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19B	40345	RUFF CREEK	8.700	989.00	7.25	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.002	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
United Mine	PA0216186	0.0250	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Permit No. PA0216186

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19B	40345	RUFF CREEK	8.300	980.00	7.40	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.002	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Permit No. PA0216186

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19B		40345				RUFF CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
8.700	0.01	0.00	0.01	.0387	0.00426	.334	6.03	18.06	0.03	0.965	21.21	7.00
Q1-10 Flow												
8.700	0.01	0.00	0.01	.0387	0.00426	NA	NA	NA	0.02	1.016	20.85	7.00
Q30-10 Flow												
8.700	0.02	0.00	0.02	.0387	0.00426	NA	NA	NA	0.03	0.921	21.51	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Permit No. PA0216186

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19B	40345	RUFF CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.700	United Mine	9.1	10.93	9.1	10.93	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
8.700	United Mine	1.72	2.42	1.72	2.42	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
8.70	United Mine	25	25	2.42	2.42	4	4	0	0

ATTACHMENT C TRC SPREADSHEET

	A	B	C	D	E	F	G
1	TRC EVALUATION						
2	Input appropriate values in A3:A9 and D3:D9						
3	0.01214	= Q stream (cfs)		0.5	= CV Daily		
4	0.025	= Q discharge (MGD)		0.5	= CV Hourly		
5	4	= no. samples		1	= AFC_Partial Mix Factor		
6	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor		
7	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)		
8	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)		
9	0	= % Factor of Safety (FOS)			=Decay Coefficient (K)		
10	Source	Reference	AFC Calculations		Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 0.119		1.3.2.iii	WLA_cfc = 0.109	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 0.044		5.1d	LTA_cfc = 0.063	
14							
15	Source		Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.720				
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.076		AFC		
18			INST MAX LIMIT (mg/l) = 0.179				
19							
20			$\text{WLA_afc} = \left(\frac{0.019}{e^{-k \cdot \text{AFC_tc}}} \right) + \left[\left(\frac{\text{AFC_Yc} \cdot \text{Qs} \cdot 0.019}{\text{Qd} \cdot e^{-k \cdot \text{AFC_tc}}} \right) \dots \right. \\ \left. \dots + \text{Xd} + \left(\frac{\text{AFC_Yc} \cdot \text{Qs} \cdot \text{Xs}}{\text{Qd}} \right) \right] \cdot (1 - \text{FOS}/100)$ $\text{LTAMULT_afc} = \text{EXP}((0.5 \cdot \text{LN}(\text{cvh}^2 + 1)) - 2.326 \cdot \text{LN}(\text{cvh}^2 + 1)^{0.5})$ $\text{LTA_afc} = \text{wla_afc} \cdot \text{LTAMULT_afc}$ $\text{WLA_cfc} = \left(\frac{0.011}{e^{-k \cdot \text{CFC_tc}}} \right) + \left[\left(\frac{\text{CFC_Yc} \cdot \text{Qs} \cdot 0.011}{\text{Qd} \cdot e^{-k \cdot \text{CFC_tc}}} \right) \dots \right. \\ \left. \dots + \text{Xd} + \left(\frac{\text{CFC_Yc} \cdot \text{Qs} \cdot \text{Xs}}{\text{Qd}} \right) \right] \cdot (1 - \text{FOS}/100)$ $\text{LTAMULT_cfc} = \text{EXP}((0.5 \cdot \text{LN}(\text{cvd}^2 / \text{no_samples} + 1)) - 2.326 \cdot \text{LN}(\text{cvd}^2 / \text{no_samples} + 1)^{0.5})$ $\text{LTA_cfc} = \text{wla_cfc} \cdot \text{LTAMULT_cfc}$ $\text{AML_MULT} = \text{EXP}(2.326 \cdot \text{LN}((\text{cvd}^2 / \text{no_samples} + 1)^{0.5}) - 0.5 \cdot \text{LN}(\text{cvd}^2 / \text{no_samples} + 1))$ $\text{AVG MON LIMIT} = \text{MIN}(\text{BAT_BPJ}, \text{MIN}(\text{LTA_afc}, \text{LTA_cfc}) \cdot \text{AML_MULT})$ $\text{INST MAX LIMIT} = 1.5 \cdot ((\text{av_mon_limit} / \text{AML_MULT}) / \text{LTAMULT_afc})$				
21							
22	WLA_afc						
23							
24	LTAMULT_afc						
25	LTA_afc						
26							
27	WLA_cfc						
28							
29	LTAMULT_cfc						
30	LTA_cfc						
31							
32	AML_MULT						
33	AVG MON LIMIT						
34	INST MAX LIMIT						
35							
36							
37							
38							
39							
40							
41	$\left(\frac{0.011}{\text{EXP}(-K \cdot \text{CFC_tc} / 1440)} \right) + \left(\left(\frac{\text{CFC_Yc} \cdot \text{Qs} \cdot 0.011}{1.547 \cdot \text{Qd}} \right) \dots \right.$						
42	$\dots \cdot \text{EXP}(-K \cdot \text{CFC_tc} / 1440) \left. \right) + \text{Xd} + \left(\frac{\text{CFC_Yc} \cdot \text{Qs} \cdot \text{Xs}}{1.547 \cdot \text{Qd}} \right) \cdot (1 - \text{FOS}/100)$						