

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**


Application No. PA0216381
 APS ID 1104015
 Authorization ID 1467810

Applicant and Facility Information

Applicant Name	<u>MDDA LLC</u>	Facility Name	<u>Holly Hill STP</u>
Applicant Address	<u>114 Snyder Drive</u> <u>Rochester, PA 15074-2706</u>	Facility Address	<u>200 Freedom Road</u> <u>Freedom, PA 15042</u>
Applicant Contact	<u>Robert Anzio</u>	Facility Contact	<u>Robert Anzio</u>
Applicant Phone	<u>(724) 630-9762</u>	Facility Phone	<u>(878) 207-2582</u>
Client ID	<u>381910</u>	Site ID	<u>240103</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>New Sewickley Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Beaver</u>
Date Application Received	<u>January 2, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 22, 2024</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an existing NPDES permit for the discharge of treated sewage.</u>		

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Derek S. Garner / Project Manager	March 20, 2024
X		<i>Mahbuba Iasmin</i> Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineer Manager	March 21, 2024

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0178</u>
Latitude	<u>40° 40' 48.00"</u>	Longitude	<u>-80° 12' 39.00"</u>
Quad Name	<u>Baden</u>	Quad Code	<u>1304</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>UNT of Crows Run</u>	Stream Code	<u>36558-U</u>
NHD Com ID	<u>99678786</u>	RMI	<u>3.15 ⁽¹⁾</u>
Drainage Area	<u>n/a</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>2013 WQPR</u>
Elevation (ft)	<u>897</u>	Slope (ft/ft)	<u>n/a</u>
Watershed No.	<u>20-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>n/a</u>	Existing Use Qualifier	<u>n/a</u>
Exceptions to Use	<u>n/a</u>	Exceptions to Criteria	<u>n/a</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>n/a</u>		
Source(s) of Impairment	<u>n/a</u>		
TMDL Status	<u>n/a</u>	Name	<u>n/a</u>

(1) Point of first use on Crows Run

Treatment Facility Summary

The Holly Hill Sewage Treatment Plant is a stabilization lagoon system constructed and operated under WQM Permit No. 0471418, issued October 29, 1971. The existing treatment process consists of one (1) primary and one (1) secondary clay-lined stabilization lagoon and one (1) chlorine contact tank. Hypochlorite is used for disinfection.

The STP's annual average design flow is 0.009 MGD and the hydraulic design capacity is 0.0178 MGD. The organic design capacity is estimated at 40 lbs BOD / day.

DEP is unaware of any substantive changes since the previous renewal.

Compliance History

The facility was most recently inspected by DEP on August 19, 2021. The associated inspection report indicated that the lagoons appeared to be in good operating condition with adequate freeboard space and minimal duck weed growth. No violations were noted at the time of the inspection.

There violations were identified during the existing permit's term.

There are no open violations associated with the permittee.

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.009
 Latitude 40° 40' 48.00" Longitude -80° 12' 39.00"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

The above limitations are consistent with the existing NPDES permit.

Water Quality-Based Limitations

The receiving UNT of Crows Run is a dry drainage way. Historically, where the unnamed tributary meets Crows Run has been designated as the point of first use for modeling purposes.

The attached WQM 7 v1.1 modeling output indicates that the existing water-quality based limits are protective. Accordingly, DEP recommends that the existing WQBELs for ammonia-n of 20 mg/l average monthly and 40 mg/l instantaneous maximum and the 2/month monitoring requirements remain in the permit.

The attached TRC_CALC spreadsheet indicates the existing technology-based limits are protective.

Best Professional Judgment (BPJ) Limitations

DEP recommends the following:

- Existing minimum dissolved oxygen limit of 3.0 mg/l should remain in the permit to protect the receiving surface water.
- Existing annual monitoring for total nitrogen and total phosphorus should remain in the permit per 25 PA § 92a.61(c).
- Annual E. Coli reporting requirements are proposed per the 2017 Triennial Review of Water Quality Standards, published in the PA Bulletin on July 11, 2020.

Additional Considerations

Mass loading limits and influent monitoring are not applicable for non-publicly owned treatment works.

Anti-Backsliding

No limits or monitoring requirements are proposed to be made less stringent.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.0178	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	3.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	20.0	XXX	40.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	36558	CROWS RUN	3.150	853.00	7.53	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.033	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Holly Hill STP	PA0216381	0.0090	0.0090	0.0090	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	36558	CROWS RUN	2.150	776.00	11.70	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.033	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20G		36558				CROWS RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
3.150	0.25	0.00	0.25	.0139	0.01458	.423	8.92	21.1	0.07	0.878	24.73	7.00
Q1-10 Flow												
3.150	0.21	0.00	0.21	.0139	0.01458	NA	NA	NA	0.06	0.962	24.69	7.00
Q30-10 Flow												
3.150	0.34	0.00	0.34	.0139	0.01458	NA	NA	NA	0.08	0.745	24.80	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.84	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20G	36558	CROWS RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.150	Holly Hill STP	11.36	50	11.36	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.150	Holly Hill STP	1.38	25	1.38	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.15	Holly Hill STP	25	25	25	25	3	3	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20G	36558	CROWS RUN		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
3.150	0.009	24.735		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
8.917	0.423	21.096		0.070
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
3.22	0.369	1.33		1.008
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
7.965	20.031	Owens		5
<u>Reach Travel Time (days)</u>	Subreach Results			
0.878	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.088	3.09	1.21	7.57
	0.176	2.97	1.11	7.57
	0.263	2.85	1.02	7.57
	0.351	2.74	0.93	7.57
	0.439	2.63	0.85	7.57
	0.527	2.53	0.78	7.57
	0.614	2.43	0.71	7.57
	0.702	2.33	0.65	7.57
	0.790	2.24	0.60	7.57
	0.878	2.15	0.55	7.57

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20G		36558		CROWS RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.150	Holly Hill STP	PA0216381	0.009	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

1A	B	C	D	E	F	G
2	TRC EVALUATION					
3	Input appropriate values in B4:B8 and E4:E7					
4	0.25	= Q stream (cfs)		0.5	= CV Daily	
5	0.009	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	=Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA afc = 5.747	1.3.2.iii	WLA cfc = 5.595	
12	PENTOXSD TRG	5.1a	LTAMULT afc = 0.373	5.1c	LTAMULT cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc= 2.141	5.1d	LTA_cfc = 3.253	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ		
18			INST MAX LIMIT (mg/l) = 1.635			
	WLA afc	(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
	LTAMULT afc	EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)				
	LTA_afc	wla_afc*LTAMULT_afc				
	WLA_cfc	(.011/e(-k*CFC_tc) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
	LTAMULT_cfc	EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)				
	LTA_cfc	wla_cfc*LTAMULT_cfc				
	AML MULT	EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))				
	AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
	INST MAX LIMIT	1.5*(av_mon_limit/AML_MULT)/LTAMULT_afc				