



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. **PA0216984**
APS ID **1146423**
Authorization ID **1542427**

Applicant and Facility Information

Applicant Name	Shannock Valley Gen Service Authority	Facility Name	Numine WWTP
Applicant Address	111 South Center Street	Facility Address	111 South Center Street
	Numine, PA 16244-0168		Numine, PA 16244
Applicant Contact	Lee Calarie	Facility Contact	Lee Calarie
Applicant Phone	(724) 873-2454	Facility Phone	(724) 873-2454
Client ID	45258	Site ID	238113
Ch 94 Load Status		Municipality	Cowanshannock Township
Connection Status		County	Armstrong
Date Application Received	September 16, 2025	EPA Waived?	Yes
Date Application Accepted		If No, Reason	--
Purpose of Application	Renewal Application for Minor Sewage Facility		

Summary of Review

On September 16, 2025, the Department received a renewal application for Individual Permit No. PA0216984 for Numine Wastewater Treatment Plant. The WWTP serves the Cowanshannock Township which has a population of 2,742. There is one outfall (Outfall 001) that discharges to Cowanshannock Creek (WWF).

Act 14 notifications were submitted and received.

The facility is currently enrolled in the eDMR system.

Sludge use and disposal description and location(s): Sludge from the Yatesboro STP is accepted at this facility. The sludge is managed under beneficial use permits for disposal at the Homer City Waste Management Site and the Carbon Limestone Landfill. All sludge not used is disposed of at an approved landfill.

There are no open violations in WMS for the subject Client ID (45258) as of October 29, 2025.

Proposed Changes:

- None

Approve	Deny	Signatures	Date
X		Carlee Wilson Carlee Wilson / Environmental Engineering Trainee	October 31, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	November 12, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.065
Latitude	40° 47' 36.02"	Longitude	-79° 16' 55.01"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Cowanshannock Creek (WWF)	Stream Code	46965
NHD Com ID	134403962	RMI	18.52
Drainage Area	16.1	Yield (cfs/mi ²)	0.042
Q ₇₋₁₀ Flow (cfs)	0.679	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1119	Slope (ft/ft)	-
Watershed No.	17-E	Chapter 93 Class.	WWF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	Name -		
Background/Ambient Data		Data Source	
pH (SU)	7.0	default	
Temperature (°F)	68	default	
Hardness (mg/L)	100	default	
Other:	-	-	
Nearest Downstream Public Water Supply Intake	PA American Water Company		
PWS Waters	Allegheny River	Flow at Intake (cfs)	987
PWS RMI	45.6	Distance from Outfall (mi)	22.0

Changes Since Last Permit Issuance: None

Other Comments:

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Treatment Facility Summary				
Treatment Facility Name: Numine WWTP				
WQM Permit No.		Issuance Date		
0399402 A-1		8/09/2001		
0399402		9/20/1999		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Ultraviolet (UV)	0.030
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.065	108	Not Overloaded	Aerated Holding Tank	Landfill

Changes Since Last Permit Issuance: None

WQM 0399402

An equalization tank, two clarification tanks, and Ultraviolet (UV) light disinfection. Sludge is stored in an aerated holding tank.

SHANNOCK VALLEY
GENERAL SERVICES AUTHORITY
ARMSTRONG COUNTY, PENNSYLVANIA

NUMINE
WASTEWATER TREATMENT FACILITY
NPDES PERMIT APPLICATION
LINE DRAWING

BE BIMSON ENGINEERS, INC. DRAWN BY: D.P. APPROVED BY: J.W. DATE: JUNE 1999 SHEET 2 OF 2
CONTRACTING ENGINEERS, INC. 1000 BIMSON DRIVE, BIRMINGHAM, AL 35243-5000

Compliance History

DMR Data for Outfall 001 (from September 1, 2024, to August 31, 2025)

Parameter	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24
Flow (MGD) Average Monthly	0.015	0.012	0.015	0.019	0.020	0.025	0.024	0.009	0.011	0.014	0.009	0.009
Flow (MGD) Daily Maximum	0.022	0.022	0.026	0.026	0.029	0.029	0.026	0.024	0.025	0.022	0.023	0.019
pH (S.U.) Instantaneous Minimum	6.9	7.0	7.1	7.1	7.1	7.0	7.0	7.0	7.0	7.0	7.0	7.0
pH (S.U.) Instantaneous Maximum	7.9	7.7	7.9	7.8	7.8	7.9	7.7	7.8	7.8	7.8	7.9	7.6
DO (mg/L) Instantaneous Minimum	5.0	5.0	5.1	5.6	5.4	5.1	5.1	5.5	5.2	5.1	5.1	5.1
CBOD5 (lbs/day) Average Monthly	3.75	0.300	0.37	0.258	0.500	0.6255	0.60	0.24	0.60	0.035	3.0	0.23
CBOD5 (mg/L) Average Monthly	3.005	3.0	3.0	3.68	3.0	3.0	3.0	3.15	6.6	3.0	4.5	3.0
CBOD5 (mg/L) Instantaneous Maximum	3.01	3.0	3.0	4.36	3.0	3.0	3.0	3.30	8.67	3.0	5.97	3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	43	26.6	15.8	21	33	56.6	41	8.8	29.1	26	22.9	17.3
BOD5 (mg/L) Raw Sewage Influent Average Monthly	342	266	126.75	129.5	198.8	271.5	206	117.5	312.5	224.5	306	230.5
BOD5 (mg/L) Raw Sewage Influent Instantaneous Maximum	410	401	182	192	335	330	278	134	414	231	440	247
TSS (lbs/day) Average Monthly	0.43	0.280	2.0	0.98	1.6	1.17	1.8	0.54	0.60	0.46	0.33	0.49
TSS (lbs/day) Raw Sewage Influent Average Monthly	28.9	34.7	18.5	44	39	43.8	41	15.0	22	27	32.5	15

NPDES Permit Fact Sheet
Numine WWTP

NPDES Permit No. PA0216984

TSS (mg/L) Average Monthly	3.4	2.8	16.1	6.2	9.80	5.6	9.20	7.2	6.6	4.0	4.5	6.6
TSS (mg/L) Raw Sewage Influent Average Monthly	231.5	347.52	148	278	235	210.5	206	201	241	230	434	199
TSS (mg/L) Instantaneous Maximum	5.20	3.60	23.0	8.0	10.0	7.20	10.8	8.40	6.80	6.40	5.97	7.20
TSS (mg/L) Raw Sewage Influent Instantaneous Maximum	312	415	176	316	342	245	278	288	258	234	630	274
Fecal Coliform (No./100 ml) Geometric Mean	926	220	3022	15	184	645	47	70	337.7	54	53	10.2
Fecal Coliform (No./100 ml) Instantaneous Maximum	3076.0	2420	9678.4	29.6	580.0	995.6	586.4	121.0	2190.0	344.8	96.0	10.4
E. Coli (No./100 ml) Instantaneous Maximum			509.4			1102.0			1376.4			432.4
UV Transmittance (%) Average Monthly	10.9	10.2	10.9	11.0	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.2
UV Transmittance (%) Instantaneous Maximum	11.5	11.1	11.1	11.1	11.0	11.8	11.0	11.0	11.0	10.9	10.9	10.4
Total Nitrogen (mg/L) Instantaneous Maximum			9.042			0.5000			0.5000			0.5000
Ammonia (lbs/day) Average Monthly	0.307	0.1413	0.0125	0.0831	0.0166	0.0471	0.02001 6	0.007	0.0091	0.01	0.08	0.008
Ammonia (mg/L) Average Monthly	2.4569	1.412	0.1000	0.5248	0.1000	0.226	0.1000	0.1000	0.1000	0.1000	1.09	0.1000
Ammonia (mg/L) Instantaneous Maximum	4.777	2.305	0.1000	0.8356	0.1000	0.1260	0.1000	0.1000	0.1000	0.1000	2.1	0.1000
Total Phosphorus (mg/L) Instantaneous Maximum			2.65			2.96			3.66			4.56

Compliance History

Effluent Violations for Outfall 001, from: October 1, 2024, To: August 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	06/30/25	Geo Mean	3022	No./100 ml	200	No./100 ml
Fecal Coliform	07/31/25	Geo Mean	220	No./100 ml	200	No./100 ml
Fecal Coliform	08/31/25	Geo Mean	926	No./100 ml	200	No./100 ml
Fecal Coliform	08/31/25	IMAX	3076.0	No./100 ml	1000	No./100 ml
Fecal Coliform	06/30/25	IMAX	9678.4	No./100 ml	1000	No./100 ml
Fecal Coliform	07/31/25	IMAX	2420	No./100 ml	1000	No./100 ml

Summary of Inspections:

Table 1. Inspection Summary of the Last 5 Years

Site Name	Inspected Date	Inspection Type	Inspection Result	Inspector	No. of Violations
NUMINE WWTP	09/22/2025	Compliance Evaluation	No Violations Noted	TOLLINI, BRIAN	0

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 47' 36.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .065
Longitude -79° 16' 55.00"

1. Technology-Based Limitations

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Phosphorous	Report	Average Quarterly	-	92a.61
Total Nitrogen	Report	Average Quarterly	-	92a.61
E. Coli	Report	IMAX	-	92a.61

The above limits are minimum technology-based and BPJ standards for individual sewage permits which are found in the Department's "Establishing Effluent Limitations for Individual Sewage Permits" document (SOP. No. BCW-PMT-033). The limits for pH are technology-based on Chapter 93.7. The limits for Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus are based on Chapter 92a.61.

2. Water Quality-Based Limitations

Table 1. WQM 7 Results

Parameter	Limit (mg/l)	SBC
CBOD5	25	Average Monthly
NH3-N	18.62	Average Monthly
	37.24	IMAX
DO	4	Instantaneous Minimum

The Department's Toxics Management Spreadsheet was not used for this case since no sampling other than sewage-related parameters was performed for this facility with the renewal application. The above parameters were evaluated using water quality modeling (Attachment 5). This model (WQM 7) is used to determine and/or establish WQBELs to protect water quality. In this evaluation, the model provided the above limits for CBOD5, Ammonia-Nitrogen and Dissolved Oxygen. The existing permit limits (Table 2) are equal to or more stringent than the limits above, therefore the current limitations will remain.

Since Ultraviolet (UV) disinfection is used, Total Residual Chlorine (TRC) limits are not imposed. UV transmittance (%) will be retained into this renewal.

3. Anti-Backsliding

Table 2. Existing Permit Limitations for Outfall 001

Parameter	Effluent Limitations					
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)			
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX
CBOD5	13.6	XXX	XXX	25.0	XXX	50.0
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report
TSS	16.3	XXX	XXX	30.0	XXX	60.0
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report
UV Transmittance (%)	XXX	XXX	XXX	Report	XXX	Report
Total Nitrogen	XXX	XXX	XXX	XXX	XXX	Report
Ammonia Nov 1 - Apr 30	13.6	XXX	XXX	25.0	XXX	50.0
Ammonia May 1 - Oct 31	5.4	XXX	XXX	10.0	XXX	20.0
Total Phosphorus	XXX	XXX	XXX	XXX	XXX	Report

Comments: There are no proposed changes to the limitations in the current permit. All permit limitations, monitoring, requirements, and conditions will be retained into the next permit.

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	13.6	XXX	XXX	25.0	XXX	50.0	2/month	Grab
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report	2/month	Grab
TSS	16.3	XXX	XXX	30.0	XXX	60.0	2/month	Grab
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX Geo Mean	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX Geo Mean	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	XXX	Report	XXX	Report	1/day	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia Nov 1 - Apr 30	13.6	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Ammonia May 1 - Oct 31	5.4	XXX	XXX	10.0	XXX	20.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Compliance Sampling Location: Outfall 001 – after disinfection

Attachment 1
eMapPA – Receiving Stream Details



Attachment 2
Google Earth – Aerial Site View



Attachment 3
USGS StreamStats – Point of First Use (RMI 18.52)

StreamStats Report

Region ID:

PA

Workspace ID:


PA20251030123258772000

Clicked Point (Latitude, Longitude):

40.79295, -79.28322

Time:

2025-10-30 08:33:22 -0400



► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	16.1	square miles	2.33	1720
ELEV	Mean Basin Elevation	1329	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.52	ft ³ /s	43	43
30 Day 2 Year Low Flow	2.18	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.679	ft ³ /s	54	54
30 Day 10 Year Low Flow	0.963	ft ³ /s	49	49
90 Day 10 Year Low Flow	1.41	ft ³ /s	41	41

Low-Flow Statistics Citations


[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

Attachment 4
USGS StreamStats – Endpoint (RMI 17.2)

StreamStats Report

Region ID:
Workspace ID:
Clicked Point (Latitude, Longitude):
Time:

PA
PA20251030123827201000
40.79406, -79.30228
2025-10-30 08:38:50 -0400



➤ **Low-Flow Statistics**

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	17.4	square miles	2.33	1720
ELEV	Mean Basin Elevation	1320	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.63	ft ³ /s	43	43
30 Day 2 Year Low Flow	2.34	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.734	ft ³ /s	54	54
30 Day 10 Year Low Flow	1.04	ft ³ /s	49	49
90 Day 10 Year Low Flow	1.53	ft ³ /s	41	41

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

Attachment 5
Water Quality Modeling (WQM 7)

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
17E		46965	COWANSHANNOCK CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
18.520	Numine WWTP	PA0216984	0.065	CBOD5	25		
				NH3-N	18.62	37.24	
				Dissolved Oxygen			4

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46965	COWANSHANNOCK CREEK	18.520	1119.00	16.10	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	Stream Data									
	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH
Q7-10	0.042	0.00	0.68	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Numine WWTP	PA0216984	0.0650	0.0650	0.0650	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

Design Cond.	LFY (cfs/m)	Trib Flow (cfs)	Stream Flow (cfs)	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
				Rch Trav Time (days)	Rch Velocity (fps)						
Q7-10	0.042	0.00	0.73	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
				Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
						0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data											
				Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
				CBOD5		25.00	2.00	0.00	1.50		
				Dissolved Oxygen		3.00	8.24	0.00	0.00		
				NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
		17E		46965		COWANSHANNOCK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
18.520	0.68	0.00	0.68	.1006	0.00201	.519	16.35	31.51	0.09	0.877	20.64	7.00
Q1-10 Flow												
18.520	0.43	0.00	0.43	.1006	0.00201	NA	NA	NA	0.07	1.083	20.94	7.00
Q30-10 Flow												
18.520	0.92	0.00	0.92	.1006	0.00201	NA	NA	NA	0.11	0.753	20.49	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17E	46965	COWANSHANNOCK CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
18.520	Numine WWTP	15.5	50	15.5	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
18.520	Numine WWTP	1.83	18.62	1.83	18.62	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
18.52	Numine WWTP	25	25	18.62	18.62	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17E	46965	COWANSHANNOCK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
18.520	0.065	20.645	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
16.345	0.519	31.507	0.092	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
4.97	0.728	2.40	0.736	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.696	14.994	Owens	5	
<u>Reach Travel Time (days)</u>		Subreach Results		
0.877	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.088	4.65	2.25	8.05
	0.175	4.35	2.11	8.14
	0.263	4.08	1.98	8.14
	0.351	3.82	1.86	8.14
	0.439	3.58	1.74	8.14
	0.526	3.35	1.63	8.14
	0.614	3.13	1.53	8.14
	0.702	2.93	1.43	8.14
	0.790	2.75	1.34	8.14
	0.877	2.57	1.26	8.14

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]