

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0216992
 APS ID 1038225
 Authorization ID 1353733

Applicant and Facility Information

Applicant Name	<u>Shannock Valley General Services Authority</u>	Facility Name	<u>Yatesboro STP</u>
Applicant Address	<u>11 South Center Street</u> <u>NuMine, PA 16244</u>	Facility Address	<u>Off of Route 85</u> <u>Yatesboro, PA 16263</u>
Applicant Contact	<u>Lee Calarie</u>	Facility Contact	<u>Lee Calarie</u>
Applicant Phone	<u>(724) 783-2454</u>	Facility Phone	<u>(724) 783-2454</u>
Client ID	<u>45258</u>	Site ID	<u>241588</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Cowanshannock Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Armstrong County</u>
Date Application Received	<u>April 23, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 11, 2021</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an existing NPDES Permit for an existing discharge of treated sanitary wastewater from a municipal sewer system.</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in effects associated with the subject Client ID (45258) as of 2/22/2022.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	2/22/2022
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	2/28/2022

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.22</u>
Latitude	<u>40° 48' 2.87"</u>	Longitude	<u>-79° 21' 2.10"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Cowanshannock Creek (WWF)</u>	Stream Code	<u>46965</u>
NHD Com ID	<u>123853922</u>	RMI	<u>13.6</u>
Drainage Area	<u>26.3</u>	Yield (cfs/mi ²)	<u>0.02</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.526</u>	Q ₇₋₁₀ Basis	<u>calculated</u>
Elevation (ft)	<u>1082</u>	Slope (ft/ft)	<u>0.003479</u>
Watershed No.	<u>17-E</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data			
		Data Source	
pH (SU)	<u>-</u>	<u>-</u>	
Temperature (°F)	<u>-</u>	<u>-</u>	
Hardness (mg/L)	<u>-</u>	<u>-</u>	
Other:	<u>-</u>	<u>-</u>	
Nearest Downstream Public Water Supply Intake	<u>PA American Water Company - Kittanning District</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>987</u>
PWS RMI	<u>45.6</u>	Distance from Outfall (mi)	<u>14.0</u>

Sludge use and disposal description and location(s): Sludge is hauled by J&D Septic to the NuMine WWTP, where it ends up at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.22 MGD of treated sewage from an existing Publicly Owned Treatment Works (POTW) in Cowanshannock Township, Armstrong County.

Permitted treatment consists of: (WQM Permit no. 0399403) A 49,667 gallon equalization tank, a 222,733 gallon extended aeration tank, a 44,766 gallon clarifier, ultraviolet (UV) light disinfection, and a 3,544 gallon post aeration tank. Sludge is handled through an 80,019 gallon holding tank.

1. Streamflow:

Crooked Creek at Crooked Creek Dam near Ford City, PA - USGS Gage no. 03039000 (1941-1991):

Q7-10: 6.6 cfs from StreamStats
Drainage Area: 278 sq. mi. from StreamStats
Yieldrate: 0.023 cfsm calculated

Cowanshannock Creek at Outfall 001:

Yieldrate: 0.023 cfsm calculated above
Drainage Area: 0.0455 sq. mi. from StreamStats
% of stream allocated: 100% Basis: No nearby discharges
Q7-10: 0.455 cfs

2. Wasteflow: Outfall 001:

Maximum discharge: 0.22 MGD = 0.34 cfs

Runoff flow period: 24 hours Basis: Runoff flow for a Municipal STP

There is less than 3 parts stream flow (Q7-10) to 1 part effluent (design flow) at the discharge point. However, since this is an existing discharge, the more stringent treatment requirements cannot be achieved, and the receiving stream is not impaired by the discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, will not be implemented in this NPDES Permit renewal.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, Phosphorus, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine. NH₃-N, CBOD₅, and Dissolved Oxygen were evaluated using WQM 7.0 at the discharge point.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 mg/l as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/quarter.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.05 MGD and less than 1.0 MGD.

e. Total Phosphorus

Limit not necessary

Basis: The previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

Limit necessary due to:

Discharge to lake, pond, or impoundment

Discharge to stream

Basis N/A

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.1 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value.

Calculated NH₃-N Summer limits: 4.1 mg/l (monthly average)
8.2 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 12.3 mg/l (monthly average)
24.6 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 1), which are more restrictive than in the previous NPDES Permit. The winter limits are calculated as three times the summer limits. Since the new limits are attainable, they will be used with this renewal.

h. CBOD₅

Median discharge pH to be used: 7.1 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ Summer limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Calculated CBOD₅ Winter limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 1), which are the same as the previous NPDES Permit and will be retained. The winter limits are calculated as three times the summer limits, but since the technology-based limits are more protective, they will be used. Since the summer limits and the winter limits are the same, the limits for CBOD₅ will be set year-round as in the previous NPDES Permit.

i. Influent Total Suspended Solids and BOD₅

Monitoring for these two parameters will be retained as recommended in the SOP for POTWs, as authorized under Chapter 92a.61.

j. Dissolved Oxygen (DO)

- 4.0 mg/l - minimum desired in effluent to protect all aquatic life.
- 5.0 mg/l - required in effluent for CWF, WWF, or TSF based on WQ Model.
- 6.0 mg/l - minimum required due to discharge going to a drainage swale or ditch.
- 8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: A Dissolved Oxygen technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1), and the SOP, based on Chapter 93.7, under the authority of Chapter 92a.61. Since the Dissolved Oxygen minimum of 5.0 mg/l in the previous permit is attainable, it will be retained with this renewal.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

k. Total Residual Chlorine (TRC)

- No limit necessary

Basis: Since Ultraviolet (UV) light is used for disinfection, limits for TRC are not necessary. UV Transmittance (%) reporting will be retained with this renewal.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

- TRC limits: _____ mg/l (monthly average)
 _____ mg/l (instantaneous maximum)

Basis: N/A

4. Reasonable Potential Analysis:

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 by the Department's Toxics Management Spreadsheet due to a lack of non-sewage data.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Reasonable Potential Analysis above does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no non-sewage sample data was provided, no calculations were performed.

Nearest Downstream potable water supply (PWS): PA American Water Company - Kittanning District
 Distance downstream from the point of discharge: 14.0 miles (approximate)

- No limits necessary
- Limits needed

Basis: Significant dilution available.

6. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

7. Flow Information:

The Yatesboro STP receives 58% of its flow from the Rural Valley Borough and 42% from the Cowanshannock Township.

The Rural Valley Borough and the Cowanshannock Township are both 100% separate sewer systems.

8. Attachment List:

Attachment 1 - WQ Modeling Printouts

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from January 1, 2021 to December 31, 2021)

Parameter	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21
Flow (MGD) Average Monthly	0.145	0.080	0.111	0.083	0.120	0.121	0.092	0.150	0.090	0.144	0.109	0.109
Flow (MGD) Daily Maximum	0.210	0.128	0.179	0.153	0.213	0.208	0.200	0.199	0.214	0.205	0.199	0.197
pH (S.U.) Minimum	7.1	7.0	7.0	7.0	6.9	7.0	6.8	6.8	6.7	6.8	6.6	6.9
pH (S.U.) Maximum	7.7	7.5	7.5	7.5	7.6	7.5	7.6	7.7	7.4	7.5	7.7	7.5
DO (mg/L) Minimum	5.1	5.0	5.0	5.0	5.0	5.0	5.0	5.5	5.6	6.3	6.0	6.0
CBOD5 (lbs/day) Average Monthly	7.9	2.0	2.77	2.1	2.88	2.2	1.73	4.3	2.6	3.2	2.0	1.8
CBOD5 (lbs/day) Weekly Average	11.3	3.2	4.48	3.8	5.11	3.8	3.75	5.7	6.1	4.6	3.7	3.3
CBOD5 (mg/L) Average Monthly	6.5	3.0	3.0	3.0	2.88	2.2	2.25	3.44	3.44	2.7	2.25	2.0
CBOD5 (mg/L) Weekly Average	8.83	3.0	3.0	3.0	2.88	2.2	2.25	3.44	3.44	2.7	2.25	2.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	117	161	140	101	121	79	9.1	153	153	137	195	211
BOD5 (lbs/day) Raw Sewage Influent Weekly Average	169	257	226	186	215	134	16.4	203	364	137	195	211
BOD5 (mg/L) Raw Sewage Influent Average Monthly	97	241	151.7	145.4	121	78	98.4	122.25	204	116	217	305
BOD5 (mg/L) Raw Sewage Influent Weekly Average	122	241	309	145.4	121	78	98.4	122.25	204	116	217	305
TSS (lbs/day) Average Monthly	8.0	2.29	5.6	5.2	4.34	5.2	4.1	7.0	5.2	9.0	8.3	10.0
TSS (lbs/day) Raw Sewage Influent Average Monthly	161	121.0	275	142.2	184.7	187	126	1.45	114	107	297	318
TSS (lbs/day) Raw Sewage Influent Weekly Average	233	193.6	444	262.2	327.9	321	275	1.93	273	107	297	318

TSS (lbs/day) Weekly Average	11.5	3.67	9.1	9.6	7.7	8.9	8.8	9.0	12.5	13.0	15.0	18.0
TSS (mg/L) Average Monthly	6.6	3.44	6.1	7.5	4.34	5.125	5.3	5.4	7.0	7.4	9.25	11.0
TSS (mg/L) Raw Sewage Influent Average Monthly	133	181.4	298	205.5	184.6	185	164.8	116	153	104	340	467
TSS (mg/L) Raw Sewage Influent Weekly Average	220	181.4	665	205.5	184.6	185	164.8	116	153	104	340	467
TSS (mg/L) Weekly Average	11.6	6.40	8.40	7.5	4.34	5.125	5.3	5.4	7.0	7.4	9.25	11.0
Fecal Coliform (CFU/100 ml) Geometric Mean	37.2	97.8	20	37.6	13.62	3.1	24.2	20.19	1	27	9.6	4.5
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	980.4	344.8	95.8	101.7	46.5	15.800	75.900	204.60	1.000	224.70	48.00	30.90
UV Transmittance (%) Average Monthly	13.0	13.1	12.9	12.8	12.8	12.7	12.8	12.9	13.0	13.1	13.1	13.1
Ammonia (lbs/day) Average Monthly	0.12	0.066	0.09	0.069	0.4009	0.10	0.077	0.125	0.34	0.22	0.10	0.10
Ammonia (lbs/day) Weekly Average	0.18	0.106	0.14	0.127	0.712	0.17	0.1668	0.166	0.82	0.31	0.18	0.18
Ammonia (mg/L) Average Monthly	0.1000	0.1000	0.1000	0.1000	0.4006	0.1	0.1000	0.1000	0.4575	0.18	0.11	0.11
Ammonia (mg/L) Weekly Average	0.1000	0.1000	0.1000	0.1000	0.4006	0.1	0.1000	0.1000	0.4575	0.18	0.11	0.11

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5 Nov 1 - Apr 30	45.9	69.8	XXX	25.0	38.0	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	36.7	55.1	XXX	20.0	30.0	40	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS	55.1	82.6	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	22.5	33.7	XXX	12.3	18.4	24.6	1/week	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen May 1 - Oct 31	7.5	11.2	XXX	4.1	6.1	8.2	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location: at Outfall 001, after ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliform are technology based on Chapter 92a.47. Monitoring for influent BOD₅ and influent Total Suspended Solids is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, UV Transmittance, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17E		46965		COWANSHANNOCK CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
13.600	Yatesboro	PA0216992	0.220	CBOD5	25		
				NH3-N	4.19	8.38	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
17E	46965	COWANSHANNOCK CREEK	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
13.600	0.220	25.000	7.037
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
17.793	0.532	33.423	0.091
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
11.04	0.462	1.65	1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
6.576	15.794	Owens	5
<u>Reach Travel Time (days)</u>	Subreach Results		
2.940	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.294	9.30	1.22
	0.588	7.84	0.90
	0.882	6.61	0.66
	1.176	5.57	0.49
	1.470	4.70	0.36
	1.764	3.96	0.27
	2.058	3.34	0.20
	2.352	2.81	0.15
	2.646	2.37	0.11
	2.940	2.00	0.08

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46965	COWANSHANNOCK CREEK	13.600	1082.00	26.30	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.020	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Yatesboro	PA0216992	0.2200	0.0000	0.0000	0.000	25.00	7.10

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46965	COWANSHANNOCK CREEK	9.200	1003.00	40.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.020	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17E	46965	COWANSHANNOCK CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
13.600	Yatesboro	10.61	21.1	10.61	21.1	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
13.600	Yatesboro	1.35	4.19	1.35	4.19	1	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
13.60	Yatesboro	25	25	4.19	4.19	4	4	0	0

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17E		46965				COWANSHANNOCK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
13.600	0.53	0.00	0.53	.3403	0.00340	.532	17.79	33.42	0.09	2.940	25.00	7.04
Q1-10 Flow												
13.600	0.34	0.00	0.34	.3403	0.00340	NA	NA	NA	0.08	3.375	25.00	7.05
Q30-10 Flow												
13.600	0.72	0.00	0.72	.3403	0.00340	NA	NA	NA	0.10	2.632	25.00	7.03