



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0217140**
APS ID **1100640**
Authorization ID **1461315**

Applicant and Facility Information

Indiana County Municipal Service Authority		Facility Name	Sheolocta STP
Applicant Name	602 Kolter Drive	Facility Address	179 Sewage Plant Road
Applicant Address	Indiana, PA 15701-3570		Indiana, PA 15701
Applicant Contact	Tricia Lefko	Facility Contact	Robert Allenbaugh
Applicant Phone	(724) 349-6640	Facility Phone	(724) 349-6640
Client ID	38534	Site ID	259139
Ch 94 Load Status	Not Overloaded	Municipality	Armstrong Township
Connection Status	No Limitations	County	Indiana
Date Application Received	<u>October 23, 2023</u>	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	NPDES permit renewal of a minor sewage facility discharge.		

Summary of Review

This is an existing discharge for a minor municipal sewage treatment facility.

Act 14 proof of notification was submitted and received.

There are currently 11 open violations for this client (38534) as of 10/30/2024, but none for this facility.

Quarterly monitoring for E. Coli has been added per Department SOP for new and reissued NPDES permits with design flows exceeding 0.05 MGD but less than 1.0 MGD.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	October 30, 2024
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	November 1, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.07
Latitude	40° 39' 31.01"	Longitude	-79° 18' 23.09"
Quad Name	Elderton	Quad Code	40079F3
Wastewater Description:	Sewage Effluent		
Receiving Waters	Crooked Creek (WWF)	Stream Code	46216
NHD Com ID	123865542	RMI	
Drainage Area	106	Yield (cfs/mi ²)	0.056
Q ₇₋₁₀ Flow (cfs)	5.99	Q ₇₋₁₀ Basis	Streamstats
Elevation (ft)	977	Slope (ft/ft)	---
Watershed No.	17-E	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	NUTRIENTS, ORGANIC ENRICHMENT		
Source(s) of Impairment	AGRICULTURE, AGRICULTURE		
TMDL Status	Final	Name	Crooked Creek Watershed
Background/Ambient Data			
pH (SU)	7.3	Data Source	USGS Stream Gage #03038000
Temperature (°F)	19.5		USGS Stream Gage #03038000
Hardness (mg/L)	84		USGS Stream Gage #03038000
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	Allegheny River	Cadogan Water District	
PWS RMI	320.45	Flow at Intake (cfs)	
		Distance from Outfall (mi)	34.6

Changes Since Last Permit Issuance: None

Other Comments: Yield was back-calculated from Q7-10 in Streamstats, 5.99cfs / 106 mi²

Treatment Facility Summary				
Treatment Facility Name: Shelota STP				
WQM Permit No.	Issuance Date			
3297405	3/23/1998			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with NH3-N Reduction	Extended Aeration	UV	0.044
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.07	149	Not Overloaded	Aerated SHT	Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments: Influent is pumped from the pump stations to an equalization tank where two pumps feed a splitter box, then pumped to two aeration tanks, then gravity flows to two clarifiers, then to the UV disinfection unit prior to discharge.

Lime is added at a rate of 50 lbs/day to increase alkalinity.

Compliance History

DMR Data for Outfall 001 (from September 1, 2023 to August 31, 2024)

Parameter	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23
Flow (MGD) Average Monthly	0.04	0.035	0.038	0.053	0.058	0.056	0.047	0.056	0.048	0.037	0.035	0.034
pH (S.U.) Instantaneous Minimum	6.5	6.8	7.0	7.1	6.9	6.9	6.9	6.9	6.8	6.7	6.7	6.8
pH (S.U.) Instantaneous Maximum	7.3	7.7	7.5	7.5	7.6	7.2	7.6	7.6	7.2	7.2	7.1	7.4
DO (mg/L) Instantaneous Minimum	5.0	5.0	5.0	5.0	4.3	5.2	5.0	5.0	5.4	5.3	5.0	4.3
CBOD5 (lbs/day) Average Monthly	< 1.0	< 0.9	< 3.0	< 1.9	< 3.1	< 2.6	< 2.0	< 1.5	< 1.4	< 0.9	< 0.9	< 0.8
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 4.0	< 6.0	< 5.0	< 4.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	< 3.0	< 3.0	4.21	9.41	6.84	5.02	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	25.0	41.0	49.0	55.0	58.0	36.0	59.0	95.0	78.0	64.0	53.0	56.0
BOD5 (mg/L) Raw Sewage Influent Average Monthly	77.2	135.3	150.0	110.7	115.0	70.4	125.0	198.8	165.0	208.0	178.0	209.0
TSS (lbs/day) Average Monthly	< 0.5	1.0	< 0.7	< 1.2	2.4	2.7	5.2	4.6	2.6	3.3	4.8	< 0.7
TSS (lbs/day) Raw Sewage Influent Average Monthly	41.0	75.0	65.0	47.0	65.0	40.0	53.0	45.0	75.0	34.0	66.0	61.0
TSS (mg/L) Average Monthly	< 2.0	3.0	< 2.0	< 2.0	5.0	5.0	10.0	10.0	6.0	11.0	16.0	< 3.0

NPDES Permit Fact Sheet
Shelota STP

NPDES Permit No. PA0217140

TSS (mg/L) Raw Sewage Influent Average Monthly	122.0	247.0	196.0	108.0	129.0	79.0	115.0	94.0	156.0	107.0	217.0	226.0
TSS (mg/L) Instantaneous Maximum	< 1.6	5.0	2.8	3.2	6.8	6.0	14.0	14.8	8.8	15.2	26.4	3.6
Fecal Coliform (No./100 ml) Average Monthly	26.0	1.0	137.0	206.0	2.0	6.0	< 3.0	< 3.0	4.0	7.0	< 3.0	1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	328.2	2.0	686.7	1732.9	3.1	37.9	9.7	10.9	8.6	8.5	9.7	2.0
UV Transmittance (%) Daily Minimum	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.3	0.2
Total Nitrogen (mg/L) Annual Average									24.99			
Ammonia (mg/L) Average Monthly	< 0.2013	8.023	14.33	10.1	3.1	< 0.75	< 0.1	< 0.1	0.1	< 0.1	< 0.1593	< 0.1154
Ammonia (mg/L) Instantaneous Maximum	0.3026	12.34	15.49	14.76	4.535	1.39	< 0.1	< 0.1	< 0.1	< 0.1	0.2186	0.1307
Total Phosphorus (mg/L) Annual Average									3.8			

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.07	
Latitude	40° 39' 28.00"	Longitude	-79° 18' 24.00"	
Wastewater Description:	Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli (No./100ml)	Report	IMAX		92a.61

Comments: E. Coli monitoring was added based on the Department's SOP for new and reissued permits.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia (May-Oct)	25	Average Monthly	WQM v.1.0b
CBOD ₅	25	Average Monthly	WQM v1.0b
Dissolved Oxygen (DO)	3.0	Daily Minimum	WQM v.1.0b

Comments: For existing discharges, if WQM modeling results for summer indicates that an average monthly limit of 25 mg/L is acceptable, the Department will generally establish a year-round monitoring requirement for ammonia-nitrogen, at a minimum, per the Department SOP for Establishing Effluent Limitations for Individual Sewage Permits, revised Feb 2024. Therefore, Ammonia monitoring shall be retained from the previous permit cycle.

A Dissolved Oxygen minimum of 3.0 mg/l was determined by WQM modeling to be protective and the Department maintains a minimum limit of 4.0 as Best Professional Judgment, but the previous permit cycle's minimum limit of 5.0 mg/l shall be retained per the Department's Anti-Backsliding policy.

Best Professional Judgment (BPJ) Limitations

Comments: None.

Anti-Backsliding

A Dissolved Oxygen minimum limit of 5.0 mg/l shall be retained per Anti-Backsliding policy.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	14.6	XXX	XXX	25	XXX	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS	17.5	XXX	XXX	30	XXX	60	2/month	Grab
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Ammonia	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
E. Coli (No./100ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Compliance Sampling Location: Outfall 001, after disinfection.
Other Comments: None.

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
17E	46216	CROOKED CREEK					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
32.500	Shelota STP	7.74	50	7.74	50	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
32.500	Shelota STP	1.66	25	1.66	25	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
32.50	Shelota STP	25	25	25	25	3	3
						0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
17E	46216	CROOKED CREEK			
RML	Total Discharge Flow (mgd)		Analysis Temperature (°C)	Analysis pH	
32.500	0.070		19.599	7.292	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>		<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
44.338	0.756		58.654	0.180	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>		<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.41	0.184		0.45	0.679	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>		<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.149	1.684		Tsivoglou	6	
<u>Reach Travel Time (days)</u>		<u>Subreach Results</u>			
0.712		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.071	2.38	0.43	8.14
		0.142	2.35	0.41	8.13
		0.213	2.32	0.39	8.13
		0.285	2.29	0.37	8.13
		0.356	2.26	0.35	8.14
		0.427	2.23	0.34	8.15
		0.498	2.20	0.32	8.16
		0.569	2.18	0.30	8.18
		0.640	2.15	0.29	8.20
		0.712	2.12	0.28	8.22

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
32.500	Shelocta STP	PA0217140	0.070	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
17E	46216 CROOKED CREEK			32.500	977.00	106.00	0.00000	0.00	<input checked="" type="checkbox"/>		
Stream Data											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.056	0.00	0.00	0.000	0.000	0.0	0.00	0.00	0.00	0.00	19.50
Q1-10		0.00	0.00	0.000	0.000						7.30
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
				Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
Name		Permit Number		0.0700	0.0700	0.0700	0.000	25.00	7.00		
Parameter Data											
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
Parameter Name											
CBOD5				25.00	2.00	0.00	1.50				
Dissolved Oxygen				3.00	8.24	0.00	0.00				
NH3-N				25.00	0.00	0.00	0.70				

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RML	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46216	CROOKED CREEK	30.400	966.00	190.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trb Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Temp	Tributary pH	Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.056	0.00	0.00	0.000	0.000	0.0	0.00	0.00	0.00	0.00	19.50	7.30
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing	Permitted	Design	Reserve Factor	Disc	Disc
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)		Temp (°C)	pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
17E		46216		CROOKED CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)		(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
32.500	5.94	0.00	5.94	.1083	0.00099	.756	44.34	58.65	0.18	0.712	19.60	7.29
Q1-10 Flow												
32.500	3.80	0.00	3.80	.1083	0.00099	NA	NA	NA	0.14	0.909	19.65	7.29
Q30-10 Flow												
32.500	8.07	0.00	8.07	.1083	0.00099	NA	NA	NA	0.21	0.601	19.57	7.29

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		