



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0217361**  
APS ID **1126584**  
Authorization ID **1508031**

**Applicant and Facility Information**

Applicant Name	<b>Municipal Authority of Westmoreland County</b>	Facility Name	<b>Iron Bridge STP</b>
Applicant Address	124 Park and Pool Road	Facility Address	214 Sewage Plt Lane
	New Stanton, PA 15672		Mt Pleasant, PA 15666
Applicant Contact	Katelyn Warheit	Facility Contact	Katelyn Warheit
Applicant Phone	(724) 755-5800	Facility Phone	(724) 755-5800
Client ID	64197	Site ID	487047
Ch 94 Load Status	Not Overloaded	Municipality	East Huntingdon Township
Connection Status	No Limitations	County	Westmoreland
Date Application Received	<u>November 26, 2024</u>	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	NPDES permit renewal application.		

**Summary of Review**

The PA Department of Environmental Protection (PADEP/Department) received an NPDES renewal application from Gibson Thomas Engineering (consultant) on behalf of Municipal Authority of Westmoreland County (MAWC/permittee) on November 26, 2024, for permittee's Iron Bridge STP (facility). The facility is in East Huntingdon Township, Westmoreland County and the treated effluent is discharged into Jacobs Creek in state watershed 19-D. The current permit will expire on May 31, 2025. The terms and conditions of the current permit is automatically extended since the renewal application was received at least 180 days prior to the expiration date. Renewal NPDES permit applications under Clean Water program are not covered by PADEP's PDG per 021-2100-001. This fact sheet is developed in accordance with 40 CFR §124.56.

Changes in this renewal: More stringent: CBOD5, Ammonia, TRC. New monitoring: E. Coli, Total Zinc.

Sludge use and disposal description and location(s): Aerobically digested biosolids are sent to Mt. Pleasant Borough STP for further treatment and ultimate disposal.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		Reza H. Chowdhury, P.E. / Environmental Engineer 	May 27, 2025
X		Pravin Patel Pravin C. Patel, P.E. / Environmental Engineer Manager	05/28/2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.25
Latitude	40° 6' 46"	Longitude	-79° 33' 11.7"
Quad Name	Connellsville	Quad Code	1809
Wastewater Description:	Sewage Effluent		
Receiving Waters	Jacobs Creek (WWF)	Stream Code	37868
NHD Com ID	69914951	RMI	17.02
Drainage Area	48.8 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.023
Q <sub>7-10</sub> Flow (cfs)	1.12	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	1029.38	Slope (ft/ft)	
Watershed No.	19-D	Chapter 93 Class.	WWF
Existing Use	WWF	Existing Use Qualifier	Ch. 93
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Aquatic Life, Recreational,		
Cause(s) of Impairment	<b>Habitat Alterations, Aluminum, Siltation, Iron, E. Coli</b>		
Source(s) of Impairment	<b>Highway/Road/Bridge Runoff, AMD, Urban Runoff/Storm Sewers, CSOs</b>		
TMDL Status	Name _____		
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°C)	25	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	MAWC McKeesport		
PWS Waters	Youghiogheny River	Flow at Intake (cfs)	
PWS RMI	1.66	Distance from Outfall (mi)	42.13

Changes Since Last Permit Issuance: The permit was transferred from East Huntingdon Township to MAWC on June 13, 2024. The Part II WQM permit 6598407 was amended on October 29, 2024, to replace existing gas chlorination with liquid chlorination system to meet the TRC limit in the NPDES permit.

**Streamflow:**

There's no nearby StreamGage from this discharge point. The USGS's web based watershed delineation tool StreamStats (accessible at <https://streamstats.usgs.gov/ss/>, accessed on May 20, 2025) was utilized to determine the drainage area at discharge point and at confluence with UNT 37940 (node 2). The drainage area at Outfall 001 was found to be 48.8 mi<sup>2</sup> and 50 mi<sup>2</sup> at node 2. The Q<sub>7-10</sub> at discharge point was found to be 1.12 cfs. The resulting yield is 1.12 cfs/48.8 mi<sup>2</sup> or 0.023 cfs/mi<sup>2</sup>. The default Q<sub>1-10</sub>:Q<sub>7-10</sub> of 0.64 and default Q<sub>30-10</sub>:Q<sub>7-10</sub> of 1.36 will be used for modeling, as appropriate.

**PWS Intake:**

The nearest downstream public water supply is MAWC's McKeesport facility in McKeesport City, Allegheny County, on Youghiogheny River at RMI 1.66. Its approximately 42.13 miles downstream of Outfall 001. Discharge from this facility is expected not to impact the PWS intake.

**Wastewater Characteristics:**

Default discharge pH of 7.0 S.U., temperature of 25°C and hardness of 100 mg/l will be used for modeling, as appropriate.

**Background data:**

There's no nearby WQN station to collect the stream data from. In absence of site-specific data, a default pH of 7.0, temperature of 25°C, and hardness of 100 mg/l will be used for modeling, as appropriate.

**Jacobs Creek Impairment:**

The receiving stream, Jacobs Creek, is Aquatic Life impaired (Siltation, Habitat Alterations) from urban runoff/storm sewer (May 16, 2025), and Recreational use impaired (E. Coli) from CSO and Urban Runoff/Storm sewers (1/31/2024). The terms, conditions, and effluent limits will be set to avoid addition to the existing impairment.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The receiving streams are designated as Warm Water Fishes (WWF). No High-Quality stream or Exceptional Value water is impacted by this discharge; therefore, no Antidegradation Analysis is performed for the discharge.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Iron Bridge STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6598407		11/17/1998		
6598407 T-1		6/13/2024		
6598407 A-1		10/29/2024		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.25
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.25	438	Not Overloaded	Combination	Landfill

Other Comments: None

Facility Information
----------------------

Municipal Authority of Westmoreland County (MAWC) owns and operates a minor sewage treatment plant named Iron Bridge STP. The ownership of the facility was transferred to MAWC from East Huntingdon Township on June 6, 2024. Per the transferred WQM permit (June 13, 2024), the facility consists of the following treatment units:

- One (1) 2.3 MGD comminutor
- One (1) one-inch Bypass manually cleaned bar screen
- One (1) 77,120-gallon aerated flow equalization tank with emergency overflow to the aeration basin
- Two (2) Goulds 45D 1.5 HP pump
- Three (3) 190-cfm blowers
- Three (3) 1170-cfm blowers
- Two (2) 45,300-gallon extended aeration tank
- Forty-four (44) removeable Sanitaire D-24 type coarse air diffusers
- Two (2) 31,760-gallon clarifiers with airlock return activated sludge pumps
- Two (2) aerobic sludge digesters with emergency overflow
- Two (2) 2,594-gallon chlorine contact tanks

- Two (2) Gas Chlorination vacuum fed submerged chemical induction units with a dosage rate of 2.6 ppm
- One (1) polishing clarifier
- One (1) post treatment aeration and dechlorination tank
- One (1) Control Building with gas chlorine storage, office space, electrical storage, and laboratory.

Biosolids management: Aerobically digested biosolids are sent to Mt. Pleasant Borough STP for further treatment and ultimate disposal.

**Existing Limits**

The following limits were applied in the current permit for the period of June 1, 2020, to May 31, 2025 at Outfall 001:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5 Nov 1 - Apr 30	52	79	XXX	25.0	37.5	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	31	48	XXX	15	23	30	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
TSS	63	94	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/week	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	37	56	XXX	18	27	36	1/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	13	19	XXX	6	9	12	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/week	8-Hr Composite

Compliance History

DMR Data for Outfall 001 (from April 1, 2024 to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.149	0.337	0.137	0.152	0.139	0.096	0.106	0.109	0.117	0.107	0.154	0.296
Flow (MGD) Weekly Average	0.167	0.444	0.218	0.22	0.176	0.132	0.106	0.132	0.144	0.121	0.195	0.533
pH (S.U.) IMIN	7.1	7.1	7.1	7.0	7.2	7.3	7.3	7.2	7.0	7.0	7.1	7.0
pH (S.U.) IMAX	7.6	7.5	7.4	7.5	7.8	7.8	7.8	7.8	7.7	7.7	7.4	7.4
DO (mg/L) IMIN	7.0	5.2	6.7	5.2	5.9	6.4	5.7	5.4	5.9	5.2	6.3	5.1
TRC (mg/L) Average Monthly	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.05	0.1	0.1
TRC (mg/L) IMAX	0.44	0.35	0.91	0.68	1.36	0.35	0.64	0.35	0.84	0.27	0.55	0.74
CBOD5 (lbs/day) Average Monthly	28	13	8	11	4	5	3	3	6	4	4	< 33
CBOD5 (lbs/day) Weekly Average	43	22	10	25	6	8	4	3	10	5	5	158
CBOD5 (mg/L) Average Monthly	23.7	6.4	8.1	7.2	4.8	5.3	3.6	3.4	5.3	4.5	3.5	< 8.5
CBOD5 (mg/L) Weekly Average	34.2	8.3	11.0	12.9	7.4	11.0	4.4	4.3	6.8	6.9	4.3	23.1
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	312	330	306	313	237	325	274	273	335	295	414	319
BOD5 (lbs/day) Raw Sewage Influent Weekly Average	481	433	413	471	302	387	321	334	615	379	725	378
BOD5 (mg/L) Raw Sewage Influent Average Monthly	252	172	302	221	259	387	346	322	273	323	372	190
BOD5 (mg/L) Raw Sewage Influent Weekly Average	345	233	372	344	388	534	370	378	335	369	731	304
TSS (lbs/day) Average Monthly	33	13	< 6	< 11	8	< 5	< 4	< 4	< 6	< 5	< 6	< 90
TSS (lbs/day) Raw Sewage Influent Average Monthly	234	258	163	246	161	169	151	157	310	217	205	321
TSS (lbs/day) Raw Sewage Influent Weekly Average	263	323	189	336	182	245	215	226	730	253	216	655

NPDES Permit Fact Sheet  
Iron Bridge STP

NPDES Permit No. PA0217361

TSS (lbs/day) Weekly Average	58	20	8	18	12	< 6	< 4	< 4	< 13	6	< 7	505
TSS (mg/L) Average Monthly	28	6	< 6	< 7	8	< 5	< 5	< 5	< 5	< 6	< 5	< 17
TSS (mg/L) Raw Sewage Influent Average Monthly	193	130	165	164	184	197	190	187	219	238	178	153
TSS (mg/L) Raw Sewage Influent Weekly Average	244	178	202	202	240	316	248	274	290	247	218	246
TSS (mg/L) Weekly Average	46	7	10	9	12	7	< 5	< 5	< 5	6	< 5	74
Fecal Coliform (No./100 ml) Geometric Mean	< 5	< 6	< 5	< 8	< 5	< 9	< 5	< 6	< 5	< 33	< 7	< 19
Fecal Coliform (No./100 ml) IMAX	< 5	10	< 5	60	5	16	5	10	< 5	1494	26	1049
Total Nitrogen (mg/L) Daily Maximum	GG	GG	4.6	GG	GG	GG	GG	GG	GG	GG	GG	GG
Ammonia (lbs/day) Average Monthly	< 4	4	2	5	2	0.5	< 0.2	< 0.4	< 2	< 0.9	< 0.3	< 8
Ammonia (lbs/day) Weekly Average	7	7	5	11	5	0.9	0.2	0.5	7	2	1	34
Ammonia (mg/L) Average Monthly	< 3.1	2.0	2.3	3.2	2.8	0.6	< 0.2	< 0.4	< 0.8	< 1.0	< 0.3	< 1.6
Ammonia (mg/L) Weekly Average	6.3	3.9	5.4	5.8	6.6	1.3	0.3	0.6	2.7	2.4	1.0	5.0
Total Phosphorus (mg/L) Daily Maximum	GG	GG	1.09	GG	GG	GG	GG	GG	GG	GG	GG	GG

Compliance History

Effluent Violations for Outfall 001, from: May 1, 2024 To: March 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	03/31/25	Wkly Avg	46	mg/L	45	mg/L
Fecal Coliform	06/30/24	IMAX	1494	No./100 ml	1000	No./100 ml
Fecal Coliform	06/30/24	IMAX	1494	No./100 ml	1000	No./100 ml

Summary of Inspections:

10/03/2023: RTPT conducted. No violation noted.

07/12/2023: CEI conducted. Review of the DMR data indicated violations including effluent violations for DO, Fecal Coliform, TRC, and TSS; and SSO. The plant appeared to be operating properly, effluent from the CCT appeared clear and in good visual condition, and no offensive odors were detected during the inspection.

08/26/2020: CEI conducted. Violations noted including no samples collected for April and May of 2020 and TRC effluent violation. The effluent after CCT appeared clear.

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	0.25	
Latitude	40° 6' 45.00"	Longitude	-79° 33' 12.00"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

### Mass-Based Limits

The federal regulation at 40 CFR 122.45(f) requires that effluent limits be expressed in terms of mass, if possible. The regulation at 40 CFR 122.45(b) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass-based limits are expressed in pounds per day and are calculated as follows:

Mass based limit (lb/day) = concentration limit (mg/L) × design flow (mgd) × 8.34

### Model input data

The following data will be used for modeling, as needed:

- Discharge pH 7.0 (Default)
- Discharge Temperature 25°C (Default)
- Discharge Hardness 100 mg/l (Default)
- Stream pH 7.0 (Default)
- Stream Temperature 25.0°C (Default)
- Stream Hardness 100 mg/l (Default)

The following two nodes were used in modeling:

Node 1: At the outfall 001 on Jacobs Creek (37868)  
 Elevation: 1029.15 ft (National Map-Advanced Viewer, 5/20/2025)  
 Drainage Area: 48.8 mi<sup>2</sup> (StreamStat Version 3.0, 5/20/2025)  
 River Mile Index: 17.02 (PA DEP eMapPA)  
 Low Flow Yield: 0.023 cfs/mi<sup>2</sup>  
 Q<sub>7-10</sub>: 1.12 cfs  
 Discharge Flow: 0.25 MGD

Node 2: At confluence with UNT 37940 with Jacobs Creek  
 Elevation: 1025.38 ft (National Map-Advanced Viewer, 5/20/2025)  
 Drainage Area: 50 mi<sup>2</sup> (StreamStat Version 3.0, 5/20/2025)  
 River Mile Index: 16.26 (PA DEP eMapPA)

Low Flow Yield: 0.023 cfs/mi<sup>2</sup>  
Discharge Flow: 0.0 MGD

### WQM 7.0 Model

WQM 7.0 version 1.11 is a water quality model designed to assist DEP to determine appropriate effluent limits for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO. The model simulates two basic processes. In the NH<sub>3</sub>-N module, the model simulates the mixing and degradation of NH<sub>3</sub>-N in the stream and compares calculated instream NH<sub>3</sub>-N concentrations to NH<sub>3</sub>-N water quality criteria. In the D.O. module, the model simulates the mixing and consumption of D.O. in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>N and compares calculated instream D.O. concentrations to D.O. water quality criteria. The model was utilized for this permit renewal by using Q<sub>7-10</sub> and current background water quality levels of the stream.

#### **NH<sub>3</sub>-N**

WQM 7.0 suggested NH<sub>3</sub>-N limit of 3.29 mg/l as monthly average and 6.58 mg/l as IMAX limit during summer to protect water quality standards. The current permit has summer limit of 6 mg/l as AML (Average Monthly Limit) and 12 mg/l IMAX. The proposed limits are more stringent than existing limits. The reasons for more stringent limit might be that the original modeling was conducted in 2008 using WQM 6.3 version that utilized a LFY of 0.043 cfs/mi<sup>2</sup>, resulting a Q<sub>7-10</sub> of 1.5656 cfs, whereas StreamStats produced a Q<sub>7-10</sub> of 1.12 cfs (resulting LFY is 0.023 cfs/mi<sup>2</sup>) during this renewal. Therefore, even though StreamStats provided higher drainage area (48.8 mi<sup>2</sup>) compared to 2008 permit (36.41 mi<sup>2</sup>), due to lower yield, the ultimate available flow is lower, which could have resulted in more stringent ammonia limit. The winter limits are calculated by multiplying the summer limits with a factor of 3, resulting in AML of 9.87 mg/l and IMAX of 19.74 mg/l. A review of the past 12 months DMR data indicated that the facility is discharging at much lower concentration, therefore, a compliance schedule isn't needed.

#### **CBOD5**

WQM 7.0 suggests CBOD5 limit of 10.96 mg/l as AML during summer season. The current permit has summer AML of 15 mg/l. The probable reason for more stringent model output might be less available dilution. The winter limits are calculated by multiplying summer limits with a factor of 3 (391-2000-013), which resulted in AML of 32.88 mg/l, 49.32 mg/l as Weekly Average, and 65.76 mg/l as IMAX. The current permit has winter AML of 25 mg/l, Weekly Average of 37.5 mg/l, and IMAX of 50 mg/l. More stringent limits will be applied. A review of the past 12 months DMR data indicated that the facility is discharging at a concentration below 10 mg/l (except for 1 winter month-23.7 mg/l). Since the facility is meeting more stringent proposed limits, a compliance schedule isn't needed.

#### **DO**

WQM 7.0 suggests minimum DO of 5.0 mg/l which is the model input and same as existing limit. Existing limit will be carried over.

### Toxics Management Spreadsheet (TMS)

The facility provided 1 sample result for **Total Copper, Total Lead, and Total Zinc**. These toxics are modeled through TMS and the model recommended monitoring requirement for **Total Zinc**, based on an input value of 0.0504 mg/l. Since there's only 1 sample result to analyze, it is recommended that the permittee should collect more data during this permit term to evaluate on the next renewal. With this consideration, it is recommended that a 1/6 month monitoring is needed that will provide sufficient (10) data points for next renewal.

### Other Requirements/BPJ based limits

#### **Total Phosphorus:**

PADEP's SOP BCW-PMT-033 recommends monitoring for Total Phosphorus for facilities with design flow more than 2000-GPD, which is also supported by Pa Code 25 Ch. 92a.61. Current monitoring requirement will be continued. The minimum sampling frequency is changed from 1/week to 1/year, based on an email confirmation during last permit term and frequencies applied to facilities of similar size.

#### **Total Nitrogen:**

PADEP's SOP BCW-PMT-033 recommends monitoring for Total Nitrogen for facilities with design flow more than 2000-GPD, which is also supported by Pa Code 25 Ch. 92a.61. Current monitoring requirement will be continued. The minimum sampling frequency is changed from 1/week to 1/year and sampling type is changed from 8-hr composite to calculation.

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml. These are existing requirements and will be carried over in this renewal.

**E. Coli:**

Pa Code 25 § 92a. 61 requires monitoring of E. Coli. DEP's SOP titled "Establishing Effluent Limitations for Individual Sewage Permits (BCW-PMT-033, revised March 24, 2021) recommends quarterly E. Coli monitoring for minor sewage dischargers with a design flow between  $\geq 0.05$  MGD and 1.0 MGD. This requirement will be applied from this permit term.

**pH:**

The TBEL for pH is above 6.0 and below 9.0 S.U. (40 CFR §133.102(c) and Pa Code 25 §§ 95.2(1), 92a.47) which are existing limits and will be carried over.

**Total Suspended Solids (TSS):**

The existing limits of 30 mg/L average monthly, 45 mg/l as weekly average, and 60 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment, 25 Pa. Code § 92a.47 and 40CFR 133.102(b). The mass based average monthly and weekly average limit is calculated to be 63 lbs./day and 94 lbs./day which are the same as were in existing permit and will be carried over.

**Total Residual Chlorine (TRC):**

The attached computer printout utilizes the equation and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID#391-2000-015) for developing chlorine limitations. The model recommends AML of 0.432 mg/l and IMAX of 1.414 mg/l, which are more stringent than current limits of 0.5 mg/l AML and 1.6 mg/l IMAX. A review of past 12 months DMR data indicated that the facility is discharging around 0.1 mg/l as monthly average, which is much lower than proposed AML. The proposed limits will be applied without a compliance schedule.

**Flow and Influent BOD<sub>5</sub> and TSS Monitoring Requirement:**

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii). Influent BOD<sub>5</sub> and TSS monitoring requirements are established in the permit per the requirements set in Pa Code 25 Chapter 94.

**Monitoring Frequency and Sample Types:**

Otherwise specified above, the monitoring frequency and sample type of compliance monitoring for existing parameters are recommended by DEP's SOP and Permit Writers Manual and/or on a case-by-case basis using best professional judgment (BPJ).

**Anti-Backsliding**

Anti-backsliding prohibition is justified in sections where an exception is justified for the affected pollutant(s). For remaining pollutants, this prohibition isn't applicable since the proposed limits are at least as stringent as were in current permit.

**Rounding of numbers:**

Rounding of numbers followed the guidelines as provided in 362-0400-001, Chapter 5, page 9; unless the lab can't report at that number. In those cases, BPJ was applied to round up/down the numbers that were most appropriate to the specific pollutant and the number.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.43	XXX	1.41	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	52	79	XXX	25.0	37.5	50	1/week	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	22.94	34.4	XXX	11.0	16.5	22.0	1/week	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
Total Suspended Solids	63	94	XXX	30	45	60	1/week	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Avg Qrtly	Report Daily Max	XXX	1/quarter	Grab

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Calculation
Ammonia-Nitrogen Nov 1 - Apr 30	20.6	31	XXX	9.9	14.8	19.8	1/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	6.9	10.3	XXX	3.3	5.0	6.6	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Zinc, Total	XXX	XXX	XXX	Report SEMI AVG	Report Daily Max	XXX	1/6 months	8-Hr Composite

Compliance Sampling Location: At Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Treatment Plant Schematic



StreamStats at Outfall 001


## PA0217361 at outfall 001

**Region ID:** PA

**Workspace ID:** PA20250521013330205000

**Clicked Point (Latitude, Longitude):** 40.11253, -79.55357

**Time:** 2025-05-20 21:33:52 -0400



### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	48.8	square miles
ELEV	Mean Basin Elevation	1498	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	48.8	square miles	2.26	1400
ELEV	Mean Basin Elevation	1498	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, P|U: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2.83	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	4.62	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	1.12	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	1.84	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	3.27	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

StreamStats at node 2


PA0217361 at node 2

Region ID: PA

Workspace ID: PA20250521013544123000

Clicked Point (Latitude, Longitude): 40.10596, -79.56069

Time: 2025-05-20 21:36:05 -0400



Collapse All

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	50	square miles
ELEV	Mean Basin Elevation	1489	feet

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	50	square miles	2.26	1400
ELEV	Mean Basin Elevation	1489	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

P|L: Lower 90% Prediction Interval, P|U: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2.9	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	4.72	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	1.16	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	1.88	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	3.34	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

**USGS Data Disclaimer:** Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

**USGS Software Disclaimer:** This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

**USGS Product Names Disclaimer:** Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

WQM 7.0

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
						(ft)	(sq mi)	(ft/ft)	(mgd)	
19D		37868 JACOBS CREEK				17.020	1029.15	48.80	0.00000	0.00 <input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.023	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Iron Bridge STP	PA0217361	0.2500	0.2500	0.2500	0.000	25.00	7.00		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	15.00	2.00	0.00	1.50					
	Dissolved Oxygen	5.00	8.24	0.00	0.00					
	NH3-N	6.00	0.00	0.00	0.70					

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
						(ft)	(sq mi)	(ft/ft)	(mgd)	
19D		37868 JACOBS CREEK				16.260	1025.38	50.00	0.00000	0.00 <input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.023	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	3.00	8.24	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
19D			37868			JACOBS CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
17.020	1.12	0.00	1.12	.3868	0.00094	.616	25.04	40.66	0.10	0.474	25.00	7.00
<b>Q1-10 Flow</b>												
17.020	0.72	0.00	0.72	.3868	0.00094	NA	NA	NA	0.08	0.565	25.00	7.00
<b>Q30-10 Flow</b>												
17.020	1.53	0.00	1.53	.3868	0.00094	NA	NA	NA	0.11	0.415	25.00	7.00

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 D.O. Simulation**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
19D		37868		JACOBS CREEK			
<u>RMI</u>	17.020	<u>Total Discharge Flow (mgd)</u>	0.250	<u>Analysis Temperature (°C)</u>	25.000	<u>Analysis pH</u>	7.000
<u>Reach Width (ft)</u>	25.037	<u>Reach Depth (ft)</u>	0.616	<u>Reach WDRatio</u>	40.664	<u>Reach Velocity (fps)</u>	0.098
<u>Reach CBOD5 (mg/L)</u>	4.30	<u>Reach Kc (1/days)</u>	0.631	<u>Reach NH3-N (mg/L)</u>	0.84	<u>Reach Kn (1/days)</u>	1.029
<u>Reach DO (mg/L)</u>	7.412	<u>Reach Kr (1/days)</u>	0.984	<u>Kr Equation</u>	Tsivoglou	<u>Reach DO Goal (mg/L)</u>	5
<u>Reach Travel Time (days)</u>	0.474	<u>Subreach Results</u>					
		<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>		
			0.047	4.14	0.80	7.04	
			0.095	3.98	0.76	6.71	
			0.142	3.84	0.73	6.41	
			0.190	3.70	0.69	6.14	
			0.237	3.56	0.66	5.89	
			0.285	3.43	0.63	5.67	
			0.332	3.30	0.60	5.47	
			0.380	3.18	0.57	5.30	
			0.427	3.06	0.54	5.15	
			0.474	2.95	0.52	5.01	

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19D	37868	JACOBS CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
17.020	Iron Bridge STP	11.07	12	11.07	12	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
17.020	Iron Bridge STP	1.37	6	1.37	6	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
17.02	Iron Bridge STP	10.96	10.96	3.29	3.29	5	5	0	0

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19D	37868	JACOBS CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
17.020	Iron Bridge STP	PA0217361	0.250	CBOD5	10.96		
				NH3-N	3.29	6.58	
				Dissolved Oxygen			5

TMS



## Discharge Information

Instructions **Discharge** Stream

Facility: Iron Bridge STP NPDES Permit No.: PA0217361 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated sewage

Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Discharge Characteristics					
			Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.25	100	7						

			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
<b>Group 1</b>	Total Dissolved Solids (PWS)	mg/L									
	Chloride (PWS)	mg/L									
	Bromide	mg/L									
	Sulfate (PWS)	mg/L									
	Fluoride (PWS)	mg/L									
<b>Group 2</b>	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	mg/L	0.00181								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	mg/L	< 0.001								
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
	Total Thallium	µg/L									
	Total Zinc	mg/L	0.0504								
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								
	Carbon Tetrachloride	µg/L	<								



## Stream / Surface Water Information

Iron Bridge STP, NPDES Permit No. PA0217361, Outfall 001

**Instructions      Discharge      Stream**

W. B. Smith, M.A.

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	037868	17.02	1029.38	48.8			Yes
End of Reach 1	037868	16.26	1025.38	50			Yes

Q7-10

Location	RMI	LFY (cfs/mi <sup>2</sup> ) <sup>a</sup>	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH <sup>b</sup>	Hardness	pH
Point of Discharge	17.02	0.023											100	7	
End of Reach 1	16.26	0.023											100	7	

Q<sub>1</sub>

Model Results

Iron Bridge STP, NPDES Permit No. PA0217361, Outfall 001

Instructions	Results	<a href="#">RETURN TO INPUTS</a>	<a href="#">SAVE AS PDF</a>	<a href="#">PRINT</a>	0 All 0 Inputs 0 Results 0 Limits																																				
<input type="checkbox"/> <b>Hydrodynamics</b> <input checked="" type="checkbox"/> <b>Wasteload Allocations</b>																																									
<input checked="" type="checkbox"/> <b>AFC</b> CCT (min): <input type="text" value="15"/> PMF: <input type="text" value="0.695"/> Analysis Hardness (mg/l): <input type="text" value="100"/> Analysis pH: <input type="text" value="7.00"/>																																									
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Pollutants</th> <th style="width: 15%;">Stream Conc</th> <th style="width: 15%;">Stream CV</th> <th style="width: 15%;">Trib Conc (µg/L)</th> <th style="width: 15%;">Fate Coef</th> <th style="width: 15%;">WQC (µg/L)</th> <th style="width: 15%;">WQ Obj (µg/L)</th> <th style="width: 15%;">WLA (µg/L)</th> <th style="width: 15%;">Comments</th> </tr> </thead> <tbody> <tr> <td>Total Copper</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>13.439</td> <td>14.0</td> <td>42.2</td> <td>Chem Translator of 0.96 applied</td> </tr> <tr> <td>Total Lead</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>64.581</td> <td>81.8</td> <td>246</td> <td>Chem Translator of 0.791 applied</td> </tr> <tr> <td>Total Zinc</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>117.180</td> <td>120</td> <td>361</td> <td>Chem Translator of 0.978 applied</td> </tr> </tbody> </table>						Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments	Total Copper	0	0		0	13.439	14.0	42.2	Chem Translator of 0.96 applied	Total Lead	0	0		0	64.581	81.8	246	Chem Translator of 0.791 applied	Total Zinc	0	0		0	117.180	120	361	Chem Translator of 0.978 applied
Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments																																	
Total Copper	0	0		0	13.439	14.0	42.2	Chem Translator of 0.96 applied																																	
Total Lead	0	0		0	64.581	81.8	246	Chem Translator of 0.791 applied																																	
Total Zinc	0	0		0	117.180	120	361	Chem Translator of 0.978 applied																																	
<input checked="" type="checkbox"/> <b>CFC</b> CCT (min): <input type="text" value="31.081"/> PMF: <input type="text" value="1"/> Analysis Hardness (mg/l): <input type="text" value="100"/> Analysis pH: <input type="text" value="7.00"/>																																									
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Pollutants</th> <th style="width: 15%;">Stream Conc (µg/L)</th> <th style="width: 15%;">Stream CV</th> <th style="width: 15%;">Trib Conc (µg/L)</th> <th style="width: 15%;">Fate Coef</th> <th style="width: 15%;">WQC (µg/L)</th> <th style="width: 15%;">WQ Obj (µg/L)</th> <th style="width: 15%;">WLA (µg/L)</th> <th style="width: 15%;">Comments</th> </tr> </thead> <tbody> <tr> <td>Total Copper</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>8.956</td> <td>9.33</td> <td>36.4</td> <td>Chem Translator of 0.96 applied</td> </tr> <tr> <td>Total Lead</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>2.517</td> <td>3.18</td> <td>12.4</td> <td>Chem Translator of 0.791 applied</td> </tr> <tr> <td>Total Zinc</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>118.139</td> <td>120</td> <td>468</td> <td>Chem Translator of 0.986 applied</td> </tr> </tbody> </table>						Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments	Total Copper	0	0		0	8.956	9.33	36.4	Chem Translator of 0.96 applied	Total Lead	0	0		0	2.517	3.18	12.4	Chem Translator of 0.791 applied	Total Zinc	0	0		0	118.139	120	468	Chem Translator of 0.986 applied
Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments																																	
Total Copper	0	0		0	8.956	9.33	36.4	Chem Translator of 0.96 applied																																	
Total Lead	0	0		0	2.517	3.18	12.4	Chem Translator of 0.791 applied																																	
Total Zinc	0	0		0	118.139	120	468	Chem Translator of 0.986 applied																																	
<input checked="" type="checkbox"/> <b>THH</b> CCT (min): <input type="text" value="31.081"/> PMF: <input type="text" value="1"/> Analysis Hardness (mg/l): <input type="text" value="N/A"/> Analysis pH: <input type="text" value="N/A"/>																																									
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Pollutants</th> <th style="width: 15%;">Stream Conc (µg/L)</th> <th style="width: 15%;">Stream CV</th> <th style="width: 15%;">Trib Conc (µg/L)</th> <th style="width: 15%;">Fate Coef</th> <th style="width: 15%;">WQC (µg/L)</th> <th style="width: 15%;">WQ Obj (µg/L)</th> <th style="width: 15%;">WLA (µg/L)</th> <th style="width: 15%;">Comments</th> </tr> </thead> <tbody> <tr> <td>Total Copper</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td></td> </tr> <tr> <td>Total Lead</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td></td> </tr> <tr> <td>Total Zinc</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td></td> </tr> </tbody> </table>						Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments	Total Copper	0	0		0	N/A	N/A	N/A		Total Lead	0	0		0	N/A	N/A	N/A		Total Zinc	0	0		0	N/A	N/A	N/A	
Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments																																	
Total Copper	0	0		0	N/A	N/A	N/A																																		
Total Lead	0	0		0	N/A	N/A	N/A																																		
Total Zinc	0	0		0	N/A	N/A	N/A																																		
<input checked="" type="checkbox"/> <b>CRL</b> CCT (min): <input type="text" value="16.245"/> PMF: <input type="text" value="1"/> Analysis Hardness (mg/l): <input type="text" value="N/A"/> Analysis pH: <input type="text" value="N/A"/>																																									
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Pollutants</th> <th style="width: 15%;">Stream Conc (µg/L)</th> <th style="width: 15%;">Stream CV</th> <th style="width: 15%;">Trib Conc (µg/L)</th> <th style="width: 15%;">Fate Coef</th> <th style="width: 15%;">WQC (µg/L)</th> <th style="width: 15%;">WQ Obj (µg/L)</th> <th style="width: 15%;">WLA (µg/L)</th> <th style="width: 15%;">Comments</th> </tr> </thead> <tbody> <tr> <td>Total Copper</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td></td> </tr> <tr> <td>Total Lead</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td></td> </tr> <tr> <td>Total Zinc</td> <td>0</td> <td>0</td> <td style="background-color: #cccccc;"></td> <td>0</td> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td></td> </tr> </tbody> </table>						Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments	Total Copper	0	0		0	N/A	N/A	N/A		Total Lead	0	0		0	N/A	N/A	N/A		Total Zinc	0	0		0	N/A	N/A	N/A	
Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments																																	
Total Copper	0	0		0	N/A	N/A	N/A																																		
Total Lead	0	0		0	N/A	N/A	N/A																																		
Total Zinc	0	0		0	N/A	N/A	N/A																																		
<input type="checkbox"/> <b>Recommended WQBELs &amp; Monitoring Requirements</b>																																									
No. Samples/Month: <input type="text" value="4"/>																																									
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2" style="width: 15%;">Pollutants</th> <th colspan="2" style="width: 30%;">Mass Limits</th> <th colspan="4" style="width: 55%;">Concentration Limits</th> </tr> <tr> <th style="width: 15%;">AML (lbs/day)</th> <th style="width: 15%;">MDL (lbs/day)</th> <th style="width: 15%;">AML</th> <th style="width: 15%;">MDL</th> <th style="width: 15%;">IMAX</th> <th style="width: 15%;">Units</th> <th rowspan="2" style="width: 15%;">Comments</th> </tr> </thead> <tbody> <tr> <td>Total Zinc</td> <td>Report</td> <td>Report</td> <td>Report</td> <td>Report</td> <td>Report</td> <td>mg/L</td> <td>Governing WQBEL 0.23 WQBEL Basis AFC Comments Discharge Conc &gt; 10% WQBEL (no RP)</td> </tr> </tbody> </table>						Pollutants	Mass Limits		Concentration Limits				AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Comments	Total Zinc	Report	Report	Report	Report	Report	mg/L	Governing WQBEL 0.23 WQBEL Basis AFC Comments Discharge Conc > 10% WQBEL (no RP)														
Pollutants	Mass Limits		Concentration Limits																																						
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Comments																																		
Total Zinc	Report	Report	Report	Report	Report	mg/L		Governing WQBEL 0.23 WQBEL Basis AFC Comments Discharge Conc > 10% WQBEL (no RP)																																	
<input type="checkbox"/> <b>Other Pollutants without Limits or Monitoring</b>																																									
<p>The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., &lt;= Target QL).</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Pollutants</th> <th style="width: 15%;">Governing WQBEL</th> <th style="width: 15%;">Units</th> <th colspan="3" style="width: 55%;">Comments</th> </tr> </thead> <tbody> <tr> <td>Total Copper</td> <td>0.027</td> <td>mg/L</td> <td colspan="3">Discharge Conc ≤ 10% WQBEL</td> </tr> <tr> <td>Total Lead</td> <td>N/A</td> <td>N/A</td> <td colspan="3">Discharge Conc &lt; TQL</td> </tr> <tr> <td></td> <td></td> <td></td> <td colspan="3"></td> </tr> <tr> <td></td> <td></td> <td></td> <td colspan="3"></td> </tr> </tbody> </table>						Pollutants	Governing WQBEL	Units	Comments			Total Copper	0.027	mg/L	Discharge Conc ≤ 10% WQBEL			Total Lead	N/A	N/A	Discharge Conc < TQL																				
Pollutants	Governing WQBEL	Units	Comments																																						
Total Copper	0.027	mg/L	Discharge Conc ≤ 10% WQBEL																																						
Total Lead	N/A	N/A	Discharge Conc < TQL																																						

TRC

TRC\_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.943		1.3.2.iii	WLA_cfc = 0.912
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.351		5.1d	LTA_cfc = 0.530
Source		Effluent Limit Calculations			
PENTOXSD TRG	5.1f		AML MULT = 1.231		
PENTOXSD TRG	5.1g		AVG MON LIMIT (mg/l) = 0.432	AFC	
			INST MAX LIMIT (mg/l) = 1.414		
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc		$\text{EXP}((0.5^*\text{LN}(cvh^2+1))-2.326^*\text{LN}(cvh^2+1)^{0.5})$			
LTA_afc		wla_afc*LTAMULT_afc			
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc		$\text{EXP}((0.5^*\text{LN}(cvd^2/no_samples+1))-2.326^*\text{LN}(cvd^2/no_samples+1)^{0.5})$			
LTA_cfc		wla_cfc*LTAMULT_cfc			
AML MULT		$\text{EXP}(2.326^*\text{LN}((cvd^2/no_samples+1)^{0.5})-0.5^*\text{LN}(cvd^2/no_samples+1))$			
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)			
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)			