

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0217565
 APS ID 1102173
 Authorization ID 1464096

Applicant and Facility Information

Applicant Name	<u>John & Lynae Williams</u>	Facility Name	<u>Maple Valley Personal Care Home</u>
Applicant Address	<u>2212 Anthony Run Road</u> <u>Indiana, PA 15701-4413</u>	Facility Address	<u>2212 Anthony Run Road</u> <u>Indiana, PA 15701-4413</u>
Applicant Contact	<u>John Williams</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 465-4343</u>	Facility Phone	<u></u>
Applicant Email	<u>jwilliams70@verizon.net</u>		<u></u>
Client ID	<u>349984</u>	Site ID	<u>485285</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Armstrong Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Indiana</u>
Date Application Received	<u>November 17, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>April 1, 2024</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an Existing Discharge of 0.006</u>		

Summary of Review

This is a renewal Sewage Individual NPDES Permit for an Existing Discharge of 0.006 MGD from a non-municipal minor sewage facility. The existing treatment process consists of extended aeration, final clarification and chlorination. Extended aeration plant has 1 digester, 2 aeration tanks, 1 settling tank and 1 clearwell.

Act 14 – Proof of Notification was submitted and received.

This facility is currently using eDMR system.

SPECIAL CONDITIONS: NONE

The EPA waiver is in effect.

There are NO open violations in WMS for the subject Client ID (349984) as of April 5, 2024.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Aeshah Shameseldin Aeshah Shameseldin / Civil Engineer	April 5, 2024
		Vacant / Environmental Engineer Manager	Okay to Draft JCD 4/23/2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.006</u>
Latitude	<u>40° 37' 48"</u>	Longitude	<u>-79° 16' 26"</u>
Quad Name	<u>Elderton</u>	Quad Code	<u>40079F3</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Anthony Run (CWF)</u>	Stream Code	<u>46692</u>
NHD Com ID	<u>123858097</u>	RMI	<u>2.38</u>
Drainage Area	<u>2.89 square miles</u>	Yield (cfs/mi ²)	<u>0.1</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.289</u>	Q ₇₋₁₀ Basis	<u>Stream Gage # 03038000, Crooked Creek at Idaho, Pa</u>
Elevation (ft)	<u>1060</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>17-E</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>---</u>	Existing Use Qualifier	<u>---</u>
Exceptions to Use	<u>---</u>	Exceptions to Criteria	<u>---</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Siltation</u>		
Source(s) of Impairment	<u>Removal of Riparian Vegetation</u>		
TMDL Status	<u>Final</u>	Name	<u>Crooked Creek Watershed</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	
Temperature (°F)	<u>68</u>	Default	
Hardness (mg/L)	<u>100</u>	Default	
Other:	<u></u>		
Nearest Downstream Public Water Supply Intake	<u>Buffalo Township Municipal Water Authority - Freeport</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2576</u>
PWS RMI	<u>30</u>	Distance from Outfall (mi)	<u>---</u>

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary				
Treatment Facility Name: Maple Valley Personal Care Home				
WQM Permit No.		Issuance Date		
3298401 A-1		October 9, 2019		
3298401		July 24, 1998		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine with Dechlorination	0.006
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.006		Not Overloaded		Off site

Changes Since Last Permit Issuance: Treatment facilities under WQM 3298401 have been amended to house a sodium bisulfite tablet feeder for dechlorination and a 12" air diffuser inside a new 48" manhole.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from March 1, 2023 to February 29, 2024)

Parameter	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23
Flow (MGD) Average Monthly	0.004	0.004	0.004	0.004	0.0043	0.004	0.004	0.004	0.004	0.004	0.0045	0.004
Flow (MGD) Daily Maximum	0.005	0.005	0.005	0.005	0.0043	0.005	0.005	0.004	0.005	0.004	0.005	0.005
pH (S.U.) Instantaneous Minimum	6.8	6.8	6.8	6.8	6.8	7.0	6.8	6.8	6.8	6.8	6.8	6.8
pH (S.U.) Instantaneous Maximum	7.4	7.2	7.5	7.7	7.6	7.7	7.4	7.5	7.4	7.1	7.7	7.2
DO (mg/L) Instantaneous Minimum	5.0	5.6	5.0	5.0	5.5	5.0	5.0	5.0	5.0	6.0	5.6	5.0
TRC (mg/L) Average Monthly	0.07	0.08	0.08	0.09	0.08	0.08	0.07	0.07	0.10	0.07	0.07	0.08
TRC (mg/L) Instantaneous Maximum	0.15	0.15	0.19	0.20	0.20	0.20	0.20	0.19	0.19	0.22	0.20	0.19
CBOD5 (mg/L) Average Monthly	3	3	3	3	3	3	3	5.085	4.765	3	3.02	3
CBOD5 (mg/L) Instantaneous Maximum	3	3	3	3	3	3	3	7.17	5.53	3	3.04	3
TSS (mg/L) Average Monthly	1.60	1.0	2.40	17.6	13.8	4.8	10.8	2.8	6	19.6	18.6	9.2
TSS (mg/L) Instantaneous Maximum	1.60	1.0	3.20	19.6	18.8	8.0	14.8	3.20	10.4	22	29.6	16.8
Fecal Coliform (No./100 ml) Geometric Mean	2.05	6.3	48.8	42	259	13.8	49.5	101	4	2	11.4	4.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	3.1	6.3	104.8	579.4	488.4	191.8	77.1	1046	4	4	16.4	4.0
Total Nitrogen (mg/L) Daily Maximum			0.5000									

Ammonia (mg/L) Average Monthly					0.1000	0.5296	0.691	1.9712	0.1812	0.1000		
Ammonia (mg/L) Instantaneous Maximum					0.1000	0.9593	1.282	3.687	0.2620	0.1000		
Total Phosphorus (mg/L) Daily Maximum			4.01									

Compliance History

Effluent Violations for Outfall 001, from: April 1, 2023 to: February 29, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	07/31/23	IMAX	1046	No./100 ml	1000	No./100 ml

Summary of Inspections: Site inspection has been conducted on May 13, 2022. The inspection report did not cite any violations.

Other Comments: None.

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	.006
Latitude	40° 37' 48.00"	Longitude	-79° 16' 26.00"
Wastewater Description: Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	§ 92a.61

Comments: Monitoring for E. Coli is placed in the permit in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.”

Water Quality-Based Limitations

CBOD₅, Ammonia, and DO are evaluated using WQM 7.0 (See Attachment 1). TRC is evaluated using the department’s TRC evaluation spreadsheet (See Attachment 2).

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	4.0	Daily Min.	WQM 7.0
CBOD ₅	25	Avg. Monthly	WQM 7.0
	50	IMAX	
Ammonia Nitrogen (May 1 – Oct 31)	21.0	Average Monthly	WQM 7.0
Ammonia Nitrogen (Nov 1 - Apr 30)	Report	IMAX	
TRC	0.5	Average Monthly	TRC evaluation spreadsheet

Comments: WQM 7.0 didn’t calculate more stringent average monthly limits for Ammonia-Nitrogen. The current limits established in previous permits are attainable and will be retained.

The TRC evaluation spreadsheet didn’t calculate more stringent average monthly TRC limit at perennial conditions using the plant design flow, the current limits established in previous permits are attainable and will be retained.

Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen effluent limit of a minimum of 4.0 mg/L, and monitoring for total nitrogen, total phosphorus and raw sewage influent monitoring for CBOD₅ and TSS are placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Winter monitoring has been established for Ammonia-Nitrogen as part of this renewal. In accordance with the department's SOP "*Establishing Effluent Limitations for Individual Sewage Permits*" a seasonal multiplier of 3 times the summertime average monthly limit should be established for the winter period. In accordance with Table 6-3 in the "*Technical Guidance for the Development and Specification of Effluent Limitations*", the frequency supposed to be 2/month sampling, however, since the discharge has consistently achieved effluent concentrations well below the required ammonia nitrogen limits and there are currently no known threatened or endangered mussels in the vicinity of the discharge, the monitoring requirement has been established as "Report" and the sampling frequency has been relaxed to 1/month.

Anti-Backsliding

No backsliding of limits is being proposed.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.006	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	XXX	XXX	Report	1/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	21.0	XXX	42.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Outfall Location - eMap with Aerial Imagery

The screenshot displays the Pennsylvania eMapPA web application interface. At the top, the Pennsylvania Department of Environmental Protection logo is on the left, and navigation links for PA State Agencies, Online Services, and state officials are on the right. The main map area shows aerial imagery with streams overlaid in various colors. A legend on the left categorizes streams by quality (e.g., Cold Water Fish, Exceptional Value) and designated uses. A popup window titled 'Designated Use Streams (1 of 3)' is open over a stream, displaying detailed metadata for 'Anthony Run'. A 'Locate Latitude and Longitude' dialog box is also visible in the top right corner of the map area.

Designated Use Streams (1 of 3)

- Designated Use Gen ID: 47836
- GNIS Name: Anthony Run
- GNIS ID: 01168334
- ReachCode: 05010006001576
- COMID: 123858071
- Length Miles: 0.669
- Map Symbology: CWF
- Length Miles: 0.669
- Designated Use: 1
- DES Use ID: 1
- Use Description: CWF(COLD WATER FISHES)
- Migratory_Fish: N
- HUC: 05010006
- Basin: N
- Basin Narrative: Null
- Segment Narrative: Null
- Evaluation Date: Null
- Last Fdit Date: Null
- Zoom to

Locate Latitude and Longitude


Decimal Degrees DD/MM/SS
 Latitude: Degrees: 40 Minutes: 37 Seconds: 48
 Longitude: -79 16 26
 [Locate] [Close]

Imagery: Source: Esri, Maxar, Earthstar Geographics, and the GIS User Community; ESRI Streets: Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand), NGCC, (c) OpenStreetMap contributors, and the GIS User Community

Drainage Area Location at Outfall 001 – StreamStats with Aerial Imagery

StreamStats Report

Region ID: PA
Workspace ID: PA20240401155617928000
Clicked Point (Latitude, Longitude): 40.63007, -79.27374
Time: 2024-04-01 11:56:43 -0400



+ Collapse All


> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	2.89	square miles

Downstream Drainage Area Location – StreamStats with Aerial Imagery

StreamStats Report

Region ID: PA
 Workspace ID: PA20240401155912088000
 Clicked Point (Latitude, Longitude): 40.64682, -79.27955
 Time: 2024-04-01 11:59:34 -0400



⊕ Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	4.95	square miles

Attachment 1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17E		46692		ANTHONY RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.380	Maple Valley	PA02175565	0.006	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17E	46692	ANTHONY RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.380	0.006	20.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
8.284	0.417	19.841	0.086	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.72	0.259	0.78	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.111	21.145	Owens	6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.942	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.094	2.65	0.73	8.24
	0.188	2.59	0.68	8.24
	0.283	2.52	0.64	8.24
	0.377	2.46	0.60	8.24
	0.471	2.40	0.56	8.24
	0.565	2.35	0.52	8.24
	0.660	2.29	0.49	8.24
	0.754	2.23	0.46	8.24
	0.848	2.18	0.43	8.24
	0.942	2.13	0.40	8.24

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46692	ANTHONY RUN	2.380	1060.00	2.89	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Maple Valley	PA02175565	0.0060	0.0000	0.0000	0.000	20.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46692	ANTHONY RUN	1.050	1015.00	4.95	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17E		46692				ANTHONY RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.380	0.29	0.00	0.29	.0093	0.00641	.417	8.28	19.84	0.09	0.942	20.00	7.00
Q1-10 Flow												
2.380	0.18	0.00	0.18	.0093	0.00641	NA	NA	NA	0.07	1.198	20.00	7.00
Q30-10 Flow												
2.380	0.39	0.00	0.39	.0093	0.00641	NA	NA	NA	0.10	0.797	20.00	7.00

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
 17E 46692 ANTHONY RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.380 Maple Valley	16.76	50	16.76	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.380 Maple Valley	1.89	25	1.89	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	2.38 Maple Valley	25	25	25	25	4	4	0	0

Attachment 2

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.289	= Q stream (cfs)		0.5	= CV Daily	
0.006	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 9.951		1.3.2.iii	WLA_cfc = 9.694
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 3.708		5.1d	LTA_cfc = 5.636
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

