

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0217786  
APS ID 785031  
Authorization ID 1396776

**Applicant and Facility Information**

Applicant Name	<u>New Eagle Borough Municipal Sewer Authority</u>	Facility Name	<u>New Eagle Borough STP</u>
Applicant Address	<u>157 Main Street</u> <u>New Eagle, PA 15067-1145</u>	Facility Address	<u>Robinson Street</u> <u>New Eagle, PA 15067</u>
Applicant Contact	<u>Mr. Paul Pro</u>	Facility Contact	<u>Mr. William Tatar</u>
Applicant Phone	<u>(724) 258-2393</u>	Facility Phone	<u>(412) 915-3753</u>
Client ID	<u>116675</u>	Site ID	<u>481246</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>New Eagle Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Washington</u>
Date Application Received	<u>May 18, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for the Renewal of a NPDES permit for the discharge of treated Sewage.</u>		

**Summary of Review**

The applicant has applied for a renewal of an existing NPDES Permit, PA0217786, which was previously issued by the Department on November 16, 2017. That permit expired on November 30, 2022.

WQM Permit No. 6397409, issued on May 12, 1998, authorized construction of a STP with an annual average design flow of 0.8 MGD. The existing facility consists of influent mechanical screening & grit removal, 2 SBRs, aerobic sludge digestion, chlorine disinfection, and a belt filter press.

Application data indicates that there are no industrial or commercial users in the system, and the facility does not receive hauled-in wastes.



The receiving stream, Monongahela River, is currently classified as a WWF, located in State Watershed No. 19-C.

The applicant has complied with Act 14 Notifications and no comments were received.

Sludge use and disposal description and location(s): Application data indicates that dried sewage sludge is disposed of at Westmoreland Landfill, 901 Tyrol Blvd., Belle Vernon, PA 15012.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-

Approve	Deny	Signatures	Date
X		 William C. Mitchell, E.I.T. / Environmental Engineering Specialist	September 8, 2023
x		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	September 12, 2023

**Summary of Review**

day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.8</u>
Latitude	<u>40° 12' 34.00"</u>	Longitude	<u>-79° 56' 52.00"</u>
Quad Name	<u>Monongahela</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99409154</u>	RMI	<u>30.7</u>
Drainage Area	<u>5,300</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.10377</u>
Q <sub>7-10</sub> Flow (cfs)	<u>550</u>	Q <sub>7-10</sub> Basis	<u>US Army Corp of Engineers</u>
Elevation (ft)	<u>730</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>NONE</u>	Exceptions to Criteria	<u>NONE</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>POLYCHLORINATED BIPHENYLS (PCBS)</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>	<u></u>	
Temperature (°F)	<u></u>	<u></u>	
Hardness (mg/L)	<u></u>	<u></u>	
Other:	<u></u>	<u></u>	
Nearest Downstream Public Water Supply Intake	<u>PA American Water Company Pittsburgh, PWSID #5020039</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>550</u>
PWS RMI	<u>25.51</u>	Distance from Outfall (mi)	<u>5.19</u>

Changes Since Last Permit Issuance: None

Other Comments: The discharge is to the Monongahela River which has an EPA Approved TMDL and is impaired by PCBs and Chlordane. No WLAs have been developed for this sewage discharge, as neither PCB nor Chlordane is typically found in sewage, but instead found in legacy sediments.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> New Eagle Borough STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6397409		05/12/1998		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Sequencing Batch Reactor	Gas Chlorine	0.8
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.8	1,334	Not Overloaded	Aerobic Sludge Digestion & Belt Filter Press	Landfill

Changes Since Last Permit Issuance: None

Other Comments: N/A

Compliance History

DMR Data for Outfall 001 (from July 1, 2022 to June 30, 2023)

Parameter	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22
Flow (MGD) Average Monthly	0.200	0.182	0.207	0.432	0.274	0.547	0.236	0.271	0.228	0.192	0.193	0.187
Flow (MGD) Daily Maximum	0.626	0.389	0.435	2.036	0.669	2.624	0.886	1.500	1.517	0.498	0.909	0.676
pH (S.U.) Minimum	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8
pH (S.U.) Maximum	7.2	7.2	7.2	7.1	7.1	7.1	7.2	7.2	7.2	7.2	7.2	7.2
DO (mg/L) Minimum	4.95	4.95	5.39	6.11	5.96	6.58	6.61	5.92	5.33	5.22	4.73	4.27
TRC (mg/L) Average Monthly	0.43	0.42	0.41	0.38	0.40	0.38	0.38	0.42	0.42	0.42	0.43	0.43
TRC (mg/L) Instantaneous Maximum	0.45	0.47	0.45	0.44	0.45	0.45	0.44	0.46	0.46	0.46	0.46	0.46
CBOD5 (lbs/day) Average Monthly	4	3	3	13	6	24	9	3	3	3	5	2
CBOD5 (lbs/day) Weekly Average	6	4	6	40	8	31	30	4	8	3	15	4
CBOD5 (mg/L) Average Monthly	3	2	2	3	2	3	3	2	2	2	2	1
CBOD5 (mg/L) Weekly Average	3	2	3	3	3	4	4	3	3	3	3	2
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	188	146	137	532	167	599	237	147	131	118	291	113
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	379	209	166	1834	191	938	672	279	194	161	895	158
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	106	102	95	98	72	80	80	91	68	99	94	81
BOD5 (mg/L) Raw Sewage Influent   Weekly Average	144	126	106	136	87	92	96	135	80	110	124	118

**NPDES Permit Fact Sheet  
New Eagle Borough STP**

**NPDES Permit No. PA0217786**

TSS (lbs/day) Average Monthly	1	2	2	4	5	12	3	3	2	3	1	3
TSS (lbs/day) Raw Sewage Influent   Average Monthly	205	169	152	313	292	412	177	196	158	229	152	222
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	384	357	190	473	490	594	193	439	242	324	198	400
TSS (lbs/day) Weekly Average	3	2	3	8	9	21	4	5	3	5	2	6
TSS (mg/L) Average Monthly	1	1	1	1	2	2	2	2	1	2	1	1
TSS (mg/L) Raw Sewage Influent   Average Monthly	117	112	104	118	103	83	104	106	87	147	129	83
TSS (mg/L) Raw Sewage Influent   Weekly Average	157	147	122	125	111	90	127	175	115	201	175	122
TSS (mg/L) Weekly Average	1	2	2	2	2	3	2	2	2	3	2	2
Fecal Coliform (No./100 ml) Geometric Mean	10	8	10	11	13	17	14	9	8	9	8	9
Fecal Coliform (No./100 ml) Instantaneous Maximum	14	10	11	12	18	25	16	14	8	12	11	11
Total Nitrogen (mg/L) Daily Maximum							1.22					
Ammonia (mg/L) Average Monthly	0.400	0.400	0.400	0.800	0.800	0.800	0.800	0.800	0.800	0.800	0.800	0.800
Ammonia (mg/L) Weekly Average	0.400	0.400	0.400	0.800	0.800	0.800	0.800	0.800	0.800	0.800	0.800	0.800
Total Phosphorus (mg/L) Daily Maximum							4.9					

Compliance History

**Operations Compliance Check Summary Report**

**Facility:** New Eagle Borough STP

**NPDES Permit No.:** PA0217786

**Compliance Review Period:** 8/28/18-8/28/23

**Inspection Summary:**

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
08/29/2022	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted

**Violation Summary:**

No violations noted during review period

**Open Violations by Client ID:**

No open violations for Client ID 116675

**Enforcement Summary:**

No enforcements executed during review period

**Effluent Violation Summary:**

No effluent exceedances are indicated in eDMR during the review period. During the September 2019 monitoring period, A Non-Compliance incident was reported for an unauthorized discharge to Mingo Creek from C Pump Station. The sewage release occurred for an unknown duration when one pump failed, and a second pump became clogged with a piece of PVC pipe. The release quantity was reported as 0.001 gallons, but it is presumed that the Client intended to report the quantity as .001 MGD.

**Compliance Status:** Facility does not currently have any open violations or pending enforcements.

**Completed by:** Amanda Schmidt

**Completed date:** 8/28/23

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.8</u>
<b>Latitude</b> <u>40° 12' 34.00"</u>	<b>Longitude</b> <u>-79° 56' 52.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The discharge was evaluated using WQM 7.0 Version 1.1 & TRC\_CALC (Attachments 2 & 3) to evaluate CBOD<sub>5</sub>, Ammonia Nitrogen, Dissolved Oxygen, and TRC parameters. The modeling results show the above technology based effluent limitations are appropriate.

For existing discharges, if WQM modeling results for summer indicates that an average monthly limit of 25 mg/L (ammonia-nitrogen) is acceptable, the application manager will generally establish a year-round monitoring requirement for ammonia-nitrogen (Section I.A, Note 5, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9).

**Water Quality-Based Limitations**

Comments: NO WQBELs will be established at this time for this facility.

**Best Professional Judgment (BPJ) Limitations**

Comments: A minimum Dissolved Oxygen (DO) limit of 4.0 mg/L will be established based on BPJ to ensure adequate operation and maintenance (Section I.A, Note 6, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9).

**Anti-Backsliding**

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the



time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

**Additional Considerations**

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document No. 386-0400-001).

For POTWs, mass loading limits will be established for CBOD5, TSS, NH3-N, and where necessary Total P and Total N. In general, average monthly mass loading limits will be established for CBOD5, TSS, NH3-N, and where necessary Total P and Total N, and average weekly mass loading limits will be established for CBOD5 and TSS (Section IV, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9).

For POTWs with design flows greater than 2,000 GPD and for non-municipal sewage facilities that service municipalities or portions thereof, the application manager will establish influent BOD5 and TSS monitoring in the permit using the same frequency and sample type as is used for other effluent parameters (Section IV.E.8, SOP for Clean Water Program, New and Reissuance Sewage Individual NPDES Permit Applications, Final November 9, 2012, Revised February 3, 2022, Version 2.0).

Sewage discharges will include monitoring, at a minimum, for *E. Coli*, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows  $\geq 0.05$  and  $< 1$  MGD per 92a.61 and Section I.A, Note 12, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9.

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). A 1/quarter monitoring requirement for Total N & Total P has been added to the permit per Chapter 92a.61 and Section I.A, Note 7 & 8, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9. Discharge is to waters not impaired for nutrients.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	165	265	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	24-Hr Composite
TSS	200	300	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite
Ammonia-Nitrogen	XXX	Report Avg Mo	XXX	Report	XXX	XXX	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001


Other Comments: N/A

## Attachment 1 – USGS StreamStats Report

### PA0217786 - StreamStats Report

Region ID: PA  
 Workspace ID: PA20230831185517626000  
 Clicked Point (Latitude, Longitude): 40.20924, -79.93811  
 Time: 2023-08-31 14:55:46 -0400



 Collapse All

#### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	5300	square miles
ELEV	Mean Basin Elevation	1830	feet

#### ➤ Low-Flow Statistics

Low-Flow Statistics Parameters [99.9 Percent (5290 square miles) Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	5300	square miles	2.26	1400
ELEV	Mean Basin Elevation	1830	feet	1050	2580

Low-Flow Statistics Disclaimers [99.9 Percent (5290 square miles) Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.9 Percent (5290 square miles) Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	698	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	926	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	408	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	477	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	707	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any

such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.17.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**Attachment 2 – WQM 7.0 Version 1.1 – Summer Period**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37185	MONONGAHELA RIVER	30.700	730.00	5300.00	0.00010	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.104	550.00	0.00	0.000	0.000	0.0	783.10	9.50	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
New Eagle STP	PA0217786	0.8000	0.8000	0.8000	0.000	20.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37185	MONONGAHELA RIVER	30.200	730.00	5300.50	0.00010	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.104	550.00	0.00	0.000	0.000	0.0	890.39	9.50	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70



**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19A		37185				MONONGAHELA RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
30.700	550.00	0.00	550.00	1.2376	0.00010	9.5	783.1	82.43	0.07	0.412	24.99	7.00
<b>Q1-10 Flow</b>												
30.700	352.00	0.00	352.00	1.2376	0.00010	NA	NA	NA	0.05	0.644	24.98	7.00
<b>Q30-10 Flow</b>												
30.700	748.00	0.00	748.00	1.2376	0.00010	NA	NA	NA	0.10	0.303	24.99	7.00

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

SWP Basin      Stream Code                      Stream Name  
 19A                      37185                                      MONONGAHELA RIVER

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
30.700	New Eagle STP	11.09	50	11.09	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
30.700	New Eagle STP	1.37	25	1.37	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
30.70	New Eagle STP	25	25	25	25	4	4	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19A	37185	MONONGAHELA RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
30.700	0.800	24.989	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
783.100	9.500	82.432	0.074	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.05	0.029	0.06	1.028	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.233	0.135	O'Connor	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.412	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.041	2.05	0.05	7.54
	0.082	2.05	0.05	7.54
	0.124	2.04	0.05	7.54
	0.165	2.04	0.05	7.54
	0.206	2.04	0.05	7.54
	0.247	2.03	0.04	7.54
	0.289	2.03	0.04	7.54
	0.330	2.03	0.04	7.54
	0.371	2.02	0.04	7.54
	0.412	2.02	0.04	7.54

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19A	37185	MONONGAHELA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
30.700	New Eagle STP	PA0217786	0.800	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

### Attachment 3 – TRC CALC

PA\_0217786\_TRC\_CALC

#### TRC EVALUATION

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="width: 50%;">550 = Q stream (cfs)</td><td style="width: 50%;">0.5 = CV Daily</td></tr> <tr><td>0.8 = Q discharge (MGD)</td><td>0.5 = CV Hourly</td></tr> <tr><td>30 = no. samples</td><td>1 = AFC_Partial Mix Factor</td></tr> <tr><td>0.3 = Chlorine Demand of Stream</td><td>1 = CFC_Partial Mix Factor</td></tr> <tr><td>0 = Chlorine Demand of Discharge</td><td>15 = AFC_Criteria Compliance Time (min)</td></tr> <tr><td>0.5 = BAT/BPJ Value</td><td>720 = CFC_Criteria Compliance Time (min)</td></tr> <tr><td>= % Factor of Safety (FOS)</td><td>=Decay Coefficient (K)</td></tr> </table>	550 = Q stream (cfs)	0.5 = CV Daily	0.8 = Q discharge (MGD)	0.5 = CV Hourly	30 = no. samples	1 = AFC_Partial Mix Factor	0.3 = Chlorine Demand of Stream	1 = CFC_Partial Mix Factor	0 = Chlorine Demand of Discharge	15 = AFC_Criteria Compliance Time (min)	0.5 = BAT/BPJ Value	720 = CFC_Criteria Compliance Time (min)	= % Factor of Safety (FOS)	=Decay Coefficient (K)	
550 = Q stream (cfs)	0.5 = CV Daily														
0.8 = Q discharge (MGD)	0.5 = CV Hourly														
30 = no. samples	1 = AFC_Partial Mix Factor														
0.3 = Chlorine Demand of Stream	1 = CFC_Partial Mix Factor														
0 = Chlorine Demand of Discharge	15 = AFC_Criteria Compliance Time (min)														
0.5 = BAT/BPJ Value	720 = CFC_Criteria Compliance Time (min)														
= % Factor of Safety (FOS)	=Decay Coefficient (K)														
Source	Reference	AFC Calculations	Reference	CFC Calculations											
TRC	1.3.2.iii	WLA_afc = 141.785	1.3.2.iii	WLA_cfc = 138.222											
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581											
PENTOXSD TRG	5.1b	LTA_afc = 52.833	5.1d	LTA_cfc = 80.356											
Source	Effluent Limit Calculations														
PENTOXSD TRG	5.1f	AML_MULT = 1.231													
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ												
		INST MAX LIMIT (mg/l) = 1.635													
WLA_afc	(.019/e <sup>-k*AFC_tc</sup> ) + [(AFC_Yc*Qs*.019/Qd*e <sup>-k*AFC_tc</sup> )]... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)														
LTAMULT_afc	EXP((0.5*LN(cvh <sup>2</sup> +1))-2.326*LN(cvh <sup>2</sup> +1) <sup>0.5</sup> )														
LTA_afc	wla_afc*LTAMULT_afc														
WLA_cfc	(.011/e <sup>-k*CFC_tc</sup> ) + [(CFC_Yc*Qs*.011/Qd*e <sup>-k*CFC_tc</sup> )]... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)														
LTAMULT_cfc	EXP((0.5*LN(cvd <sup>2</sup> /no_samples+1))-2.326*LN(cvd <sup>2</sup> /no_samples+1) <sup>0.5</sup> )														
LTA_cfc	wla_cfc*LTAMULT_cfc														
AML_MULT	EXP(2.326*LN((cvd <sup>2</sup> /no_samples+1) <sup>0.5</sup> )-0.5*LN(cvd <sup>2</sup> /no_samples+1))														
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)														
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)														