

Southwest Regional Office  
CLEAN WATER PROGRAM

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0217824  
APS ID 1114171  
Authorization ID 1485892

**Applicant and Facility Information**

Applicant Name	<u>YMCA Of Greater Pittsburgh</u>	Facility Name	<u>Camp Kon O Kwee Spencer</u>
Applicant Address	<u>126 Nagel Road</u> <u>Fombell, PA 16123-1136</u>	Facility Address	<u>290 Narrows Road</u> <u>Fombell, PA 16123-2224</u>
Applicant Contact	<u>Michael McElhinney</u>	Facility Contact	
Applicant Phone	<u>(724) 758-6283</u>	Facility Phone	
Client ID	<u>4793</u>	Site ID	<u>242812</u>
Ch 94 Load Status		Municipality	<u>Marion Township</u>
Connection Status		County	<u>Beaver</u>
Date Application Received	<u>May 21, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>Renewal</u>		

**Summary of Review**

The permittee has applied to renew PA0217824. The last renewal was issued on 12/04/2019 and expired on 12/31/2024.

The facility discharges to the Connoquenessing Creek, which is a Warm-water fishery.

The facility consists of two grinder pumps, a debris basket, two aerated/aerobic lagoons, a chlorine injection manhole, two facultative/sedimentation lagoons, and two chlorine contact tanks.

Act 14 Notifications were provided on May 17 and 19 of 2024.



The client has no open violations by client ID.

In a 1985 letter from Peter A. Yeager, Regional Water Quality Manager, the DEP established a 2.0 mg/L effluent limit for all dischargers to the Connoquenessing Creek. In the last permit renewal, the limit was negotiated to an annual mass loading limit. The letter is included in Attachment 6.

Per the previous permit renewal:

*"DEP is willing to approve a mass loading approach on an annual basis with the understanding a concentration limit of 2 mg/l is not changing and that the load will not be based on the plant's design flow of 0.03 mgd. An annual TP mass load effluent limitation of 42.62 lbs. is imposed in the permit and is based on historical flow records that establish a current existing average daily flow in mgd multiplied by a concentration limit of 2 mg/l, a conversion factor of 8.34, and 365 days/year.*

*The daily discharge load for TP (lbs./day) equals the flow (mgd) on the day of sampling, multiplied by that day's sample concentration of TP (mg/l), multiplied by 8.34. A monthly total mass load is computed by taking the sum of the actual daily*

Approve	Return	Deny	Signatures	Date
x			 Sam Mahsoob, EIT / Environmental Engineering Trainee	7/8/2025
x			 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineer Manager	7/11/2025

### Summary of Review

discharge loads for TP (lbs./day) divided by the number of samples per month, multiplied by the number of days in the month in which there was a discharge. The permit is conditioned to require the daily discharge flow the day of sampling be measured and recorded on the Daily Effluent Monitoring Report.

An example of how a monthly mass load is to be calculated is provided below:

Flow volume day sample #1 taken = 2,550 gallons  
TP concentration for sample #1 = 1.7 mg/l  
Daily discharge load =  $0.00255 \text{ mgd} \times 1.7 \text{ mg/l} \times 8.34 = 0.036 \text{ lbs.}$

Flow volume day sample #2 taken = 3,650 gallons  
TP concentration for sample #2 = 3.0 mg/l  
Daily discharge load =  $0.00365 \text{ mgd} \times 3.0 \text{ mg/l} \times 8.34 = 0.091 \text{ lbs.}$

The sum of the daily discharge loads =  $0.036 \text{ lbs.} + 0.091 \text{ lbs.} = 0.127 \text{ lbs.}$

The sum of the daily discharge loads of 0.127 lbs. is divided by the number of samples taken for the month, therefore  $0.127 \text{ lbs.} \div 2 = 0.064 \text{ lbs.}$

The monthly total mass load would be computed by taking 0.064 lbs. multiplied by the number of days in June, therefore  $0.064 \text{ lbs.} \times 30 = 1.91 \text{ lbs.}$

This approach allows flexibility for the camp to make adjustments as needed throughout the year to stay in compliance with the mass load effluent limit while still maintaining the actual 2 mg/l concentration limit as an average over the year, based on actual flow discharged. The Department did not permit the use of the design flow of 0.03 mgd to establish a mass flow effluent limit as this would allow the camp to take credit for flow that is not actually discharged. Because actual flows are much lower than the design flow of 0.03 mgd, the camp would have been able to discharge flows with concentrations greater than 2.0 mg/l while still meeting a mass loading based on the design flow."

### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.005
Latitude	40° 48' 57"	Longitude	-80° 13' 26"
Quad Name	Zelienople	Quad Code	40080G2
Wastewater Description:	Sewage Effluent		
Receiving Waters	Connoquenessing Creek (WWF)	Stream Code	34025
NHD Com ID	126223595	RMI	12.6
Drainage Area	353	Yield (cfs/mi <sup>2</sup> )	0.032
Q <sub>7-10</sub> Flow (cfs)	11.3	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	859.71	Slope (ft/ft)	0.001
Watershed No.	20-C	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	<b>Not Impaired</b>		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	<b>None</b>	Name	
Background/Ambient Data	Data Source		
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	PWS ID: 5040012 System Name: BEAVER FALLS MUNI AUTH		
PWS Waters	Beaver River	Flow at Intake (cfs)	3180
PWS RMI	5.6	Distance from Outfall (mi)	19.42

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Camp Kon O Kwee Spencer				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
0400408	10/09/2000			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Aerated Lagoon	Chlorination	.005
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
.03	88	Not Overloaded	None	None

**Compliance History**

**A compliance check will be provided for the final permit.**

Compliance History

DMR Data for Outfall 001 (from June 1, 2024 to May 31, 2025)

Parameter	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24
Flow (MGD) Average Monthly	0.007	0.003	0.003	0.005	0.0018	0.002	0.001	0.001	0.003	0.007	0.007	0.005
pH (S.U.) Instantaneous Minimum	6.98	6.96	7.24	7.01	7.14	7.10	7.08	7.01	6.96	7.03	6.97	6.99
pH (S.U.) Instantaneous Maximum	7.45	8.00	7.95	7.85	8.50	7.99	7.37	7.76	7.91	7.43	7.28	7.23
DO (mg/L) Instantaneous Minimum	5.49	7.80	5.67	9.21	10.96	5.96	6.79	2.97	2.47	3.36	2.27	2.80
TRC (mg/L) Average Monthly	0.17	0.17	0.12	0.17	0.18	0.12	0.15	0.09	0.06	0.06	0.06	0.09
TRC (mg/L) Instantaneous Maximum	0.46	0.34	0.32	0.48	0.46	0.25	0.33	0.43	0.38	0.13	0.13	0.25
CBOD5 (mg/L) Average Monthly	< 3.0	3.3	6.0	< 3.0	5.4	< 5.50	< 3.0	5.4	< 3.0	3.0	3.0	5.5
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	3.5	8.9	< 3.0	7.4	< 8.0	< 3.0	7.7	< 3.0	3.0	3.0	6.2
TSS (mg/L) Average Monthly	5.5	5.75	< 5.0	6.0	5.0	< 5.0	< 5.0	< 5.0	6.5	7.3	5.0	5.3
TSS (mg/L) Instantaneous Maximum	5.5	6.5	< 5.0	7.0	5.0	< 5.0	< 5.0	< 5.0	8.0	9.5	5.0	5.5
Fecal Coliform (No./100 ml) Geometric Mean	5.57	2	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	1	1
Fecal Coliform (No./100 ml) Instantaneous Maximum	31	4	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	1	1
Total Nitrogen (mg/L) Average Monthly	5.47	8.55	8.78	8.14	3.48	2.32	2.68	3.58	2.51	4.52	7.95	5.04

NPDES Permit Fact Sheet  
Camp Kon O Kwee Spencer

NPDES Permit No. PA0217824

Total Nitrogen (mg/L) Instantaneous Maximum	5.593	10.6	9.84	8.57	3.79	3.51	2.78	3.84	2.97	5.08	8.26	5.34
Ammonia (mg/L) Average Monthly	2.40	3.59	2.64	2.06	0.94	0.70	0.85	1.21	1.695	1.42	6.00	3.27
Total Phosphorus (mg/L) Average Monthly	1.075	1.24	1.27	1.29	1.48	0.98	1.43	0.82	0.774	1.42	1.46	0.943
Total Phosphorus (mg/L) Instantaneous Maximum	1.31	1.53	1.36	1.37	1.61	1.77	1.50	1.62	1.07	2.54	1.49	1.03
Total Phosphorus (lbs) Effluent Net   Total Monthly	2.10	1.08	0.63	1.28	1.44	0.023	0.105	0.20	0.57	2.79	1.86	0.585
Total Phosphorus (lbs) Effluent Net   Total Annual						7.74						

DMR Data for Outfall 101 (from June 1, 2024 to May 31, 2025)

Parameter	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24
Flow (MGD) Groundwater   Daily Maximum			0.009			0.007			0.02			0.013
CBOD5 (mg/L) Groundwater   Daily Maximum			< 3.0			< 3.0			< 3.0			10.0
TSS (mg/L) Groundwater   Daily Maximum			< 5.0			< 5.0			5.0			< 5.0
Fecal Coliform (No./100 ml) Groundwater   Daily Maximum			< 1			< 1			< 1			< 1
Ammonia (mg/L) Groundwater   Daily Maximum			< 0.30			< 0.30			< 0.30			< 0.30

**Development of Effluent Limitations**

**Outfall No.** 001  
**Latitude** 40° 48' 57.00"  
**Wastewater Description:** Sewage Effluent

**Design Flow (MGD)** .005  
**Longitude** -80° 13' 26.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/L)	SBC	Federal Regulation	State Regulation
Flow	Report	Max Daily	-	§§ 92a.27, 92a.61
Flow	Report	Max Daily	-	§§ 92a.27, 92a.61
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Nitrogen	Report	Average Monthly	-	92a.61(7)
Total Phosphorus	Report	Average Monthly	-	92a.61(8)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
E. Coli (No./100 ml)	-	Report		93a.61(11)(12)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.6	IMAX	-	92a.47-48(3)(4)
Ammonia-Nitrogen	25	Average Monthly	-	BPJ (5)
Ammonia-Nitrogen	50	IMAX	-	BPJ (5)
Dissolved Oxygen	4.0	IMIN	-	BPJ (6)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling ():

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen	25.0	Average Monthly	WQM 7.0
Ammonia-Nitrogen	50.0	IMAX	WQM 7.0
Dissolved Oxygen	4.0	Minimum	WQM 7.0
Total Residual Chlorine	0.5	Average Monthly	TRC
Total Residual Chlorine	1.6	IMAX	TRC

Comments: The WQM 7.0 and TRC models recommended the default limits be imposed for Ammonia-Nitrogen, Dissolved Oxygen, and Total Residual Chlorine.

**Development of Effluent Limitations**

<b>Outfall No.</b>	101	<b>Design Flow (MGD)</b>	0
<b>Latitude</b>	40° 48' 51.00"	<b>Longitude</b>	-80° 13' 37.00"
Groundwater beneath the sewage treatment plant's liner system to check for contamination			
<b>Wastewater Description:</b> due to leaks.			

Pollutant	Limit (mg/l)	SBC
Flow (mgd)	Report	Daily Maximum
CBOD <sub>5</sub>	Report	Daily Maximum
Total Suspended Solids	Report	Daily Maximum
Ammonia Nitrogen	Report	Daily Maximum
Fecal Coliform (No./100 ml)	Report	Daily Maximum

Comments: The above requirements are consistent with the previous NPDES permit. The previous permit however, required Fecal Coliform to be reported in CFU/100 ml and this renewal permit eliminates the effluent concentration be reported as a geometric mean because only 1 sample is required per quarter. Last five years' data does not suggest that additional sampling is required.

### Additional Considerations

#### Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation. Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

*(40 CFR 122.44 (l)(2) Establishing limitations, standards, and other permit conditions., 40 CFR Ch. I (7-1-21 Edition))*

No permits limits have been made less stringent in the renewal draft permit.

#### E. Coli

Sewage discharges will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/month for design flows  $\geq 1$  MGD, 1/quarter for design flows  $\geq 0.05$  and  $< 1$  MGD, 1/year for design flows of 0.002 – 0.05 MGD.

*(Note 12 SOP-Establishing Effluent Limitations for Individual Sewage Permits Final November 9, 2012, Revised February 5, 2024, Version 2.0. and 25 PA Code 92a.61(b).)*

#### Effluent Multipliers

Section 2.C of the Permit Writers Manual contains the procedure for converting average monthly effluent limitations to average weekly, maximum daily, and instantaneous maximum effluent limitations. The average monthly limit is multiplied according to the following chart:

Discharge <u>Solution</u>	Parameters	Average <u>Weekly</u>	Maximum <u>Daily</u>	Instantaneous Maximum <u>Multiplier</u>
Sewage	All	1.5		2.0
Industrial	All		2.0	2.5*

*(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))*

#### Chlorine Disinfection

Disinfection at this facility is provided by tablet chlorination. Per the SOP for effluent limitations and the recommendations from the TRC\_Calc Model (See Attachment 1), a monthly limit of 0.5 mg/L and an instantaneous maximum of 1.6 mg/L is established.

*(Section I.A, Note 3, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9 and 25 PA Code 92a.61(b).)*

### Nutrient Monitoring

Nutrient monitoring is required by the SOP for Effluent Limitations for Individual Sewage Permits. Monitoring is included to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). The receiving stream is not listed as impaired for nutrients, therefore at the discretion of the application manager, a monitoring frequency less than the equivalent of conventional pollutants in Table 6-3 of the Permit Writer's Manual has been selected. Per a memorandum from Peter Yeager dated January 9, 1985, a maximum technology limit of 2.0 mg/L of phosphorous should be incorporated into all NPDES permits for the Connoquenessing Creek watershed. In the last permit renewal, the limit was negotiated to an annual mass loading limit of 42.62 lbs/year.

*(Section I.A, Note 7 & 8, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9 and 25 PA Code 92a.61(b).)*

### Rounding Off

Section 5 C.2. of the Permit Writers Manual contains general guidelines for rounding conventional and toxic pollutants, with instructions to round down to the nearest decimal place indicated.

<u>General Magnitude</u>	<u>Conventional Pollutants</u>	<u>Toxic Pollutants</u>
<0.01	to nearest 0.001	to nearest 0.001
0.01 - 0.1	to nearest 0.01	to nearest 0.01
0.1 - 1.0	to nearest 0.1	to nearest 0.01
1.0 - 10.0	to nearest 0.5	to nearest 0.01
10.0 - 60.0	to nearest 1.0	to nearest 0.01
60.0 or greater	to nearest 5.0	to nearest 0.10

*(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))*

### Effluent Multipliers

Section 2.C of the Permit Writers Manual contains the procedure for converting average monthly effluent limitations to average weekly, maximum daily, and instantaneous maximum effluent limitations. The average monthly limit is multiplied according to the following chart:

Discharge Solution	Parameters	Average Weekly	Maximum Daily	Instantaneous Maximum Multiplier
Sewage	All	1.5	2.0	2.0
Industrial	All		2.0	2.5*

*(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))*

Table 6-3 – Self-Monitoring Requirements for SEWAGE Discharges

Plant Design Flow (MGD)	Flow Monitoring	C-BOD <sub>5</sub> or BOD <sub>5</sub>	Suspended Solids	pH	Fecal Coliform	Chlorine Residual	NH <sub>3</sub> -N	Phosphorus	DO	Toxics
Single Residence (Individual Permit)	2/year by estimate	2/year*	2/year*	1/month*	2/year*	1/month*	2/year*	2/year*	2/year*	N/A
.0005 to .002	weekly, using average pump rate or weir (a)	1/month*	1/month*	daily*	1/month*	daily*	1/month*	1/month*	daily*	N/A
.002 to .01	<b>weekly, using average pump rate or weir (a)</b>	<b>2/month*</b>	<b>2/month*</b>	<b>daily*</b>	<b>2/month*</b>	<b>daily*</b>	<b>2/month*</b>	<b>2/month*</b>	<b>daily*</b>	N/A
0.01 to 0.1	weekly, using average pump rate or weir (a)	2/month*	2/month*	daily*	2/month*	daily*	2/month*	2/month*	Daily*	1/week*
0.1 to 1.0	meter	1/week**	1/week**	daily*	1/week*	daily*	1/week**	1/week**	daily*	1/week****
1.0 to 5.0	meter	2/week***	2/week***	daily*	2/week*	daily*	2/week***	2/week***	daily*	1/week****
5.0 to 25.0	meter	daily***	daily***	daily*	daily*	1/shift*	daily***	daily***	daily*	1/week****
over 25.0	meter	daily***	daily***	1/shift*	daily*	1/shift*	1/shift***	1/shift***	1/shift*	1/week****

\* Grab sample-these should be most representative of the effluent and are to be taken at a time when the normal daily maximum flow would reach the sampling point.

\*\* 8-hour composite sample.

\*\*\* 24-hour composite sample.

\*\*\*\* Same sample type as for Industrial Process Wastewater (See Table 6-4).

## Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Total Phosphorus (lbs) Effluent Net	XXX	42.62 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs) Effluent Net	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 101, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Daily Maximum	Maximum	Instant. Maximum		
Flow (MGD) Groundwater	XXX	Report Daily Max	XXX	XXX	XXX	XXX	1/quarter	Measured
CBOD5 Groundwater	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Grab
TSS Groundwater	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Grab
Fecal Coliform (No./100 ml) Groundwater	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Grab
Ammonia Groundwater	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Grab

Compliance Sampling Location: Outfall 101


# Attachment 1

## USGS StreamStats

### Upstream

StreamStats Report - Upstream

Region ID: PA  
Workspace ID: PA20250625195320784000  
Clicked Point (Latitude, Longitude): 40.81608, -80.22418  
Time: 2025-06-25 15:53:52 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	353	square miles
ELEV	Mean Basin Elevation	1190	feet

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	353	square miles	2.26	1400

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ELEV	Mean Basin Elevation	1190	feet	1050	2580
<b>Low-Flow Statistics Flow Report [Low Flow Region 4]</b>					
PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR <sup>2</sup> : Pseudo R Squared (other -- see report)					
Statistic		Value	Unit	SE	ASEp
7 Day 2 Year Low Flow		22.3	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow		32.7	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow		11.3	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow		15.6	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow		24	ft <sup>3</sup> /s	41	41
<i>Low-Flow Statistics Citations</i>					
Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. ( <a href="http://pubs.usgs.gov/sir/2006/5130/">http://pubs.usgs.gov/sir/2006/5130/</a> )					

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


# Attachment 2

## USGS StreamStats

### Downstream

StreamStats Report - Downstream

Region ID: PA  
Workspace ID: PA20250625195930750000  
Clicked Point (Latitude, Longitude): 40.81248, -80.22970  
Time: 2025-06-25 15:59:58 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	355	square miles
ELEV	Mean Basin Elevation	1190	feet

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	355	square miles	2.26	1400

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ELEV	Mean Basin Elevation	1190	feet	1050	2580
<b>Low-Flow Statistics Flow Report [Low Flow Region 4]</b>					
PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR <sup>2</sup> : Pseudo R Squared (other -- see report)					
Statistic		Value	Unit	SE	ASEp
7 Day 2 Year Low Flow		22.4	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow		32.9	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow		11.4	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow		15.7	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow		24.1	ft <sup>3</sup> /s	41	41
<i>Low-Flow Statistics Citations</i>					
Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. ( <a href="http://pubs.usgs.gov/sir/2006/5130/">http://pubs.usgs.gov/sir/2006/5130/</a> )					

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

# Attachment 3

## WQM 7.0 Model -

## Summer

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34025 CONNOQUENESSING CREEK				12.600	859.71	353.00	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.032	0.00	0.00	0.000	0.000	0.0	172.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000				0.00	0.00
Q30-10		0.00	0.00	0.000	0.000				0.00	0.00
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Outfall 001	PA0217824	0.0050	0.0050	0.0050	0.000	20.00	7.50		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	4.00	8.24	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
20C	34025 CONNOQUENESSING CREEK				12.220	857.58	355.00	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)		
Q7-10	0.032	0.00	0.00	0.000	0.000	0.0	190.00	0.00	25.00	7.00		
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>												
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
			0.0000	0.0000	0.0000	0.000	25.00	7.00				
<b>Parameter Data</b>												
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
	CBOD5		25.00	2.00	0.00	1.50						
	Dissolved Oxygen		3.00	8.24	0.00	0.00						
	NH3-N		25.00	0.00	0.00	0.70						

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5.5		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
20C			34025			CONNOQUENESSING CREEK							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
12.600	11.30	0.00	11.30	.0077	0.00106	.333	172	517.23	0.20	0.118	25.00	7.00	
<b>Q1-10 Flow</b>													
12.600	7.23	0.00	7.23	.0077	0.00106	NA	NA	NA	0.15	0.151	24.99	7.00	
<b>Q30-10 Flow</b>													
12.600	15.36	0.00	15.36	.0077	0.00106	NA	NA	NA	0.23	0.099	25.00	7.00	

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>															
20C	34025	CONNOQUENESSING CREEK																
<b>NH3-N Acute Allocations</b>																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
12.600	Outfall 001	11.08	50	11.08	50	0	0											
<b>NH3-N Chronic Allocations</b>																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
12.600	Outfall 001	1.37	25	1.37	25	0	0											
<b>Dissolved Oxygen Allocations</b>																		
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>												
12.60	Outfall 001	25	25	25	25	4	4											
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)											
						Critical Reach	Percent Reduction											

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u> 20C	<u>Stream Code</u> 34025	<u>Stream Name</u> CONNOQUENESSING CREEK		
		Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
RMI 12.600		0.005	24.997	7.000
Reach Width (ft) 172.000	Reach Depth (ft) 0.333		Reach WDRatio 517.231	Reach Velocity (fps) 0.198
Reach CBOD5 (mg/L) 2.02	Reach Kc (1/days) 0.011		Reach NH3-N (mg/L) 0.02	Reach Kn (1/days) 1.028
Reach DO (mg/L) 8.240	Reach Kr (1/days) 1.612		Kr Equation Tsivoglou	Reach DO Goal (mg/L) 5.5
<u>Reach Travel Time (days)</u> 0.118		<b>Subreach Results</b>		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.012	2.02	0.02	7.54
	0.024	2.02	0.02	7.54
	0.035	2.01	0.02	7.54
	0.047	2.01	0.02	7.54
	0.059	2.01	0.02	7.54
	0.071	2.01	0.02	7.54
	0.082	2.01	0.02	7.54
	0.094	2.01	0.02	7.54
	0.106	2.01	0.02	7.54
	0.118	2.01	0.02	7.54

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34025	CONNOQUENESSING CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Efl. Limit 30-day Ave. (mg/L)	Efl. Limit Maximum (mg/L)	Efl. Limit Minimum (mg/L)
12.600	Outfall 001	PA0217824	0.005	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

# Attachment 4

## WQM 7.0 Model -

### Winter

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34025 CONNOQUENESSING CREEK				12.600	859.71	353.00	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.064	0.00	0.00	0.000	0.000	0.0	172.00	0.00	5.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Outfall 001	PA0217824	0.0050	0.0050	0.0050	0.000	15.00	7.50		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	4.00	12.51	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34025 CONNOQUENESSING CREEK				12.220	857.58	355.00	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.064 0.00 0.00 0.000 0.000 0.0 190.00 0.00 5.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
<b>Discharge Data</b>										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
0.0000 0.0000 0.0000 0.000 25.00 7.00										
<b>Parameter Data</b>										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5 Dissolved Oxygen NH3-N				25.00	2.00	0.00	1.50			
3.00 25.00				8.24	0.00	0.00				
				0.00	0.00	0.70				

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5.5		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
20C			34025			CONNOQUENESSING CREEK							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
12.600	22.59	0.00	22.59	.0077	0.00106	.451	172	381.33	0.29	0.080	5.00	7.00	
<b>Q1-10 Flow</b>													
12.600	14.46	0.00	14.46	.0077	0.00106	NA	NA	NA	0.23	0.102	5.01	7.00	
<b>Q30-10 Flow</b>													
12.600	30.73	0.00	30.73	.0077	0.00106	NA	NA	NA	0.35	0.067	5.00	7.00	

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>															
20C	34025	CONNOQUENESSING CREEK																
<b>NH3-N Acute Allocations</b>																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
12.600	Outfall 001	24.1	50	24.1	50	0	0											
<b>NH3-N Chronic Allocations</b>																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
12.600	Outfall 001	4.36	25	4.36	25	0	0											
<b>Dissolved Oxygen Allocations</b>																		
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>												
12.60	Outfall 001	25	25	25	25	4	4											
RMI	Discharge Name	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)											

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34025	CONNOQUENESSING CREEK		
<u>RMI</u> 12.600	<u>Total Discharge Flow (mgd)</u> 0.005	<u>Analysis Temperature (°C)</u> 5.003	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 172.000	<u>Reach Depth (ft)</u> 0.451	<u>Reach WDRatio</u> 381.326	<u>Reach Velocity (fps)</u> 0.291	
<u>Reach CBOD5 (mg/L)</u> 2.01	<u>Reach Kc (1/days)</u> 0.006	<u>Reach NH3-N (mg/L)</u> 0.01	<u>Reach Kn (1/days)</u> 0.221	
<u>Reach DO (mg/L)</u> 12.507	<u>Reach Kr (1/days)</u> 1.479	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5.5	
<u>Reach Travel Time (days)</u> 0.080	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.008	2.01	0.01	11.45
	0.016	2.01	0.01	11.45
	0.024	2.01	0.01	11.45
	0.032	2.01	0.01	11.45
	0.040	2.01	0.01	11.45
	0.048	2.01	0.01	11.45
	0.056	2.01	0.01	11.45
	0.064	2.01	0.01	11.45
	0.072	2.01	0.01	11.45
	0.080	2.01	0.01	11.45

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34025	CONNOQUENESSING CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Efl. Limit 30-day Ave. (mg/L)	Efl. Limit Maximum (mg/L)	Efl. Limit Minimum (mg/L)
12.600	Outfall 001	PA0217824	0.005	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

# Attachment 5

## TRC Model

TRC\_CALC

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc = 466.044		1.3.2.iii	WLA_cfc = 454.348		
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581		
PENTOXSD TRG	5.1b	LTA_afc = 173.659		5.1d	LTA_cfc = 264.137		
Effluent Limit Calculations							
PENTOXSD TRG	5.1f	AML MULT = 1.231		BAT/BPJ			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500 INST MAX LIMIT (mg/l) = 1.635					
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_afc		$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$					
LTA_afc		wla_afc*LTAMULT_afc					
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_cfc		$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$					
LTA_cfc		wla_cfc*LTAMULT_cfc					
AML MULT		$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$					
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)					

# Attachment 6 – 1985 Phosphorous Loading to Connoquenessing Creek Letter

Attachment

Phosphorus Loading to Connoquenessing Creek  
SUBJECT: Butler County

TO: Edward R. Brezina, Chief  
Division of Water Quality  
Bureau of Water Quality Management

FROM: Peter A. Sager  
Regional Water Quality Manager  
Bureau of Water Quality Management

COMMONWEALTH OF PENNSYLVANIA 117  
1012 Water Street  
Meadville, PA 16335  
NETWORK: 673-6950  
January 9, 1985

STREAM FILE 9.20.1  
Connoquenessing Creek

See Paragraph 7

re: 2.0 mg/l effluent  
limit for all dischargers

Pursuant to our telephone conversation (including J.T. Ulanoski, K.A. Bartal, and R. B. Patel) on November 28, 1984, the following comments were prepared concerning phosphorus loading to the Connoquenessing Creek Watershed, Butler County:

1. Tables 1 and 2 (attached) summarize phosphorus loads from point sources in the watershed (excluding Slippery Rock Creek).
2. The Table 1 data were compiled using actual reported "P" concentrations and flows from 1983 - 84 (April-October) monthly discharge monitoring reports (DMRs). Critical period
3. The Table 2 data are considered "best guesstimates". Many of these treatment facilities do not as yet have NPDES permits, consequently, discharge monitoring information was inadequate or not available. Inspection reports and samples taken by our field staff (since 1980) did provide limited data for making the phosphorus loading calculations.
4. Based on our calculations, the six publicly owned treatment works (Table 1) account for approximately 91% (149 lbs/day) of the total point source phosphorus load (164 lbs) to Connoquenessing Creek. Of these six, the Butler Area Sanitary Authority is the largest contributor with an average phosphorus load of 132 lbs/day.
5. Five of the six municipal plants have tertiary treatment. Three of these are able to meet the .5 mg/l "P" limit established under the implementation plan. Saxonburg Borough comes close with .83 mg/l "P". The Butler Area Sewer Authority and Borough of Mars treatment plants have monthly average "P" concentrations of 2.14 mg/l and 2.72 mg/l, respectively.

-2-

217

6. The 26 non-municipal dischargers (Table 2) account for 9% of the total point source phosphorus load (15 lbs/day). Only two of these facilities have average "P" concentrations less than .5 mg/l. Eighteen facilities exceed the maximum technology based "P" limit of 2.0 mg/l (monthly average).
7. In a telephone conversation with Jim Ulanoski on December 7, 1984, it was agreed that the maximum technology limit of 2.0 mg/l phosphorus should be incorporated into all NPDES permits for this watershed. All existing tertiary treatment facilities, however, would be required to remain operational so that there would be no net increase in phosphorus from current levels. Those facilities which cannot meet the 2.0 mg/l limit will be required to do so.
8. Very little information was available for estimating phosphorus loading from non-point sources. However, land use information supplied by the Butler County Conservation District (Table 3) suggests that agricultural activities are a major contributing factor and will need to be addressed in the future. By estimating yearly soil loss from agricultural areas in the watershed and by estimating the average phosphorus content of those soils, the daily average of phosphorus discharged to Connoquenessing Creek can be guesstimated at 380 lbs/day. However inaccurate this figure may be, we believe it does represent a substantial impact on the watershed - at least as significant as the point discharges. It should also be noted that all non-point sources (e.g. malfunctioning septic tanks, urban runoff, silvicultural activities, etc.) were not included in the estimate and actual "P" loading from non-point sources may be greater than 380 lbs/day.

RLH/llk

cc: Mr. Yeager  
Mr. Hasse  
Mr. Zimmerman ✓  
Ms. Pesek  
Mr. Ulanoski - Thru: Mr. Clista  
Mr. Patel - Thru: Mr. Bartal  
Central Files  
Regional Files

\* Per Headville Regional Office, impose avg monthly limit of 2mg/l for phosphorus for the period 4/1 - 10/31, the critical period, for discharges to Connoquenessing CT. Also, use Inst. Max limit of 4mg/l