

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0217913  
APS ID 1030069  
Authorization ID 1339006

**Applicant and Facility Information**

Applicant Name	<u>William B. McIntire</u>	Facility Name	<u>Urling Mine 1 &amp; 2 Main Portal STP</u>
Applicant Address	<u>1160 Hudson Road</u> <u>Creekside, PA 15732</u>	Facility Address	<u>Anthony Run Road</u> <u>Shelocta, PA 15774</u>
Applicant Contact	<u>William B. McIntire</u>	Facility Contact	<u>William B. McIntire</u>
Applicant Phone	<u>(724) 397-8387</u>	Facility Phone	<u>(724) 397-8387</u>
Client ID	<u>307765</u>	Site ID	<u>253854</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Armstrong Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Indiana County</u>
Date Application Received	<u>March 20, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 17, 2019</u>	If No, Reason	<u>-</u>

Purpose of Application Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater. This application also transfers ownership from the William J. McIntire Estate to William B. McIntire.

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.  
Water Quality Management permit number 3274409 will be transferred with the Final NPDES Permit issuance.  
The applicant should be able to continue to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Public sewerage availability
- E. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management
- III. Compliance Schedule for Total Residual Chlorine (TRC)

There are no open violations in effects associated with the subject Client ID (307765) as of 5/14/2021.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	5/14/2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	5/17/2021

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>002</u>	Design Flow (MGD)	<u>0.023</u>
Latitude	<u>40° 38' 53.00"</u>	Longitude	<u>-79° 16' 55.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Anthony Run (CWF)</u>	Stream Code	<u>46692</u>
NHD Com ID	<u>123858097</u>	RMI	<u>0.92</u>
Drainage Area	<u>4.99</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.49</u>	Q <sub>7-10</sub> Basis	<u>calculated</u>
Elevation (ft)	<u>1030</u>	Slope (ft/ft)	<u>0.00697</u>
Watershed No.	<u>17-E</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Impaired*</u>		
Cause(s) of Impairment	<u>Siltation</u>		
Source(s) of Impairment	<u>Removal of Riparian Vegetation</u>		
TMDL Status	<u>Final, 04/08/2009</u>	Name	<u>Crooked Creek Watershed</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>	<u>-</u>	
Temperature (°F)	<u>-</u>	<u>-</u>	
Hardness (mg/L)	<u>-</u>	<u>-</u>	
Other:	<u>-</u>	<u>-</u>	
Nearest Downstream Public Water Supply Intake	<u>Buffalo Township Municipal Water Authority - Freeport</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2,576</u>
PWS RMI	<u>30.0</u>	Distance from Outfall (mi)	<u>46.5</u>

\* - The receiving stream at the Outfall is impaired. The contribution of siltation from a sewage plant of this nature is expected to be less than water quality criteria and therefore not contributing to the stream impairment. No new monitoring related to the stream impairment will be added with this renewal.

The mines are not currently operating. This discharge is from the treatment of office wastewater.

Sludge use and disposal description and location(s): Sludge is not used, it is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.023 MGD of treated sewage from an STP in Armstrong Township, Indiana County.

Treatment permitted under Water Quality Management Permit No. 3274409 consists of the following: A comminutor, aeration, clarification, surge tank, sludge holding tank, and chlorine disinfection with a contact tank.

**1. Streamflow:**

Crooked Creek at Idaho, Pa. (1970-2008):

Q <sub>7-10</sub> :	<u>19.9</u>	cfs	(USGS StreamStats)
Drainage Area:	<u>191</u>	sq. mi.	(USGS StreamStats)
Yieldrate:	<u>0.1</u>	cfsm	calculated

Anthony Run at Outfall 001:

Yieldrate:	<u>0.1</u>	cfsm	calculated above
Drainage Area:	<u>4.99</u>	sq. mi.	(USGS StreamStats)
Q <sub>7-10</sub> :	<u>0.49</u>	cfs	calculated

% of stream allocated: 100% Basis: No nearby discharges

**2. Wasteflow:**

Maximum discharge: 0.023 MGD = 0.035 cfs

Runoff flow period: 16 hours Basis: Runoff flow for small STPs

24 hour flow: 0.023 MGD x 24/16 = 0.034 MGD = 0.053 cfs

There is greater than 3 parts stream flow (Q7-10) to 1 part effluent (design flow). In accordance with the SOP, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, are not required to be evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, Total Residual Chlorine, influent Total Suspended Solids, and influent BOD<sub>5</sub>. NH<sub>3</sub>-N, CBOD<sub>5</sub>, and Dissolved Oxygen were evaluated using WQM 7.0 at the discharge point.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits. The measurement frequency was previously set to 2/month, but will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30 mg/l as a monthly average and 60 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP.

e. Phosphorus

- Limit necessary due to:
- Discharge to lake, pond, or impoundment
  - Discharge to stream

Basis: Chapter 96.5 does not apply.

- Limit not necessary

Basis: The previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: Default, no eDMR data available

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH<sub>3</sub>-N concentration: 0.1 mg/l

Basis: Default value

Calculated NH<sub>3</sub>-N Summer limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Calculated NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. Since the previous summer NH3-N limits are more restrictive, they will be retained. Per the SOP, winter NH3-N will remain monitor only.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 7.0 Standard Units (S.U.)

Basis: Default, no eDMR data available

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD<sub>5</sub> concentration: 2.0 mg/l

Basis: Default value

CBOD<sub>5</sub> Summer limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

CBOD<sub>5</sub> Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1), which are the same as in the previous permit. The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. Since the summer and winter limits are technology-based, per the SOP, the year-round limit of 25.0 mg/l monthly average and 50.0 mg/l instantaneous maximum will be retained with this renewal.

i. Dissolved Oxygen (DO)

- 4.0 mg/l - minimum desired in effluent to protect all aquatic life
- 5.0 mg/l - desired in effluent for CWF, WWF, or TSF
- 6.0 mg/l - minimum required due to discharge falling under guidance document 391-2000-014
- 8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. The measurement frequency was previously set to 2/month, but will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

j. Total Residual Chlorine (TRC)

- No limit necessary

Basis: N/A

- TRC limits: 0.5 mg/l (monthly average)  
1.6 mg/l (instantaneous maximum)

Basis: The TRC limits above are technology-based using the TRC Calc Spreadsheet (see Attachment 2), and are more restrictive than in the previous permit. Since there is no eDMR data to decide if the new limits are attainable, the previous limits will be set for 1 year to allow time for the Permittee to adjust to the new limits. The measurement frequency was previously set to 4/month, but will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

k. Anti-Backsliding

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**4. Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

A Reasonable Potential Analysis, if performed, does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no data was provided, mass-balance calculations were not able to be performed.

Nearest Downstream potable water supply (PWS): Buffalo Township Municipal Water Authority - Freeport  
Distance downstream from the point of discharge: 46.5 miles (approximate)

- No limits necessary  
 Limits needed

Basis: Significant dilution available.

**6. Attachment List:**

- Attachment 1 - WQ Modeling Printouts
- Attachment 2 - TRC\_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 002, Effective Period: Permit Effective Date through July 31, 2022.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	1.0	XXX	2.3	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	13.0	XXX	26.0	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Outfall 002, Continued (from Permit Effective Date through July 31, 2022)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: at Outfall 002, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology-based on Chapter 93.7. The limits for CBOD<sub>5</sub>, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for influent BOD<sub>5</sub> and influent TSS is based on Chapter 92a.61. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7.



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 002, Effective Period: August 1, 2022 through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	Report	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	13.0	XXX	26.0	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Outfall 002, Continued (from August 1, 2022 through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: at Outfall 002, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology-based on Chapter 93.7. The limits for CBOD<sub>5</sub>, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for influent BOD<sub>5</sub> and influent TSS is based on Chapter 92a.61. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7.

Attachment 1

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17E		46692		ANTHONY RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.920	Urling Mine 1&2	PA0217913	0.034	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
17E	46692	ANTHONY RUN	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.920	0.034	20.483	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
10.995	0.462	23.810	0.109
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
4.22	0.711	2.42	0.727
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.833	20.738	Owens	6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		
0.517	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.052	4.07	2.33
	0.103	3.92	2.24
	0.155	3.77	2.16
	0.207	3.63	2.08
	0.258	3.50	2.00
	0.310	3.37	1.93
	0.362	3.25	1.86
	0.413	3.13	1.79
	0.465	3.01	1.72
	0.517	2.90	1.66

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46692	ANTHONY RUN	0.920	1030.00	4.99	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Urling Mine 1&2	PA0217913	0.0345	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17E	46692	ANTHONY RUN	0.000	996.00	5.21	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Wasteload Allocations**

SWP Basin      Stream Code                      Stream Name  
 17E                      46692                                      ANTHONY RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.920	Urling Mine 1&2	15.79	50	15.79	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.920	Urling Mine 1&2	1.84	25	1.84	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.92	Urling Mine 1&2	25	25	25	25	4	4	0	0



**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17E		46692				ANTHONY RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.920	0.50	0.00	0.50	.0534	0.00700	.462	11	23.81	0.11	0.517	20.48	7.00
<b>Q1-10 Flow</b>												
0.920	0.32	0.00	0.32	.0534	0.00700	NA	NA	NA	0.09	0.644	20.72	7.00
<b>Q30-10 Flow</b>												
0.920	0.68	0.00	0.68	.0534	0.00700	NA	NA	NA	0.13	0.441	20.36	7.00

Attachment 2

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9					
0.49	= Q stream (cfs)		0.5	= CV Daily	
0.0345	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 2.948		1.3.2.iii	WLA_cfc = 2.866
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 1.098		5.1d	LTA_cfc = 1.666
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot 0.19 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot 0.11 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				