

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. PA0218359
APS ID 1063593
Authorization ID 1396595

Applicant and Facility Information

Applicant Name	<u>Green Township Municipal Authority</u>	Facility Name	<u>Green Township Municipal Authority WWTP</u>
Applicant Address	<u>PO Box 129</u> <u>Commodore, PA 15729-0129</u>	Facility Address	<u>11 Sylvia Drive</u> <u>Starford, PA 15729</u>
Applicant Contact	<u>David Putt</u>	Facility Contact	<u>David Putt</u>
Applicant Phone	<u>(724) 254-1343</u>	Facility Phone	<u>(724) 254-1343</u>
Client ID	<u>40964</u>	Site ID	<u>532059</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Green Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Indiana</u>
Date Application Received	<u>May 13, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 13, 2022</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit.</u>		


Summary of Review

The applicant is requesting the renewal of an NPDES permit to discharge up to 0.120 MGD of treated sewage into an unnamed tributary of North Branch Two Lick Creek, a Cold-Water Fish (CWF) receiving stream in State Water Plan Basin 18-D (Conemaugh River – Blacklick Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. This discharge is not expected to affect public water supplies.

The receiving stream is subject to the Kiskiminetas-Conemaugh River Watershed TMDL for acid mine drainage. The pollutants of concern, aluminum, iron, manganese, pH and TSS are already monitored in the NPDES permit. The WWTP doesn't currently accept industrial wastewater and eDMR data shows pollutant concentrations from the facility are not expected to exceed Chapter 93 water quality standards. An aggregate waste load allocation was included in the TMDL for these types of facilities and yearly monitoring is required for a WWTP of this design capacity (0.002 MGD - 0.499 MGD).

All limitations and monitoring requirements from the previously issued permit (effective November 1, 2017) are carried over in this renewal and summarized in a table at the end of the fact sheet. Monitoring frequencies for all parameters with limitations are consistent with the recommended frequencies found in Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations (Document No. 362-0400-001).

Sample results submitted with the NPDES renewal application were modeled with DEP's Toxics Management Spreadsheet (TMS). The TMS recommended monitoring requirements for Total Copper since the discharge concentration (9.49 µg/L) is more than 10% of the calculated water quality-based effluent limitation (56.8 µg/L). Yearly monitoring/reporting is included in the renewed permit for Total Copper. The statewide default low flow yield (LFY) of 0.1 cfs/mi² was used to model the discharge. Drainage areas for the modeling points were obtained from the USGS StreamStats interactive map, RMI values were obtained using the Department's eMapPA, and elevations were obtained using the elevation profile tool on StreamStats (see Watershed Information section). Based on drainage areas used in the original modeling performed for this WWTP, it's

Approve	Deny	Signatures	Date
X		 Brian Burden, E.I.T. / Project Manager	December 9, 2024
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	December 11, 2024

Summary of Review

assumed that the point of first aquatic use (first modeling point) is at the confluence of the unnamed tributary and North Branch Two Lick Creek. Note: When modeling at the nearest downstream public water supply intake location using the default LFY of 0.1 cfs/mi² an error was received in the TMS indicating there's not enough stream flow for the PWS withdrawal amount, therefore, the LFY was adjusted upward until adequate flow was generated.

As per current DEP guidance, quarterly monitoring/reporting requirements are included in the renewed permit for E. Coli.

Sludge use and disposal description and location(s): The permit renewal application indicates 3.742 dry tons of sludge was hauled to the Punxsutawney WWTP during the previous calendar year.

The most recently submitted Chapter 94 report for 2023 doesn't show any current or projected hydraulic/organic overloads at the WWTP. Template Part C special conditions are included in the permit.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.12
Latitude	40° 41' 42"	Longitude	-78° 57' 36"
Quad Name	Commodore	Quad Code	1314
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed tributary to North Branch Two Lick Creek	Stream Code	44341
NHD Com ID	123717725	RMI	1.67
Drainage Area	9.9 mi ²	Yield (cfs/mi ²)	0.1
Q ₇₋₁₀ Flow (cfs)	0.99	Q ₇₋₁₀ Basis	Default LFY
Elevation (ft)	1329	Slope (ft/ft)	0.0045
Watershed No.	18-D	Chapter 93 Class.	CWF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, Siltation		
Source(s) of Impairment	Acid Mine Drainage		
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL
Background/Ambient Data		Data Source	
pH (SU)	-		-
Temperature (°F)	-		-
Hardness (mg/L)	-		-
Other:	-		-
Nearest Downstream Public Water Supply Intake	PAWC (6,000,000 gpd safe yield)		
PWS Waters	Two Lick Creek	Flow at Intake (cfs)	9.49
PWS RMI	13.2	Distance from Outfall (mi)	~15.9

Treatment Facility Summary				
Treatment Facility Name: Green Township Municipal Authority WWTP				
WQM Permit No.	Issuance Date			
3200401	August 21, 2000			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Reduction	Extended Aeration	Chlorine with Dechlorination	0.12
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.12	240	Not Overloaded	Holding Tank	Hauled

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 41' 42"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.12
Longitude -78° 57' 36"

Technology-Based Limitations

The NPDES permit application was evaluated based on applicable regulations, policies, procedures and guidelines.

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
Total Suspended Solids	30.0	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45.0	Average Weekly	133.102(b)(2)	92a.47(a)(2)
	60.0	IMAX	-	-
CBOD ₅ (11/1 – 4/30)	25.0	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	37.5	Average Weekly	-	-
	50.0	IMAX	-	-
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

Comments: Mass-based limitations for TSS are also included in the permit.

Water Quality-Based Limitations

The following concentration limitations were determined through water quality modeling:

Parameter	Limit (mg/l)	SBC	Model
Total Residual Chlorine	0.2	Average Monthly	Previous modeling
	0.7	IMAX	
Dissolved Oxygen	4.0	Minimum	Previous modeling
CBOD ₅ (5/1 – 10/31)	20.0	Average Monthly	Previous modeling
	30.0	Average Weekly	
	40.0	IMAX	
NH ₃ -N (5/1 – 10/31)	5.0	Average Monthly	Previous modeling
	10.0	IMAX	
NH ₃ -N (11/1 – 4/30)	15.0	Average Monthly	
	30.0	IMAX	

Comments: Mass-based limitations for CBOD₅ and NH₃-N are also included in the permit.

Monitoring Requirements

The following monitoring requirements have been established:

Parameter	SBC	Model / Basis
Flow (MGD)	Average Monthly	Standard requirement
	Daily Maximum	
Influent BOD ₅	Average Monthly	Standard requirement for POTWs
Influent TSS	Average Monthly	
Total Nitrogen	Daily Maximum	Standard requirement
Total Phosphorus	Daily Maximum	
Total Aluminum	Daily Maximum	TMDL Metals of Concern
Total Iron	Daily Maximum	
Total Manganese	Daily Maximum	
Total Copper	Daily Maximum	
E. Coli	IMAX	2024 TMS
		2024 DEP Guidance / § 92a.61

Comments: Mass-based monitoring requirements are included in the permit for influent BOD₅ and influent TSS.

Anti-Backsliding

No limitations were made less stringent or removed from the permit.

Previous Effluent Limitations / Monitoring Requirements from November 1, 2017 Permit

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Maximum	Instant. Maximum		
Flow	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Min	XXX	9.0	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	4.0 Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	0.2	XXX	XXX	0.7	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	25.0	37.6	25.0	37.5	XXX	50	1/week	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	20.0	30.0	20.0	30.0	XXX	40	1/week	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	Report	XXX	XXX	XXX	1/week	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	Report	XXX	XXX	XXX	1/week	8-Hr Composite
Total Suspended Solids	30.0	45.1	30.0	45.0	XXX	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	15.0	XXX	15.0	XXX	XXX	30	1/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	5.0	XXX	5.0	XXX	XXX	10	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Aluminum, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Iron, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite
Manganese, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	8-Hr Composite

Watershed Information

@ Outfall 001 on North Branch Two Lick Creek (stream code 44341)

RMI = 1.67

Clicked Point (Latitude, Longitude): 40.69478, -78.95973


Time: 2024-11-15 15:19:27 -0500



DRNAREA Area that drains to a point on a stream 9.9 square miles

Elevation: 1329 ft

Elevation profile




@ Tributary 44344 to North Branch Two Lick Creek

RMI = 0.8

Clicked Point (Latitude, Longitude): 40.68466, -78.96464


Time: 2024-11-16 09:28:22 -0500



DRNAREA Area that drains to a point on a stream 10.5 square miles

Elevation: 1308 ft

Elevation profile




@ nearest downstream PWS intake on Two Lick Creek (6 MGD safe yield)

Distance from Outfall 001: 15.9 miles

Clicked Point (Latitude, Longitude): 40.59618, -79.11914


Time: 2024-11-17 09:45:53 -0500



DRNAREA Area that drains to a point on a stream 79.1 square miles

Elevation: 1086 ft

Elevation profile



WQM Modeling

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18D	44341	NORTH BRANCH TWO LICK CREEK	1.670	1329.00	9.90	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Green Twp	PA0218359	0.1200	0.1200	0.1200	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18D	44341	NORTH BRANCH TWO LICK CREEK	0.800	1308.00	10.50	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
18D	44341	NORTH BRANCH TWO LICK CREEK										
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.670	0.99	0.00	0.99	.1856	0.00457	.527	16.19	30.75	0.14	0.386	20.79	7.00
Q1-10 Flow												
1.670	0.63	0.00	0.63	.1856	0.00457	NA	NA	NA	0.11	0.472	21.13	7.00
Q30-10 Flow												
1.670	1.35	0.00	1.35	.1856	0.00457	NA	NA	NA	0.16	0.332	20.61	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
18D	44341	NORTH BRANCH TWO LICK CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.670	Green Twp	8.91	39.32	8.91	39.32	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.670	Green Twp	1.83	15.14	1.83	15.14	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.67	Green Twp	25	25	15.14	15.14	3	3	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18D	44341	NORTH BRANCH TWO LICK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
1.670	0.120	20.790	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
16.193	0.527	30.751	0.138	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.63	0.950	2.39	0.744	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.415	6.103	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.386	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.039	5.42	2.32	7.20
	0.077	5.22	2.26	7.04
	0.116	5.02	2.19	6.94
	0.154	4.84	2.13	6.87
	0.193	4.66	2.07	6.84
	0.231	4.48	2.01	6.83
	0.270	4.32	1.96	6.83
	0.308	4.16	1.90	6.85
	0.347	4.00	1.85	6.88
	0.386	3.85	1.79	6.92

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18D		44341	NORTH BRANCH TWO LICK CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.670	Green Twp	PA0218359	0.120	CBOD5	25		
				NH3-N	15.14	30.28	
				Dissolved Oxygen			3

Saturday, November 16, 2024

Version 1.0b

TRC Calculation

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.99	= Q stream (cfs)	0.5	= CV Daily		
0.12	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA afc = 1.720		1.3.2.iii	WLA cfc = 1.670
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c	LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc= 0.641		5.1d	LTA_cfc = 0.971
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA afc	$(.019/e(-k^*AFC_tc)) + [(AFC_Yc^*Qs^*.019/Qd^*e(-k^*AFC_tc))... \\ ...+ Xd + (AFC_Yc^*Qs^*Xs/Qd)]^*(1-FOS/100)$				
LTAMULT afc	$EXP((0.5^*LN(cvh^*2+1))-2.326^*LN(cvh^*2+1)^*0.5)$				
LTA_afc	wla_afc^*LTAMULT_afc				
WLA_cfc	$(.011/e(-k^*CFC_tc) + [(CFC_Yc^*Qs^*.011/Qd^*e(-k^*CFC_tc))... \\ ...+ Xd + (CFC_Yc^*Qs^*Xs/Qd)]^*(1-FOS/100)$				
LTAMULT_cfc	$EXP((0.5^*LN(cvd^*2/no_samples+1))-2.326^*LN(cvd^*2/no_samples+1)^*0.5)$				
LTA_cfc	wla_cfc^*LTAMULT_cfc				
AML MULT	$EXP(2.326^*LN((cvd^*2/no_samples+1)^*0.5)-0.5^*LN(cvd^*2/no_samples+1))$				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)^*AML_MULT)				
INST MAX LIMIT	1.5^*((av_mon_limit/AML_MULT)/LTAMULT_afc)				

TMS Modeling



Tools Management Spreadsheet
Version 1.4, May 2023

Discharge Information

Instructions Discharge Stream

Facility: Green Twp NPDES Permit No.: PA0218359 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₂₋₁₀	Q ₅
0.12	100	7						

			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank					
Discharge Pollutant			Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transf	
Group 1	Total Dissolved Solids (PWS)	mg/L		318										
	Chloride (PWS)	mg/L		88.9										
	Bromide	mg/L	<	0.362										
	Sulfate (PWS)	mg/L		59.3										
	Fluoride (PWS)	mg/L												
Group 2	Total Aluminum	µg/L	<	100										
	Total Antimony	µg/L												
	Total Arsenic	µg/L												
	Total Barium	µg/L												
	Total Beryllium	µg/L												
	Total Boron	µg/L												
	Total Cadmium	µg/L												
	Total Chromium (III)	µg/L												
	Hexavalent Chromium	µg/L												
	Total Cobalt	µg/L												
	Total Copper	µg/L		9.49										
	Free Cyanide	µg/L												
	Total Cyanide	µg/L												
	Dissolved Iron	µg/L												
	Total Iron	µg/L	<	200										
	Total Lead	µg/L	<	1.4										
	Total Manganese	µg/L	<	22.4										
	Total Mercury	µg/L												
	Total Nickel	µg/L												
	Total Phenols (Phenolics) (PWS)	µg/L												
	Total Selenium	µg/L												
	Total Silver	µg/L												
	Total Thallium	µg/L												
	Total Zinc	µg/L		39.3										
	Total Molybdenum	µg/L												
		Acrolein	µg/L	<										
		Acrylamide	µg/L	<										
		Acrylonitrile	µg/L	<										
		Benzene	µg/L	<										
Bromofom		µg/L	<											

Discharge Information

11/17/2024

Page 1

Page 2

Page 3



Stream / Surface Water Information

Green Twp, NPDES Permit No. PA0218359, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: North Branch Two Lick Creek

No. Reaches to Model: 1

- ☒ Statewide Criteria
☐ Great Lakes Criteria
☐ ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	044341	1.67	1329	9.9			Yes
End of Reach 1	044341	0.8	1308	10.5			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	1.67	0.1										100	7		
End of Reach 1	0.8	0.1													

Q_A

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	1.67														
End of Reach 1	0.8														



Toolbox Management Spreadsheet
Version 1.4, May 2023

Model Results

Green Twp, NPDES Permit No. PA0218359, Outfall 001

Instructions **Results** [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#) ☒ All ☐ Inputs ☐ Results ☐ Limits

☐ Hydrodynamics

☒ Wasteload Allocations

☒ **AFC** CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	4,750	
Total Copper	0	0		0	13.439	14.0	88.7	Chem Translator of 0.96 applied
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	64.581	81.6	517	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	117.180	120	759	Chem Translator of 0.978 applied

☒ **CFC** CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	59.1	Chem Translator of 0.96 applied
Total Iron	0	0		0	1,500	1,500	9,499	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.517	3.18	20.1	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	118.139	120	759	Chem Translator of 0.986 applied

☒ **THH** CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Model Results

11/17/2024

Page 3

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	6,333	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ CRL OCT (min): 3.878 PMP: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	Report	Report	Report	Report	Report	µg/L	56.8	AFC	Discharge Conc > 10% WQBEL (no RP)

☒ Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS

Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	3,044	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	9,499	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	20.1	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	6,333	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	486	µg/L	Discharge Conc ≤ 10% WQBEL

TMS Modeling at Nearest PWS Intake



Tools Management Spreadsheet
Version 1.4, May 2023

Discharge Information

Instructions Discharge Stream

Facility: Green Twp NPDES Permit No.: PA0218359 Outfall No.: 001
Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated sewage

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			
			AFC	CFC	THH	CRL
0.12	100	7				

Discharge Pollutant			Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
					Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod
Group 1	Total Dissolved Solids (PWS)	mg/L		315								
	Chloride (PWS)	mg/L		88.9								
	Bromide	mg/L	<	0.362								
	Sulfate (PWS)	mg/L		59.3								
	Fluoride (PWS)	mg/L										
Group 2	Total Aluminum	µg/L	<	100								
	Total Antimony	µg/L										
	Total Arsenic	µg/L										
	Total Barium	µg/L										
	Total Beryllium	µg/L										
	Total Boron	µg/L										
	Total Cadmium	µg/L										
	Total Chromium (III)	µg/L										
	Hexavalent Chromium	µg/L										
	Total Cobalt	µg/L										
	Total Copper	µg/L		9.49								
	Free Cyanide	µg/L										
	Total Cyanide	µg/L										
	Dissolved Iron	µg/L										
	Total Iron	µg/L	<	200								
	Total Lead	µg/L	<	1.4								
	Total Manganese	µg/L		22.4								
	Total Mercury	µg/L										
	Total Nickel	µg/L										
	Total Phenols (Phenolics) (PWS)	µg/L										
	Total Selenium	µg/L										
	Total Silver	µg/L										
	Total Thallium	µg/L										
	Total Zinc	µg/L		39.3								
Total Molybdenum	µg/L											
	Acrolein	µg/L	<									
	Acrylamide	µg/L	<									
	Acrylonitrile	µg/L	<									
	Benzene	µg/L	<									
	Bromoform	µg/L	<									

Discharge Information

11/18/2024

Page 1

Page 2

Group 6	2,6-Dinitrotoluene	µg/L	<																				
	Di-n-Octyl Phthalate	µg/L	<																				
	1,2-Diphenylhydrazine	µg/L	<																				
	Fluoranthene	µg/L	<																				
	Fluorene	µg/L	<																				
	Hexachlorobenzene	µg/L	<																				
	Hexachlorobutadiene	µg/L	<																				
	Hexachlorocyclopentadiene	µg/L	<																				
	Hexachloroethane	µg/L	<																				
	Indeno(1,2,3-cd)Pyrene	µg/L	<																				
	Isophorone	µg/L	<																				
	Naphthalene	µg/L	<																				
	Nitrobenzene	µg/L	<																				
	n-Nitrosodimethylamine	µg/L	<																				
	n-Nitrosodi-n-Propylamine	µg/L	<																				
	n-Nitrosodiphenylamine	µg/L	<																				
	Phenanthrene	µg/L	<																				
	Pyrene	µg/L	<																				
	1,2,4-Trichlorobenzene	µg/L	<																				
Group 7	Aldrin	µg/L	<																				
	alpha-BHC	µg/L	<																				
	beta-BHC	µg/L	<																				
	gamma-BHC	µg/L	<																				
	delta BHC	µg/L	<																				
	Chlordane	µg/L	<																				
	4,4-DDT	µg/L	<																				
	4,4-DDE	µg/L	<																				
	4,4-DDD	µg/L	<																				
	Dieldrin	µg/L	<																				
	alpha-Endosulfan	µg/L	<																				
	beta-Endosulfan	µg/L	<																				
	Endosulfan Sulfate	µg/L	<																				
	Endrin	µg/L	<																				
	Endrin Aldehyde	µg/L	<																				
	Heptachlor	µg/L	<																				
	Heptachlor Epoxide	µg/L	<																				
	PCB-1016	µg/L	<																				
	PCB-1221	µg/L	<																				
	PCB-1232	µg/L	<																				
	PCB-1242	µg/L	<																				
	PCB-1248	µg/L	<																				
	PCB-1254	µg/L	<																				
	PCB-1260	µg/L	<																				
	PCBs, Total	µg/L	<																				
	Toxaphene	µg/L	<																				
	2,3,7,8-TCDD	ng/L	<																				
Group 7	Gross Alpha	pCi/L	<																				
	Total Beta	pCi/L	<																				
	Radium 226/228	pCi/L	<																				
	Total Strontium	µg/L	<																				
	Total Uranium	µg/L	<																				
	Osmotic Pressure	mOsm/kg																					



Toxic Management Spreadsheet
Version 1.4, May 2023

Stream / Surface Water Information

Green Twp, NPDES Permit No. PA0218359, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: North Branch Two Lick Creek

No. Reaches to Model: 1

- ☒ Statewide Criteria
☐ Great Lakes Criteria
☐ ORSANCO Criteria

Location	Stream Code ¹	RMI ²	Elevation (ft) ³	DA (mi ³ /y) ⁴	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria ⁵
Point of Discharge	044341	15.9	1329	9.9			Yes
End of Reach 1	044341	0.01	1086	79.1		6	Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²) ⁶	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	15.9	0.1										100	7		
End of Reach 1	0.01	0.12													

Q₁

Location	RMI	LFY (cfs/mi ²) ⁶	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	15.9														
End of Reach 1	0.01														



Tools Management Spreadsheet
Version 1.4, May 2023

Model Results

Green Twp, NPDES Permit No. PA0218359, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

☒ All ☐ Inputs ☐ Results ☐ Limits

☐ Hydrodynamics

☒ Wasteload Allocations

☒ AFC

CCT (min): 12.929

PMF: 1

Analysis Hardness (mg/l): 100

Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream C/V	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	4,750	
Total Copper	0	0		0	13.439	14.0	88.7	Chem Translator of 0.96 applied
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	64.581	81.5	517	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	117.180	120	759	Chem Translator of 0.978 applied

☒ CFC

CCT (min): 12.929

PMF: 1

Analysis Hardness (mg/l): 100

Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream C/V	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	59.1	Chem Translator of 0.96 applied
Total Iron	0	0		0	1,500	1,500	9,499	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.517	3.18	20.1	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	118.139	120	759	Chem Translator of 0.986 applied

☒ THH

CCT (min): 12.929

THH PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

PWS PMF: 1

Model Results

11/18/2024

Page 5

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	25,532,321	WQC applied at RMI 0.01 with a design stream flow of 9.294 cfs
Chloride (PWS)	0	0		0	250,000	250,000	12,766,160	WQC applied at RMI 0.01 with a design stream flow of 9.294 cfs
Sulfate (PWS)	0	0		0	250,000	250,000	12,766,160	WQC applied at RMI 0.01 with a design stream flow of 9.294 cfs
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	6,333	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ CRL OCT (min): 5.083 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	Report	Report	Report	Report	Report	µg/L	56.8	AFC	Discharge Conc > 10% WQBEL (no RP)

☒ Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	25,532	mg/L	Discharge Conc ≤ 10% WQBEL
Chloride (PWS)	12,766	mg/L	Discharge Conc ≤ 10% WQBEL
Bromide	N/A	N/A	No WQS

Sulfate (PWS)	12,766	mg/L	Discharge Conc ≤ 10% WQBEL
Total Aluminum	3,044	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	9,499	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	20.1	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	6,333	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	486	µg/L	Discharge Conc ≤ 10% WQBEL