

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0218812  
APS ID 1038432  
Authorization ID 1354020

**Applicant and Facility Information**

Applicant Name	<u>Indiana County Municipal Service Authority</u>	Facility Name	<u>Hillsdale STP</u>
Applicant Address	<u>602 Kolter Drive</u> <u>Indiana, PA 15701-3570</u>	Facility Address	<u>893 Rowley Cemetery Road</u> <u>Indiana, PA 15701</u>
Applicant Contact	<u>Tricia Lefko</u>	Facility Contact	<u>Robert Allenbaugh</u>
Applicant Phone	<u>(724) 349-6640</u>	Facility Phone	<u>(724) 349-6640</u>
Client ID	<u>38534</u>	Site ID	<u>534659</u>
Ch 94 Load Status		Municipality	<u>Montgomery Township</u>
Connection Status		County	<u>Indiana</u>
Date Application Received	<u>April 27, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES permit renewal for a municipal sewage treatment plant.</u>		

**Summary of Review**

This is an existing discharge for a minor sewage treatment facility.

Act 14 – Proof of Notification was submitted and received.

Existing treatment consists of (WQM Permit No. 3202405): Flow enters lift station where it's pumped through a grinder to an equalization tank. A splitter box equally divides flow into two aeration tanks, then to two clarifiers. Clarifier sludge is either returned to aeration or sent to one waste tank. Clarifier effluent flows through an ultraviolet (UV) disinfection chamber, then is discharged.

There are 10 open violations in WMS for the subject Client ID (38534) as of 12/21/2023, all for Safe Drinking Water violations at facilities other than this one. *Permittee will be notified of open violations in the draft permit cover letter and given an opportunity to address the violations prior to final permit issuance. CWY 12/22/2023*

Annual monitoring for E. Coli has been added per Department SOP for new and reissued NPDES permits with design flows exceeding 2000 GPD.

The EPA Waiver is in effect.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania*

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	December 21, 2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	12/22/2023

**Summary of Review**

*Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.055</u>
Latitude	<u>40° 50' 16.76"</u>	Longitude	<u>-78° 52' 9.26"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Straight Run (HQ-CWF)</u>	Stream Code	<u>27100</u>
NHD Com ID	<u>123854606</u>	RMI	<u>7.8</u>
Drainage Area	<u>1.54</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.154</u>	Q <sub>7-10</sub> Basis	<u>Streamstats</u>
Elevation (ft)	<u>1568</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>17-D</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°F)	<u>20</u>	Default	<u></u>
Hardness (mg/L)	<u>100</u>	Default	<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>PA American Water Company</u>		
PWS Waters	<u>West Branch – Susquehanna River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Hillsdale STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
3202405		10/27/2003		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary with Ammonia Nitrogen removal	Extended Aeration	UV	0.02
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.055	110	Not Overloaded	Aerobic Digestion	

Changes Since Last Permit Issuance: None

Other Comments: The Hillsdale STP consists of the following treatment units:

- A comminutor and automatic bypass bar screen.
- A 19,944 gallon capacity flow equalization basin.
- Two parallel aeration basins each having a capacity of 27,500 gallons.
- Two final clarifiers.
- A 10,233 gallon aerobic digester.
- An ultraviolet disinfection system.

The plant was designed for an organic capacity of 81.2 lbs. BOD5/day but has an actual available organic capacity of 110.3 lbs. BOD5/day

Compliance History	
<b>Summary of DMRs:</b>	Facility exceeded Ammonia-Nitrogen both monthly average and IMAX limits in one month (May 2017) since the previous permit was issued  Facility fell below the minimum for Dissolved Oxygen five times during the same period, 4/2019, 4/2022, 5/2022, 7/2022, 10/2022
<b>Summary of Inspections:</b>	Facility has not been inspected in several years.

Other Comments: Client has 10 Open Violations as of 12/7/2023, but none for this facility

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.055</u>
<b>Latitude</b> <u>40° 50' 26.00"</u>	<b>Longitude</b> <u>-78° 52' 9.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
E. Coli	Report	IMAX		92a.61

Comments: E. Coli monitoring is based on the Department's SOP for new and reissued permits

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD <sub>5</sub>	25	Average Monthly	WQM 7.0, v1.1b
NH <sub>3</sub> -N (May 1 – Oct 31)	5.98	Average Monthly	WQM 7.0, v1.1b
NH <sub>3</sub> -N (Nov 1 – Apr 31)	17.94	Average Monthly	WQM 7.0, v1.1b
Dissolved Oxygen	3.0	Minimum	WQM 7.0, v1.1b

Comments: Dissolved Oxygen, Ammonia-Nitrogen and CBOD<sub>5</sub> limits calculated by WQM were less stringent than existing limits, so the existing limits will be kept due to anti-backsliding policies (see below).

**Best Professional Judgment (BPJ) Limitations**

Comments: Previous permit cycles gave less stringent CBOD<sub>5</sub> limits for months November-April. CBOD<sub>5</sub> limits of 9.2 lbs/day, 20.0 mg/l monthly average, and 40.0 mg/l IMAX are now imposed year-round. The facility's eDMR data shows the facility is easily capable of meeting these limits all year, which makes the previously less-stringent winter limits unnecessary.

**Anti-Backsliding**

Less stringent limits for Dissolved Oxygen, Ammonia-Nitrogen and CBOD<sub>5</sub> were calculated by WQM, but since the facility has demonstrated an ability to meet the current limits they will be retained in accordance with the EPA anti-backsliding policy.

**Disinfection**

Ultraviolet (UV) disinfection is used therefore Total Residual Chlorine (TRC) limits are not applicable. Routine monitoring of UV intensity will be at the same monitoring frequency that is used for TRC.

**MASS LOADINGS**

Mass loading limits are applicable for publicly owned treatment works. Current policy requires average monthly mass loading limits be established for CBOD<sub>5</sub>, TSS, and NH<sub>3</sub>-N. Average monthly mass loading limits (lbs./day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

**TN and TP MONITORING**

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 gpd require monitoring, at a minimum, for Total Nitrogen and Total Phosphorus. Annual monitoring is used for facilities that are not in impaired waters for nutrients.

**Monitoring Frequency Considerations**

Monitoring frequencies were established in accordance with Table 6-3, Self-Monitoring Requirements for Sewage Discharges, Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, 362-0400-001

**Chesapeake Bay and further TN and TP Monitoring**

According to Phase 3 Watershed Implementation Plan (WIP) Wastewater Supplement Revised July 29, 2022, Section II, pg. 17, the Hillsdale STP is considered a non-significant Phase 5 facility because its design annual average daily flow of 0.055 mgd is less than 0.2 mgd and greater than 0.002 mgd. The permittee has no plans to expand the Hillsdale STP. Annual monitoring for TN and TP will be retained in accordance with Section II, pg. 17 of the Phase 3 WIP.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Average Monthly	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0	XXX	XXX	XXX	1/day	Grab
CBOD5	9.2	XXX	XXX	20.0	XXX	40	2/month	Grab
BOD5 Raw Sewage Influent	Report	XXX	Report	XXX	XXX	XXX	2/month	Grab
TSS	13.8	XXX	XXX	30.0	XXX	60.0	2/month	Grab
TSS Raw Sewage Influent	Report	XXX	Report	XXX	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report Min Mo Avg	Report	XXX	XXX	1/day	Recorded
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	1.3	XXX	XXX	2.8	XXX	5.6	2/month	Grab
Ammonia May 1 - Oct 31	0.9	XXX	XXX	1.9	XXX	3.8	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None.



## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
08B	27100	CUSH CREEK

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.800	Hillsdale STP	8.18	17.66	8.18	17.66	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.800	Hillsdale STP	1.73	5.98	1.73	5.98	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
7.80	Hillsdale STP	25	25	5.98	5.98	3	3	0	0

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
08B	27100	CUSH CREEK	7.800	1568.00	1.54	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.15	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Hillsdale STP	PA0218812	0.0270	0.0550	0.0550	0.000	25.00	7.00

  

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
08B	27100	CUSH CREEK	4.100	1377.00	5.82	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.58	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
08B	27100	CUSH CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
7.800	0.055	21.779	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
6.588	0.400	16.456	0.091	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
10.19	0.601	2.13	0.803	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.377	24.641	Owens	6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
2.495	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.249	8.66	1.74	7.98
	0.499	7.35	1.43	7.98
	0.748	6.25	1.17	7.98
	0.998	5.31	0.95	7.98
	1.247	4.51	0.78	7.98
	1.497	3.84	0.64	7.98
	1.746	3.26	0.52	7.98
	1.996	2.77	0.43	7.98
	2.245	2.35	0.35	7.98
	2.495	2.00	0.29	7.98

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
08B		27100		CUSH CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.800	Hillsdale STP	PA0218812	0.027	CBOD5	25		
				NH3-N	5.98	11.96	
				Dissolved Oxygen			3

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
08B		27100				CUSH CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
7.800	0.15	0.00	0.15	.0851	0.00978	.4	6.59	16.46	0.09	2.495	21.78	7.00
<b>Q1-10 Flow</b>												
7.800	0.10	0.00	0.10	.0851	0.00978	NA	NA	NA	0.08	2.892	22.32	7.00
<b>Q30-10 Flow</b>												
7.800	0.21	0.00	0.21	.0851	0.00978	NA	NA	NA	0.10	2.220	21.44	7.00

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		