

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0218821
APS ID 1055494
Authorization ID 1382932

Applicant and Facility Information

Applicant Name	<u>Indiana County Municipal Service Authority</u>	Facility Name	<u>Penn Run STP</u>
Applicant Address	<u>602 Kolter Drive</u> <u>Indiana, PA 15701-3570</u>	Facility Address	<u>656 Spaulding Road</u> <u>Indiana, PA 15701</u>
Applicant Contact	<u>Tricia Lefko</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 349-6640</u>	Facility Phone	<u>(724) 349-6640</u>
Client ID	<u>38534</u>	Site ID	<u>534583</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Cherryhill Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Indiana</u>
Date Application Received	<u>January 25, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal of a municipal sewage treatment plant (STP).</u>		

Summary of Review

This is an existing discharge for a minor sewage treatment facility.

Act 14 – Proof of Notification was submitted and received.

Existing treatment consists of (WQM Permit No. 3202406): Equalization tank, aeration tank, clarifier, then UV disinfection unit. Sludge is air lifted from clarifier to a waste treatment tank.

There are 10 open violations in WMS for the subject Client ID (38534) as of 12/5/2023, all for Safe Drinking Water violations at facilities other than this one. *Permittee will be notified in the Draft Permit Cover Letter of open violations and given an opportunity to address them prior to final permit issuance. CWY 12/15/2023*

Annual monitoring for E. Coli has been added per Department SOP for new and reissued NPDES permits with design flows exceeding 2000GPD.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	December 5, 2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	12/15/2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.03</u>
Latitude	<u>40° 37' 36.99"</u>	Longitude	<u>-79° 0' 16.96"</u>
Quad Name	<u>Clymer</u>	Quad Code	<u>40079F1</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Penn Run (CWF)</u>	Stream Code	<u>44276</u>
NHD Com ID	<u>123716911</u>	RMI	<u></u>
Drainage Area	<u>2.08</u>	Yield (cfs/mi ²)	<u>0.12</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.2496</u>	Q ₇₋₁₀ Basis	<u>Streamstats</u>
Elevation (ft)	<u>1421</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>18-D</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>METALS, SILTATION</u>		
Source(s) of Impairment	<u>ACID MINE DRAINAGE, STREAMBANK MODIFICATIONS/DESTABILIZATION</u>		
TMDL Status	<u>Final, Final</u>	Name	<u>Kiskiminetas-Conemaugh River Watersheds TMDL, Penn Run Watershed</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°F)	<u>20</u>	Default	<u></u>
Hardness (mg/L)	<u>100</u>	Default	<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>PA American Water Company – Two-Lick Creek</u>		
PWS Waters	<u>Two-Lick Creek</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary				
Treatment Facility Name: Penn Run STP				
WQM Permit No.		Issuance Date		
3202406		10/27/2003		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage		Aeration and Settling	Ultraviolet	0.011
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.031	75	Not Overloaded		

Changes Since Last Permit Issuance: None

Other Comments: None.

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.03</u>
Latitude <u>40° 37' 38.00"</u>	Longitude <u>-79° 0' 18.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
E. Coli	Report	IMAX		92a.61

Comments: E. Coli monitoring is based on the Department's SOP for new and reissued permits.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD ₅	25.0	Avg. Monthly	WQM 7.0 v.1.1b
Dissolved Oxygen	3.0	Instant. Minimum	WQM 7.0 v.1.1b
NH ₃ -N	15.0	Avg. Monthly	WQM 7.0 v.1.1b

Comments: WQM modeling calculated a minimum Dissolved Oxygen (DO) limit of 3.0 mg/l, but a 4.0 mg/l limit shall be imposed per the Department's SOP as a BPJ limit. *WQM modeling calculated a summertime NH₃-N limit of 15.0 mg/l, but the more restrictive limit of 5.0 mg/l in the existing permit will be retained in accordance with the EPA anti-backsliding policy. CWY 12/15/2023*

Best Professional Judgment (BPJ) Limitations

Comments: Monitoring frequencies for Dissolved Oxygen and pH are established as 1/day in congruence with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits" (SOP No. BPNPSM-PMT-033, dated November 9, 2012, Revised March 24, 2021).

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 GPD require monitoring, at a minimum, for Total Nitrogen and Total Phosphorus in new and reissued permits. Discharge flows below 0.500MGD are required to sample these two parameters at a rate of 1/year.

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	6.3	XXX	XXX	25.0	XXX	50.0	2/month	Grab
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
TSS	7.5	XXX	XXX	30.0	XXX	60.0	2/month	Grab
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
UV Transmittance (%)	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None.

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
18D 44276 PENN RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.400	Penn Run STP	15.27	50	15.27	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.400	Penn Run STP	1.82	15.09	1.82	15.09	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.40	Penn Run STP	25	25	15.09	15.09	3	3	0	0

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18D	44276	PENN RUN	3.400	1421.00	2.08	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)								Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.120	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Penn Run STP	PA0218821	0.0125	0.0300	0.0300	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18D	44276	PENN RUN	1.800	1323.00	6.85	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.120	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18D	44276	PENN RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
3.400	0.030	20.784	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
7.364	0.414	17.768	0.097	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.61	0.771	2.37	0.744	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.421	23.621	Owens	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
1.008	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.101	5.17	2.20	8.12
	0.202	4.77	2.04	8.12
	0.302	4.40	1.89	8.12
	0.403	4.06	1.75	8.12
	0.504	3.75	1.63	8.12
	0.605	3.46	1.51	8.12
	0.706	3.19	1.40	8.12
	0.807	2.94	1.30	8.12
	0.907	2.71	1.21	8.12
	1.008	2.50	1.12	8.12

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18D		44276		PENN RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.400	Penn Run STP	PA0218821	0.013	CBOD5	25		
				NH3-N	15.09	30.18	
				Dissolved Oxygen			3

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
18D		44276		PENN RUN								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
3.400	0.25	0.00	0.25	.0464	0.01160	.414	7.36	17.77	0.10	1.008	20.78	7.00
Q1-10 Flow												
3.400	0.16	0.00	0.16	.0464	0.01160	NA	NA	NA	0.08	1.235	21.13	7.00
Q30-10 Flow												
3.400	0.34	0.00	0.34	.0464	0.01160	NA	NA	NA	0.11	0.869	20.60	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		