

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

Application No. **PA0218944**  
APS ID **1103233**  
Authorization ID **1466215**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>Franklin Township Sewer Authority Fayette County</b>	Facility Name	<b>Franklin Fayette Sewer Authority WWTF</b>
Applicant Address	PO Box 55  Smock, PA 15480-0055	Facility Address	Hursch & Burma Roads  Smock, PA 15480
Applicant Contact	Michael Voytovich	Facility Contact	Same as Applicant
Applicant Phone	(724) 677-2272	Facility Phone	Same as Applicant
Client ID	159043	Site ID	549158
Ch 94 Load Status	Not Overloaded	Municipality	Franklin Township
Connection Status	No Limitations	County	Fayette
Date Application Received	<u>December 26, 2023</u>	EPA Waived?	No
Date Application Accepted	<u>December 26, 2023</u>	If No, Reason	Discharge to TMDL Waters.
Purpose of Application	<u>NPDES Permit Renewal for Discharge of Treated Sewage Effluent.</u>		

**Summary of Review**

Franklin Township Sewer Authority has applied for the renewal of the NPDES Permit PA0218944. The previous permit was issued on May 29, 2019 and will expire on June 30, 2024. The renewal application was received on December 26, 2023, which considered timely.

The design discharge flow rate is 0.1 MGD, and the discharge is to Redstone Creek, which is classified as warm water fisheries (WWF) and located in the State Watershed 19-C.


WQM permit 2601403 was issued on April 12, 2002 and approved the construction of the following facilities: Manual Bar Screen, SBR Tanks, and Ultraviolet Disinfection. The sludge from SBR tanks is pumped to an aerobic digesting tank.

After reviewing the application, DEP sent a deficiency letter on January 23, 2024 for missing information including:

- Application was missing information on Page 1, Sec. 4, and Page 3 of the renewal application to describe the sewage sludge use/disposal.
- No description was included for the treatment plant process over Page 2 of the renewal application.
- Application was missing the full list of the effluent sample results listed on page 6 of the renewal application including the TMDL parameters.

The applicant responded on February 22, 2024 with an updated application document that fulfil DEP's request.

No hydraulic or organic overloads are projected to occur within the next five years per CH94 report for 2023.

Approve	Deny	Signatures	Date
X		 Hazim Aldalli / Environmental Engineering Specialist	June 27, 2024
X		 Mahbuba Iasmin, Ph.D., P.E./ Environmental Engineering Manager	July 5, 2024

### Summary of Review

Operations compliance report on January 31, 2024 concluded that the permittee is in general compliance with no open violations.

No industrial users are discharging to this facility per the application.

The application stated that there were no changes to the facility conditions regarding discharge, receiving stream, or treatment technology, also not foreseen for the next five years, thus Act 537 was not needed.

The applicant is currently enrolled in and will continue to use eDMR.

The Act 14-PL 834 Municipal Notification was provided by the December 11, 2023 letters and no comments were received.

Sludge use and disposal description and location(s): Sludge/ biosolids produced for 2022 was 0.81 dry tons and hauled to Clairton Wastewater Treatment Plant. Also, this plant (per application) is not receiving additional sludge from other sources.

### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	0.10
Latitude	39° 59' 52"	Longitude	-79° 47' 14"
Quad Name	New Salem	Quad Code	39079H7
Wastewater Description:	Sewage Effluent		
Receiving Waters	Redstone Creek (WWF)	Stream Code	39931
NHD Com ID	99411876	RMI	8.92
Drainage Area	84.7	Yield (cfs/mi <sup>2</sup> )	0.0238
Q <sub>7-10</sub> Flow (cfs)	2.02	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	1265	Slope (ft/ft)	0.001
Watershed No.	19-C	Chapter 93 Class.	WWF
Existing Use			
Exceptions to Use	None.		
Assessment Status	Impaired		
Cause(s) of Impairment	METALS		
Source(s) of Impairment	ACID MINE DRAINAGE		
TMDL Status	Final, 2008	Name	Redstone Creek Watershed
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake		Newell Muni Auth	
PWS Waters	Monongahela River	Flow at Intake (cfs)	550
PWS RMI	50.8	Distance from Outfall (mi)	>12.0

Changes Since Last Permit Issuance:

- Q<sub>7-10</sub> flow, elevation, drainage area, and low flow yield were all updated to match USGS Stream Stats new data (see Attachment A).
- DEP updated its WQM 7.0 criteria for Ammonia-Nitrogen (NH<sub>3</sub>-N) in 2019. Limits and conditions of this permit need to be redeveloped to an adequate level to protect water quality.
- *E. Coli* monitoring requirements will be introduced to this renewal which is in compliance with DEP SOP No. BCW-PMT-033 revised February 5, 2024.

Other Comments: None.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Franklin Fayette Sewer Authority WWTF				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
2601403	April 12, 2002			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Ultraviolet	0.048
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.1	240	Not Overloaded	Aerobic Digestion	Off Site

Changes Since Last Permit Issuance: None.

## Operations Compliance Check Summary Report

**Facility:** Franklin Fayette Sewer Authority WWTF

**NPDES Permit No.:** PA0218944

**Compliance Review Period:** 1/1/19-1/31/24

### Inspection Summary:

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	INSPECTION COMMENT
05/02/2023	Compliance Evaluation	PA Dept of Environmental Protection	Violation(s) Noted	
05/01/2023	Administrative/File Review	PA Dept of Environmental Protection	No Violations Noted	An administrative review of eDMRs from 2/1/20 to 5/1/23 revealed (4) effluent violations which have been noted on the 5/2/23 CEI report.
02/11/2020	Compliance Evaluation	PA Dept of Environmental Protection	Violation(s) Noted	

### Violation Summary:

VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE	VIOLATION COMMENT
05/02/2023	92A.44	NPDES - Violation of effluent limits in Part A of permit	01/26/2024	1/31/2022 Fecal Geo Mean 2712 > 2000 No./100 ml 1/31/2022 CBOD Weekly Avg. 63 > 37.5 mg/L 1/31/2022 Fecal I Max 97,000 > 10,000 No./100 ml 1/31/2022 CBOD I Max 63 > 50 mg/L
02/11/2020	92A.44	NPDES - Violation of effluent limits in Part A of permit	10/31/2022	

### Open Violations by Client ID:

No open violations for Client ID 159043

### Enforcement Summary:

ENF TYPE	EXECUTED DATE	VIOLATIONS	ENF FINAL STATUS	ENF CLOSED DATE
NOV	05/12/2023	92A.44	Administrative Close Out	02/06/2024
NOV	02/11/2020	92A.44	Administrative Close Out	02/06/2024

### Effluent Violation Summary:

MON	PD	PARAMETER	SAMPLE	PERMIT	UNIT	STAT BASE CODE	FACILITY COMMENTS
Jan-22		Carbonaceous Biochemical Oxygen Demand (CBOD5)	63	37.5	mg/L	Weekly Average	Didn't know any
Jan-22		Carbonaceous Biochemical Oxygen Demand (CBOD5)	63	50	mg/L	Instantaneous Maximum	problems on 1/12/2022 plant was running
Jan-22		Fecal Coliform	2712	2000	No./100 ml	Geometric Mean	normal. I found out what had happened when checking plant on the

		No./100	Instantaneous	20th of January. Had problem fixed-motor failure.
Jan-22	Fecal Coliform	97000	10000 ml	Maximum

**Compliance Status:** Facility does not currently have any open violations or pending enforcements.

**Completed by:** Amanda Illar

**Completed date:** 1/31/24 (Updated 2/7/24)

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 59' 52.00"  
Wastewater Description: Treated Sewage Effluent.

Design Flow (MGD) 0.1  
Longitude -79° 47' 14.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/L)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli (No./100 ml)	Report	IMAX	-	92a.61
D.O. (mg/L)	4.0	Min	-	BPJ
NH <sub>3</sub> -N (mg/L)	25	Average Monthly	-	BPJ
	50	IMAX		
Total N (mg/L)	Report	Average Monthly	-	92a.61
Total P (mg/L)	Report	Average Monthly	-	92a.61

Comments: The existing discharge was evaluated using WQM 7.0 to develop CBOD<sub>5</sub>, NH<sub>3</sub>-N, and D.O. parameters.

The Total Suspended Solids (TSS), pH, and Fecal Coliform parameters are not evaluated using WQM 7.0. The bases for the proposed technology-based limitations are listed in the above table.

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling, output files attached (Attachments B):

Parameter	Limit (mg/l)	SBC	Model
CBOD <sub>5</sub> (May1-Oct 31)	25	Average Monthly	WQM7.0
CBOD <sub>5</sub> (Nov 1- Apr 30)	25	Average Monthly	WQM7.0
NH <sub>3</sub> -N (May1-Oct 31)	21.5	Average Monthly	WQM7.0
NH <sub>3</sub> -N (Nov 1- Apr 30)	25	Average Monthly	WQM7.0
Dissolved Oxygen	4.0	Minimum	WQM7.0

Comments: WQM 7.0 was used to determine the newly imposed seasonal limits for Ammonia Nitrogen NH<sub>3</sub>-N. After applying DEP's regulation (Implementation Guidance of Section 93.7 Ammonia Criteria, 1997); the new limits will be AML of 21.5 mg/L for the warm period and AML of 25.0 mg/L for the cold period.

Per renewal application effluent sampling and eDMR values; the facility can meet the newly imposed Ammonia limits as this plant has achieved lower than the new proposed limits; no compliance schedule is necessary, weekly monitoring shall be required.

For the Carbonaceous Biochemical Oxygen Demand  $\text{CBOD}_5$ , the WQM 7.0 model generated a WQBEL AML of 25 mg/L a year around, which matches the previous permit limits. Weekly monitoring shall be required.

### **Best Professional Judgment (BPJ) Limitations**

A minimum Dissolved Oxygen (DO) limit of 4.0 mg/L should be established based on DEP water quality model WQM 7.0 Version 1.1 (Appendix B) and on Best Professional Judgment (BPJ) to ensure adequate operation and maintenance as listed in the table under Technology-Based Limitations section (see page 7).

### **Anti-Backsliding**

The previously imposed limits for pH Effluent Limitation of (6.0 Minimum, and 9.0 Maximum SIU), Fecal Coliform AML Geo Mean seasonal limits of (200 & 2000 CFU/100 ml), and TSS AML, Weekly Average, and Ins. Max of (30, 45, and 60 mg/L); will be all unchanged due to Anti-Backsliding as stated in 40 CFR Section 122.44(l).

### **Total Maximum Daily Load (TMDL) Considerations**

This facility discharges to the Redstone River Watersheds, this Watershed has a Final TMDL and is impaired by metals and abandoned mine drainage is the source for the TMDL impairment. This sanitary sewage discharge is not expected to contribute to the stream metals impairment. The contribution for metals pollution by Aluminum, Iron, and Manganese from a sewage plant of this nature is expected to be insignificant.

No WLAs have been developed for this facility; monitoring requirements for Total Iron, Total Manganese, and Total Aluminum were imposed per the previous permit.

The application's effluent sampling results for TMDL metals showed no in stream water quality criteria exceedance. Therefore, no limits are needed to be imposed and monitoring will continue through this renewal. The permittee will be asked again to show no violations to the water quality criteria for this TMDL through the renewal application effluent sampling.

### **Total Dissolved Solids (TDS) and its Major Constituents**

Total Dissolved Solids (TDS) and its major constituents including sulfate, chloride, and bromide have emerged as pollutants of concern. The conservative nature of these solids allows them to accumulate in surface waters and they may remain a concern even if the immediate downstream public water supply is not directly impacted. Bromide has been linked to formation of disinfection byproducts at increased levels in public water systems.

Because of actions associated with Triennial Review 13, the Environmental Quality Board has directed DEP to collect additional data if the Bromide is greater than 1 mg/L, and the TDS is greater than 1000 mg/L or the TDS exceeds 20,000 lbs/day. The maximum reported concentration for Bromide is <0.20 mg/L as listed in the updated renewal application dated 2/21/2024. The maximum reported concentration for TDS is 318 mg/L as listed in the updated renewal application dated 2/21/2024.

Therefore, monitoring is not required for TDS, Bromide, Chloride, and Sulfate.

### **TN and TP Monitoring**

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 gpd require monitoring. Redstone Creek segment within the facility is not impaired for nutrients (per PA eMAP), also, the stringent newly proposed Ammonia limits will help in lowering Total Nitrogen.

Per DEP-SOP No. BCW-PMT-033 revised February 5, 2024, 1/year monitoring for Total Nitrogen and Total Phosphorus will be applied at Outfall 001.

### **Disinfection**

Per DEP SOP BCW-PMT-033 - *Establishing Effluent Limitations for Individual Sewage Permits* Revised, February 5, 2024, permittee can even report (at a minimum) UV transmittance (%), UV dosage ( $\mu\text{Ws}/\text{cm}^2$  or  $\text{mWs}/\text{cm}^2$  or  $\text{mJoules}/\text{cm}^2$ ) or UV intensity ( $\mu\text{W}/\text{cm}^2$  or  $\text{mW}/\text{cm}^2$ ). The previous permit required Ultraviolet Disinfection Light Transmittance be measured in  $\text{mJoules}/\text{cm}^2$ . Since there is no change to current regs and SOPs, the renewal permit will carry over the limit with the same frequency and units.

Part C33 will be added to the renewal permit.

### **E. Coli**

Pursuant to 25 Pa. code § 92a.61(b), quarterly monitoring for *E. Coli* will be imposed at Outfall 001 per DEP SOP No. BCW-PMT-033 revised February 5, 2024.

### **Mass Loadings**

Mass loading limits are applicable for publicly owned treatment works (POTW). Current policy requires average monthly and average weekly mass loading limits be established for  $\text{CBOD}_5$  and TSS.

Average monthly mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

### **Influent Monitoring**

Per DEP SOP No. BCW-PMT-033 revised February 5, 2024, for POTWs with design flows greater than 2,000 GPD, influent  $\text{BOD}_5$  and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters.

### **Monitoring Frequency Considerations**

For pH, Dissolved Oxygen (DO) and Ultraviolet (UV) , a monitoring frequency of "1/day" has been imposed. The daily monitoring frequencies are consistent with current policy and Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations. Daily monitoring is required for these parameters to provide minimum assurance that the facility is being operated properly.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	20.9	31.3	XXX	25	37.5 Wkly Avg	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	25.0	37.6	XXX	30	45 Wkly Avg	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen (NH3-N) May 1 - Oct 31	17.9	26.5	XXX	21.5	31.75	43	1/week	8-Hr Composite
Ammonia-Nitrogen (NH3-N) Nov 1 - Apr 30	20.9	31.3	XXX	25	37.5	50	1/week	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Maximum	Instant. Maximum		
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Aluminum	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Iron	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Manganese	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: at Outfall 001


Other Comments: None.



**ATTACHMENT A:**  
**USGS StreamStats**

## StreamStats Report

Region ID: PA  
Workspace ID: PA20240131193647296000  
Clicked Point (Latitude, Longitude): 39.99749, -79.78664  
Time: 2024-01-31 14:37:10 -0500



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	84.7	square miles
ELEV	Mean Basin Elevation	1265	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	84.7	square miles	2.26	1400
ELEV	Mean Basin Elevation	1265	feet	1050	2580

#### Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	4.61	ft^3/s	43	43
30 Day 2 Year Low Flow	7.25	ft^3/s	38	38
7 Day 10 Year Low Flow	2.02	ft^3/s	66	66
30 Day 10 Year Low Flow	3.11	ft^3/s	54	54
90 Day 10 Year Low Flow	5.19	ft^3/s	41	41

#### Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.19.3

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**ATTACHMENT B:**  
**WQM7.0 Model Results (Summer)**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	39931	REDSTONE CREEK	8.920	1265.00	84.70	0.00100	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.024	2.02	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Franklin WWTF	PA0218944	0.1000	0.1000	0.1000	0.000	20.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	39031	REDSTONE CREEK			4.700	1236.00	102.00	0.00100	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Roh Trav Time (days)	Roh Velocity (fps)	WD Ratio	Roh Width (ft)	Roh Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.025	2.51	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Franklin WWTF	PA0218944	0.0000	0.0000	0.0000	0.000	20.00	7.00		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	4.00	8.24	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin			Stream Code		Stream Name							
19C			39931		REDSTONE CREEK							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach	Analysis	Analysis
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	Trav Time	Temp	pH
<b>Q7-10 Flow</b>												
8.920	2.02	0.00	2.02	.1547	0.00100	1.426	14.26	10	0.11	2.411	24.64	7.00
<b>Q1-10 Flow</b>												
8.920	1.29	0.00	1.29	.1547	0.00100	NA	NA	NA	0.09	3.028	24.47	7.00
<b>Q30-10 Flow</b>												
8.920	2.75	0.00	2.75	.1547	0.00100	NA	NA	NA	0.13	2.051	24.73	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19C	39931	REDSTONE CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
8.920	0.100	24.644	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
14.259	1.428	10.000	0.107	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.64	0.200	1.55	1.001	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.941	1.135	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
2.411	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.241	3.43	1.22	6.46
	0.482	3.23	0.98	5.63
	0.723	3.04	0.75	5.24
	0.964	2.86	0.59	5.13
	1.206	2.70	0.48	5.20
	1.447	2.54	0.38	5.37
	1.688	2.39	0.29	5.60
	1.929	2.25	0.22	5.85
	2.170	2.12	0.18	6.11
	2.411	2.00	0.14	6.35

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
19C	39931	REDSTONE CREEK							
<b>NH3-N Acute Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
	8.920 Franklin WWTF	7.02	50	7.02	50	0	0		
<b>NH3-N Chronic Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
	8.920 Franklin WWTF	1.37	25	1.37	25	0	0		
<b>Dissolved Oxygen Allocations</b>									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
	8.92 Franklin WWTF	25	25	21.76	21.76	4	4	0	0

**WQM 7.0 Effluent Limits**

SWP Basin 19C	Stream Code 39931	Stream Name REDSTONE CREEK					
		Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
8.920	Franklin WWTF	PA0218944	0.100	CBOD5	25		
				NH3-N	21.76	43.52	
				Dissolved Oxygen			4

**ATTACHMENT B:**  
**WQM7.0 Model Results (Winter)**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
				(ft)	(sq mi)	(ft/ft)	(mgd)		
19C	39931	REDSTONE CREEK		8.920	1265.00	84.70	0.00100	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>									
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C) pH
	(cfs/m)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C) pH
Q7-10	0.048	2.02	0.00	0.000	0.000	10.0	0.00	0.00	5.00 7.00
Q1-10		0.00	0.00	0.000	0.000				
Q30-10		0.00	0.00	0.000	0.000				
<b>Discharge Data</b>									
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
	Franklin WWTF	PA0218944	0.1000	0.1000	0.1000	0.000	15.00	7.00	
<b>Parameter Data</b>									
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
	CBOD5		25.00	2.00	0.00	1.50			
	Dissolved Oxygen		4.00	12.51	0.00	0.00			
	NH3-N		25.00	0.00	0.00	0.70			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	39931	REDSTONE CREEK			4.700	1236.00	102.00	0.00100	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.049	2.51	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Franklin WWTF	PA0218944	0.0000	0.0000	0.0000	0.000	15.00	7.00		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	4.00	12.51	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name											
		19C	39931	REDSTONE CREEK									
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
8.920	2.02	0.00	2.02	.1547	0.00100	1.426	14.26	10	0.11	2.411	5.71	7.00	
<b>Q1-10 Flow</b>													
8.920	1.29	0.00	1.29	.1547	0.00100	NA	NA	NA	0.09	3.028	6.07	7.00	
<b>Q30-10 Flow</b>													
8.920	2.75	0.00	2.75	.1547	0.00100	NA	NA	NA	0.13	2.051	5.53	7.00	

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19C	39931	REDSTONE CREEK		
<u>RMI</u> 8.920	<u>Total Discharge Flow (mgd)</u> 0.100	<u>Analysis Temperature (°C)</u> 5.711	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 14.259	<u>Reach Depth (ft)</u> 1.426	<u>Reach WDRatio</u> 10.000	<u>Reach Velocity (fps)</u> 0.107	
<u>Reach CBOD5 (mg/L)</u> 3.64	<u>Reach Kc (1/days)</u> 0.428	<u>Reach NH3-N (mg/L)</u> 1.78	<u>Reach Kn (1/days)</u> 0.233	
<u>Reach DO (mg/L)</u> 11.905	<u>Reach Kr (1/days)</u> 0.724	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 2.411	<u>Subreach Results</u>			
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.241	3.45	1.68	11.25
	0.482	3.27	1.59	10.89
	0.723	3.10	1.50	10.55
	0.964	2.94	1.42	10.29
	1.206	2.78	1.34	10.11
	1.447	2.64	1.27	9.99
	1.688	2.50	1.20	9.91
	1.929	2.37	1.13	9.87
	2.170	2.25	1.07	9.86
	2.411	2.13	1.01	9.88

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
19C		39931	REDSTONE CREEK						
<b>NH3-N Acute Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
	8.920 Franklin WWTF	20.59	50	20.59	50	0	0		
<b>NH3-N Chronic Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
	8.920 Franklin WWTF	4.08	25	4.08	25	0	0		
<b>Dissolved Oxygen Allocations</b>									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
	8.92 Franklin WWTF	25	25	25	25	4	4	0	0

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19C	39931	REDSTONE CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
8.920	Franklin WWTF	PA0218944	0.100	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4