

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0219045
APS ID 1063118
Authorization ID 1395835

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|--|
| Applicant Name | <u>Apollo Ridge School District</u> | Facility Name | <u>Apollo Ridge School District STP</u> |
| Applicant Address | <u>1825 State Route 56</u> <u>Spring Church, PA 15686-9735</u> | Facility Address | <u>State Route 56</u> <u>Spring Church, PA 15686</u> |
| Applicant Contact | <u>Greg Barsoum</u> <u>(Barsoumg@apolloridge.com)</u> | Facility Contact | <u>Greg Barsoum</u> <u>(Barsoumg@apolloridge.com)</u> |
| Applicant Phone | <u>(724) 478-6050</u> | Facility Phone | <u>(724) 478-6050</u> |
| Client ID | <u>51860</u> | Site ID | <u>550928</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Kiskiminetas Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Armstrong</u> |
| Date Application Received | <u>May 10, 2022</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>May 11, 2022</u> | If No, Reason | <u>-</u> |
| Purpose of Application | <u>Renewal of an existing NPDES Permit for an existing discharge of treated sanitary wastewater from a non-municipal sewer system.</u> | | |

Summary of Review

Act 14 - Proof of Notification was submitted and received.
A Part II Water Quality Management permit is not required at this time.
The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization
- F. Little Assimilative Capacity

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in effects associated with the subject Client ID (51860) as of 3/29/2023. *4/18/2023 CWY*

| Approve | Deny | Signatures | Date |
|---------|------|---|-----------|
| X | | Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist | 3/29/2023 |
| X | | Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager | 4/18/2023 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|--|--|------------------------------|---|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>0.0267</u> |
| Latitude | <u>40° 36' 7.00"</u> | Longitude | <u>-79° 28' 37.00"</u> |
| Quad Name | <u>-</u> | Quad Code | <u>-</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Unnamed Tributary to the Roaring Run (CWF)</u> | Stream Code | <u>N/A</u> |
| NHD Com ID | <u>125291151</u> | RMI | <u>N/A</u> |
| Drainage Area | <u>0.62</u> | Yield (cfs/mi ²) | <u>0.1</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>0.062</u> | Q ₇₋₁₀ Basis | <u>calculated</u> |
| Elevation (ft) | <u>1385</u> | Slope (ft/ft) | <u>0.04753</u> |
| Watershed No. | <u>18-B</u> | Chapter 93 Class. | <u>CWF</u> |
| Existing Use | <u>-</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>Attaining Use(s)</u> | | |
| Cause(s) of Impairment | <u>-</u> | | |
| Source(s) of Impairment | <u>-</u> | | |
| TMDL Status | <u>Final*</u> | Name | <u>Kiskiminetas-Conemaugh River Watersheds TMDL</u> |
| Background/Ambient Data | | Data Source | |
| pH (SU) | <u>-</u> | | <u>-</u> |
| Temperature (°F) | <u>-</u> | | <u>-</u> |
| Hardness (mg/L) | <u>-</u> | | <u>-</u> |
| Other: | <u>-</u> | | <u>-</u> |
| Nearest Downstream Public Water Supply Intake | <u>Buffalo Township Municipal Water Authority - Freeport</u> | | |
| PWS Waters | <u>Allegheny River</u> | Flow at Intake (cfs) | <u>2,576</u> |
| PWS RMI | <u>30.0</u> | Distance from Outfall (mi) | <u>23.0</u> |

* - This discharge consists of treated non-municipal sewage only and does not contribute to the impairment of the receiving stream. However, since the stream is impaired for AMD metals, per the SOP, monitoring for Total Aluminum, Total Iron, and Total Manganese will be retained with this renewal.

Sludge use and disposal description and location(s): All sludge is hauled by CWM Environmental to the AVJSA WWTP, where it is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be

published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.0267 MGD of treated sewage from two existing schools in Kiskiminetas Township, Armstrong County.

Treatment permitted under WQM Permit No. 0301404 consists of the following: A muffin monster with bypass bar screen, a two-chamber flow equalization tank, six aeration tanks in series, one clarifier, a two-chamber aerobic digester, tablet chlorine disinfection with a contact tank, sodium bisulfite dechlorination, a polishing tank, and a post-aeration chamber. The treated effluent flows into a storm sewer pipe and then into an unnamed tributary to the Roaring Run.

1. Streamflow:

Crooked Creek at Idaho, Pa. 03038000 (1970-2008)

| | | | |
|---------------------|-------------|---------|--------------------|
| Drainage Area: | <u>191</u> | sq. mi. | (USGS StreamStats) |
| Q ₇₋₁₀ : | <u>19.9</u> | cfs | (USGS StreamStats) |
| Yieldrate: | <u>0.1</u> | cfs/m | calculated |

Unnamed Tributary to the Roaring Run at Outfall 001:

| | | | |
|------------------------|--------------|---------|----------------------|
| Yieldrate: | <u>0.1</u> | cfs/m | calculated above |
| Drainage Area: | <u>0.62</u> | sq. mi. | (USGS StreamStats) |
| % of stream allocated: | <u>100%</u> | Basis: | No nearby discharges |
| Q ₇₋₁₀ : | <u>0.062</u> | cfs | calculated |

2. Wasteflow:

Maximum discharge: 0.0267 MGD = 0.04 cfs

Runoff flow period: 24 hours Basis: Runoff with flow equalization

The calculated stream flow (Q₇₋₁₀) is less than 3 times the permitted discharge flow. However, since this is an existing discharge, the more stringent treatment requirements cannot be achieved, and the receiving stream is not impaired by the discharge, the standards in DEP guidance (391-2000-014) will not be applied.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency will remain as 5/week per the SOP.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum based on Chapter 92a47.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Total Phosphorus

Chapter 96.5 does not apply. The previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61. However, the monitoring frequency will be reduced from 1/quarter to 1/year since the receiving stream is not impaired, per the SOP.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61. However, the monitoring frequency will be reduced from 1/quarter to 1/year since the receiving stream is not impaired, per the SOP.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.5 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value

Calculated NH₃-N Summer limits: 5.3 mg/l (monthly average)
10.6 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 15.9 mg/l (monthly average)
31.8 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits. The calculated limits are less restrictive than in the previous permit. Since the previous limits are attainable, they will be retained.

h. CBOD₅

Median discharge pH to be used: 7.5 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated limits above (see Attachment 1). The limits are the same as in the previous permit and will be retained.

i. Dissolved Oxygen (DO)

The technology-based minimum of 3.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. However, the previous technology-based limit of 6.0 mg/l from DEP guidance number 391-2000-014 will be retained.

The measurement frequency will remain as 5/week per the SOP.

j. Disinfection

Ultraviolet (UV) light

TRC limits: 0.22 mg/l (monthly average)

0.74 mg/l (instantaneous maximum)

Basis: The TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 2). The calculated limits are less restrictive than in the previous permit. Since the previous limits are attainable, they will be retained.

The measurement frequency will remain as 5/week per the SOP.

4. Reasonable Potential Analysis for Receiving Stream:

A Reasonable Potential Analysis was not performed in accordance with State practices using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no sample data was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Buffalo Township Municipal Water Authority - Freeport
Distance downstream from the point of discharge: 23.0 miles

Result: No limits or monitoring is necessary as there is significant dilution available.

6. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

7. Attachment List:

Attachment 1 - WQ Modeling Printouts
Attachment 2 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from February 1, 2022 to January 31, 2023)

| Parameter | JAN-23 | DEC-22 | NOV-22 | OCT-22 | SEP-22 | AUG-22 | JUL-22 | JUN-22 | MAY-22 | APR-22 | MAR-22 | FEB-22 |
|--|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Flow (MGD) Average Monthly | 0.00327 | 0.00319 | 0.00257 | 0.00504 | 0.00614 | 0.00136 | 0.00029 | 0.00444 | 0.00548 | 0.00398 | 0.00454 | 0.00934 |
| pH (S.U.) Minimum | 7.41 | 7.55 | 7.51 | 7.17 | 7.34 | 7.48 | 7.5 | 7.12 | 7.01 | 6.94 | 6.86 | 6.72 |
| pH (S.U.) Maximum | 8.62 | 8.28 | 8.78 | 8.16 | 8.38 | 8.26 | 8.65 | 8.72 | 7.97 | 7.87 | 8.26 | 8.52 |
| DO (mg/L) Minimum | 9.59 | 11.24 | 9.72 | 8.98 | 7.14 | 6.58 | 7.21 | 6.41 | 7.59 | 9.31 | 10.42 | 11.4 |
| TRC (mg/L) Average Monthly | < 0.10 | < 0.04 | < 0.10 | 0.05 | 0.1 | 0.1 | 0.04 | < 0.10 | 0.05 | 0.04 | < 0.1 | < 0.1 |
| TRC (mg/L) Instantaneous Maximum | 0.21 | 0.13 | 0.22 | 0.1 | 0.21 | 0.19 | 0.10 | 0.21 | 0.13 | 0.15 | 0.28 | 0.21 |
| CBOD5 (mg/L) Average Monthly | < 9.0 | < 3.0 | < 3.0 | < 3.0 | 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 |
| CBOD5 (mg/L) Instantaneous Maximum | 14.3 | < 3.0 | < 3.0 | 3.3 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 | < 3.0 |
| TSS (mg/L) Average Monthly | 5.0 | 6.0 | < 3.0 | 6.0 | 9.0 | < 4.0 | < 4.0 | < 3.0 | 8.0 | < 3.0 | < 4.0 | < 3.0 |
| TSS (mg/L) Instantaneous Maximum | 5.0 | 8.0 | < 3.0 | 7 | 10.0 | 4.0 | 4.0 | 3.0 | 8.0 | 3.0 | 4.0 | < 3.0 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 1.0 | < 1.0 | < 16.0 | 135.0 | 118 | 19.0 | 18.0 | 30.0 | 95 | 17 | < 14.0 | 74 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | < 1.0 | < 1.0 | 31 | 436 | 1554 | 33.0 | 18.0 | 58.0 | 167 | 29.0 | 26.0 | 143 |
| Total Nitrogen (mg/L) Daily Maximum | | < 1.0 | | | | | | | | | | |
| Ammonia (mg/L) Average Monthly | < 0.20 | 0.10 | < 0.10 | 0.1 | < 0.20 | < 0.10 | 0.1 | 0.20 | 0.10 | < 0.101 | 0.10 | 0.20 |
| Ammonia (mg/L) Instantaneous Maximum | 0.22 | 0.13 | < 0.10 | 0.14 | 0.39 | < 0.10 | 0.16 | 0.24 | 0.13 | 0.14 | 0.15 | 0.34 |
| Total Phosphorus (mg/L) Daily Maximum | | 9.19 | | | | | | | | | | |
| Total Aluminum (mg/L) Daily Maximum | | < 0.10 | | | | | | | | | | |
| Total Iron (mg/L) Daily Maximum | | 0.07 | | | | | | | | | | |
| Total Manganese (mg/L) Daily Maximum | | < 0.02 | | | | | | | | | | |

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|-------------------|-----------------------|--------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | XXX | XXX | XXX | XXX | XXX | 2/month | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | 9.0 | XXX | 5/week | Grab |
| DO | XXX | XXX | 6.0 | XXX | XXX | XXX | 5/week | Grab |
| TRC | XXX | XXX | XXX | 0.1 | XXX | 0.3 | 5/week | Grab |
| CBOD5 | XXX | XXX | XXX | 25.0 | XXX | 50.0 | 2/month | Grab |
| TSS | XXX | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/year | Grab |
| Total Nitrogen | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |
| Ammonia Nov 1 - Apr 30 | XXX | XXX | XXX | 5.5 | XXX | 11.0 | 2/month | Grab |
| Ammonia May 1 - Oct 31 | XXX | XXX | XXX | 2.0 | XXX | 4.0 | 2/month | Grab |
| Total Phosphorus | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |
| Total Aluminum | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|-----------------|-------------------------------------|-------------------|-----------------------|--------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Total Iron | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |
| Total Manganese | XXX | XXX | XXX | Report Annl Avg | XXX | XXX | 1/year | Grab |

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids (TSS), and Fecal Coliforms are technology-based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, Total Nitrogen, Total Phosphorus, Total Aluminum, Total Iron, and Total Manganese is based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits (Perennial Reach)

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|--------------|--------------------|-----------------|--------------------|--------------------------------|----------------------------|----------------------------|
| 18B | | 43050 | | ROARING RUN | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 1.430 | Apollo Ridge | PA0219045a | 0.027 | CBOD5 | 19.23 | | |
| | | | | NH3-N | 4.93 | 9.86 | |
| | | | | Dissolved Oxygen | | | 3 |

CBOD5 is the same as the Dry Reach input, so the Dry Reach limit is protective.

The DO limit is more restrictive than the Dry Reach inputs, so it governs.

For NH3-N, the limit can be back-calculated using the equation: $Ct = (Co)e^{-kt}$, where

$Ct = 4.93 \text{ mg/l}$

$k = 0.7 \text{ days}^{-1} = \text{constant for NH3-N}$

$t = 0.127 \text{ days} = \text{Dry Reach Model travel time}$

Therefore, $4.93 \text{ mg/l} = (Ct)e^{-(0.7 \text{ days}^{-1})(0.127 \text{ days})}$

$Ct = 5.38$

$\text{NH3-N} = 5.3 \text{ mg/l}$

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|
| 18B | 43050 | ROARING RUN | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> |
| 1.430 | 0.027 | 21.999 | 7.139 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> |
| 3.524 | 0.371 | 9.485 | 0.079 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> |
| 8.89 | 1.149 | 1.97 | 0.816 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> |
| 6.147 | 25.927 | Owens | 6 |
| <u>Reach Travel Time (days)</u> | Subreach Results | | |
| 0.774 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> |
| | | | <u>D.O. (mg/L)</u> |
| | 0.077 | 8.06 | 1.85 |
| | 0.155 | 7.31 | 1.74 |
| | 0.232 | 6.63 | 1.63 |
| | 0.310 | 6.02 | 1.53 |
| | 0.387 | 5.46 | 1.44 |
| | 0.465 | 4.95 | 1.35 |
| | 0.542 | 4.49 | 1.27 |
| | 0.619 | 4.07 | 1.19 |
| | 0.697 | 3.70 | 1.11 |
| | 0.774 | 3.35 | 1.05 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 18B | 43050 | ROARING RUN | 1.430 | 1385.00 | 0.62 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.100 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|--------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Apollo Ridge | PA0219045a | 0.0267 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.50 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 19.23 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 2.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 21.45 | 0.00 | 0.00 | 0.70 |

(input from Dry Reach)

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 18B | 43050 | ROARING RUN | 0.430 | 1134.00 | 1.37 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.100 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Wasteload Allocations

| | | |
|------------------|--------------------|--------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 18B | 43050 | ROARING RUN |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 1.430 | Apollo Ridge | 11.28 | 22.11 | 11.28 | 22.11 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 1.430 | Apollo Ridge | 1.62 | 4.93 | 1.62 | 4.93 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 1.43 | Apollo Ridge | 19.23 | 19.23 | 4.93 | 4.93 | 3 | 3 | 0 | 0 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|-------------------|--------------------|-----------------------|--------------------------|---------------------|--------------------|------------|-----------|----------------|------------------------|--------------------|-------------|
| 18B | | 43050 | | | | ROARING RUN | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 1.430 | 0.06 | 0.00 | 0.06 | .0413 | 0.04754 | .371 | 3.52 | 9.49 | 0.08 | 0.774 | 22.00 | 7.14 |
| Q1-10 Flow | | | | | | | | | | | | |
| 1.430 | 0.04 | 0.00 | 0.04 | .0413 | 0.04754 | NA | NA | NA | 0.07 | 0.887 | 22.55 | 7.19 |
| Q30-10 Flow | | | | | | | | | | | | |
| 1.430 | 0.08 | 0.00 | 0.08 | .0413 | 0.04754 | NA | NA | NA | 0.09 | 0.694 | 21.64 | 7.11 |

WQM 7.0 D.O.Simulation (Dry Reach)

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|
| 18B | 43050 | ROARING RUN | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 0.220 | 0.027 | 24.882 | | 7.478 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 0.931 | 0.429 | 2.171 | | 0.106 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 24.41 | 1.500 | 24.41 | | 1.019 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 3.953 | 25.910 | Owens | | NA |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | |
| 0.127 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.013 | 23.83 | 24.10 | 2.00 |
| | 0.025 | 23.27 | 23.79 | 2.00 |
| | 0.038 | 22.73 | 23.48 | 2.00 |
| | 0.051 | 22.19 | 23.18 | 2.00 |
| | 0.063 | 21.67 | 22.88 | 2.00 |
| | 0.076 | 21.16 | 22.59 | 2.00 |
| | 0.089 | 20.66 | 22.30 | 2.00 |
| | 0.102 | 20.17 | 22.01 | 2.00 |
| | 0.114 | 19.70 | 21.73 | 2.00 |
| | 0.127 | 19.23 | 21.45 | 2.00 |

(input into Perennial Reach)

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|------------|-------------------------------------|-------------------------------------|
| Parameters | D.O. | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | Simulation | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 2 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|--------------------------|
| 18B | 43050 | ROARING RUN | 0.220 | 1399.00 | 0.01 | 0.00000 | 0.00 | <input type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.100 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Dry Reach | PA0219045 | 0.0267 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.50 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 0.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 4.00 | 2.00 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------|-------|----------------|-----------------------|---------------|----------------------|--------------------------|
| 18B | 43050 | ROARING RUN | 0.000 | 1385.00 | 0.02 | 0.00000 | 0.00 | <input type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.100 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|--------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 18B | | 43050 | | | | ROARING RUN | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 0.220 | 0.00 | 0.00 | 0.00 | NA | 0.01205 | .429 | .93 | 2.17 | 0.11 | 0.127 | 24.88 | 7.48 |
| Q1-10 Flow | | | | | | | | | | | | |
| 0.220 | 0.00 | 0.00 | 0.00 | NA | 0.01205 | NA | NA | NA | 0.00 | 0.000 | 0.00 | 0.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 0.220 | 0.00 | 0.00 | 0.00 | NA | 0.01205 | NA | NA | NA | 0.00 | 0.000 | 0.00 | 0.00 |

Attachment 2

| TRC EVALUATION | | | | | |
|---|--|-------------------------------|--|-----------|--------------------------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | | |
| 0.062 | = Q stream (cfs) | | | 0.5 | = CV Daily |
| 0.0267 | = Q discharge (MGD) | | | 0.5 | = CV Hourly |
| 30 | = no. samples | | | 1 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | | | 1 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | | | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BPJ Value | | | 720 | = CFC_Criteria Compliance Time (min) |
| 0 | = % Factor of Safety (FOS) | | | 0 | = Decay Coefficient (K) |
| Source | Reference | AFC Calculations | | Reference | CFC Calculations |
| TRC | 1.3.2.iii | WLA_afc = 0.498 | | 1.3.2.iii | WLA_cfc = 0.478 |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | | 5.1c | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = 0.186 | | 5.1d | LTA_cfc = 0.278 |
| Source | Effluent Limit Calculations | | | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.231 | | | |
| PENTOXSD TRG | 5.1g | AVG_MON_LIMIT (mg/l) = 0.228 | | AFC | |
| | | INST_MAX_LIMIT (mg/l) = 0.747 | | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | | |
| LTA_afc | wla_afc * LTAMULT_afc | | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | | |
| LTA_cfc | wla_cfc * LTAMULT_cfc | | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | | |
| AVG_MON_LIMIT | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT) | | | | |
| INST_MAX_LIMIT | $1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$ | | | | |