



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0219185**
APS ID **1097421**
Authorization ID **1455944**

Applicant and Facility Information

Applicant Name	Glen Campbell Borough Indiana County		
Applicant Address	P O Box 43	Facility Name	Glen Campbell Borough WTP
	Glen Campbell, PA 15708	Facility Address	State Route 286 North
Applicant Contact	Dave Lucas	Facility Contact	
Applicant Phone	(814) 845-7861	Facility Phone	
Client ID	145809	Site ID	262079
Ch 94 Load Status	Not Overloaded	Municipality	Glen Campbell Borough
Connection Status	No Limitations	County	Indiana
Date Application Received	<u>September 18, 2023</u>	EPA Waived?	Yes
Date Application Accepted	<u>October 4, 2023</u>	If No, Reason	
Purpose of Application	This is an application to renew the NPDES Permit for Glen Campbell Boroughs Sewage Treatment Plant.		

Summary of Review

Glen Campbell Borough owns a Sewage Treatment Plant that collects and treats domestic sewage from approximately 220 residents. Sewage at the facility is treated through flow equalization, extended aeration, final clarification, and chlorine disinfection.

Key changes on this renewal include an increased monitoring frequency for Total Nitrogen and Total Phosphorous, addition of E. Coli monitoring, and a TRC Compliance schedule as the facility does not already meet the new limit more than 75% of the time.

Sludge use and disposal description and location(s): 2.7 Dry Tons of sewage/biosolids are disposed of offsite at West Branch, Northern Cambria or Punxsutawney Sewer Authority.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Dustin Hargenrater Dustin Hargenrater / Project Manager	March 5, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	March 6, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.034
Latitude	40° 49' 3"	Longitude	-78° 49' 13"
Quad Name	Burnside	Quad Code	40078G7
Wastewater Description:	Sewage Effluent		

Receiving Waters	Unnamed Tributary to West Branch Susquehanna River (CWF)	Stream Code	38162
NHD Com ID	61834833	RMI	0.11
Drainage Area	1.64	Yield (cfs/mi ²)	0.0507
Q ₇₋₁₀ Flow (cfs)	0.0832	Q ₇₋₁₀ Basis	USGS - StreamStats
Elevation (ft)	1351	Slope (ft/ft)	---
Watershed No.	8-B	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	

Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°F)	60	Default	
Hardness (mg/L)	100	Default	
Other:			

Nearest Downstream Public Water Supply Intake	PA American Water Company – White Deer		
PWS Waters	West Branch Susquehanna River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	>100

Changes Since Last Permit Issuance: This facility has not been modeled since the original permitting of the facility so more recent data is being used. Modeling outputs did not suggest more stringent limits; however, the modeling output files will be attached to ensure an updated model is present in the permit file.

Compliance History

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD) Average Monthly	0.014	0.0166	0.0131	0.0117	0.0112	0.018	0.00958	0.012	0.012	0.0269	0.0174	0.0119
Flow (MGD) Instantaneous Maximum	0.024	0.027	0.0185	0.0154	0.0157	0.0692	0.017	0.08	0.088	0.0712	0.05	0.0276
pH (S.U.) Instantaneous Minimum	7.0	7.0	7.1	7.1	6.88	6.8	6.81	6.83	6.67	6.7	6.9	6.4
pH (S.U.) Instantaneous Maximum	7.1	7.6	7.8	7.7	7.44	7.07	7.1	7.7	6.93	6.95	7.27	7.17
DO (mg/L) Instantaneous Minimum	10.0	9.2	9.61	8.0	7.88	6.8	8.6	8.40	9.0	9.11	9.89	9.36
TRC (mg/L) Average Monthly	0.23	0.26	0.25	0.28	0.29	0.25	0.29	0.29	0.28	0.31	0.29	0.30
TRC (mg/L) Instantaneous Maximum	0.45	0.48	0.47	0.49	0.50	0.49	0.48	0.48	0.48	0.46	0.47	0.46
CBOD5 (lbs/day) Average Monthly	0.4	0.3	0.2	0.2	0.2	0.3	0.2	0.2	0.8	0.3	0.3	0.2
CBOD5 (mg/L) Average Monthly	3.2	2.4	2.0	2.0	2.2	3.0	2	2.2	2.4	2.0	2.2	2.0
CBOD5 (mg/L) Instantaneous Maximum	3.63	2.61	2.0	2.0	2.4	3.4	2	2.5	2.44	2.0	2.28	2.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	29	29	16	12	11	39	14	15	87	17	17.0	25
BOD5 (mg/L) Raw Sewage Influent Average Monthly	236	225	159	130	151	339	173	198	251	124	142	276
BOD5 (mg/L) Raw Sewage Influent Instantaneous Maximum	266	248	186	165	195	452	262	209	295	148	172.0	341

NPDES Permit Fact Sheet
Glen Campbell Borough WTP

NPDES Permit No. PA0219185

TSS (lbs/day) Average Monthly	0.6	0.8	0.5	0.5	0.4	1.1	0.4	0.4	2.0	0.6	0.6	0.5
TSS (lbs/day) Raw Sewage Influent Average Monthly	17	16	11	15	7.0	24	18	16	106	17	15	26
TSS (mg/L) Average Monthly	5	5	5	5.0	5.0	9	5	5	5.0	5.0	5.0	5.0
TSS (mg/L) Raw Sewage Influent Average Monthly	139	126	114	166	103	213	225	212	282	115	135	290
TSS (mg/L) Instantaneous Maximum	5.0	5	5	5.0	5.0	13	5.0	5	5.0	5.0	5.0	5.0
TSS (mg/L) Raw Sewage Influent Instantaneous Maximum	198	144	131	200	150	254	326	276	310	120	178	380
Fecal Coliform (No./100 ml) Geometric Mean	14	5.74	3.16	1.0	2.2	13.93	2	14.9	3.87	2.83	11.8	2.24
Fecal Coliform (No./100 ml) Instantaneous Maximum	14	33	10	1.0	4	194	2	37	5.0	8.0	139.0	5
Total Nitrogen (mg/L) Daily Maximum			24									
Ammonia (lbs/day) Average Monthly	0.2	0.02	0.1	0.01	0.006	0.2	0.03	0.01	0.08	1.1	0.5	0.05
Ammonia (mg/L) Average Monthly	0.2	0.1	0.1	0.1	0.1	1.5	0.2	0.2	0.2	0.4	0.4	0.5
Ammonia (mg/L) Instantaneous Maximum	0.2	0.2	0.1	0.1	0.02	3.86	0.4	0.152	0.0118	0.126	0.4	0.5
Total Phosphorus (mg/L) Daily Maximum			3.68									

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 49' 3.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .034
Longitude -78° 49' 13.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen	4.0	Average Monthly	WQM 6.3*
Dissolved Oxygen	5.0	Instantaneous Minimum	WQM 6.3*
TRC	0.25	Average Monthly	TRC_CALC

*This discharge was modeled using WQM 7.0 however the WQM 7.0 Model produced less stringent limits for Ammonia-Nitrogen than were previously calculated. This limit is not subject to backsliding as it does not fall under any of the exceptions to backslide limits contained in 40 CFR Part 122.44 (l).2.i.

This discharge was modeled using WQM 7.0 to determine limitations for CBOD₅, Ammonia-Nitrogen, and Dissolved Oxygen. The modeling results suggested that the limits for CBOD₅ are appropriate. Existing Dissolved Oxygen limitations were also determined to be sufficient for the facility. Ammonia-Nitrogen limits produced by the model suggested a less stringent limit of 5.87 mg/l Monthly Average Limit and 11.74 mg/l, however due to anti-backsliding requirements these limitations will not be implemented. It seems the main difference in the models was the stream-flow figured at the receiving stream. Based on USGS – StreamStats the anticipated low-flow rate of the stream was 0.0834 cfs, the previous model used a value of 0.05 cfs for the low-flow of the stream. It is unclear where this number was derived from however this seems to be the main difference between the two models.

Total Residual Chlorine was modeled using the TRC_CALC spreadsheet to calculate effluent limitations for TRC. The modeling results for TRC_CALC suggested an average monthly limitation of 0.251 mg/l and an instantaneous maximum limitation of 0.784 mg/l. The average monthly limitation of 0.251 mg/l is more stringent than the current limits so this limit will be implemented. The facility does not already meet this limitation more than 75% of the time so a 3-year compliance schedule has been implemented into the renewal permit. The instantaneous maximum limit of 0.784 mg/l is less stringent than the current limitation and is not eligible for backsliding so the 0.51 mg/l instantaneous maximum limit that is currently in the permit will remain. Again a value of 0.05 cfs was used for the flow at the stream as well as a Coefficient of Variation of 0.03 was used in the original model which appear to be the main differences between the models and an explanation as to how a less stringent instantaneous maximum limit was calculated on the updated model.

Best Professional Judgment (BPJ) Limitations

Comments: No BPJ Limitations are being considered at this time.

Anti-Backsliding

Less stringent limitations for Ammonia-Nitrogen and TRC Instantaneous Maximum limits were calculated using updated models however due the anti-backsliding regulations contained in 40 CFR Part 122.44 (l).1, these less stringent limitations are not eligible to be applied. The facility has not requested a relaxation of these limits and already meets the limits a majority of the time so the more stringent limits will remain part of the permit.

Additional Changes

Sewage dischargers with design flows > 2,000 GPD will include monitoring, at a minimum, for Total Nitrogen and Total Phosphorous in new and reissued permits, with a monitoring frequency equivalent to conventional pollutants in Table 6-3 of the Permit Writers Manual based on the SOP for Establishing Effluent Limitations for Individual Sewage Permits.

Sewage discharges will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/year for design flows of 0.002 – 0.05 MGD based on the SOP for Establishing Effluent Limitations for Individual Sewage Permits.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through End of Interim Period 1.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report IMAX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.33	XXX	0.51	1/day	Grab
CBOD5	7.1	XXX	XXX	25	XXX	50	2/month	Grab
TSS	8.5	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia Nov 1 - Apr 30	3.4	XXX	XXX	12.0	XXX	24.0	2/month	Grab
Ammonia May 1 - Oct 31	1.1	XXX	XXX	4.0	XXX	8.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: TRC Compliance Schedule – Phase 1.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: End of Interim Period 1 through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report IMAX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.25	XXX	0.51	1/day	Grab
CBOD5	7.1	XXX	XXX	25	XXX	50	2/month	Grab
TSS	8.5	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia Nov 1 - Apr 30	3.4	XXX	XXX	12.0	XXX	24.0	2/month	Grab
Ammonia May 1 - Oct 31	1.1	XXX	XXX	4.0	XXX	8.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: TRC Compliance Schedule – Final Effluent Limitations.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report	2/month	Grab
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report	2/month	Grab

Compliance Sampling Location: Influent Monitoring Poin

TRC_CALC Modeling Output Files

TRC_CALC

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc = 0.522		1.3.2.iii	WLA_cfc = 0.502		
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581		
PENTOXSD TRG	5.1b	LTA_afc = 0.195		5.1d	LTA_cfc = 0.292		
Effluent Limit Calculations							
PENTOXSD TRG	5.1f	AML MULT = 1.288					
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.251			INST MAX LIMIT (mg/l) = 0.784	AFc	
WLA_afc		$(.019/e(-k* AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k* AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)*(1-FOS/100)]$					
LTAMULT_afc		$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$					
LTA_afc		wla_afc*LTAMULT_afc					
WLA_cfc		$(.011/e(-k* CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k* CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)*(1-FOS/100)]$					
LTAMULT_cfc		$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$					
LTA_cfc		wla_cfc*LTAMULT_cfc					
AML MULT		$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$					
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT		$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$					

WQM 7.0 Modeling Output Files

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19D		38162 Trib 38162 of Youghiogheny River	0.110	1351.00	1.64	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.051	0.08	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
GlenCampbellSTP	PA0219185	0.0340	0.0340	0.0340	0.000	20.00	7.11
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	5.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19D	38162	Trib 38162 of Youghiogheny River	0.000	1335.00	1.66	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.051	0.08	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		5.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
19D			38162			Trib 38162 of Youghiogheny River							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
Q7-10 Flow													
0.110	0.08	0.00	0.08	.0526	0.02755	.375	5.11	13.63	0.07	0.095	20.00	7.04	
Q1-10 Flow													
0.110	0.05	0.00	0.05	.0526	0.02755	NA	NA	NA	0.06	0.109	20.00	7.05	
Q30-10 Flow													
0.110	0.11	0.00	0.11	.0526	0.02755	NA	NA	NA	0.08	0.085	20.00	7.03	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
19D 38162 Trib 38162 of Youghiogheny River

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.110	GlenCampbellIST	16	32.2	16	32.2	1	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.110	GlenCampbellIST	1.86	5.87	1.86	5.87	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.11	GlenCampbellISTP	25	25	5.87	5.87	5	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19D	38162	Trib 38162 of Youghiogheny River		
<u>RML</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.110	0.034	20.000	7.039	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
5.107	0.375	13.632	0.071	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
10.91	1.320	2.27	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.987	22.672	Owens	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.095	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.009	10.77	2.26
		0.019	10.64	2.24
		0.028	10.51	2.23
		0.038	10.38	2.21
		0.047	10.25	2.20
		0.057	10.12	2.19
		0.066	9.99	2.17
		0.076	9.87	2.16
		0.085	9.75	2.14
		0.095	9.63	2.13
				7.16
				7.31
				7.42
				7.52
				7.60
				7.67
				7.73
				7.78
				7.82
				7.86

WQM 7.0 Effluent Limits

SWP Basin 19D	Stream Code 38162	Stream Name Trib 38162 of Youghiogheny River					
		Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.110	GlenCampbellSTP	PA0219185	0.034	CBOD5	25		
				NH3-N	5.87	11.74	
				Dissolved Oxygen			5