

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0219258
APS ID 1095567
Authorization ID 1452120

Applicant and Facility Information

Applicant Name	<u>Mechling Shakley Veterans Center Inc.</u>	Facility Name	<u>Mechling Shakley Veterans Center</u>
Applicant Address	<u>1431 State Route 268</u> <u>Cowansville, PA 16218</u>	Facility Address	<u>Mechling Shakley Veterans Cent</u> <u>Cowansville, PA 16218</u>
Applicant Contact	<u>Sean Taladay, Executive Director</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 545-9016</u>	Facility Phone	<u>(724) 545-9016</u>
Applicant E Mail	<u>sean@268center.com</u>	Facility E Mail	<u></u>
Client ID	<u>162952</u>	Site ID	<u>552248</u>
Municipality	<u>Sugarcreek Township</u>	County	<u>Armstrong</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
SIC Code	<u></u>	SIC Code	<u>4952</u>
SIC Description	<u></u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Date Application Received	<u>August 9, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 6, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal</u>		

Summary of Review

No violations open or otherwise on file. [10/10/2023 CWY](#) Existing TRC, DO, & pH monitoring is 3/week while daily monitoring is recommended by the and the NPDES Permits Writers Manual.

1 dry ton sludge sent to Allegheny Valley Joint Sewage Authority STP for further treatment and disposal.

Facility operation by CWM Environmental.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	September 6, 2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. Environmental Engineer Manager	10/10/2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.008</u>
Latitude DP	<u>40° 55' 18.00"</u>	Longitude DP	<u>79° 36' 59.00"</u>
Latitude NHD	<u>40° 55' 6.36"</u>	Longitude NHD	<u>79° 36' 54.71"</u>
Quad Name	<u>East Brady</u>	Quad Code	<u>1109</u>
Wastewater Description: <u>Treated domestic sewage</u>			
Receiving Waters	<u>Unnamed Tributary of Patterson Creek</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>123971284</u>	RMI	<u>0.04</u>
Drainage Area	<u>0.158</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>USGS topographic map</u>
Elevation (ft)	<u>1420.00</u>	Slope (ft/ft)	<u>0.095</u>
Watershed No.	<u>18-F</u>	Chapter 93 Class.	<u>HQ-TSF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>0.04-mile dry swale discharge to dry stream RMI 0.15 at elevation 1320 feet Node and basin Drainage 0.158-square mile, Confluence with intermittent tributary at Node RMI 0.27 (Stream, RMI 2.69), elevation 1392.86 feet and drainage 274.5-acres (0.43-square miles)</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	<u>NA</u>	Name	_____
Background/Ambient Data		Data Source	
pH (SU)	_____		_____
Temperature (°C)	<u>20</u>		<u>CWF default</u>
Hardness (mg/L)	<u>100</u>		<u>Default</u>
CBOD ₅ (mg/L)	_____		_____
Ammonia Nitrogen (mg/L)	_____		_____
Other:	_____		_____
Nearest Downstream Public Water Supply Intake	<u>Creekside Mushrooms LTD located on Buffalo Creek</u>		
PWS Waters	_____	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	_____

Changes Since Last Permit Issuance

As the receiving waters are classified as high quality the water supply criteria is applied at the discharge.

The first downstream public (municipal) water supply is on the Allegheny River by the Harrison Township Water Authority at RMI 21.89. This is 29.0 miles downstream.

Treatment Facility Summary				
Treatment Facility Name: Mechling-Shakley Veterans Center STP				
WQM Permit No.		Issuance Date		
0303402		August 22, 2003		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration with solids removal	Chlorination followed by dechlorination	0.0015
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.008	13.4		Aerobic Digestion	Off site

Changes Since Last Permit Issuance: None

Treatment: comminutor with bypass bar screen, a flow equalization basin, an aeration tank, a final clarifier, an aerobic digester, a dual cell fixed media tank for TSS removal, a chlorine contact tank utilizing a tablet chlorinator, a de-chlorinator and post aeration.

Compliance History

No violations listed

	Month	Year	Influent			Effluent					
			Flow Mean MGD	Mass Mean PPD	Mean mg/L	Max mg/L	#	Min mg/L	Mean mg/L	Max mg/L	#
Annual Average Design Hydraulic Design Capacity			0.008								
Organic Design Capacity											
Annual Average		2022	0.112*								
		2021	0.111*								
		2020	0.121*								
Highest Monthly Average	Dec		0.136*								
pH							6.7		7.29	624	
TRC							0.01	0.01	0.01	312	
Fecal coliform								1.88	249	48	
CBOD5					290	813	48		4.24	6.8	48
TSS					320.5	816	48		4.56	14.0	48
NH3N								0.25	1.01	48	
N							1.40	31.9	62.4	2	
P							7.30	7.44	7.58	2	

The design annual average flow is 0.0015-MGD and the hydraulic average is flow 0.008 MGD.
The August 1, 2022 to July 31, 2023 self-monitoring report flow are a lot less than above.

**As reported on Application. Based on a review of eDMRs, it appears the flow listed on the application is off by two orders of magnitude. 10/10/2023 CWY*

Compliance History

DMR Data for Outfall 001 (from August 1, 2022 to July 31, 2023)

Parameter	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22
Flow (MGD) Average Monthly	0.004267	0.0040325	0.0037664	0.003548	0.003299	0.003001	0.002554	0.001985	0.001365	0.001059	0.000611	0.0009
pH (S.U.) Instant Minimum	6.92	7.28	7.8	6.9	7.03	7.15	6.98	6.9	6.92	6.89	6.9	6.93
pH (S.U.) Instant Maximum	7.72	8.4	7.11	7.62	7.59	7.50	7.51	7.11	7.01	7.03	7.06	7.04
DO (mg/L) Instant Minimum	8.13	7.48	8.8	9.08	9.9	9.86	10.0	8.28	8.01	8.05	7.96	7.92
TRC (mg/L) Average Monthly	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
TRC (mg/L) Instant Maximum	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.001	< 0.01	< 0.01	< 0.01
CBOD5 (mg/L) Average Monthly	< 3.0	< 4.2	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 4.9	< 3.0	< 3.0	< 3.7	< 3.0
CBOD5 (mg/L) Weekly Average	< 3.0	5.3	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	3.0	4.4	3.2
CBOD5 (mg/L) Instant Maximum	< 3.0	5.3	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	6.8	< 3.0	3.0	4.4	3.2
TSS (mg/L) Average Monthly	< 3.5	< 4.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	3.5	< 3.0	< 3.0	< 3.0
TSS (mg/L) Weekly Average	4.0	5.0	< 3.0	< 3.0	< 3.0	3.0	< 3.0	3.0	4.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Instant Maximum	4.0	5.0	< 3.0	< 3.0	< 3.0	3.0	< 3.0	3.0	4.0	< 3.0	< 3.0	< 3.0
Fecal Coliform (#/100 ml) Geo Mean	4.0	17.0	< 1.0	< 1.0	< 1.0	< 1.0	< 4.0	< 1.0	< 1.0	< 1.0	< 6.0	14.0
Fecal Coliform (#/100 ml) Instant Maximum	7.0	56.0	< 1.0	< 1.0	< 1.0	< 1.0	14.0	< 1.0	2.0	< 1.0	35.0	26.0
Total Nitrogen (mg/L) Daily Maximum								1.45				
Ammonia (mg/L) Average Monthly	0.12	0.57	1.57	< 0.23	0.13	< 0.10	< 0.42	0.26	< 0.3	< 0.1	< 0.1	< 0.15
Ammonia (mg/L) Instant Maximum	0.12	0.96	2.01	0.35	0.14	< 0.10	0.74	0.29	0.5	< 0.1	0.1	0.19
Total Phosphorus (mg/L) Daily Maximum								7.29				

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.008</u>
Latitude <u>40° 55' 18.00"</u>	Longitude <u>-79° 36' 59.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0	Daily minimum		BPJ
E Coli	Report			BPJ

Comments: E coli monitoring proposed as the discharge is to a HQ-TSF stream and the discharge is over 0.002-MGD.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen May 1 – Oct 31	1.9	Average Monthly	WQAM63
Ammonia-Nitrogen Nov 1 – Apr 30	3.8	Average Monthly	WQAM63
Total Residual Chlorine	0.01	Average Monthly	TRC_CALA

Additional Limitations

Parameter	Limit (mg/l)	SBC	Basis
CBOD ₅	10	Average Monthly	ABACT – Water Quality Anti-Degradation Implementation Guidance
TSS	10	Average Monthly	ABACT – Water Quality Anti-Degradation Implementation Guidance
Dissolved Oxygen	6	Minimum	ABACT – Water Quality Anti-Degradation Implementation Guidance
Total Nitrogen	Report	Annually	SOP- Establishing Effluent Limitations for Individual Sewage Permits, Version 1.0
Total Phosphorus	Report	Annually	SOP- Establishing Effluent Limitations for Individual Sewage Permits, Version 1.0

Other Considerations

CBOD5 and ammonia modelling shifted from WQM6.3 to WQM 7.1 slightly changing the modelling layout and water quality-based requirements.

Best Professional Judgment (BPJ) Limitations

Comments: Not applicable

Anti-Backsliding

Not applicable

1A	B	C	D	E	F	G	H	I	J	K	L	M
	Discharger Site Municipality County NPDES Permit 0.5		Mechling Shakley Veterans Center Inc. Mechling Shakley Veterans Center Inc. STF Sugarcreek Township Armstrong PA0219258					Revised	Tuesday, August 1, 2023 Thursday, September 7, 2023			
2	TRC EVALUATION											
3	Input appropriate values in B4:B8 and E4:E7											
4	0.001	= Q stream (cfs)							0.5	= CV Daily		
5	0.0295	= Q discharge (MGD)							0.5	= CV Hourly		
6	30	= no. samples							1	= AFC_Partial Mix Factor		
7	0.3	= Chlorine Demand of Stream							1	= CFC_Partial Mix Factor		
8	0	= Chlorine Demand of Discharge							15	= AFC_Criteria Compliance Time (min)		
9	0.5	= BAT/BPJ Value							720	= CFC_Criteria Compliance Time (min)		
	0	= % Factor of Safety (FOS)								=Decay Coefficient (K)		
10	Source	Reference	AFC Calculations				Reference	CFC Calculations				
11	TRC	1.3.2.iii	WLA afc = 0.025				1.3.2.iii	WLA cfc = 0.018				
12	PENTOXSD TRG	5.1a	LTAMULT afc = 0.373				5.1c	LTAMULT cfc = 0.581				
13	PENTOXSD TRG	5.1b	LTA_afc = 0.009				5.1d	LTA_cfc = 0.010				
14	Source	Effluent Limit Calculations										
16	PENTOXSD TRG	5.1f	AML MULT = 1.231									
17	PENTOXSD TRG	5.1g	↓ LIMIT (mg/l) = 0.011				AFC					
18			↓ LIMIT (mg/l) = 0.037									
	WLA afc	$(0.019/e^{-(k \cdot AFC_tc)}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd) \cdot e^{-(k \cdot AFC_tc)}] \dots$										
	LTAMULT afc	$\dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$										
	LTA_afc	$EXP((0.5 \cdot LN((cvh^2 + 1)) - 2.326 \cdot LN((cvh^2 + 1)^{0.5})))$										
	WLA_cfc	$(0.011/e^{-(k \cdot CFC_tc)}) + [(CFC_Yc \cdot Qs \cdot 0.011 / Qd) \cdot e^{-(k \cdot CFC_tc)}] \dots$										
	LTAMULT_cfc	$\dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$										
	LTA_cfc	$EXP((0.5 \cdot LN((cvd^2 / no_samples + 1)) - 2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5})))$										
	AML MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN((cvd^2 / no_samples + 1)))$										
	AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc)) \cdot AML_MULT$										
	INST MAX LIMIT	$1.5 \cdot ((av_mon_limit) \cdot AML_MULT) / LTA_MULT_afc$										
	$(0.011 / EXP(-k \cdot CFC_tc / 1440)) + (((CFC_Yc \cdot Qs \cdot 0.011) / (1.547 \cdot Qd)) \dots$											
	$\dots \cdot EXP(-k \cdot CFC_tc / 1440)) + Xd + (CFC_Yc \cdot Qs \cdot Xs / 1.547 \cdot Qd) \cdot (1 - FOS / 100)$											
	Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual					
	Stream	Reach/Node	1	1								
	Stream	Flow	Conditions	dry								
	Stream	Code		unknown								
	Stream	Function		OUTFALL								
	Samples			30								
	reach	outfall	RMI	0.04								
	Reach End		RMI	0								
	reach		feet	211.2								
	drainage		sq miles	0.03								
	TRC	limitation	average	mg/L	0.011							
			maximum	mg/L	0.037							
	elevation	modelled	feet	1440								
	elevation	modelled	feet	1420.00								
	slope	modelled	foot/foot	0.095								
	low flow		cfs/sq mi	0.027								
	discharge		mgd	0.0295								
	Runoff	Period	hours	24.000								
	HQ-TSF watershed											
	stream	flow		cfs	0.00080							
	stream	flow		MGD	0.000517							
	stream	flow	total	MGD	0.030017							
	stream	chlorine	demand	mg/L	0.3							
	discharge	discharge	demand	mg/L								
	stream	Total Stream/Waste	ratio		1.0							
	BAT	TRC	mean	BAT	0.5							
	BAT	TRC	maximum	BAT	1.6							

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42708	Trib 42708 to Patterson Creek	2.690	1392.86	0.28	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.027	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42708	Trib 42708 to Patterson Creek	2.420	1330.77	0.43	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.027	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18F		42708				Trib 42708 to Patterson Creek						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.880	0.00	0.00	0.00	.0124	0.09470	.304	.84	2.78	0.05	0.048	20.00	7.00
2.840	0.00	0.00	0.00	.0124	0.03427	.271	1.64	6.06	0.04	0.246	20.00	7.00
2.690	0.01	0.00	0.01	.0124	0.04355	.278	1.93	6.93	0.04	0.446	20.00	7.00
Q1-10 Flow												
2.880	0.00	0.00	0.00	.0124	0.09470	NA	NA	NA	0.05	0.048	20.00	7.00
2.840	0.00	0.00	0.00	.0124	0.03427	NA	NA	NA	0.04	0.260	20.00	7.00
2.690	0.00	0.00	0.00	.0124	0.04355	NA	NA	NA	0.03	0.483	20.00	7.00
Q30-10 Flow												
2.880	0.00	0.00	0.00	.0124	0.09470	NA	NA	NA	0.05	0.047	20.00	7.00
2.840	0.01	0.00	0.01	.0124	0.03427	NA	NA	NA	0.04	0.234	20.00	7.00
2.690	0.01	0.00	0.01	.0124	0.04355	NA	NA	NA	0.04	0.415	20.00	7.00

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42708	Trib 42708 to Patterson Creek	2.880	1440.00	0.03	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.027	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
MS Vet Ctr	PA0219258a	0.0080	0.0080	0.0080	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	6.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
 18F 42708 Trib 42708 to Patterson Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.880	MS Vet Ctr	16.76	17.45	16.76	17.45	0	0
2.840		NA	NA	16.76	NA	NA	NA
2.690		NA	NA	16.76	NA	NA	NA

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.880	MS Vet Ctr	1.89	2.04	1.89	2.04	0	0
2.840		NA	NA	1.89	NA	NA	NA
2.690		NA	NA	1.89	NA	NA	NA

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.88	MS Vet Ctr	25	25	2.04	2.04	6	6	0	0
2.84		NA	NA	NA	NA	NA	NA	NA	NA
2.69		NA	NA	NA	NA	NA	NA	NA	NA

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
18F	42708	Trib 42708 to Patterson Creek			
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
2.880	0.008	20.000		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
0.844	0.304	2.779		0.051	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
23.61	1.492	1.93		0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
6.136	26.886	Owens		6	
<u>Reach Travel Time (days)</u>					
0.048					
Subreach Results					
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.005	23.44	1.92	6.24	
	0.010	23.27	1.91	6.33	
	0.014	23.11	1.91	6.41	
	0.019	22.95	1.90	6.48	
	0.024	22.78	1.89	6.55	
	0.029	22.62	1.89	6.61	
	0.033	22.46	1.88	6.66	
	0.038	22.30	1.88	6.71	
	0.043	22.14	1.87	6.76	
	0.048	21.99	1.86	6.80	
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
2.840	0.008	20.000		7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
1.642	0.271	6.060		0.037	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
17.88	1.449	1.50		0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.094	26.788	Owens		6	
<u>Reach Travel Time (days)</u>					
0.246					
Subreach Results					
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.025	17.26	1.48	7.32	
	0.049	16.65	1.45	7.46	
	0.074	16.07	1.43	7.56	
	0.098	15.51	1.40	7.63	
	0.123	14.96	1.38	7.69	
	0.148	14.44	1.35	7.75	
	0.172	13.93	1.33	7.79	
	0.197	13.44	1.31	7.79	
	0.222	12.97	1.29	7.79	
	0.246	12.52	1.26	7.79	

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18F	42708	Trib 42708 to Patterson Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.690	0.008	20.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
1.926	0.278	6.931	0.037	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
10.80	1.356	1.04	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.860	25.472	Owens	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.446	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.045	10.16	1.00	7.79
	0.089	9.57	0.97	7.79
	0.134	9.01	0.94	7.79
	0.178	8.48	0.91	7.79
	0.223	7.98	0.89	7.79
	0.267	7.51	0.86	7.79
	0.312	7.07	0.83	7.79
	0.357	6.66	0.81	7.79
	0.401	6.27	0.78	7.79
	0.446	5.90	0.76	7.79

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	85.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42708	Trib 42708 to Patterson Creek	2.840	1420.00	0.16	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.027	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
	A	0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
18F	42708	Trib 42708 to Patterson Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.880	MS Vet Ctr	PA0219258a	0.008	CBOD5	25		
				NH3-N	2.04	4.08	
				Dissolved Oxygen			6

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Average Monthly	Weekly Average	Maximum	Instant. Maximum		
Flow (MGD)	0.008	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	0.01	XXX	XXX	0.03	1/day	Grab
CBOD5	XXX	XXX	10.0	15.0	XXX	20.0	2/month	Grab
TSS	XXX	XXX	10.0	15.0	XXX	20.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E Coli	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	2.5 Avg Mo	XXX	5.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	1.9 Avg Mo	XXX	3.8	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection