

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0219444
APS ID 1033702
Authorization ID 1345566

Applicant and Facility Information

Applicant Name	<u>Markleysburg Borough Fayette County</u>	Facility Name	<u>Markleysburg Area STP</u>
Applicant Address	<u>PO Box 25</u> <u>Markleysburg, PA 15459-0025</u>	Facility Address	<u>Bruceston Road</u> <u>Markleysburg, PA 15459</u>
Applicant Contact	<u>Brian Frazee</u>	Facility Contact	<u>Edgar Harris</u>
Applicant Phone	<u>724-329-1459</u>	Facility Phone	<u>724-966-2278</u>
Client ID	<u>110672</u>	Site ID	<u>608732</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Henry Clay Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Fayette</u>
Date Application Received	<u>March 8, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 11, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for renewal of NPDES Permit.</u>		

Summary of Review

The permittee has applied for a renewal of NPDES Permit No. PA0219444. NPDES Permit No. PA0219444 was previously issued by the PA Department of Environmental Protection (DEP) on August 11, 2016. That permit expires on August 31, 2021.



Sewage from this facility is treated with flow equalization, extended aeration, final clarification, chlorination and de-chlorination before discharging to Pinkham Run through outfall 001.

The applicant is currently enrolled in and will continue to use eDMR.

Sewage Sludge is disposed of in Clairton STP

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Stephanie Conrad / Environmental Engineering Specialist	April 27, 2021
X		 Christopher Kriley, P.E. / Program Manager	April 29, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.075</u>
Latitude	<u>39° 45' 3"</u>	Longitude	<u>-79° 26' 41"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Pinkham Run</u>	Stream Code	<u>39381</u>
NHD Com ID	<u>69923289</u>	RMI	<u>0.3</u>
Drainage Area	<u>3.75</u>	Yield (cfs/mi ²)	<u>0.008</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.03</u>	Q ₇₋₁₀ Basis	<u>Previous Pollution Report</u>
Elevation (ft)	_____	Slope (ft/ft)	_____
Watershed No.	<u>19-E</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	_____	Name	_____
Background/Ambient Data		Data Source	
pH (SU)	_____		_____
Temperature (°F)	_____		_____
Hardness (mg/L)	_____		_____
Other:	_____		_____
Nearest Downstream Public Water Supply Intake _____			
PWS Waters	_____	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	_____

Changes Since Last Permit Issuance:

Other Comments:

Compliance History	
Summary of DMRs:	Between March 2016 and March 2021, the facility has complied with submittal of Discharge Maintenance Reports. During the review period, three effluent limit violations (Type 92A.44) were issued for five exceedances. The majority of the exceedances were for Ammonia-Nitrogen, with the exception being an exceedance for fecal coliform in 2016. All three violations have been administratively closed as of March 24, 2021.
Summary of Inspections:	Between March 2016 and March 2021, the facility received three compliance evaluations. Each evaluation resulted in one of the three violations discussed above.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from March 1, 2020 to February 28, 2021)

Parameter	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20
Flow (MGD) Average Monthly	0.04307	0.03961	0.04752	0.03717	0.02940	0.02677	0.02702	0.02974	0.02797	0.04167	0.052	0.05361
pH (S.U.) Minimum	6.8	6.8	7.0	7.1	7.0	7.0	6.7	7.0	6.7	6.7	6.8	6.9
pH (S.U.) Maximum	7.5	7.3	7.2	7.4	7.3	7.2	7.2	7.1	7.2	7.2	7.2	7.2
DO (mg/L) Minimum	7.9	8.2	7.9	8.3	7.9	7.3	7.2	7.7	7.0	7.0	7.4	7.2
TRC (mg/L) Average Monthly	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
TRC (mg/L) Instantaneous Maximum	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
CBOD5 (lbs/day) Average Monthly	0.5	1.0	0.7	0.6	0.4	0.6	0.4	0.5	0.8	0.9	0.7	0.8
CBOD5 (mg/L) Average Monthly	2.0	2.1	2.0	2.2	2.0	2.0	2.0	2.0	2.9	2.3	2.0	2.0
CBOD5 (mg/L) Instantaneous Maximum	2.0	2.1	2.0	2.3	2.0	2.0	2.0	2.0	3.8	2.6	2.0	2.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	28.4	24.8	31.7	46.9	42.1	53.4	29.9	55.6	33.2	35.4	31.7	33.2
BOD5 (mg/L) Raw Sewage Influent Average Monthly	103.6	84.5	88.5	126.9	222.7	174.2	149.7	264.6	149.3	100.7	93.6	61.1
BOD5 (mg/L) Raw Sewage Influent Instantaneous Maximum	121.5	100.6	106.1	132.1	290.0	185.0	165.8	302.5	160.3	156.4	104.2	70.4
TSS (lbs/day) Average Monthly	0.7	1.5	1.8	1.8	0.9	1.5	1.0	1.1	1.1	2.1	1.7	3.3

**NPDES Permit Fact Sheet
Markleysburg Area STP**

NPDES Permit No. PA0219444

TSS (lbs/day) Raw Sewage Influent Average Monthly	33.6	32.3	34.0	32.6	22.1	38.3	28.4	90.9	31.1	30.1	14.5	30.9
TSS (mg/L) Average Monthly	6.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	6.0
TSS (mg/L) Raw Sewage Influent Average Monthly	127.0	114.0	92.0	84.0	118.0	130.0	150.0	451.0	138.0	87.0	43.0	58.0
TSS (mg/L) Instantaneous Maximum	6.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	7.0
TSS (mg/L) Raw Sewage Influent Instantaneous Maximum	176.0	164.0	96.0	104.0	124.0	184.0	176.0	750.0	168.0	140.0	48.0	82.0
Fecal Coliform (CFU/100 ml) Geometric Mean	1	1	1	2	1	2	1	1	1	1	3	1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1	1	1	2	1	6	1	1	1	1	10	1
Total Nitrogen (mg/L) Daily Maximum			17.6									
Ammonia (lbs/day) Average Monthly	0.03	0.06	0.07	0.05	0.06	0.11	0.11	0.06	0.04	0.23	0.07	0.08
Ammonia (mg/L) Average Monthly	0.1	0.2	0.2	0.2	0.4	0.4	0.6	0.3	0.2	0.7	0.2	0.2
Ammonia (mg/L) Instantaneous Maximum	0.1	0.2	0.3	0.2	0.6	0.4	0.6	0.5	0.3	1.2	0.3	0.2
Total Phosphorus (mg/L) Daily Maximum			4.4									

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.075</u>
Latitude <u>39° 45' 4.00"</u>	Longitude <u>-79° 26' 41.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

TRC was re-modeled with the TRC Spreadsheet, and it was determined that a stricter limit should be imposed. A review of eDMR data determined that the facility should be able to comply with the new limit without issue.

The discharge was previously modeled using (WQM 6.3) to evaluate the CBOD₅, Ammonia Nitrogen and Dissolved Oxygen parameters. Because there have been no changes to the discharge or receiving stream, those limits will be reimposed. The modeling results show technology based effluent limitations for CBOD₅ are appropriate. The modeling results also confirm that Ammonia-Nitrogen limitations are necessary to meet in-stream water quality criterion.

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH ₃ N	2.5	Average Monthly	WQM6.3
TRC	0.04	Average Monthly	TRC Spreadsheet

Comments:

Best Professional Judgment (BPJ) Limitations

A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 **(I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.**

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations

The stream is not impaired for nutrients, therefore, annual sampling for phosphorus and nitrogen will again be imposed per 25 PA Code §92a.6.

Sewage discharges will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows ≥ 0.05 and < 1 MGD.

Mass Loading

Mass loading limits are applicable for publicly owned treatment works. Current policy requires average monthly mass loading units be established for CBOD5, TSS and NH3-N. Average monthly mass loading limits (lbs./day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion Factor (8.34)

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	3/week	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	3/week	Grab
TRC	XXX	XXX	XXX	0.04	XXX	0.15	3/week	Grab
CBOD5	15.6	XXX	XXX	25	XXX	50	2/month	Grab
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report	2/month	Grab
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	Report	2/month	Grab
TSS	18.8	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	4.7	XXX	XXX	7.5	XXX	15.0	2/month	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Ammonia May 1 - Oct 31	1.6	XXX	XXX	2.5	XXX	5.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: at Outfall 001

Other Comments:

Copy of TRC_CALC

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.03	= Q stream (cfs)		0.5	= CV Daily
0.075	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.III	WLA_afc = 0.101		1.3.2.III
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.038		5.1d
		WLA_cfc = 0.091		
		LTAMULT_cfc = 0.581		
		LTA_cfc = 0.053		
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.047		AFC
		INST MAX LIMIT (mg/l) = 0.152		
WLA_afc	$(.019/e^{-k \cdot AFC_to}) + [(AFC_Yo \cdot Qs \cdot 0.019 / Qd \cdot e^{-k \cdot AFC_to}) \dots + Xd + (AFC_Yo \cdot Qs \cdot Xa / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	$wla_afc \cdot LTAMULT_afc$			
WLA_cfc	$(.011/e^{-k \cdot CFC_to}) + [(CFC_Yo \cdot Qs \cdot 0.011 / Qd \cdot e^{-k \cdot CFC_to}) \dots + Xd + (CFC_Yo \cdot Qs \cdot Xa / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	$wla_cfc \cdot LTAMULT_cfc$			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$			
INST MAX LIMIT	$1.5 \cdot ((av_mon_lim / AML_MULT) / LTAMULT_afc)$			

POLLUTION REPORT

December 15, 2008

(I) Project Description New Discharge Change
Existing Discharge (X) Preliminary

A. NPDES Application/Permit No. PA 0219444
 Part II Permit Nos. 2603401

B. Applicant, Case Name or Permittee: Borough of Markleysburg
 Municipality: Henry Clay Township
 County: Fayette

C. Type Waste D. Source and characteristics

Sewage
 Industrial
 Mine

Domestic wastewater

E. USGS Quad : Ohlopyle and Friendsville

F. Latitude (or in. N) 39 45 03
 Longitude (or in. W) 79 26 40

(II) Water Uses and Criteria

A. Receiving waters Pinkham Run Stream Code 39382
 Chapter 93 classification WWF R.M.I. 0.3
 D.A. 3.75 sq. mi. Yield 0.008 cfs/sq.mi.
 Flow 0.0300 cfs. Based on data from _____
 Previous pollution report _____
 Elevation _____ ft.

Exceptions to standard water use lists : Water Quality Criteria-Exceptions to Specific Criteria :
 Add _____ Add _____
 Delete _____ Delete _____


Impoundment _____
 Special Downstream Uses : _____

B. Secondary Waters Hall Run R.M.I. 4.57
 Distance from discharge 4.87 mi. Ch. 93 classification wwf
 D.A. _____ sq. mi. Yield _____ cfs/sq.mi.
 Flow _____ cfs. Based on data from _____
 DEP Stream Directory _____
 Elevation _____ ft. Stream Code 39369

Exceptions to standard water use lists : Water Quality Criteria-Exceptions to Specific Criteria :
 Add _____ Add _____
 Delete _____ Delete _____

Impoundment _____
 Special Downstream Uses : _____
 Downstream PWS : location Ohlopyle Municipal Waterworks
 distance from discharge 20 mi. intake 0.13 mgd.
 stream flow at intake _____ cfs.

39381
 39382
 Wrong Stream Code



Summer Period

FILE: c:\63model\sum3.wqm

Default Data

- a. Stream Values
- 1 Q1-10/Q7-10 ratio.....: .64
 - 2 Q30-10/Q7-10 ratio.....: 2.23 - Updated.
 - 3 Temperature.....: 25
 - 4 pH.....: 7
 - 5 C-BOD5.....: 2
 - 6 NH3-N.....: .1
 - 7 D.O. Saturation (%).....: .85
 - 8 D.O. Goal.....: 5
 - 9 Width/Depth ratio.....: 10
 - 10 KC... (Headwaters only!).....: 0
 - 11 RN.....: .6
- b. Discharge Values (30-day avgs.)
- 12 C-BOD5.....: 25
 - 13 NH3-N.....: 25
 - 14 Effluent D.O.....: 2
 - 15 Effluent Temp.....: 20
 - 16 KC.....: 1.5
 - 17 Balanced Technology(1=y 0=no).....: 0

FILE: c:\63model\sum3.wqm

REACH # 1

Headwaters and Tributary data

No. of Reaches : 1

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
HW	0.0028	25	7	7.12	2	.1
1	0.0000					

Q7-10 updated From Low-Flow Statistics For George's
Creek at SMITHFIELD.

FILE: c:\63model\sum4.wqm

REACH # 1
 Headwaters and Tributary data

No. of Reaches : 1

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
HW	0.0300	25	7	7.12	2	.1
1	0.0000					

FILE: c:\63model\sum4.wqm

DISCHARGE # 1
 Discharger Data
 Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/days)
1	0.0750	20	7	5	25	25	1.5

FILE: c:\63model\sum4.wqm

REACH # 1						
Reach Characteristics						
Rh	D.O. GOAL	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
----	----	----	-----	-----	-----	-----
1	5	.6	0.02500	4000	3.75	10

(WQAM63.EXE) Release 1.2 06-19-2003 15:05:23

FILE: c:\63model\sum4.wqm

REACH # 1
 Reach Characteristics

Rh	KR (/D)	TT (Days)
1	0	0

FILE: c:\63model\sum4.wqm

NH3-N Discharge Allocations at Q30-10 (EMPR)

DIS	Q (mgd)	BASE. CONC. (mg/l)	MULT. CONC. (mg/l)	CRIT. RCH. (%)	PCT. RED. (%)	NH3-N CRIT. (mg/l)
1	0.0750	2.59	2.59	0	0	1.68

FILE: c:\63model\sum4.wqm

NH3-N Discharge Allocations at Q1-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT.
	(mgd)	(mg/l)	(mg/l)		(%)	(mg/l)
1	0.0750	10.69	10.69	0	0	9.19

(WQAM63.EXE) Release 1.2 06-19-2003 15:05:57

FILE: c:\63model\sum4.wqm

D.O. Allocations (EMPR)

DIS #	Q (MGD)	---NH3-N---		---CBODS---		CRIT. RCH.	PCT. REM.
		IND. Conc.	CUM. Conc.	IND. Conc.	CUM. Conc.		
		(mg/l)	(mg/l)	(mg/l)	(mg/l)		(%)
1	0.0750	2.6	2.6	25	25	0	0

(WQAM63.EXE) Release 1.2 06-19-2003 15:06:05

FILE: c:\63model\sum4.wqm

(Total) Discharge = .075 MGD
 Temp = 21 pH = 7 Width = 4.89
 CBOD-5 = 20.27 NH3-N = 2.09 Depth = 0.49
 D.O. = 5.44 D.O. Goal = 5 Velocity = 0.061
 KC' = 1.443 KN = .6 W/D RATIO = 10
 KR = 12.543 (OWENS)
 Dis. 1 Rch. 1 Trvl Time: .757

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.076	18.08	1.99	5.21
0.151	16.12	1.89	5.37
0.227	14.38	1.80	5.65
0.303	12.82	1.71	5.95
0.379	11.43	1.63	6.24
0.454	10.20	1.55	6.51
0.530	9.09	1.48	6.75
0.606	8.11	1.41	6.97
0.682	7.23	1.34	7.12
0.757	6.45	1.28	7.12

(WQAM63.EXE) Release 1.2 06-19-2003 15:06:15

FILE: c:\63model\sum4.wqm

Effluent Limitations Display

DIS #	Q	NH3-N TOX.	DISS. OXYGEN
	MGD	1 DAY 30 DAY	C-BOD5 NH3-N EFF. 30-DAY 30-DAY D.O.
1	.075	5.2 2.6	25 2.6 5

Impose NH3 Limit of 2.5 mg/L

(WQAM63.EXE) Release 1.2 06-19-2003 15:06:20

FILE: c:\63model\sum4.wqm

D.O. Allocations (EMPR)

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT. RCH.	PCT. REM.
		IND. Conc. (mg/l)	CUM. Conc. (mg/l)	IND. Conc. (mg/l)	CUM. Conc. (mg/l)		
1	0.0750	2.6	2.6	25	25	0	0

(WQAM63.EXE) Release 1.2 06-19-2003 15:07:24

FILE: c:\63model\wint3.wqm

WINTER PERIOD

Default Data

a. Stream Values

1	Q1-10/Q7-10 ratio.....	.64	
2	Q30-10/Q7-10 ratio.....	2.23	- Updated
3	Temperature.....	25	
4	pH.....	7	
5	C-BOD5.....	2	
6	NH3-N.....	.1	
7	D.O. Saturation (%).....	.85	
8	D.O. Goal.....	5	
9	Width/Depth ratio.....	10	
10	KC... (Headwaters only!).....	0	
11	KN.....	.6	

b. Discharge Values (30-day avgs.)

12	C-BOD5.....	25
13	NH3-N.....	25
14	Effluent D.O.....	2
15	Effluent Temp.....	20
16	KC.....	1.5
17	Balanced Technology(1=y 0=no).....	0

(WQAM63.EXE) Release 1.2 06-16-2003 14:56:24

Q7-10 updated From Low-Flow Statistics For George's
Creek at Smithfield.

FILE: c:\63model\wint3.wqm

REACH # 1
 Headwaters and Tributary data

No. of Reaches : 1

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
HW	0.0600	5	7	10.82	2	.1
1	0.0000					

FILE: c:\63model\wint3.wqm

Stream Characteristics

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
1	.06	5	7	10.82	2	.1

Q 1-10/Q 7-10 = .64
 Q 30-10/Q 7-10 = 2.23

FILE: c:\63model\wint3.wgm

DISCHARGE # 1
Discharger Data
Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/days)
1	0.0750	15	7	5	25	25	1.5

(WQAM63.EXE) Release 1.2 06-19-2003 15:09:07

FILE: c:\63model\wint3.wqm

REACH # 1
Reach Characteristics

Rh	D.O. GOAL (/D)	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
1	5	.6	0.02500	4000	3.75	10

FILE: c:\63model\wint3.wqm

REACH # 1
Reach Characteristics

Rh	KR (/D)	TT (Days)
1	0	0

FILE: c:\63model\wint4.wqm

NH3-N Discharge Allocations at Q30-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT.
	(mgd)	(mg/l)	(mg/l)		(%)	(mg/l)
1	0.0750	8.67	8.67	0	0	4.08

FILE: c:\63model\wint4.wqm

NH3-N Discharge Allocations at Q1-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT.
	(mgd)	(mg/l)	(mg/l)		(%)	(mg/l)
1	0.0750	22.51	22.51	0	0	16.94

(WQAM63.EXE) Release 1.2 06-19-2003 15:10:12

FILE: c:\63model\wint4.wqm

D.O. Allocations (EMPR)

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT.	PCT.
		IND. Conc. (mg/l)	CUM. Conc. (mg/l)	IND. Conc. (mg/l)	CUM. Conc. (mg/l)	RCH.	REM.
1	0.0750	8.7	8.7	25	25	0	0

(WQAM63.EXE) Release 1.2 06-19-2003 15:10:24

FILE: c:\63model\wint4.wqm

{Total}Discharge = .075 MGD
 Temp = 11.6 pH = 7 Width = 5.09
 CBOD-5 = 17.16 NH3-N = 5.77 Depth = 0.51
 D.O. = 6.98 D.O. Goal = 5 Velocity = 0.068
 KC' = 1.416 KN = .6 W/D RATIO = 10
 KR = 12.468 (OWENS)
 Dis. 1 Rch. 1 Trvl Time: .682

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.068	16.07	5.65	7.74
0.136	15.05	5.53	8.14
0.205	14.09	5.41	8.38
0.273	13.20	5.29	8.55
0.341	12.36	5.18	8.69
0.409	11.57	5.07	8.81
0.478	10.84	4.97	8.92
0.546	10.15	4.86	9.02
0.614	9.51	4.76	9.11
0.682	8.90	4.66	9.20

(WQAM63.EXE) Release 1.2 06-19-2003 15:10:34

FILE: c:\63model\wint4.wqm

DISCHARGE CHARACTERISTICS

END OF REACH 1

(TOTAL) FLOW-MGD.....: .075
 TEMPERATURE.....: 15
 pH.....: 7
 DISSOLVED OXYGEN (mg/l).....: 8.399999
 C-BOD5 (mg/l).....: 12.5
 NH3-N (mg/l).....: 7
 KC (1/Day).....: 1.5

(WQAM63.EXE) Release 1.2 06-19-2003 15:10:40

FILE: c:\63model\wint4.wqm

Effluent Limitations Display

DIS #	Q MGD	NH3-N DAY	TOX. DAY	DISS. OXYGEN 30-DAY	C-BOD5 30-DAY	NH3-N EFF. D.O.
1	.075	17.3	8.7	25	8.7	5

Impose NH₃ Limit of 7.5 mg/L which 3times the summer limit of 2.5mg/L and less than model limit of 8.7 mg/L. Impose 7.5mg/L

(WQAM63.EXE) Release 1.2 06-19-2003 15:10:44

FILE: c:\63model\wint4.wqm

D.O. Allocations (EMPR)

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT.	PCT.
		IND. Conc. (mg/l)	CUM. Conc. (mg/l)	IND. Conc. (mg/l)	CUM. Conc. (mg/l)	RCH.	REM. (%)
1	0.0750	8.7	8.7	25	25	0	0

(WQAM63.EXE) Release 1.2 06-19-2003 15:10:48

Fecal Coliform Evaluation

Warm Period:

Title 25, Chapter 95, Section 92.2c(b)(2) defines effective disinfection. Effective disinfection to control disease-producing organisms shall be the production of an effluent which will contain a concentration of not greater than 200/100 milliliters of fecal coliform organisms as a geometric average.

Cold Period

Q_s (cfs) = 0.030
 Q_w (mgd) = 0.075 therefore, Q_w (cfs) = 0.116
 C_s (#/100 ml) : 200 If no data, assume 10 % of criteria
 C_{sw} (#/100 ml) : 2000
 Q_{sw} (cfs) = 0.146
 solve for C_w
 $C_w = (C_{sw} * Q_{sw}) - (Q_s * C_s) / Q_w$
 C_w (#/100 ml) = 2,465

Impose limit of 2,000/100ml