

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0219461  
APS ID 1060381  
Authorization ID 1391049

**Applicant and Facility Information**

Applicant Name	<u>Center-West Joint Sewer Authority</u>	Facility Name	<u>Center-West STP</u>
Applicant Address	<u>102 East End Road</u> <u>Brownsville, PA 15417-8636</u>	Facility Address	<u>101 Low Hill Road</u> <u>Brownsville, PA 15417</u>
Applicant Contact	<u>Mr. Edward Sukal</u>	Facility Contact	<u>Ms. Liz Hosa</u>
Applicant Phone	<u>724.785.5400</u>	Facility Phone	<u>724.785.5400</u>
Client ID	<u>205813</u>	Site ID	<u>550980</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Centerville Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Washington</u>
Date Application Received	<u>March 22, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>Application for the Renewal of a NPDES permit for the discharge of treated Sewage.</u>		

**Summary of Review**

The Authority has applied for a renewal of NPDES Permit No. PA0026212, which was previously issued by the Department on July 18, 2017. That permit expired on July 31, 2022.

WQM Permit No. 6304406 A-1 was issued on February 5, 2010 authorizing the construction of an STP to treat an average design flow of 0.42 MGD with a design organic loading of 711 lbs/day.

The STP consists of mechanical screening, 3 SBRs, an aerobic digester and UV disinfection.

Application data indicates that there are no industrial or commercial users in the system and the facility does receive hauled-in wastes.


The receiving stream, Monongahela River, is currently classified as a WWF, located in State Watershed No. 19-C.

The Authority has complied with Act 14 Notifications and no comments were received.

Sludge use and disposal description and location(s): Sludge is aerobically digested, dewatered using a belt filter press, and hauled to Westmoreland Sanitary Landfill.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-

Approve	Deny	Signatures	Date
X		 William C. Mitchell, E.I.T. / Project Manager	June 7, 2024
X		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	June 13, 2024

#### Summary of Review

day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	0.42
Latitude	40° 01' 23.00"	Longitude	-79° 54' 46.00"
Quad Name	California	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Monongahela River (WWF)	Stream Code	37185
NHD Com ID	99411736	RMI	57.3
Drainage Area	4,980	Yield (cfs/mi <sup>2</sup> )	0.106
Q <sub>7-10</sub> Flow (cfs)	530	Q <sub>7-10</sub> Basis	US Army Corp of Engineers
Elevation (ft)	744.0	Slope (ft/ft)	0.0001
Watershed No.	19-C	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use	NONE	Exceptions to Criteria	NONE
Assessment Status	Impaired		
Cause(s) of Impairment	POLYCHLORINATED BIPHENYLS (PCBS)		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status	Final	Name	Monongahela River TMDL
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	PA American Water Company - Brownsville		
PWS Waters	Monongahela River	Flow at Intake (cfs)	530
PWS RMI	57.0	Distance from Outfall (mi)	0.3

Changes Since Last Permit Issuance: None

Other Comments: The discharge is to the Monongahela River which has an EPA Approved TMDL and is impaired by PCBs and Chlordane. No WLAs have been developed for this sewage discharge, as neither PCB nor Chlordane is typically found in sewage, but instead found in legacy sediments.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Center W Joint Sewer Authority STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
6304406	05/26/2006			
6304406 A-1	02/05/2010			
6304406 A-2	02/15/2011			
6304406 A-3	03/14/2017			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Sequencing Batch Reactor	Ultraviolet	0.42
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.42	771	Not Overloaded	Belt Filtration	Landfill

Changes Since Last Permit Issuance: None

Other Comments: N/A

**Compliance History**

**Operations Compliance Check Summary Report**

**Facility:** Center West JSA WWTP

**NPDES Permit No.:** PA0219461

**Compliance Review Period:** 6/1/19-6/3/24

**Inspection Summary:**

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
09/27/2022	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted

**Violation Summary:**

No violations noted during review period

**Open Violations by Client ID:**

No open violations for Client ID 205813

**Enforcement Summary:**

No enforcements executed during review period

**Effluent Violation Summary:**

MON PD	PARAMETER	SAMPLE	PERMIT	UNIT	STAT BASE CODE
Feb-24	Fecal Coliform	> 2420	10000	No./100 ml	Instantaneous Maximum
Feb-24	Fecal Coliform	> 7	2000	No./100 ml	Geometric Mean
Jan-24	Fecal Coliform	> 2420	10000	No./100 ml	Instantaneous Maximum
Jan-24	Fecal Coliform	> 9	2000	No./100 ml	Geometric Mean
Aug-22	Fecal Coliform	> 2420	1000	No./100 ml	Instantaneous Maximum
Aug-22	Fecal Coliform	> 7	200	No./100 ml	Geometric Mean

**Compliance Status:** Facility is generally in compliance with no open violations or pending enforcements. Above listed exceedances of Fecal Coliforms occurred since the last Compliance Evaluation Inspection, which should be addressed with an NOV upon the next routine inspection. Assigned inspector has been notified.

**Completed by:** Amanda Illar **Completed date:** 6/3/24

Compliance History

DMR Data for Outfall 001 (from May 1, 2023 to April 30, 2024)

Parameter	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23
Flow (MGD) Average Monthly	0.272	0.147	0.122	0.174	0.106	0.105	0.100	0.093	0.109	0.110	0.113	0.101
Flow (MGD) Daily Maximum	1.876	0.716	0.401	0.316	0.214	0.287	0.222	0.144	0.275	0.268	0.398	0.185
pH (S.U.) Minimum	7.0	6.9	7.0	7.0	6.9	7.0	6.9	6.7	7.0	6.9	6.9	6.8
pH (S.U.) Maximum	7.1	7.0	7.2	7.1	7.1	7.2	7.0	7.0	7.0	7.0	7.0	7.1
DO (mg/L) Minimum	6.4	6.3	6.2	6.3	6.1	5.5	6.5	6.5	6.2	6.4	6.6	6.4
CBOD5 (lbs/day) Average Monthly	< 2.9	< 2.6	< 2.4	< 2.3	< 12.4	< 1.3	< 1.4	< 1.3	< 1.7	< 1.7	< 2.2	< 3.4
CBOD5 (lbs/day) Weekly Average	4.5	< 3.3	3.5	< 2.9	42.8	< 1.9	< 1.5	< 2.0	2.3	< 2.2	4.3	9.3
CBOD5 (mg/L) Average Monthly	< 2.6	< 2.0	< 2.4	< 2.0	< 11.4	2.0	< 2.0	< 2.0	< 2.1	< 2.0	< 2.1	< 3.5
CBOD5 (mg/L) Weekly Average	4.5	< 2.0	3.7	< 2.0	39.5	< 2.0	< 2.0	< 2.0	2.6	< 2.0	2.3	6.9
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	159.5	175.5	189.7	209.9	261.9	< 91.0	< 110.4	67.6	81.2	< 107.7	120.0	117.4
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	299.4	286.9	256.2	2770	313.6	168.7	202.0	127.2	106.9	200.6	133.4	203.1
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	125.8	137.8	201.2	199.9	233.3	< 148.5	< 154.3	110.4	106.2	< 125.9	138.6	139.2
TSS (lbs/day) Average Monthly	< 6.2	< 6.6	< 5.1	< 5.7	< 9.9	< 3.3	< 3.6	< 3.3	< 3.9	< 4.2	< 5.2	< 4.4
TSS (lbs/day) Raw Sewage Influent   Average Monthly	168.5	86.2	112.3	137.8	167.3	84.7	93.6	129.7	86.1	114.3	82.5	107.1
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	512.7	148.3	264.9	249.6	290.6	243.1	216.9	255.2	162.1	242.9	142.0	156.0

NPDES Permit Fact Sheet  
Center W Joint Sewer Authority STP

NPDES Permit No. PA0219461

TSS (lbs/day) Weekly Average	< 11.3	< 8.3	< 8.7	< 7.3	20.6	< 4.7	< 3.8	< 5.0	< 4.4	< 5.4	< 9.3	< 6.8
TSS (mg/L) Average Monthly	< 5.0	< 5.0	< 5.0	< 5.0	< 9.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.3	< 5.2
TSS (mg/L) Raw Sewage Influent   Average Monthly	102	71	99	130	151	122	132	188	111	131	83	132
TSS (mg/L) Weekly Average	< 5.0	< 5.0	< 5.0	< 5.0	19.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	6.0	6.0
Fecal Coliform (No./100 ml) Geometric Mean	< 7	< 20	> 7	> 9	< 3	< 1	< 3	< 4	< 6	< 2	< 5	< 18
Fecal Coliform (No./100 ml) Instantaneous Maximum	2420	2420	> 2420	> 2420	54	1	10	16	86	33	184	45
UV Transmittance (%) Minimum	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2	2.0	2.0	2.0	2.0
Total Nitrogen (mg/L) Daily Maximum					4.82							
Ammonia (lbs/day) Average Monthly	< 1.4	< 0.5	< 0.75	7.76	< 11.3	< 0.3	< 0.3	< 0.26	< 0.3	< 0.34	< 0.41	< 0.34
Ammonia (mg/L) Average Monthly	1.9	< 0.4	1.2	6.58	< 9.8	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4	< 0.4
Total Phosphorus (mg/L) Daily Maximum					3.7							

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	0.42	
Latitude	40° 01' 23.00"	Longitude	-79° 54' 46.00"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The discharge was evaluated using WQM 7.0 Version 1.1 (Attachment 2) to evaluate CBOD<sub>5</sub>, Ammonia Nitrogen, and Dissolved Oxygen. The modeling results show the above technology based effluent limitations are appropriate.

For existing discharges, if WQM modeling results for summer indicates that an average monthly limit of 25 mg/L (ammonia-nitrogen) is acceptable, the application manager will generally establish a year-round monitoring requirement for ammonia-nitrogen (Section I.A, Note 5, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits).

### Water Quality-Based Limitations

Comments: Based upon module output files, WQM 7.0 & TMS, NO WQBELs will be established at this time for this facility (Attachments 2 & 3).

### Best Professional Judgment (BPJ) Limitations

Comments: A minimum Dissolved Oxygen (DO) limit of 4.0 mg/L will be established based on BPJ to ensure adequate operation and maintenance (Section I.A, Note 6, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits).

### Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the

time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits

### **Additional Considerations**

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document No. 386-0400-001).

Ultraviolet (UV) disinfection is used, TRC limits are not applicable, but the limits table(s) in Part A will generally contain, at a minimum, routine monitoring of UV transmittance (%), UV dosage ( $\mu$ Ws/cm<sup>2</sup> or mWs/cm<sup>2</sup> or mjoules/cm<sup>2</sup>) or UV intensity ( $\mu$ W/cm<sup>2</sup> or mW/cm<sup>2</sup>) at the same monitoring frequency that would be used for TRC per Section I.A, Note 4, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits.

For POTWs, mass loading limits will be established for CBOD<sub>5</sub>, TSS, NH<sub>3</sub>-N, and where necessary Total P and Total N. In general, average monthly mass loading limits will be established for CBOD<sub>5</sub>, TSS, NH<sub>3</sub>-N, and where necessary Total P and Total N, and average weekly mass loading limits will be established for CBOD<sub>5</sub> and TSS. Mass loading limits for toxic pollutants with effluent concentration limits are also being established at this time per the application managers discretion (Section IV, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits).

For POTWs with design flows greater than 2,000 GPD and for non-municipal sewage facilities that service municipalities or portions thereof, the application manager will establish influent BOD<sub>5</sub> and TSS monitoring in the permit using the same frequency and sample type as is used for other effluent parameters (Section IV.E.8, SOP No BCW-PWT-002, New and Reissuance Sewage Individual NPDES Permit Applications).

Sewage discharges will include monitoring, at a minimum, for *E. Coli*, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows  $\geq 0.05$  and  $< 1$  MGD per 25 Pa. Code § 92a.061 and Section I.A, Note 12, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits.

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). The discharge is to waters not impaired for nutrients. A 1/quarter monitoring requirement for Total N & Total P has been added to the permit per Chapter 92a.61 and Section I.A, Note 7 & 8, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits.

**Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
CBOD5	85.0	140.0	XXX	25.0	40.0	50	1/week	8-Hr Composite
BOD5								8-Hr
Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	Composite
TSS	105.0	155.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS								8-Hr
Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	1/week	Composite
Fecal Coliform (No./100 ml)				2000				
Oct 1 - Apr 30	XXX	XXX	XXX	Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml)				200				
May 1 - Sep 30	XXX	XXX	XXX	Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite
Ammonia	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: N/A

## Attachment 1 – USGS StreamStats Report

### StreamStats Report

**Region ID:** PA

**Workspace ID:** PA20240528181920223000

**Clicked Point (Latitude, Longitude):** 40.02199, -79.91198

**Time:** 2024-05-28 14:19:46 -0400



 [Collapse All](#)

#### » Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	4980	square miles
ELEV	Mean Basin Elevation	1875	feet

## ➤ Low-Flow Statistics

### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	4980	square miles	2.26	1400
ELEV	Mean Basin Elevation	1875	feet	1050	2580

### Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

### Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	664	ft^3/s
30 Day 2 Year Low Flow	884	ft^3/s
7 Day 10 Year Low Flow	383	ft^3/s
30 Day 10 Year Low Flow	451	ft^3/s
90 Day 10 Year Low Flow	674	ft^3/s

#### *Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**Attachment 2 – WQM 7.0 Version 1.1 – Summer Period**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A		37185 MONONGAHELA RIVER	57.300	744.00	4980.00	0.00010	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.106	530.00	0.00	0.000	0.000	0.0	707.93	7.50	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data								
Name		Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
CWJSA WWTP		PA0219461	0.4200	0.4200	0.0000	0.000	20.00	7.00
Parameter Data								
Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5			25.00	2.00	0.00	1.50		
Dissolved Oxygen			3.00	8.24	0.00	0.00		
NH3-N			25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A		37185 MONONGAHELA RIVER	57.000	743.99	4981.00	0.00010	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.106	0.00	0.00	0.000	0.000	0.0	632.46	7.50	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
		0.0000	0.0000	0.0000	0.000	0.00	7.00
Parameter Data							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Monday, June 3, 2024 Version 1.1 Page 2 of 2

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
19A			37185			MONONGAHELA RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
57.300	530.00	0.00	530.00	.6497	0.00010	7.5	707.93	94.39	0.10	0.183	24.99	7.00
<b>Q1-10 Flow</b>												
57.300	339.20	0.00	339.20	.6497	0.00010	NA	NA	NA	0.06	0.286	24.99	7.00
<b>Q30-10 Flow</b>												
57.300	720.80	0.00	720.80	.6497	0.00010	NA	NA	NA	0.14	0.135	25.00	7.00

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
19A			37185			MONONGAHELA RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
57.300	530.00	0.00	530.00	.6497	0.00010	7.5	707.93	94.39	0.10	0.183	24.99	7.00
<b>Q1-10 Flow</b>												
57.300	339.20	0.00	339.20	.6497	0.00010	NA	NA	NA	0.06	0.286	24.99	7.00
<b>Q30-10 Flow</b>												
57.300	720.80	0.00	720.80	.6497	0.00010	NA	NA	NA	0.14	0.135	25.00	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19A	37185	MONONGAHELA RIVER		

#### **NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	57.300 CWJSA WWTP	11.08	50	11.08	50	0	0

#### **NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	57.300 CWJSA WWTP	1.37	25	1.37	25	0	0

#### **Dissolved Oxygen Allocations**

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	57.30 CWJSA WWTP	25	25	25	25	3	3	0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19A	37185	MONONGAHELA RIVER		
<u>RMI</u>	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH	
57.300	0.420	24.994	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
707.930	7.500	94.391	0.100	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.03	0.019	0.03	1.028	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.234	0.224	O'Connor	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.183	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.018	2.03	0.03	7.54
	0.037	2.03	0.03	7.54
	0.055	2.03	0.03	7.54
	0.073	2.02	0.03	7.54
	0.092	2.02	0.03	7.54
	0.110	2.02	0.03	7.54
	0.128	2.02	0.03	7.54
	0.147	2.02	0.03	7.54
	0.165	2.02	0.03	7.54
	0.183	2.02	0.03	7.54

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
19A	37185	MONONGAHELA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
57.300	CWJSA WWTP	PA0219461	0.420	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

**Attachment 4 – TMS Version 1.4**



Toxics Management Spreadsheet  
Version 1.4, May 2023

**Discharge Information**

Instructions **Discharge** Stream

Facility: **CWJSA WWTP** NPDES Permit No.: **PA0219461** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Treated Sewage Effluent**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.42	100	7						

	Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
				Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod
Group 1	Total Dissolved Solids (PWS)	mg/L	316								
	Chloride (PWS)	mg/L	142								
	Bromide	mg/L	65								
	Sulfate (PWS)	mg/L	60.6								
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L	5								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	µg/L	< 1								
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
	Total Thallium	µg/L									
	Total Zinc	µg/L	79								
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								







## Stream / Surface Water Information

CWJSA WWTP, NPDES Permit No. PA0219461, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: Monongahela River

No. Reaches to Model: 1

- Statewide Criteria  
 Great Lakes Criteria  
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	037185	57.3	744	4980	0.0001		Yes
End of Reach 1	037185	57	743.9	4981	0.0001	3	Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	57.3	0.106	530			707.93	7.5					100	7		
End of Reach 1	57	0.106				632.46	7.5					100	7		

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	57.3														
End of Reach 1	57														



## Model Results

CWJSA WWTP, NPDES Permit No. PA0219461, Outfall 001

<a href="#">Instructions</a>	<a href="#">Results</a>	<a href="#">RETURN TO INPUTS</a>	<a href="#">SAVE AS PDF</a>	<a href="#">PRINT</a>	<input checked="" type="radio"/> All	<input type="radio"/> Inputs	<input type="radio"/> Results	<input type="radio"/> Limits
------------------------------	-------------------------	----------------------------------	-----------------------------	-----------------------	--------------------------------------	------------------------------	-------------------------------	------------------------------

**Hydrodynamics**

**Q<sub>7-10</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
57.3	530		530	0.65	0.0001	7.5	707.93	94.391	0.1	0.183	3336.201
57	530.106	4.641	525.465								

**Q<sub>h</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
57.3	1786.51		1786.51	0.65	0.0001	12.797	707.93	55.321	0.197	0.093	1499.497
57	1786.824	4.641	1782.18								

**Wasteload Allocations**

**AFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.439	14.0	780	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	4,547	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	6,673	Chem Translator of 0.978 applied

**CFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	3,544	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.517	3.18	1,209	Chem Translator of 0.791 applied
Total Zinc	0	0		0	118.139	120	45,524	Chem Translator of 0.986 applied

THH CCT (min): ##### THH PMF: 0.465 Analysis Hardness (mg/l): N/A Analysis pH: N/A PWS PMF: 0.2814

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	#####	WQC applied at RMI 57 with a design stream flow of 530.106 cfs
Chloride (PWS)	0	0		0	250,000	250,000	57,643,250	WQC applied at RMI 57 with a design stream flow of 530.106 cfs
Sulfate (PWS)	0	0		0	250,000	250,000	57,643,250	WQC applied at RMI 57 with a design stream flow of 530.106 cfs
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL CCT (min): 720 PMF: 0.693 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits					Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units				

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	115,287	mg/L	Discharge Conc ≤ 10% WQBEL
Chloride (PWS)	57,643	mg/L	Discharge Conc ≤ 10% WQBEL
Bromide	N/A	N/A	No WQS

Sulfate (PWS)	57,643	mg/L	Discharge Conc ≤ 10% WQBEL
Total Copper	500	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	N/A	N/A	Discharge Conc < TQL
Total Zinc	4,277	µg/L	Discharge Conc ≤ 10% WQBEL