

Application Type Amendment
Facility Type Municipal
Major / Minor Minor/Major

Application No. **PA0221449 A-1**
APS ID **1061683**
Authorization ID **1487883**

NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE

Applicant and Facility Information

Applicant Name	Buffalo Township Municipal Authority	Facility Name	Buffalo Township Municipal Authority STP
Applicant Address	707 South Pike Road Sarver, PA 16055-9201	Facility Address	161 Monroe Road Sarver, PA 16055
Applicant Contact	Kristine Donaldson	Facility Contact	Kristine Donaldson
Applicant Phone	(724) 383-2259 (mabt@zoominternet.net)	Facility Phone	
Client ID	62915	Site ID	262419
Ch 94 Load Status	Not Overloaded	Municipality	Buffalo Township
Connection Status	No Limitations	County	Butler
Date Application Received	<u>April 19, 2022</u>	EPA Waived?	No
Date Application Accepted	<u>May 2, 2022</u>	If No, Reason	Converting to a Major Sewage Facility
Purpose of Application	Amendment of a NPDES Permit for an existing discharge of treated sewage.		

Summary of Review

This is a publicly operated sewage treatment plant which services parts of Buffalo and Winfield Townships, Butler County. In addition, the facility has, and plans to continue accepting hauled in WTP filter backwash sludge.

This is a permit amendment to provide for a planned plant upgrade that increases the hydraulic capacity of the plant from 0.89 MGD to 1.3 MGD. The outfall location will remain the same as will the type of disinfection.

Upon completion of plant upgrades, the facility will be reclassified as a major sewage facility (>1.0 MGD), subject to additional permit requirements.

There are currently two open violations listed in EFACTS for this client, all from the Safe Drinking Water Program (10/15/2024).

Sludge use and disposal description and location(s): Dewatered sludge is hauled to Seneca Landfill for disposal.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam J. Pesek Adam J. Pesek, E.I.T. / Project Manager	10/28/2024
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	11/15/2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.89 / 1.3
Latitude	40° 42' 19"	Longitude	-79° 41' 38"
Quad Name	Freeport	Quad Code	1708
Wastewater Description:	Treated domestic sewage		
Receiving Waters	Buffalo Creek (TSF)	Stream Code	42557
NHD Com ID	123971892	RMI	3.42
Drainage Area	167.65	Yield (cfs/mi ²)	0.04284
Q ₇₋₁₀ Flow (cfs)	7.182	Q ₇₋₁₀ Basis	USGS #03049000 ('77-'11)
Elevation (ft)	778	Slope (ft/ft)	0.00183
Watershed No.	18-F	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	CAUSE UNKNOWN		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)	8.3	DEP 4/21/09 macroinvertebrate sample taken upstream	
Temperature (°C)	20	Default	
Hardness (mg/L)	108	7/13/17 upstream sample taken by permittee.	
Other:			
Nearest Downstream Public Water Supply Intake		Harrison Twp. Water Authority	
PWS Waters	Allegheny River	Flow at Intake (cfs)	2390
PWS RMI	24.2	Distance from Outfall (mi)	8.0

Changes Since Last Permit Issuance: None

Other Comments:

Treatment Facility Summary				
Treatment Facility Name: Buffalo Township Municipal Authority STP				
WQM Permit No.	Issuance Date			
1096406 A-1	5/16/2012			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Reduction	Activated Sludge	Ultraviolet	0.89
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.89	1782	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None

Other Comments: Treatment consists of influent pump station, aeration (4 tanks), settling (2 tanks), UV disinfection, sludge holding / aerobic digestion and sludge press.

Complete details of the proposed plant upgrades are not known at this time.

The upgrade is "Phase III" of the 2009 Act 537 Plan that was approved December 6, 2011.

Compliance History	
Summary of DMRs:	There have been twelve effluent limit excursions since September 2018. Seven are for D.O., four for fecal coliform, and one for TSS.
Summary of Inspections:	The last facility inspection was conducted on 8/6/2020. No violations or issues were report in the inspection report.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from September 1, 2023 to August 31, 2024)

Parameter	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23
Flow (MGD) Average Monthly	0.627	0.530	0.583	0.792	1.07	0.945	0.698	1.004	0.69	0.595	0.502	0.506
Flow (MGD) Weekly Average	0.734	0.667	0.599	0.885	1.45	1.199	1.106	1.185	0.834	0.762	0.502	0.596
pH (S.U.) Daily Minimum	6.10	6.04	6.26	6.38	6.22	6.18	6.01	6.03	6.03	6.0	6.04	6.0
pH (S.U.) Daily Maximum	6.39	6.50	6.63	6.95	6.98	6.81	6.45	6.59	6.60	7.6	7.07	6.47
DO (mg/L) Daily Minimum	5.0	4.81	5.39	3.57	4.1	4.31	4.97	2.63	4.37	4.58	6.06	5.54
CBOD5 (lbs/day) Average Monthly	< 17	< 15	< 17	< 18	< 33	< 22	< 18	< 26	< 16	< 17	< 10	< 10
CBOD5 (lbs/day) Weekly Average	< 25	< 21	21	< 20	58	< 24	< 29	< 54	32	32	< 10	16
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.4	< 3.0	< 3.9	< 3.0	< 3.0	< 3.0	< 2.4	< 2.6	< 2.1	< 2.5
CBOD5 (mg/L) Weekly Average	< 3.0	< 3.0	4.4	< 3.0	7.2	< 3.0	< 3.0	< 3.0	3.4	3.1	< 2.0	3.5
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	794	747	616	530	681	601	731	871	< 501	958	589	552
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	1149	920	762	615	1225	783	1199	2180	733	1744	765	624
BOD5 (mg/L) Raw Sewage Influent Average Monthly	147.7	154	121.6	91.6	86	83.5	124.3	96.1	< 85.1	141.3	138.1	136
TSS (lbs/day) Average Monthly	< 19	< 16	< 17	< 18	< 34	< 30	< 27	< 26	< 33	< 33	< 34	< 22
TSS (lbs/day) Raw Sewage Influent Average Monthly	1005	906	872	391	728	1197	651	1527	279	505	441	430

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

TSS (lbs/day) Raw Sewage Influent Daily Maximum	1821	1462	1968	533	1115	2126	983	3880	380	985	593	641
TSS (lbs/day) Weekly Average	25	22	20	< 20	71	41	67	< 54	< 46	< 88	< 25	27
TSS (mg/L) Average Monthly	< 3.3	< 3.4	< 3.3	< 3.0	< 3.8	< 4.0	< 4.0	< 3.0	< 5.0	< 5.0	< 6.8	< 5.5
TSS (mg/L) Raw Sewage Influent Average Monthly	188	196	177	68	95	170	117	218	46	73	103	104
TSS (mg/L) Weekly Average	4.0	5.0	4.0	3.0	6.0	5.0	7.0	< 3.0	< 5.0	< 14.0	5.0	6.0
Fecal Coliform (No./100 ml) Geometric Mean	1	< 1	< 1	< 2	15	< 3	< 1	< 2	< 10	< 10	< 6	< 4
Fecal Coliform (No./100 ml) Instantaneous Maximum	2	2	2	6	690	10	1	11	< 10	< 10	1	< 10
E. Coli (No./100 ml) Instantaneous Maximum			1									
UV Intensity (μ w/cm ²) Minimum	1.4	1.3	1.4	2.6	1.5	2.5	2	1.8	1.8	1.8	2	2.3
UV Intensity (μ w/cm ²) Average Monthly	1.6	1.7	2.1	3.0	3.6	2.8	2.3	2.2	2.0	2.1	3	2.9
Total Nitrogen (lbs/day) Annual Average									122			
Total Nitrogen (mg/L) Annual Average									26.48			
Ammonia (lbs/day) Average Monthly	< 0.7	< 0.6	< 0.9	7.4	< 10	< 2	< 1	< 3	< 1	< 1	< 0.9	< 0.8
Ammonia (mg/L) Average Monthly	< 0.12	< 0.11	< 0.18	1.37	< 1.61	< 0.31	< 0.16	< 0.41	< 0.2	< 0.2	< 0.2	< 0.2
Total Phosphorus (lbs/day) Annual Average									6			
Total Phosphorus (mg/L) Annual Average									1.34			
Total Copper (lbs/day) Average Monthly	< 0.10	0.04	0.05	< 0.06								

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

Total Copper (lbs/day) Average Quarterly					0.05			< 0.04				< 0.04
Total Copper (lbs/day) Daily Maximum	0.20	0.04	0.05	< 0.06								
Total Copper (mg/L) Average Quarterly						0.01			< 0.01			< 0.01
Total Copper (ug/L) Average Monthly	< 0.02	0.01	0.01	< 0.01								
Total Copper (ug/L) Daily Maximum	0.02	0.01	0.01	0.01								
Total Zinc (lbs/day) Average Quarterly			0.4									
Total Zinc (mg/L) Average Quarterly			0.07									

Development of Effluent Limitations (Interim Limits)				
Outfall No.	001	Design Flow (MGD)	0.89 (Prior to completion of plant upgrades)	
Latitude	40° 42' 19.00"	Longitude	-79° 41' 38.00"	
Wastewater Description:	Treated domestic sewage			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	92a.61

Comments: The TRC limit is not applicable because UV disinfection is utilized.

Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (5/01 – 10/31)	8.5	Average Monthly	Previous WQM or WQAM modeling
Total Copper	0.0242	Average Monthly	TMS Ver 1.4
Total Copper	0.0377	Daily Maximum	TMS Ver 1.4

Comments: A seasonal multiplier of "3" is typically applied for ammonia nitrogen. Current WQM 7.0 modeling (attached) did not produce effluent limits for ammonia that were as stringent as the previous limits. Previous summertime limit will remain due to anti-backsliding provisions. Wintertime period for ammonia nitrogen will receive monitoring instead of limits since the WQBEL limit of 25 mg/l, which is close the raw sewage concentration, can be easily met based on utilization of secondary treatment and historical DMR data.

Toxics modeling for the expanded flow was refined for determining WQBELs for an expanded 1.3 MGD flowrate, which resulted in the toxics model determining less stringent total copper WQBELs than is currently in the permit for the 0.89 MGD flow. The 0.89 MGD flow was calculated using the Harrison Twp Water Authority public water supply intake on the Allegheny River as an endpoint, which resulted in a calculated less gradual slope used to determine travel time and instream mixing characteristics. It was realized during the technical review that the dispersion the acute fish criterion Criteria Compliance Time (CCT) of 15 minutes that the copper limitation is based on, is achieved in Buffalo Creek before entering/comingling in the Allegheny River. Therefore, the copper limit for the expanded flow was evaluated only using the Buffalo Creek reach from the discharge point to the mouth as endpoint, resulting in a steeper slope and shorter travel

time. Using this new reach to determine limits, less stringent concentration limits were calculated for total copper. While using only the Buffalo Creek reach to calculate total copper limits using the current flow rate would also yield less stringent limits, the current limits will be retained in the amended permit as the permittee is able to easily achieve them.

The Toxics Management also recommended monitoring and reporting requirements for total zinc, which will thus be placed in the permit at a monitoring frequency of 1/quarter.

Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l and monitoring for total nitrogen, total phosphorus, and UV intensity is being placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Anti-Backsliding

N/A

Development of Effluent Limitations (Final Limits)

Outfall No.	001	Design Flow (MGD)	1.3 (After completion of plant upgrades)
Latitude	40° 42' 19.00"	Longitude	-79° 41' 38.00"
Wastewater Description: Treated domestic sewage			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	92a.61

Comments: The TRC limit is not applicable because UV disinfection will continue to be utilized.

Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD ₅	20	Average Monthly	WQM 7.0 Ver 1.1
Ammonia Nitrogen (5/01 – 10/31)	8.5	Average Monthly	WQM 7.0 Ver 1.1
Total Copper	0.0243	Average Monthly	TMS Ver 1.4
Total Copper	0.0379	Daily Maximum	TMS Ver 1.4

Comments: A seasonal multiplier of "3" is typically applied for ammonia nitrogen. Wintertime period for ammonia nitrogen will receive monitoring instead of limits since the WQBEL limit of 25 mg/l, which is close the raw sewage concentration, can be easily met based on utilization of secondary treatment and historical DMR data.

The Toxics Management also recommended monitoring and reporting requirements for total zinc, which will thus be placed in the permit at a monitoring frequency of 1/month.

Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l and monitoring for total nitrogen, total phosphorus, and UV intensity is being placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Additional Considerations

Comment: Annual monitoring will be placed in the final limits table of the amended permit for PFOA, PFOS, HFPO-DA and PFBS per Department directives for major sewage facilities that do not receive waste from one of EPA's selected industrial categories. A footnote was also added to the proposed permit for the discontinuation of sampling requirements for PFAS parameters after four consecutive non-detects are reported for all parameters at or below the Target QLs.

Monitoring frequencies were increased for all parameters except pH, D.O. and UV due to the increase in design flow using Table 6-3 of DEP's Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001) ("Permit Writer's Manual") for reference.

Anti-Backsliding

N/A

Whole Effluent Toxicity (WET)

Evaluation of Test Type, IWC and Dilution Series for Upgraded Plant

Acute Partial Mix Factor (PMFa): **0.316**

Chronic Partial Mix Factor (PMFc): **1.0**

1. Determine IWC – Acute (IWCa):

$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$

$[(1.3 \text{ MGD} \times 1.547) / ((7.182 \text{ cfs} \times 0.316) + (1.3 \text{ MGD} \times 1.547))] \times 100 = \mathbf{47\%}$

Is IWCa < 1%? YES NO

If the discharge is to the tidal portion of the Delaware River, indicate how the type of test was determined:

N/A

Type of Test for Permit Renewal: Chronic

2. Determine Target IWCC (If Chronic Tests Required)

$(Q_d \times 1.547) / (Q_{7-10} \times PMFc) + (Q_d \times 1.547)$

$[(1.3 \text{ MGD} \times 1.547) / ((7.182 \text{ cfs} \times 1) + (1.3 \text{ MGD} \times 1.547))] \times 100 = \mathbf{21\%}$

3. Determine Dilution Series

(NOTE – check Attachment C of WET SOP for dilution series based on TIWCA or TIWCC, whichever applies).

Dilution Series = 100%, 61%, 21%, 11%, and 5%.

WET Limits

Has reasonable potential been determined? YES NO

Will WET limits be established in the permit? YES NO

If WET limits will be established, identify the species and the limit values for the permit (TU).

N/A

If WET limits will not be established, but reasonable potential was determined, indicate the rationale for not establishing WET limits:

N/A

Comments: 4 quarterly tests will be required once the plant upgrades are complete

Proposed Effluent Limitations and Monitoring Requirements (Interim)

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Startup of New or Upgraded Facilities.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	5/week	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	185	295	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	225	335	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (μ w/cm ²)	XXX	XXX	Report Daily Min	Report	XXX	XXX	1/day	Measured
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Startup of New or Upgraded Facilities)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	63.0	XXX	XXX	8.5	XXX	17	1/week	24-Hr Composite
Total Phosphorus	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Copper (ug/l)	0.18	0.28 Daily Max	XXX	24.2	37.7 Daily Max	60.4	2/month	24-Hr Composite
Total Zinc	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements (Final)

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Startup of New or Upgraded Facilities through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	216	325	XXX	20.0	30.0	40	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	325	487	XXX	30.0	45.0	60	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/month	Grab
UV Intensity (μ w/cm ²)	XXX	XXX	Report Daily Min	Report	XXX	XXX	1/day	Measured
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite

Outfall 001, Continued (from Startup of New or Upgraded Facilities through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	92.0	XXX	XXX	8.5	XXX	17	2/week	24-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Total Copper (ug/l)	0.26	0.41 Daily Max	XXX	24.3	37.9 Daily Max	60.7	1/week	24-Hr Composite
Total Zinc	Report	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
PFOA (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
PFOS (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
PFBS (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
HFPO-DA (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments:

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42557	BUFFALO CREEK	3.420	778.00	167.65	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.043	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	8.30	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Buffalo Twp MA	PA0221449	0.8900	0.0000	0.0000	0.000	20.00	6.30
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	8.24	0.00	0.00		
NH3-N		25.00	0.10	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42557	BUFFALO CREEK	0.001	745.00	171.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.043	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	8.30	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
18F			42557			BUFFALO CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
3.420	7.21	0.00	7.21	1.3768	0.00183	.794	51.77	65.17	0.21	1.001	20.00	7.07
Q1-10 Flow												
3.420	4.61	0.00	4.61	1.3768	0.00183	NA	NA	NA	0.17	1.224	20.00	6.92
Q30-10 Flow												
3.420	9.80	0.00	9.80	1.3768	0.00183	NA	NA	NA	0.24	0.863	20.00	7.18

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>									
18F		42557	BUFFALO CREEK									
NH3-N Acute Allocations												
<hr/>												
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction					
3.420 Buffalo Twp MA		17.85	50	17.85	50	0	0					
NH3-N Chronic Allocations												
<hr/>												
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction					
3.420 Buffalo Twp MA		1.74	13.42	1.74	13.42	0	0					
Dissolved Oxygen Allocations												
<hr/>												
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>						
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)					
3.42 Buffalo Twp MA		25	25	13.42	13.42	4	4					
						0	0					

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18F	42557	BUFFALO CREEK		
<u>RMI</u> 3.420	<u>Total Discharge Flow (mgd)</u> 0.890	<u>Analysis Temperature (°C)</u> 20.000	<u>Analysis pH</u> 7.073	
<u>Reach Width (ft)</u> 51.768	<u>Reach Depth (ft)</u> 0.794	<u>Reach WDRatio</u> 65.168	<u>Reach Velocity (fps)</u> 0.209	
<u>Reach CBOD5 (mg/L)</u> 5.69	<u>Reach Kc (1/days)</u> 0.793	<u>Reach NH3-N (mg/L)</u> 2.24	<u>Reach Kn (1/days)</u> 0.700	
<u>Reach DO (mg/L)</u> 7.563	<u>Reach Kr (1/days)</u> 3.626	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 1.001	Subreach Results			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.100	5.25	2.08	6.93
	0.200	4.85	1.94	6.56
	0.300	4.48	1.81	6.39
	0.400	4.14	1.69	6.33
	0.500	3.83	1.57	6.36
	0.600	3.53	1.47	6.44
	0.701	3.26	1.37	6.55
	0.801	3.02	1.28	6.68
	0.901	2.79	1.19	6.81
	1.001	2.57	1.11	6.95

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
		18F	42557	BUFFALO CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.420	Buffalo Twp MA	PA0221449	0.890	CBOD5	25		
				NH3-N	13.42	26.84	
				Dissolved Oxygen			4

Buffalo Township Muni Auth STP

Buffalo Township, Butler County

PA0221449

Discharge pH

Outfall 001

<u>Date</u>	<u>pH min</u>	<u>pH max</u>	<u>$10^{-\text{pH min}}$</u>	<u>$10^{-\text{pH max}}$</u>	<u>& pH max</u>	<u>-Log (Ave pH)</u>
Jul-21	6.2	6.8	6.31E-07	1.58E-07	3.95E-07	6.4
Aug-21	6.02	6.95	9.55E-07	1.12E-07	5.34E-07	6.3
Sep-21	6.07	6.96	8.51E-07	1.1E-07	4.8E-07	6.3
Jul-22	6.0	6.8	0.000001	1.58E-07	5.79E-07	6.2
Aug-22	6.16	6.75	6.92E-07	1.78E-07	4.35E-07	6.4
Sep-22	6.04	6.71	9.12E-07	1.95E-07	5.53E-07	6.3
Jul-23	6.05	6.52	8.91E-07	3.02E-07	5.97E-07	6.2
Aug-23	6.03	6.58	9.33E-07	2.63E-07	5.98E-07	6.2
Sep-23	6.0	6.47	0.000001	3.39E-07	6.69E-07	6.2
						Median: 6.3

NPDES Permit Fact Sheet

Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

NPDES Permit Fact Sheet

Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1



Discharge Information

Instructions **Discharge** Stream

Facility: **Buffalo Township MA STP** NPDES Permit No.: **PA0221449** Outfall No.: **001**
Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Treated Domestic Sewage**

Discharge Characteristics							
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀
0.89	100	6.3					

		Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
Group 1	Group 2				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
		Total Dissolved Solids (PWS)	mg/L	518									
		Chloride (PWS)	mg/L	175									
		Bromide	mg/L	< 0.1									
		Sulfate (PWS)	mg/L	36.5									
		Fluoride (PWS)	mg/L										
		Total Aluminum	µg/L										
		Total Antimony	µg/L										
		Total Arsenic	µg/L										
		Total Barium	µg/L										
		Total Beryllium	µg/L										
		Total Boron	µg/L										
		Total Cadmium	µg/L										
		Total Chromium (III)	µg/L										
		Hexavalent Chromium	µg/L										
		Total Cobalt	µg/L										
		Total Copper	µg/L	19.73			0.5019						
		Free Cyanide	µg/L										
		Total Cyanide	µg/L										
		Dissolved Iron	µg/L										
		Total Iron	µg/L										
		Total Lead	µg/L	< 1									
		Total Manganese	µg/L										
		Total Mercury	µg/L										
		Total Nickel	µg/L										
		Total Phenols (Phenolics) (PWS)	µg/L										
		Total Selenium	µg/L										
		Total Silver	µg/L										
		Total Thallium	µg/L										
		Total Zinc	µg/L	70.5									
		Total Molybdenum	µg/L										
		Acrolein	µg/L	<									
		Acrylamide	µg/L	<									
		Acrylonitrile	µg/L	<									
		Benzene	µg/L	<									
		Bromoform	µg/L	<									

Group 3	Carbon Tetrachloride	µg/L	<																							
	Chlorobenzene	µg/L	<																							
	Chlorodibromomethane	µg/L	<																							
	Chloroethane	µg/L	<																							
	2-Chloroethyl Vinyl Ether	µg/L	<																							
	Chloroform	µg/L	<																							
	Dichlorobromomethane	µg/L	<																							
	1,1-Dichloroethane	µg/L	<																							
	1,2-Dichloroethane	µg/L	<																							
	1,1-Dichloroethylene	µg/L	<																							
	1,2-Dichloropropane	µg/L	<																							
	1,3-Dichloropropylene	µg/L	<																							
	1,4-Dioxane	µg/L	<																							
	Ethylbenzene	µg/L	<																							
	Methyl Bromide	µg/L	<																							
	Methyl Chloride	µg/L	<																							
	Methylene Chloride	µg/L	<																							
	1,1,2,2-Tetrachloroethane	µg/L	<																							
	Tetrachloroethylene	µg/L	<																							
	Toluene	µg/L	<																							
	1,2-trans-Dichloroethylene	µg/L	<																							
	1,1,1-Trichloroethane	µg/L	<																							
	1,1,2-Trichloroethane	µg/L	<																							
	Trichloroethylene	µg/L	<																							
	Vinyl Chloride	µg/L	<																							
Group 4	2-Chlorophenol	µg/L	<																							
	2,4-Dichlorophenol	µg/L	<																							
	2,4-Dimethylphenol	µg/L	<																							
	4,6-Dinitro-o-Cresol	µg/L	<																							
	2,4-Dinitrophenol	µg/L	<																							
	2-Nitrophenol	µg/L	<																							
	4-Nitrophenol	µg/L	<																							
	p-Chloro-m-Cresol	µg/L	<																							
	Pentachlorophenol	µg/L	<																							
	Phenol	µg/L	<																							
Group 5	2,4,6-Trichlorophenol	µg/L	<																							
	Acenaphthene	µg/L	<																							
	Acenaphthylene	µg/L	<																							
	Anthracene	µg/L	<																							
	Benzidine	µg/L	<																							
	Benzo(a)Anthracene	µg/L	<																							
	Benzo(a)Pyrene	µg/L	<																							
	3,4-Benzofluoranthene	µg/L	<																							
	Benzo(ghi)Perylene	µg/L	<																							
	Benzo(k)Fluoranthene	µg/L	<																							
	Bis(2-Chloroethoxy)Methane	µg/L	<																							
	Bis(2-Chloroethyl)Ether	µg/L	<																							
	Bis(2-Chloroisopropyl)Ether	µg/L	<																							
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																							
	4-Bromophenyl Phenyl Ether	µg/L	<																							
	Butyl Benzyl Phthalate	µg/L	<																							
	2-Chloronaphthalene	µg/L	<																							
	4-Chlorophenyl Phenyl Ether	µg/L	<																							
	Chrysene	µg/L	<																							
	Dibenzo(a,h)Anthracene	µg/L	<																							
	1,2-Dichlorobenzene	µg/L	<																							
	1,3-Dichlorobenzene	µg/L	<																							
	1,4-Dichlorobenzene	µg/L	<																							
	3,3-Dichlorobenzidine	µg/L	<																							
	Diethyl Phthalate	µg/L	<																							
	Dimethyl Phthalate	µg/L	<																							
	Di-n-Butyl Phthalate	µg/L	<																							
	2,4-Dinitrotoluene	µg/L	<																							



Stream / Surface Water Information

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Buffalo Creek**

No. Reaches to Model: **1**

Statewide Criteria
 Great Lakes Criteria
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042557	8	778	167.65			Yes
End of Reach 1	042122	0.001	755	11410		4	Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	8	0.043										108	8.3		
End of Reach 1	0.001	0.043	2390									100	7		

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	8														
End of Reach 1	0.001														



Model Results

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions	Results	RETURN TO INPUTS	SAVE AS PDF	PRINT	<input checked="" type="radio"/> All	<input type="radio"/> Inputs	<input type="radio"/> Results	<input type="radio"/> Limits
---------------------	----------------	----------------------------------	-----------------------------	-----------------------	--------------------------------------	------------------------------	-------------------------------	------------------------------

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
8	7.21		7.21	1.377	0.00054	0.826	55.046	66.638	0.189	2.589	167.121
0.001	2390.00	6.188	2383.812								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
8	41.76		41.76	1.377	0.00054	1.681	55.046	32.753	0.466	1.048	76.553
0.001	6663.595	6.188	6657.41								

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	14.057	14.6	37.6	Chem Translator of 0.96 applied
Total Lead	0	0		0	68.021	86.8	223	Chem Translator of 0.784 applied
Total Zinc	0	0		0	122.013	125	320	Chem Translator of 0.978 applied

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	9.467	9.86	61.5	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.701	3.46	21.6	Chem Translator of 0.782 applied
Total Zinc	0	0		0	124.829	127	789	Chem Translator of 0.986 applied

THH

CCT (min): #####

THH PMF: 1

Analysis Hardness (mg/l):

N/A

Analysis pH:

N/A

PWS PMF: 1

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	#####	WQC applied at RMI 0.001 with a design stream flow of 2390 cfs
Chloride (PWS)	0	0		0	250,000	250,000	#####	WQC applied at RMI 0.001 with a design stream flow of 2390 cfs
Sulfate (PWS)	0	0		0	250,000	250,000	#####	WQC applied at RMI 0.001 with a design stream flow of 2390 cfs
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL

CCT (min): 76.553

PMF: 1

Analysis Hardness (mg/l):

N/A

Analysis pH:

N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	0.18	0.28	24.2	37.7	60.4	µg/L	24.2	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Zinc	Report	Report	Report	Report	Report	µg/L	205	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	868,436	mg/L	Discharge Conc ≤ 10% WQBEL
Chloride (PWS)	434,218	mg/L	Discharge Conc ≤ 10% WQBEL

Model Results

12/28/2023

Page 6

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

Bromide	N/A	N/A	No WQS
Sulfate (PWS)	434,218	mg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	N/A	N/A	Discharge Conc < TQL

Model Results

12/28/2023

Page 7

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
18F	42557	BUFFALO CREEK		3.420	778.00	167.65	0.00000	0.00	<input checked="" type="checkbox"/>		
Stream Data											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (°C)	Tributary Temp (°C) pH Stream Temp (°C) pH		
Q7-10	0.043	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00 8.30 0.00 0.00		
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
Buffalo Twp MA	PA0221449	1.3000	0.0000	0.0000	0.000	20.00	6.30				
Parameter Data											
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
CBOD5	25.00	2.00	0.00	1.50							
Dissolved Oxygen	4.00	8.24	0.00	0.00							
NH3-N	25.00	0.10	0.00	0.70							

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42557	BUFFALO CREEK			0.001	745.00	171.00	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.043 0.00 0.00 0.000 0.000 0.0 0.00 0.00 20.00 8.30 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
Discharge Data										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
0.0000 0.0000 0.0000 0.000 0.00 7.00										
Parameter Data										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5 Dissolved Oxygen NH3-N				25.00	2.00	0.00	1.50			
				3.00	8.24	0.00	0.00			
				25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
18F		42557		BUFFALO CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
3.420	7.21	0.00	7.21	2.0111	0.00183	.8	53.05	66.32	0.22	0.962	20.00	6.95
Q1-10 Flow												
3.420	4.61	0.00	4.61	2.0111	0.00183	NA	NA	NA	0.18	1.157	20.00	6.81
Q30-10 Flow												
3.420	9.80	0.00	9.80	2.0111	0.00183	NA	NA	NA	0.25	0.837	20.00	7.05

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>															
18F	42557	BUFFALO CREEK																
NH3-N Acute Allocations																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
3.420	Buffalo Twp MA	19.4	50	19.4	50	0	0											
NH3-N Chronic Allocations																		
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction											
3.420	Buffalo Twp MA	1.85	10.39	1.85	10.39	0	0											
Dissolved Oxygen Allocations																		
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)											
3.42	Buffalo Twp MA	23.91	23.91	8.93	8.93	4	4											
						Critical Reach	Percent Reduction											
						0	0											

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
18F	42557	BUFFALO CREEK	
<u>RMI</u> 3.420	<u>Total Discharge Flow (mgd)</u> 1.300	<u>Analysis Temperature (°C)</u> 20.000	<u>Analysis pH</u> 6.946
<u>Reach Width (ft)</u> 53.048	<u>Reach Depth (ft)</u> 0.800	<u>Reach WDRatio</u> 66.317	<u>Reach Velocity (fps)</u> 0.217
<u>Reach CBOD5 (mg/L)</u> 6.78	<u>Reach Kc (1/days)</u> 0.892	<u>Reach NH3-N (mg/L)</u> 2.03	<u>Reach Kn (1/days)</u> 0.700
<u>Reach DO (mg/L)</u> 7.317	<u>Reach Kr (1/days)</u> 3.774	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6
<u>Reach Travel Time (days)</u> 0.962	<u>Subreach Results</u>		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.096	6.22
		0.192	5.71
		0.288	5.24
		0.385	4.81
		0.481	4.42
		0.577	4.05
		0.673	3.72
		0.769	3.41
		0.865	3.13
		0.962	2.88
			D.O. (mg/L)
			6.67
			6.32
			6.15
			6.11
			6.16
			6.26
			6.39
			6.53
			6.68
			6.84

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
18F	42557	BUFFALO CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.420	Buffalo Twp MA	PA0221449	1.300	CBOD5	23.91		
				NH3-N	8.93	17.86	
				Dissolved Oxygen			4



Discharge Information

Instructions Discharge Stream

Facility: Buffalo Township MA STP NPDES Permit No.: PA0221449 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated Domestic Sewage

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
1.3	100	6.3				

		Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
Group 1	Group 2				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
Group 1	Group 2	Total Dissolved Solids (PWS)	mg/L	518									
		Chloride (PWS)	mg/L	175									
		Bromide	mg/L	< 0.1									
		Sulfate (PWS)	mg/L	36.5									
		Fluoride (PWS)	mg/L										
Group 1	Group 2	Total Aluminum	µg/L										
		Total Antimony	µg/L										
		Total Arsenic	µg/L										
		Total Barium	µg/L										
		Total Beryllium	µg/L										
		Total Boron	µg/L										
		Total Cadmium	µg/L										
		Total Chromium (III)	µg/L										
		Hexavalent Chromium	µg/L										
		Total Cobalt	µg/L										
		Total Copper	µg/L	19.73			0.5019						
		Free Cyanide	µg/L										
		Total Cyanide	µg/L										
		Dissolved Iron	µg/L										
		Total Iron	µg/L										
		Total Lead	µg/L	< 1									
		Total Manganese	µg/L										
		Total Mercury	µg/L										
		Total Nickel	µg/L										
		Total Phenols (Phenolics) (PWS)	µg/L										
		Total Selenium	µg/L										
		Total Silver	µg/L										
		Total Thallium	µg/L										
		Total Zinc	µg/L	70.5									
		Total Molybdenum	µg/L										
Group 3	Group 4	Acrolein	µg/L	<									
		Acrylamide	µg/L	<									
		Acrylonitrile	µg/L	<									
		Benzene	µg/L	<									
		Bromoform	µg/L	<									



Stream / Surface Water Information

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Buffalo Creek**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042557	3.42	778	167.65			Yes
End of Reach 1	042557	0.001	745	171			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	3.42	0.043												108	8.3
End of Reach 1	0.001	0.043												108	8.3

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	3.42														
End of Reach 1	0.001														



Model Results

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions **Results** [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#) All Inputs Results Limits

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
3.42	7.21		7.21	2.011	0.002	0.8	53.048	66.317	0.217	0.962	77.088
0.001	7.35		7.353								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
3.42	41.76		41.76	2.011	0.002	1.587	53.048	33.418	0.52	0.402	41.058
0.001	42.489		42.49								

Wasteload Allocations

AFC

CCT (min): **15**

PMF: **0.441**

Analysis Hardness (mg/l): **104.9**

Analysis pH: **6.71**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	14.059	14.6	37.8	Chem Translator of 0.96 applied
Total Lead	0	0		0	68.032	86.8	224	Chem Translator of 0.784 applied
Total Zinc	0	0		0	122.028	125	322	Chem Translator of 0.978 applied

CFC

CCT (min): **77.088**

PMF: **1**

Analysis Hardness (mg/l): **106.26**

Analysis pH: **6.95**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

Sulfate (PWS)	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	9.432	9.83	45.0	Chem Translator of 0.96 applied
Total Lead	0	0	0	2.688	3.44	15.8	Chem Translator of 0.782 applied
Total Zinc	0	0	0	124.371	126	578	Chem Translator of 0.986 applied

THH

CCT (min): 77.088

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	500,000	500,000	N/A		
Chloride (PWS)	0	0	0	250,000	250,000	N/A		
Sulfate (PWS)	0	0	0	250,000	250,000	N/A		
Total Copper	0	0	0	N/A	N/A	N/A		
Total Lead	0	0	0	N/A	N/A	N/A		
Total Zinc	0	0	0	N/A	N/A	N/A		

CRL

CCT (min): 41.058

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits					Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units				
Total Copper	0.26	0.41	24.3	37.9	60.7	µg/L	24.3	AFC	Discharge Conc ≥ 50% WQBEL (RP)	
Total Zinc	Report	Report	Report	Report	Report	µg/L	206	AFC	Discharge Conc > 10% WQBEL (no RP)	

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable

Model Results

10/23/2024

Page 6

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Lead	N/A	N/A	Discharge Conc < TQL

Model Results

10/23/2024

Page 7



Discharge Information

Instructions Discharge Stream

Facility: Buffalo Township MA STP NPDES Permit No.: PA0221449 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated Domestic Sewage

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
1.3	100	6.3				

		Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
Group 1	Group 2				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
Group 1	Group 2	Total Dissolved Solids (PWS)	mg/L	518									
		Chloride (PWS)	mg/L	175									
		Bromide	mg/L	< 0.1									
		Sulfate (PWS)	mg/L	36.5									
		Fluoride (PWS)	mg/L										
Group 1	Group 2	Total Aluminum	µg/L										
		Total Antimony	µg/L										
		Total Arsenic	µg/L										
		Total Barium	µg/L										
		Total Beryllium	µg/L										
		Total Boron	µg/L										
		Total Cadmium	µg/L										
		Total Chromium (III)	µg/L										
		Hexavalent Chromium	µg/L										
		Total Cobalt	µg/L										
		Total Copper	µg/L	19.73			0.5019						
		Free Cyanide	µg/L										
		Total Cyanide	µg/L										
		Dissolved Iron	µg/L										
		Total Iron	µg/L										
		Total Lead	µg/L	< 1									
		Total Manganese	µg/L										
		Total Mercury	µg/L										
		Total Nickel	µg/L										
		Total Phenols (Phenolics) (PWS)	µg/L										
		Total Selenium	µg/L										
		Total Silver	µg/L										
		Total Thallium	µg/L										
		Total Zinc	µg/L	70.5									
		Total Molybdenum	µg/L										
Group 3	Group 4	Acrolein	µg/L	<									
		Acrylamide	µg/L	<									
		Acrylonitrile	µg/L	<									
		Benzene	µg/L	<									
		Bromoform	µg/L	<									



Stream / Surface Water Information

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Allegheny River PWS**

No. Reaches to Model: **1**

Statewide Criteria
 Great Lakes Criteria
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042122	4.58	745	11400			Yes
End of Reach 1	042122	0.001	744	11410		4	Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	4.58	0.243										100	7		
End of Reach 1	0.001	0.243	2391									100	7		

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	4.58														
End of Reach 1	0.001														



Model Results

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions **Results** [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#) All Inputs Results Limits

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
4.58	2770.20		2770.20	2.011	0.00004	0.804	1792.329	2228.839	1.923	0.145	948039.186
0.001	2391.00	6.188	2384.812								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
4.58	7581.30		7581.30	2.011	0.00004	1.252	1792.329	1431.477	3.379	0.083	488410.341
0.001	6666.032	6.188	6659.84								

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.439	14.0	90.7	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	529	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	776	Chem Translator of 0.978 applied

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

Sulfate (PWS)	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	8.956	9.33	363	Chem Translator of 0.96 applied
Total Lead	0	0	0	2.517	3.18	124	Chem Translator of 0.791 applied
Total Zinc	0	0	0	118.139	120	4,668	Chem Translator of 0.986 applied

THH CCT (min): **#####** THH PMF: **0.028** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A** PWS PMF: **0.0149**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	500,000	500,000	9,336,792	WQC applied at RMI 0.001 with a design stream flow of 2391 cfs	
Chloride (PWS)	0	0	0	250,000	250,000	4,668,396	WQC applied at RMI 0.001 with a design stream flow of 2391 cfs	
Sulfate (PWS)	0	0	0	250,000	250,000	4,668,396	WQC applied at RMI 0.001 with a design stream flow of 2391 cfs	
Total Copper	0	0	0	N/A	N/A	N/A		
Total Lead	0	0	0	N/A	N/A	N/A		
Total Zinc	0	0	0	N/A	N/A	N/A		

CRL CCT (min): **720** PMF: **0.038** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: **4**

Pollutants	Mass Limits		Concentration Limits					Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units				
Total Copper	Report	Report	Report	Report	Report	µg/L	58.2	AFC	Discharge Conc > 10% WQBEL (no RP)	
Total Zinc	Report	Report	Report	Report	Report	µg/L	498	AFC	Discharge Conc > 10% WQBEL (no RP)	

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments

Model Results

10/23/2024

Page 6

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449 A-1

Total Dissolved Solids (PWS)	9,337	mg/L	Discharge Conc ≤ 10% WQBEL
Chloride (PWS)	4,668	mg/L	Discharge Conc ≤ 10% WQBEL
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	4,668	mg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	N/A	N/A	Discharge Conc < TQL

Model Results

10/23/2024

Page 7