

**Northwest Regional Office
CLEAN WATER PROGRAM**

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0221619
 APS ID 1079388
 Authorization ID 1424191

Applicant and Facility Information

Applicant Name	<u>Otto Township Sanitary Authority McKean County</u>	Facility Name	<u>Otto Township STP</u>
Applicant Address	<u>PO Box 213 Duke Center, PA 16729-0213</u>	Facility Address	<u>1005 Main Street Duke Center, PA 16729-9515</u>
Applicant Contact	<u>Stacey Claycomb</u>	Facility Contact	<u>Stacey Claycomb</u>
Applicant Phone	<u>(814) 558-8920</u>	Facility Phone	<u>(814) 558-8920</u>
Client ID	<u>44814</u>	Site ID	<u>246336</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Otto Township</u>
Connection Status	<u>No Limitations</u>	County	<u>McKean</u>
Date Application Received	<u>January 17, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>This is a renewal of a Minor Sewage Facility which serves Otto Township in McKean County.</u>		

Summary of Review

This facility discharges to Knapp Creek, which is classified as Cold Water Fishes and has Aquatic Life and Recreational uses.

Act 14 – Notifications were submitted and received.

85.2% of the Flow Contribution comes from Otto Township, the remaining 14.8% of the flow comes from additional sanitary sewers not within the Otto Township limits.

There are currently 4 open violations in WMS for the subject Client ID (44814) as of 3/20/24. The open violations consist of several violations regarding the discharge and operation of the facility.

Sludge use and disposal description and location(s): This facility produced and disposed of 4.8 dry tons of sludge / biosolids which was hauled to Bradford WWTP by JJ Honey Dipper.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Dustin Hargenrater Dustin Hargenrater / Civil Engineer	April 15, 2024
		Vacant / Environmental Engineer Manager	Okay to Draft JCD 4/15/2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.23</u>
Latitude	<u>41° 56' 4.02"</u>	Longitude	<u>-78° 26' 10.03"</u>
Quad Name	<u>Eldred</u>	Quad Code	<u>41078H4</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Knapp Creek (CWF)</u>	Stream Code	<u>57507</u>
NHD Com ID	<u>112365763</u>	RMI	<u>0.1400 (Stream RMI 4.68)</u>
Drainage Area	<u>27</u>	Yield (cfs/mi ²)	<u>0.064</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.73</u>	Q ₇₋₁₀ Basis	<u>USGS – StreamStats</u>
Elevation (ft)	<u>1476</u>	Slope (ft/ft)	<u>0.00271</u>
Watershed No.	<u>16-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>Statewide</u>	Existing Use Qualifier	<u>None</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	<u>Monitoring Point 48146, Warm Month (May – Sept.) Averages from samples taken between 2003 and 2021</u>
pH (SU)	<u>7.23</u>		<u>Default</u>
Temperature (°F)	<u>68</u>		<u>Default</u>
Hardness (mg/L)	<u>100</u>		<u>Default</u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>State of New York</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>31</u>
PWS RMI	<u>263.4</u>	Distance from Outfall (mi)	<u>9.34</u>

Changes Since Last Permit Issuance: The OTSAB is planning to evaluate the cost of repairing and returning the press to operation versus hauling sludge. A decision is expected by the April board meeting (held on 3rd Tuesday of the month). Once a decision is known, Ms. Claycomb will contact the Department to clarify the course of action, which may include an amendment to the site's WQM Permit.

Other Comments: Kinzua Reservoir is 45.4 miles downstream.

Treatment Facility Summary				
Treatment Facility Name: Otto Township STP				
WQM Permit No.		Issuance Date		
4209401		1/16/2009		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Sequencing Batch Reactor	Ultraviolet	0.23
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.23	621	Not Overloaded	Aerobic Digestion	Bradford WWTP

Changes Since Last Permit Issuance: The facility has open violations regarding Failure to notify DEP of planned physical changes to a facility. This violation is in regard to the repair of the sewage sludge press being inoperable. A decision will be made whether to repair the unit and continue using the sewage sludge press or to continue hauling waste to Bradford WWTP in late April.

Other Comments: Waste sources include a septage receiving station.

Treatment is primary screening followed by two parallel sequencing batch reactors, effluent equalization and UV radiation disinfection. Included was alkalinity addition, post aeration, belt filter press, and aerobic sludge digestion. No as built certification was required. Sludge may be taken to another STP or a landfill. Alkalinity feed is to the headworks. Belt filter press filtrate is sent to the septage tank for return to the headworks.

Post Construction certification is dated June 9, 2011 for WQM permit 4209401 (low pressure sewers). Related to this permit was General Storm Water Construction permit PAG2004208003.

Compliance History

DMR Data for Outfall 001 (from February 1, 2023 to January 31, 2024)

Parameter	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23
Flow (MGD) Average Monthly	0.19001	0.1498	0.1078	0.1006	0.0899	0.3497	0.1083	0.0891	0.1009	0.1194	0.1444	0.13736
pH (S.U.) Daily Minimum	7.1	7.12	7.27	7.28	7.22	6.91	6.73	7.01	6.7	6.92	6.8	E
pH (S.U.) Daily Maximum	7.67	7.54	7.63	7.65	7.75	7.64	7.61	7.57	7.8	7.71	7.41	E
DO (mg/L) Daily Minimum	6.4	6.06	5.1	5.06	4.73	5.21	5.13	4.39	4.5	7.34	7.87	E
CBOD5 (lbs/day) Average Monthly	< 5	< 4.0	< 3.0	3.0	3.0	< 5.0	2	< 3.0	< 3.0	< 2.0	< 4.00	< 3.1
CBOD5 (lbs/day) Weekly Average	8	5.0	6.0	4.0	3.0	16.0	3	5.0	5.0	3.0	6.00	2.2
CBOD5 (mg/L) Average Monthly	< 3.2	< 3.5	< 2.9	4.3	3.6	< 2.6	3.1	< 3.5	< 3.2	< 2.2	< 3.5	< 3.1
CBOD5 (mg/L) Weekly Average	4.1	4.8	5.5	4.9	4.53	3.3	3.7	5.0	4.4	2.7	5.2	2.2
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	81	73	94	191	52	41	103	78	228	197	48	60
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	81	73	94	191	52	41	103	78	228	197	94	60
BOD5 (mg/L) Raw Sewage Influent Average Monthly	57	69	127	256	115	60	118	122	160	195	42	60.0
TSS (lbs/day) Average Monthly	< 7	< 5.0	< 3.0	< 3.0	3.0	7.0	< 3.0	10.00	8.0	9.0	< 14.00	11.00
TSS (lbs/day) Raw Sewage Influent Average Monthly	188	76	98.0	9	9	67	160	79	219	161	59	12.0
TSS (lbs/day) Raw Sewage Influent Daily Maximum	188	76	98.0	9	9	67	160	79	219	161	115	12.0

**NPDES Permit Fact Sheet
Otto Township STP**

NPDES Permit No. PA0221619

TSS (lbs/day) Weekly Average	11	8.0	3.0	4.0	3.0	24.00	3.0	33.0	15.0	17.0	30.00	21.50
TSS (mg/L) Average Monthly	< 5.00	< 4.0	< 3.0	< 4.0	5.0	3.0	< 4.0	10.0	8.00	9.0	< 13.00	11.00
TSS (mg/L) Raw Sewage Influent Average Monthly	132	72	132.00	12	20	99	184	124	154	160	51	12.0
TSS (mg/L) Weekly Average	9.50	7.50	4.50	6.0	5.5	4.0	4.0	30.0	12.50	15.0	26.50	21.50
Fecal Coliform (No./100 ml) Geometric Mean	< 2	< 1.0	< 16.00	< 28.0	48	< 5.0	< 2.0	< 2.0	< 3.0	< 307.00	152.00	< 6.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	57.1	4.0	980.4	2419	78	2419	14.8	17.5	22.8	2239	2419	19.7
UV Intensity ($\mu\text{w}/\text{cm}^2$) Average Monthly	13.4	3.17	0.20	0.40	1.0	1.24	2.1	0.80	0.80	0.90	5.3	E
Total Nitrogen (mg/L) Average Monthly	< 0.5	1.68	1.66	1.206	< 0.5000	1.307	8.785	2.90	3.62	16.015	1.325	< 1.0
Ammonia (lbs/day) Average Monthly				0.80	< 0.20	< 0.60	0.10	2.0	< 0.40			
Ammonia (mg/L) Average Monthly	< 0.2631	< 0.10	1.2211	1.0333	< 0.3975	< 0.1588	0.1233	0.832	< 0.398	< 0.199	< 0.315	< 0.103
Ammonia (mg/L) Instantaneous Maximum	0.53	< 0.10	4.656	3.191	1.2898	0.2178	0.1517	1.938	0.798	0.338	0.40	0.111
Total Phosphorus (mg/L) Average Monthly	2.24	1.58	3.86	2.51	2.28	2.62	1.31	3.42	1.78	1.79	1.10	1.78

Compliance History

Effluent Violations for Outfall 001, from: March 1, 2023 To: January 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	08/31/23	IMAX	2419	No./100 ml	1000	No./100 ml

Summary of Inspections: There have been a total of 5 inspections within the last 5 years. There have been 3 Chapter 94 inspections within this time frame, all of which no violations were noted. There has also been one Administrative/File Review which took place on 3/1/23 where one violation was noted. This violation prompted a Compliance Evaluation inspection on 3/29/23, this compliance evaluation noted 5 violations by the facility. The violations noted in the inspection report include: CSL – Failure to apply for and/or obtain a WQM permit for the construction of sewage or industrial waste facilities. NPDES – Failure to notify DEP of planned physical changes to a facility. NPDES – Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance. NPDES - Discharge contained floating materials, scum, sheen, foam, oil, grease, or substances that produced an observable change or resulted in deposits in receiving waters for NPDES permitted activities. CSL – Unauthorized, unpermitted discharge of sewage to waters of the Commonwealth. The CSL violation for failure to apply and/or obtain a WQM permit for the construction of sewage or industrial waste facilities was resolved on 4/20/2023. An amendment/new WQM application has not yet been received.

Other Comments: The open violations are currently in the works to be resolved.

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.23</u>
Latitude <u>41° 56' 4.03"</u>	Longitude <u>-78° 26' 10.03"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

This discharge was modeled using WQM 7.0 to evaluate CBOD₅, Dissolved Oxygen, and Ammonia-Nitrogen parameters. The modeling results from the previous permit term were more stringent than the suggested limits from WQM 7.0 so the previously calculated limits will be used for the permit renewal. From the previous fact sheet, no winter requirements were recommended as the normally applied 3 times winter adjustment factor generated a 30 mg/L limitation that was greater than the assumed 25 mg/L raw waste ammonia concentration.

Best Professional Judgment (BPJ) Limitations

Comments: A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and Best Professional Judgement.

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	5/week	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	5/week	Grab
CBOD5	48	76	XXX	25.0	40.0	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/month	8-Hr Composite
TSS	57	86	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Avg Qtrly	XXX	XXX	1/quarter	Grab
UV Intensity (µw/cm ²)	XXX	XXX	XXX	Report	XXX	XXX	1/day	Recorded
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	30.0	XXX	60.0	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	19.0	XXX	XXX	10.0	XXX	20.0	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: No new limits added, sampling frequencies will remain the same through the next permit term.

WQM 7.0 Modeling Results

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16C	57507	KNAPP CREEK	4.680	1476.00	27.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	Q7-10	0.064	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.23	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Otto Twp STP	PA0221619	0.2300	0.2300	0.2300	0.000	25.00	7.20

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

	Dustin Margenauer / Civil Engineer Vacant / Environmental Engineer Manager	April 15, 2024 Okay to Draft JCD 4/15/2024
--	---	--

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16C	57507	KNAPP CREEK	4.177	1465.00	27.40	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.064	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.23	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	20.00	7.23
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	4.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16C	57507	KNAPP CREEK	1.575	1429.00	29.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.064	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.23	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	20.00	7.23

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
16C		57507		KNAPP CREEK								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
4.680	1.73	0.00	1.73	.3558	0.00414	.594	23.23	39.12	0.15	0.204	20.85	7.22
4.177	1.75	0.00	1.75	.3558	0.00262	.6	24.06	40.08	0.15	1.089	20.84	7.22
Q1-10 Flow												
4.680	1.11	0.00	1.11	.3558	0.00414	NA	NA	NA	0.12	0.248	21.22	7.22
4.177	1.12	0.00	1.12	.3558	0.00262	NA	NA	NA	0.12	1.329	21.20	7.22
Q30-10 Flow												
4.680	2.35	0.00	2.35	.3558	0.00414	NA	NA	NA	0.17	0.176	20.66	7.23
4.177	2.38	0.00	2.38	.3558	0.00262	NA	NA	NA	0.17	0.940	20.65	7.23

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16C	57507	KNAPP CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.680	Otto Twp STP	12.09	49.65	12.09	49.65	0	0
4.177		NA	NA	12.1	NA	NA	NA

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.680	Otto Twp STP	1.63	12.36	1.63	12.36	0	0
4.177		NA	NA	1.63	NA	NA	NA

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
4.68	Otto Twp STP	25	25	12.36	12.36	4	4	0	0
4.18		NA	NA	NA	NA	NA	NA	NA	NA

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
16C	57507	KNAPP CREEK			
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
4.680	0.230	20.854		7.225	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
23.229	0.594	39.124		0.151	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
5.93	1.030	2.11		0.748	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.519	6.064	Tsvoglou		5	
<u>Reach Travel Time (days)</u>					
0.204					
Subreach Results					
	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.020	5.80	2.08	7.37	
	0.041	5.67	2.05	7.25	
	0.061	5.55	2.02	7.15	
	0.081	5.43	1.99	7.07	
	0.102	5.31	1.96	7.00	
	0.122	5.20	1.93	6.95	
	0.143	5.09	1.90	6.90	
	0.163	4.98	1.87	6.87	
	0.183	4.87	1.84	6.85	
	0.204	4.77	1.81	6.83	
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
4.177	0.230	20.843		7.225	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
24.063	0.600	40.078		0.146	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
4.73	0.667	1.79		0.747	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
6.848	3.709	Tsvoglou		5	
<u>Reach Travel Time (days)</u>					
1.089					
Subreach Results					
	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.109	4.39	1.65	6.62	
	0.218	4.07	1.52	6.54	
	0.327	3.77	1.40	6.55	
	0.436	3.50	1.29	6.62	
	0.544	3.24	1.19	6.73	
	0.653	3.01	1.10	6.85	
	0.762	2.79	1.01	6.98	
	0.871	2.59	0.93	7.11	
	0.980	2.40	0.86	7.24	
	1.089	2.22	0.79	7.36	
<hr/>					

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16C		57507		KNAPP CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.680	Otto Twp STP	PA0221619	0.230	CBOD5	25		
				NH3-N	12.36	24.72	
				Dissolved Oxygen			4