



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0221830  
APS ID 1097679  
Authorization ID 1456379

**Applicant and Facility Information**

Applicant Name	<u>West Sunbury Borough Municipal Authority Butler County</u>	Facility Name	<u>West Sunbury Borough STP</u>
Applicant Address	<u>PO Box 202</u>	Facility Address	<u>Sr 138 N Washington Road</u>
	<u>West Sunbury, PA 16061-0202</u>		<u>West Sunbury, PA 16061</u>
Applicant Contact	<u>Kathy Ferdinandsen</u>	Facility Contact	<u>Kathy Ferdinandsen</u>
Applicant Phone	<u>(724) 637-3000</u>	Facility Phone	<u>(724) 637-3000</u>
Client ID	<u>207551</u>	Site ID	<u>253673</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>West Sunbury Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Butler</u>
Date Application Received	<u>September 27, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES Renewal for a municipal sewage treatment plant (STP).</u>		

**Summary of Review**

This is an existing discharge for a minor municipal sewage treatment facility.

Act 14 proof of notification was submitted and received.

There are currently no open violations for this client (207551) as of 10/31/2024.

Annual monitoring for E. Coli has been added per Department SOP for new and reissued NPDES permits with design flows exceeding 2000 GPD.

The EPA Waiver is in effect.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	October 31, 2024
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	November 8, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.028
Latitude	41° 0' 44.29"	Longitude	-79° 53' 32.81"
Quad Name	West Sunbury	Quad Code	41079A8
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary of South Branch Slippery Rock Creek (CWF)	Stream Code	34634
NHD Com ID	126223136	RMI	0.2200
Drainage Area	0.32	Yield (cfs/mi <sup>2</sup> )	0.1
Q <sub>7-10</sub> Flow (cfs)	0.032	Q <sub>7-10</sub> Basis	Streamstats
Elevation (ft)	1284	Slope (ft/ft)	---
Watershed No.	20-C	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name _____		
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°F)	20	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	PA American Water – Ellwood City		
PWS Waters	Slippery Rock Creek	Flow at Intake (cfs)	53.1
PWS RMI	0.1	Distance from Outfall (mi)	>25

Changes Since Last Permit Issuance: None.

Other Comments: Yield was back-calculated from the 7-day 10-year low flow value estimated by Streamstats for this watershed.

Treatment Facility Summary			
<b>Treatment Facility Name:</b> West Sunbury Municipal Authority			
WQM Permit No.	Description		Issuance Date
1096407	Sewers and STP		6 August 1996
1096407 T-1	Transfer to authority		27 May 2003
1096407 A-1	Drying bed consolidation		11 July 2006
1096407	Aeration and piping changes		2014
1002407 T-1	Dassa McKinney Pump Station and Sewers		27 May 2003
1096407	Ultra-Sonic Flow Meter Model SLT 5.0 A-1 Level and Flow Meter		2014
1096407 A-2	STP tertiary treatment		12 August 2016
1096407 A-3	Installed AdvanTex AX-Max450 system		1/30/2019
Waste Type	Degree of Treatment	Process Type	Disinfection
Sewage	Secondary	Aerated Lagoon	Hypochlorite
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment
0.028	47	Not Overloaded	Drying
			Biosolids Use/Disposal
			Land Application

Changes Since Last Permit Issuance: WQM 1096407 A-3 was issued concurrently with the previous renewal of the NPDES permit. This WQM Amendment permitted the installation of an AdvanTex AX-Max450 system and related appurtenances.

Other Comments: None.

Compliance History

DMR Data for Outfall 001 (from September 1, 2023 to August 31, 2024)

Parameter	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23
Flow (MGD) Average Monthly	0.0123	0.0103	0.0092	0.0169	0.0266	0.0271	0.0195	0.0310	0.0213	0.0184	0.0172	0.0138
Flow (MGD) Weekly Average	0.0123	0.0103	0.0092	0.0169	0.0266	0.0271	0.0195	0.0310	0.0213	0.0184	0.0172	0.0138
pH (S.U.) Daily Minimum	7.0	7.0	7.0	6.9	7.1	7.4	7.4	7.2	7.2	7.1	7.2	7.3
pH (S.U.) Daily Maximum	7.3	7.3	7.2	7.1	7.4	7.7	7.5	7.6	7.2	7.5	7.4	7.6
DO (mg/L) Daily Minimum	5.4	5.7	5.7	5.6	9.1	11.5	14.6	13.1	10.9	9.1	7.6	7.4
TRC (mg/L) Average Monthly	0.05	0.1	0.09	< 0.08	0.10	0.06	0.06	0.10	0.01	0.04	0.10	0.10
TRC (mg/L) Instantaneous Maximum	0.11	0.1	0.14	0.12	0.14	0.14	0.11	0.12	0.01	0.10	0.16	0.16
CBOD5 (lbs/day) Average Monthly	0.277	1.005	0.307	2.03	1.020	2.147	1.756	1.111	0.817	< 0.752	0.703	0.460
CBOD5 (lbs/day) Weekly Average	1.544	1.675	0.307	3.45	1.054	3.390	1.952	1.163	0.942	0.890	0.818	0.460
CBOD5 (mg/L) Average Monthly	2.7	< 11.7	4.0	14.4	< 4.6	9.5	10.8	4.3	< 4.6	< 4.9	< 4.9	< 4.0
CBOD5 (mg/L) Weekly Average	5.3	19.5	4.0	24.5	5.2	15.0	12.0	4.5	5.3	5.8	< 5.7	< 4.0
BOD5 (mg/L) Influent   Average Monthly	171	86	149	151	110	245	96	78	174	272	343	178
TSS (lbs/day) Average Monthly	< 0.513	0.490	0.407	2.57	3.727	2.644	1.268	3.102	0.888	1.074	0.717	0.576
TSS (lbs/day) Weekly Average	< 0.513	0.558	0.422	3.52	4.215	3.390	1.708	3.102	0.888	1.074	0.717	0.576
TSS (mg/L) Average Monthly	< 5.0	5.7	5.3	18.2	16.8	11.7	< 7.8	12.0	5.0	7.0	< 5.0	< 5.0
TSS (mg/L) Influent   Average Monthly	121	100	92	114	45	109	77	65	153	90	103	78
TSS (mg/L) Weekly Average	< 5.0	6.5	5.5	25.0	19.0	15.0	< 10.5	12.0	5.0	7.0	< 5.0	< 5.0

NPDES Permit Fact Sheet  
West Sunbury Borough STP

NPDES Permit No. PA0221830

Fecal Coliform (No./100 ml) Geometric Mean	25	< 1	< 1	1	49	< 1	< 1	< 1	2	461	19	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	648	1	< 1	2	2419	< 1	< 1	< 1	3	2420	365	< 1
Total Nitrogen (mg/L) Semi-Annual Average			22.7						8.82			
Ammonia (mg/L) Average Monthly	2.3	2.7	3.0	4.3	6.5	11.6	8.7	8.5	10.00	7.97	2.74	1.77
Ammonia (mg/L) Instantaneous Maximum	2.3	3.6	3.5	4.6	6.8	14.0	9.5	10.7	10.70	8.43	3.03	2.94
Total Phosphorus (mg/L) Semi-Annual Average			4.4						8.20			

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.028	
Latitude	41° 0' 43.67"	Longitude	-79° 53' 32.37"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli (No./100ml)	Report	IMAX		92a.61

Comments:

E. Coli monitoring was added based on the Department's SOP for new and reissued permits.

### Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia (May-Oct)	2.7	Average Monthly	WQM v.1.0b
CBOD <sub>5</sub>	25	Average Monthly	WQM v1.0b
Dissolved Oxygen (DO)	3.0	Daily Minimum	WQM v.1.0b
Total Residual Chlorine (TRC)	0.1	Average Monthly	TRC Spreadsheet

Comments:

An Ammonia-Nitrogen (NH<sub>3</sub>N) limit of 2.72 mg/l was determined by WQM modeling to be protective, and shall be rounded down to 2.7 mg/l.

A Dissolved Oxygen minimum of 3.0 mg/l was determined by WQM modeling to be protective, but Department policy imposes a minimum limit no less than 4.0 mg/l by Best Professional Judgment.

The technology-based Total Residual Chlorine (TRC) limit of 0.1 mg/l was found to be protective of the receiving stream per the Department's TRC spreadsheet, which gave a result of 0.117 mg/l. This value was rounded down to 0.1 in congruence with the existing TRC limit to comply with Anti-Backsliding policy.

### Best Professional Judgment (BPJ) Limitations

Comments: A Dissolved Oxygen (DO) minimum limit of 4.0mg/l shall be retained.

### Anti-Backsliding

None.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.1	XXX	0.4	1/day	Grab
CBOD5	5.8	9.3	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	7.0	10.5	XXX	30.0	45.0	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	2/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	8.1	XXX	16.2	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.7	XXX	5.4	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report SEMI AVG	XXX	XXX	2/year	8-Hr Composite
E. Coli (No.100ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: Permittee was informed in the Fact Sheet Addendum of the previous permit cycle that sampling for pH, DO, TRC would become daily upon permit renewal.

TRC Spreadsheet - West Sunbury Boro STP

TRC EVALUATION							
Input appropriate values in A3:A9 and D3:D9							
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc = 0.255		1.3.2.iii	WLA_cfc = 0.241		
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581		
PENTOXSD TRG	5.1b	LTA_afc = 0.095		5.1d	LTA_cfc = 0.140		
Effluent Limit Calculations							
PENTOXSD TRG	5.1f	AML MULT = 1.231					
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.117			INST MAX LIMIT (mg/l) = 0.382	AFC	
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_afc		$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$					
LTA_afc		wla_afc*LTAMULT_afc					
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$					
LTAMULT_cfc		$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$					
LTA_cfc		wla_cfc*LTAMULT_cfc					
AML MULT		$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$					
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT		$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$					

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>									
20C	34629	Trib 34629 to S Br Slippery Rock Cr										
<b>NH3-N Acute Allocations</b>												
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction					
2.240 Outfall 001		7.58	11.16	7.58	10.18	2	9					
2.019 End of Reach 1		8.32	19.86	7.82	18.13	2	9					
<b>NH3-N Chronic Allocations</b>												
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction					
2.240 Outfall 001		1.6	3.21	1.6	2.72	2	15					
2.019 End of Reach 1		1.75	6.91	1.66	5.87	2	15					
<b>Dissolved Oxygen Allocations</b>												
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>						
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)					
2.24 Outfall 001		25	25	2.72	2.72	5	5					
2.02 End of Reach 1		25	25	5.87	5.87	3	3					
						0	0					
						0	0					

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34629	Trib 34629 to S Br Slippery Rock Cr		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.240	0.028	22.876	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
3.201	0.341	9.386	0.069	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
15.23	1.402	1.57	0.873	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.378	28.329	Owens	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.196	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.020	14.76	1.54	6.73
	0.039	14.30	1.51	6.95
	0.059	13.86	1.49	7.09
	0.078	13.43	1.46	7.19
	0.098	13.02	1.44	7.27
	0.117	12.62	1.41	7.33
	0.137	12.23	1.39	7.38
	0.157	11.85	1.37	7.42
	0.176	11.49	1.34	7.46
	0.196	11.13	1.32	7.50
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.019	0.056	22.398	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
5.578	0.386	14.449	0.084	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
11.32	1.242	1.96	0.842	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.675	25.397	Owens	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.801	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.080	10.13	1.83	7.50
	0.160	9.07	1.71	7.70
	0.240	8.12	1.60	7.81
	0.320	7.26	1.49	7.89
	0.400	6.50	1.40	7.89
	0.480	5.82	1.31	7.89
	0.560	5.21	1.22	7.89
	0.640	4.66	1.14	7.89
	0.721	4.17	1.07	7.89
	0.801	3.73	1.00	7.89

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.240	Outfall 001	PA0221830	0.028	CBOD5	25		
				NH3-N	2.72	5.44	
				Dissolved Oxygen			5
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.019	End of Reach 1	PA0221830	0.028	CBOD5	25		
				NH3-N	5.87	11.74	
				Dissolved Oxygen			3

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC				
20C	34629	Trib 34629 to S Br Slippery Rock Cr	2.240	1272.00	0.32	0.00000	0.00	<input checked="" type="checkbox"/>				
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>												
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
	Outfall 001	PA0221830	0.0280	0.0280	0.0280	0.000	25.00	7.00				
<b>Parameter Data</b>												
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
	CBOD5		25.00	2.00	0.00	1.50						
	Dissolved Oxygen		3.00	8.24	0.00	0.00						
	NH3-N		25.00	0.00	0.00	0.70						

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																																		
20C	34629	34629 to S Br Slippery Rock Cr		2.019	1256.00	0.94	0.00000	0.00	<input checked="" type="checkbox"/>																																																		
<b>Stream Data</b>																																																											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH	pH																																															
<table> <tr> <td>Q7-10</td><td>0.100</td><td>0.00</td><td>0.00</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td><td>0.00</td><td>0.00</td></tr> <tr> <td>Q1-10</td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Q30-10</td><td></td><td>0.00</td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>												Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00	Q1-10		0.00	0.00	0.000	0.000								Q30-10		0.00	0.00	0.000	0.000																
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00																																															
Q1-10		0.00	0.00	0.000	0.000																																																						
Q30-10		0.00	0.00	0.000	0.000																																																						
<b>Discharge Data</b>																																																											
				Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH																																																		
Name		Permit Number		0.0280	0.0280	0.0280	0.000	25.00	7.00																																																		
<table> <tr> <td>End of Reach 1</td><td>PA0221830</td><td>0.0280</td><td>0.0280</td><td>0.0280</td><td>0.000</td><td>25.00</td><td>7.00</td><td></td><td></td><td></td><td></td></tr> </table>												End of Reach 1	PA0221830	0.0280	0.0280	0.0280	0.000	25.00	7.00																																								
End of Reach 1	PA0221830	0.0280	0.0280	0.0280	0.000	25.00	7.00																																																				
<b>Parameter Data</b>																																																											
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																																				
<table> <tr> <td colspan="4">Parameter Name</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td colspan="4">CBOD5</td><td>25.00</td><td>2.00</td><td>0.00</td><td>1.50</td><td></td><td></td><td></td><td></td></tr> <tr> <td colspan="4">Dissolved Oxygen</td><td>3.00</td><td>8.24</td><td>0.00</td><td>0.00</td><td></td><td></td><td></td><td></td></tr> <tr> <td colspan="4">NH3-N</td><td>25.00</td><td>0.00</td><td>0.00</td><td>0.70</td><td></td><td></td><td></td><td></td></tr> </table>				Parameter Name												CBOD5				25.00	2.00	0.00	1.50					Dissolved Oxygen				3.00	8.24	0.00	0.00					NH3-N				25.00	0.00	0.00	0.70												
Parameter Name																																																											
CBOD5				25.00	2.00	0.00	1.50																																																				
Dissolved Oxygen				3.00	8.24	0.00	0.00																																																				
NH3-N				25.00	0.00	0.00	0.70																																																				

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC				
20C	34629	Trib 34629 to S Br Slippery Rock Cr	0.920	1216.00	1.78	0.00000	0.00	<input checked="" type="checkbox"/>				
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>									Disc Temp (°C)	Disc pH		
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor						
	End of Reach 2		0.0000	0.0000	0.0000	0.000		25.00	7.00			
<b>Parameter Data</b>									Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
	Parameter Name											
	CBOD5		25.00	2.00	0.00	1.50						
	Dissolved Oxygen		3.00	8.24	0.00	0.00						
	NH3-N		25.00	0.00	0.00	0.70						

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>									
20C		34629		Trib 34629 to S Br Slippery Rock Cr									
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)		(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
2.240	0.03	0.00	0.03	.0433	0.01371	.341	3.2	9.39	0.07	0.196	22.88	7.00	
2.019	0.09	0.00	0.09	.0866	0.00689	.386	5.58	14.45	0.08	0.801	22.40	7.00	
<b>Q1-10 Flow</b>													
2.240	0.02	0.00	0.02	.0433	0.01371	NA	NA	NA	0.06	0.215	23.39	7.00	
2.019	0.06	0.00	0.06	.0866	0.00689	NA	NA	NA	0.07	0.899	22.95	7.00	
<b>Q30-10 Flow</b>													
2.240	0.04	0.00	0.04	.0433	0.01371	NA	NA	NA	0.07	0.181	22.49	7.00	
2.019	0.13	0.00	0.13	.0866	0.00689	NA	NA	NA	0.09	0.727	22.02	7.00	

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		