

Application Type	Renewal
Facility Type	Non- Municipal
Major / Minor	Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

 Application No.
 PA0222429

 APS ID
 1099810

 Authorization ID
 1459846

Applicant and Facility Information

Applicant Name	pplicant Name Pilot Travel Center LLC		Facility Name	Pilot Travel Center 081
Applicant Address	5508 l	_onas Drive	Facility Address	2010 New Castle Road
	Knoxv	ille, TN 37909-3221		Portersville, PA 16051-1206
Applicant Contact	Joey (Cupp	Facility Contact	
Applicant Phone	(865)	474-2826	Facility Phone	
Applicant Email	joeycu	pp@pilottravelcenters.com		
Client ID	13575	0	Site ID	464877
Ch 94 Load Status	Not O	verloaded	Municipality	Muddycreek Township
Connection Status	No Lin	nitations	County	Butler
Date Application Rece	eived	September 29, 2023	EPA Waived?	Yes
Date Application Acce	pted	May 1, 2024	If No, Reason	
Purpose of Applicatior	า	Renewal of a NPDES Permit for	an Existing Discharge of	0.05

Summary of Review

This is a renewal Sewage Individual NPDES Permit for an Existing Discharge of 0.05 MGD from a non-municipal minor sewage facility. This facility is a truck stop/ travel center with retail sales of gasoline and diesel fuels. Inside operations consist of a convenience store, showers, restrooms, and a Subway restaurant. The existing treatment process consists of Sewage Pump station, Equalization Tank, Aeration Tank, Clarification, Chlor/ Dechlor and Sludge Digestion.

Act 14 - Proof of Notification was submitted and received.

This facility is currently using eDMR system.

SPECIAL CONDITIONS: NONE

The EPA waiver is in effect.

There are Four (4) open violations in WMS for the subject Client ID (135750) as of May 9, 2024.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
х		Aeshah Shameseldin Aeshah Shameseldin / Civil Engineer	May 9, 2024
х		Jason Roessing, P.E. Jason Roessing / Environmental Engineer Manager	May 28, 2024

ischarge, Receiving	g Water	s and Water Supply Info	ormation	
Outfall No. 001			_ Design Flow (MGD)	05
Latitude 40° 57' 50.43"		Longitude	-80º 8' 16.03"	
Quad Name Por	rtersville	2	_ Quad Code	40080H2
Wastewater Descrip	otion:	Sewage Effluent		
Receiving Waters	Mudd	y Creek (WWF)	Stream Code	34081
NHD Com ID		16816	RMI	3.74
Drainage Area	53 sq	uare miles	Yield (cfs/mi ²)	0.037
Q ₇₋₁₀ Flow (cfs)	1.961		Q ₇₋₁₀ Basis	Stream Gage # 03106300, Muddy Creek near Portersville,
()				Pa
Elevation (ft)	1150			
Watershed No.	20-C		Chapter 93 Class.	WWF
Existing Use			Existing Use Qualifier	
Exceptions to Use			Exceptions to Criteria	
Assessment Status		Attaining Use(s)		
Cause(s) of Impairn				
Source(s) of Impair	ment			
TMDL Status			Name	
Background/Ambier	nt Data		Data Source 5/20/88 sample taken approx.	4,400 feet, below the
pH (SU)		8.0	proposed discharge	
Temperature (°F)				
Hardness (mg/L)		100	Default	
Other:				
Nearest Downstrea	m Publi	c Water Supply Intake	Pennsylvania American Wate	r Company - Ellwood City
PWS Waters E	Beaver	River	Flow at Intake (cfs)	292.5
PWS RMI 1	3.0		Distance from Outfall (mi)	

Changes Since Last Permit Issuance: None.

Other Comments: None.

	Tre	atment Facility Summa	ry	
Treatment Facility Na	me: Pilot Travel Center 081			
WQM Permit No.	Issuance Date			
1097410 A-2	July 3, 2013			
	Degree of			Avg Annual
Waste Type	Treatment	Process Type	Disinfection	Flow (MGD)
* 1	Secondary with	21	Chlorine with	
Sewage	Ammonia Reduction	Extended Aeration	Dechlorination	0.05
Hydraulic Capacity	Organic Capacity			Biosolids
(MGD)	(lbs/day)	Load Status	Biosolids Treatment	Use/Disposal
0.05	84.1	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments: None.

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

Parameter	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23
Flow (MGD)												
Average Monthly	0.007	0.006	0.007	0.008	0.007	0.007	0.008	0.010	0.009	0.002	0.008	0.002
pH (S.U.)												
Instantaneous												
Minimum	6.98	6.14	6.65	7.05	6.53	6.15	6.90	6.55	6.86	6.84	6.90	6.05
pH (S.U.)												
Instantaneous												
Maximum	7.32	7.63	7.89	7.35	7.73	7.25	7.28	7.19	7.97	7.29	7.38	7.20
DO (mg/L)												
Instantaneous												
Minimum	5.01	6.55	6.70	7.20	5.10	5.10	6.10	5.30	5.88	6.02	5.20	6.29
TRC (mg/L)												
Average Monthly	0.04	0.03	0.04	0.04	0.04	0.06	0.05	0.03	0.07	0.03	0.03	0.03
TRC (mg/L)												
Instantaneous												
Maximum	0.10	0.10	0.10	0.10	0.10	0.2	0.10	0.10	0.20	0.10	0.10	0.04
CBOD5 (mg/L)												
Average Monthly	4.0	4.0	3.0	3.0	3.0	3.00	3.0	7.0	3.0	3.0	3.0	4.0
TSS (mg/L)												
Average Monthly	10	11.00	16	17	11.0	8.0	19.0	16.0	6.0	4.0	4.0	3.0
Fecal Coliform												
(No./100 ml)												
Geometric Mean	3.0	1.0	5.0	10	2.0	39.42	2.0	1.0	17	2.0	1.0	5.0
Fecal Coliform												
(No./100 ml)												
Instantaneous												
Maximum	7.0	1.0	21	96	2.0	1554	3.0	1.0	48	2.0	1.0	19.0
Total Nitrogen (mg/L)												
Average Quarterly	2.80			1.75			1.62			2.31		
Ammonia (mg/L)												
Average Monthly	0.14	0.10	0.23	0.27	0.10	0.10	0.10	0.11	0.14	0.16	0.10	0.18
Total Phosphorus												
(mg/L)												
Average Quarterly	6.74			7.55			7.71			7.58		

Development of Effluent Limitations

Outfall No.	001		Design Flow (MGD)	.05
Latitude	40º 57' 50.43	3"	Longitude	-80º 8' 16.03"
Wastewater De	escription:	Sewage Effluent	-	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
CBOD5	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
Solids	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
рН	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform				
(10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	§ 92a.61

Comments: Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Water Quality-Based Limitations

Approximately 1 mile downstream, the Cooper Lake Campground (PA0239674) discharges 0.0275 MGD (design flow). Based on the previous fact sheet, an interaction happened when both discharges modeled together. As a result, the 0.05 MGD discharge from the Pilot Travel Center and the 0.0275 MGD discharge from the Copper Lake Campground have been modeled together as part of this renewal.

CBOD5, Ammonia, and DO are evaluated using WQM 7.0 (See Attachment 1). TRC is evaluated using the department's TRC evaluation spreadsheet (See Attachment 2).

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	4.0	Daily Min.	WQM 7.0
CBOD5	25	Average Monthly	WQM 7.0
	50	IMAX	
Ammonia Nitrogen (May 1 – Oct 31)	15.59	Average Monthly	WQM 7.0
	31.18	IMAX	
Ammonia Nitrogen (Nov 1 - Apr 30)	Report	Average Monthly	
TRC	0.5	Average Monthly	TRC evaluation spreadsheet

NPDES Permit Fact Sheet Pilot Travel Center 081

Comments: WQM 7.0 didn't calculate more stringent average monthly limits for Ammonia-Nitrogen. The calculated limits are equal to the limits established in the previous permit (15.59 mg/L rounded down to 15 mg/L). The current limits are attainable and will be retained.

The TRC evaluation spreadsheet didn't calculate more stringent average monthly TRC limit at perennial conditions using the plant design flow, the limits established in the previous permit are attainable and will be retained.

Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen effluent limit of a minimum of 4.0 mg/L, and monitoring for total nitrogen, total phosphorus and raw sewage influent monitoring for CBOD₅ and TSS are placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Anti-Backsliding

No backsliding of limits is being proposed.

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

			Effluent L	imitations.			Monitoring Re	quirements
Parameter	Mass Units	(lbs/day) (1)	Concentrations (mg/L)				Minimum ⁽²⁾	Required
Farameter	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	xxx	6.0 Inst Min	xxx	XXX	9.0	3/week	Grab
DO	xxx	xxx	4.0 Inst Min	xxx	xxx	xxx	3/week	Grab
TRC	xxx	XXX	xxx	0.5	xxx	1.6	3/week	Grab
CBOD5 Nov 1 - Apr 30	ХХХ	XXX	xxx	25.0	xxx	50	2/month	8-Hr Composite
CBOD5 May 1 - Oct 31	ХХХ	XXX	xxx	20.0	xxx	40	2/month	8-Hr Composite
TSS	XXX	XXX	xxx	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	ХХХ	XXX	xxx	2000 Geo Mean	xxx	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	xxx	1000	2/month	Grab
E. Coli (No./100 ml)	ххх	XXX	xxx	xxx	XXX	Report	1/quarter	Grab
Total Nitrogen	ххх	xxx	xxx	Report Avg Qrtly	xxx	ххх	1/quarter	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	xxx	XXX	xxx	15.0	XXX	30	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	xxx	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite


Compliance Sampling Location: Outfall 001, after disinfection.

Outfall Location - eMap with Aerial Imagery



Drainage Area Location at Outfall 001 – StreamStats with Aerial Imagery

StreamStats Report



Collapse All

Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	53	square miles

Attachment 1

	<u>SWP Basin</u> 20C	Stream Code 34081		<u>Stream Name</u> MUDDY CREE			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.740	Pilot Trvl 081	PA0222429	0.050	CBOD5	25		
				NH3-N	15.59	31.18	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.890	Cooper Lake	PA0239674	0.027	CBOD5	25		
				NH3-N	19.08	38.16	
				Dissolved Oxygen			4

WQM 7.0 Effluent Limits

Thursday, May 9, 2024

Version 1.1

20C	34081			MUDDY CREEK	
<u>RMI</u>	Total Discharge		<u>) Ana</u>	ysis Temperature (°C)	<u>Analysis pH</u>
3.740	0.05			24.810	7.842
Reach Width (ft)	Reach De	26 G.W.		Reach WDRatio	Reach Velocity (fps)
27.052	0.62 Deach Ke			43.075	0.120 Deceb Kn (1/dece)
Reach CBOD5 (mg/L)	Reach Kc 0.37		R	<u>each NH3-N (mg/L)</u> 0.69	<u>Reach Kn (1/days)</u> 1.014
2.87 Reach DO (mg/L)	Reach Kr (Kr Equation	Reach DO Goal (mg/L)
7.406	2.27			Tsivoglou	5
<u>Reach Travel Time (days)</u> 0.433	Tra∨Time (days)	Subreech CBOD5 (mg/L)	Results NH3-N (mg/L)	D.O. (mg/L)	
	0.043	2.82	0.66	7.29	
	0.087		0.63	7.19	
	0.130		0.60	7.11	
	0.173		0.58	7.04	
	0.216	2.60	0.55	6.98	
	0.260	2.54	0.53	6.94	
	0.303	2.49	0.51	6.90	
	0.346	2.44	0.48	6.88	
	0.390	2.39	0.46	6.86	
	0.433	2.35	0.44	6.85	
RMI	Total Discharge	Flow (mgd	<u>) Ana</u>	vsis Temperature (°C)	<u>Analysis pH</u>
2.890	0.07	7		24.714	7.836
Reach Width (ft)	<u>Reach De</u>	pth (ft)		<u>Reach WDRatio</u>	Reach Velocity (fps)
24.823	0.61			40.178	0.137
Reach CBOD5 (mg/L)	Reach Kc	-14A	<u>R</u>	each NH3-N (mg/L)	Reach Kn (1/days)
2.80	0.20 <u>Reach Kr (</u>			0.82 <u>Kr Equation</u>	1.006 <u>Reach DO Goal (mg/L</u>)
<u>Reach DO (mg/L)</u> 6.799	10.50	08/0 4/00		Tsivoglou	<u>1 (cach Do Goar (mg/L)</u> 5
Reach Travel Time (days)		~		-	
1.288	Tra∨Time (days)	Subreach CBOD5 (mg/L)	MH3-N (mg/L)	D.O. (mg/L)	
	0.129	2.71	0.72	7.54	
	0.258	2.62	0.63	7.54	
	0.386	2.54	0.56	7.54	
	0.515		0.49	7.54	
	0.644		0.43	7.54	
	0.773		0.38	7.54	
	0.902		0.33	7.54	
	1.030		0.29	7.54	
	1.159		0.26	7.54	
	1.288	2.01	0.22	7.54	

WQM 7.0 D.O.Simulation

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	-
WLA Method	EMPR	Use Inputted W/D Ratio	
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	✓
D.O. Saturation	90.00%	Use Balanced Technology	✓
D.O. Goal	5		

Thursday, May 9, 2024

Version 1.1

Page 1 of 1

	SWP Basin	Strea Coc		Stre	eam Name		RMI		evation (ft)	Drainag Area (sq m		Slope (ft/ft)	PWS Withdra (mga	awal	Apply FC
	20C	340	081 MUDE	Y CREE	<		3.74	40	1150.00	53	3.00 0.	.00000		0.00	✓
÷					St	ream Dat	a								
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Ten	<u>Tributar</u> 1p	У pH	Tem	<u>Stream</u> 1p	pН	
Cond.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	:)		(°C)		
Q7-10 Q1-10 Q30-10	0.037	0.00 0.00 0.00	0.00 0.00 0.00	0.000 0.000 0.000	0.000 0.000 0.000	0.0	0.00	0.0	00 2	5.00	8.00	i	0.00	0.00	
					Dı	scharge [Data								
			Name	Per	mit Number	Disc	Permitte Disc Flow (mgd)	Dis Flo	sc Res ow Fa	serve ictor	Disc Temp (°C)		sc iH		
		Pilot	Trvl 081	PA	0222429	0.0500	0.000)0 0.0	0000	0.000	20.0	00	6.90		
					P.	irameter [Jaca								
				Paramete	r Name	Di Co		Frib Conc	Stream Conc	Fate Coef					
	_					(m	g/L) (n	ng/L)	(mg/L)	(1/days	5)				
			CBOD5			:	25.00	2.00	0.00	1.5	50				
			Dissolved	Oxygen			4.00	7.54	0.00	0.0	00				
			NH3-N			:	25.00	0.10	0.00	0.7	70				

Input Data WQM 7.0

Input Data WQM 7.0

	SWP Basir			Stre	eam Name		RMI	Ele	evation (ft)	Drainage Area (sq mi)	Sloj (ft/1	Wi	PWS thdrawal (mgd)	Apply FC
	20C	340	081 MUDE	Y CREE	<		2.8	90	1142.00	53.40	0.00	0000	0.00	✓
					St	ream Dat	ta							
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	n Tem	<u>Tributary</u> np pH		<u>Stre</u> Temp	<u>eam</u> pH	
oona.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	;)		(°C)		
Q7-10 Q1-10 Q30-10	0.037	0.00 0.00 0.00		0.000 0.000 0.000	0.000	0.0	0.00	0.0	00 2	5.00 8	00	0.00	0.00	2
					D	scharge	Data							
			Name	Per	rmit Numbe	Existing Disc	Permitt Disc Flow (mgd	Dis Flo	sc Res ow Fa	Di serve Tel ctor (°	mp	Disc pH		
		Coop	er Lake	PA	0239674	0.027	5 0.00	0. 00	0000	0.000	20.00	7.6	0	
					Р	ara m eter	Data							
			i	Paramete	r Name	С	onc (Trib Conc mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	=		CBOD5				25.00	2.00	0.00					
			Dissolved	Oxygen			4.00	7.54	0.00	0.00				
			NH3-N				25.00	0.10	0.00	0.70				

Input	Data	WQM	7.0
mpac	- ucu		

	SWP Basin	Strea Coo		Stre	eam Name		RMI		vation (ft)	Drainage Area (sq mi)		ope t/ft)	PW: Withdra (mg)	awal	Apply FC
	20C	340	081 MUDE	Y CREE	ĸ		0.0	10	1032.00	58.3	30 0.0	00000		0.00	✓
					St	ream Dat	a								
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tem	<u>Tributary</u> p p	н	Tem	<u>Stream</u> p	pН	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)			
Q7-10 Q1-10	0.037	0.00 0.00	0.00 0.00	0.000 0.000	0.000 0.000	0.0	0.00	0.0	00 2	5.00	8.00	0	0.00	0.00	
Q30-10		0.00	0.00	0.000	0.000										
					Dı	scharge	Data								
			Name	Per	mit Number	Existing Disc Flow (mgd)	Permit Disc Flow (mgd	Flo	sc Res w Fa	erve T ctor	Disc ēmp (°C)	Dis pł			
		-				0.000	0 0.00	00 0.0	0000	0.000	25.00	D	7.00		
					P,	ram eter	Data								
				Paramete	r Nomo			Trib Conc	Stream Conc	Fate Coef					
				-aramete	INdiffe	(m	ig/L) (mg/L)	(mg/L)	(1/days)					
			CBOD5				25.00	2.00	0.00	1.50					
			Dissolved	Oxygen			3.00	8.24	0.00	0.00					
			NH3-N				25.00	0.00	0.00	0.70					

		am Code		St	<u>ream Name</u>		
	20C	34081		MU	DDY CREEK		
NH3-N	Acute Allocatio	ns					
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reductior
3.7	40 Pilot Trvl 081	3.98	50	3.98	50	0	0
2.8	90 Cooper Lake	2.72	50	4.06	50	0	0
NH3-N	Chronic Allocat	ions					
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.7	40 Pilot Trvl 081	.67	20.43	.67	15.59	2	24
2.8	90 Cooper Lake	.57	25	.68	19.08	2	24

Dissolved Oxygen Critical Percent CBOD5 <u>NH3-N</u> RMI Discharge Name Baseline Multiple Baseline Multiple Baseline Multiple Reach Reduction (mg/L) (mg/L) (mg/L) (mg/L) (mg/L) (mg/L) 3.74 Pilot Trvl 081 25 25 15.59 15.59 4 4 0 0 4 0 2.89 Cooper Lake 25 25 19.08 19.08 4 0

Thursday, May 9, 2024

Version 1.1

	SW	P Basin	Strea	m Code				Stream	Name			
		20C		4081				IUDDY (
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Tra∨ Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-1	0 Flow											
3.740	1.96	0.00	1.96	.0773	0.00178	.628	27.05	43.08	0.12	0.433	24.81	7.84
2.890	1.98	0.00	1.98	.1199	0.00723	.618	24.82	40.18	0.14	1.288	24.71	7.84
Q1-1	0 Flow											
3.740	1.26	0.00	1.26	.0773	0.00178	NA	NA	NA	0.09	0.549	24.71	7.78
2.890	1.26	0.00	1.26	.1199	0.00723	NA	NA	NA	0.11	1.625	24.57	7.77
Q30-'	10 Flow											
3.740	2.67	0.00	2.67	.0773	0.00178	NA	NA	NA	0.14	0.367	24.86	7.88
2.890	2.69	0.00	2.69	.1199	0.00723	NA	NA	NA	0.16	1.094	24.79	7.87

WQM 7.0 Hydrodynamic Outputs

Version 1.1

Page 1 of 1

Attachment 2

Input appropria									
		3:A9 and D3:D9							
Guinta Dyuddu viz	= Q stream (c		Institution In	= CV Daily					
	5 = Q discharge		0.5 = CV Hourly						
5.0453	= no. samples			= AFC_Partial Mix Factor					
		mand of Stream		1 = CFC_Partial Mix Factor					
10	All and a second s	mand of Discharge			Compliance Time (min)				
	5 = BAT/BPJ Va		720 = CFC_Criteria Compliance Time (m						
(= % Factor of		0	=Decay Coeffic					
Source	Reference	AFC Calculations		Reference	CFC Calculations				
TRC	1.3.2.iii	WLA afc =	ACCOL DIMENSION	1.3.2.iii	WLA cfc = 7.896				
PENTOXSD TRG	5.1a	LTAMULT afc =		5.1c	LTAMULT cfc = 0.581				
PENTOXSD TRG	5.1b	LTA_afc= 3.021 5.1d LTA_cfc = 4							
Source		Efflue	nt Limit Calcul	ations					
PENTOXSD TRG	5.1f		AML MULT =	1.231					
PENTOXSD TRG	5.1g	AVG MON	LIMIT (mg/l) =	0.500	BAT/BPJ				
			LIMIT (mg/l) =	1.000					
	(.019/e(-k*AF)	C_tc)) + [(AFC_Yc*Qs*.019							
WLA atc	NEWLARK ADVANCESSION SOULD FILM	second se	Manual Action and the American Plants 2000	_tc))					
	+ Xd + (AFC	_Yc*Qs*Xs/Qd)]*(1-FOS/10	0)	_tc))					
LTAMULT afc	+Xd+(AFC EXP((0.5*LN(d	_ Yc*Qs*Xs/Qd)]*(1-FOS/10 wh^2+1))-2.326*LN(cvh^2-	0)	_tc)}					
WLA afc LTAMULT afc LTA_afc	+ Xd + (AFC	_ Yc*Qs*Xs/Qd)]*(1-FOS/10 wh^2+1))-2.326*LN(cvh^2-	0)	_tc))					
LTAMULT afc LTA_afc	+ Xd + (AFC EXP((0.5*LN(c wla_afc*LTAM (.011/e(-k*CF	_Yc*Qs*Xs/Qd)]*(1-FOS/10 vh^2+1))-2.326*LN(cvh^2- IULT_afc C_tc) + [(CFC_Yc*Qs*.011)	90) +1)^0.5) /Qd*e(-k*CFC_						
LTAMULT afc LTA_afc WLA_cfc	+Xd + (AFC EXP((0.5*LN(c wla_afc*LTAM (.011/e(-k*CF +Xd + (CFC	_ Yc*Qs*Xs/Qd)]*(1-FOS/10 wh^2+1))-2.326*LN(cvh^2- IULT_afc	00) +1)^0.5) /Qd*e(-k*CFC_ 00)	_tc))	0.5)				
LTAMULT afc	+Xd + (AFC EXP((0.5*LN(c wla_afc*LTAM (.011/e(-k*CF +Xd + (CFC	_Yc*Qs*Xs/Qd)]*(1-FOS/10 wh^2+1))-2.326*LN(cvh^2- IULT_afc C_tc) + [(CFC_Yc*Qs*.011/ _Yc*Qs*Xs/Qd)]*(1-FOS/10 wd^2/no_samples+1))-2.32	00) +1)^0.5) /Qd*e(-k*CFC_ 00)	_tc))).5)				
LTAMULT afc LTA_afc WLA_cfc LTAMULT_cfc	+Xd + (AFC EXP((0.5*LN(c wla_afc*LTAN (.011/e(-k*CF +Xd + (CFC EXP((0.5*LN(c wla_cfc*LTAN	_Yc*Qs*Xs/Qd)]*(1-FOS/10 wh^2+1))-2.326*LN(cvh^2- IULT_afc C_tc) + [(CFC_Yc*Qs*.011/ _Yc*Qs*Xs/Qd)]*(1-FOS/10 wd^2/no_samples+1))-2.32	90) +1)^0.5) /Qd*e(-k*CFC_)0) 6*LN(cvd^2/n	_ tc)) o_samples+1)^(
LTAMULT afc LTA_afc WLA_cfc LTAMULT_cfc LTA_cfc	+Xd + (AFC EXP((0.5*LN(c wla_afc*LTAN (.011/e(-k*CF +Xd + (CFC EXP((0.5*LN(c wla_cfc*LTAN EXP(2.326*LN	_Yc*Qs*Xs/Qd)]*(1-FOS/10 wh^2+1))-2.326*LN(cvh^2- IULT_afc C_tc) + [(CFC_Yc*Qs*.011/ _Yc*Qs*Xs/Qd)]*(1-FOS/10 wd^2/no_samples+1))-2.32	90) +1)^0.5) /Qd*e(-k*CFC_)0) :6*LN(cvd^2/n 5)-0.5*LN(cvd	_ tc)) o_samples+1)^(