

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0222496
APS ID 970520
Authorization ID 1233015

Applicant and Facility Information

Applicant Name	<u>Summerville Borough Municipal Authority</u>	Facility Name	<u>Summerville Borough STP</u>
Applicant Address	<u>PO Box 278</u> <u>Summerville, PA 15864-0278</u>	Facility Address	<u>Anderson Drive</u> <u>Summerville, PA 15864-0278</u>
Applicant Contact	<u>Howard Johnson</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 856-3210</u> <u>sbma@windstream.net</u>	Facility Phone	<u></u>
Client ID	<u>33297</u>	Site ID	<u>543483</u>
Municipality	<u>Summerville Borough</u>	County	<u>Jefferson</u>
Ch 94 Load Status	No overloaded	Connection Status	No requirements
Application Received	<u>May 31, 2018</u>	EPA Waived?	<u>Yes</u>
Application Accepted	<u>June 27, 2018</u>	If No, Reason	<u></u>
Purpose of Application	<u>MPDES discharge permit renewal</u>		

Summary of Review

No current violations filed.

Added is Influent and effluent ammonia twice a month monitoring with a minimum daily effluent DO at 4.0-mg/L.

The certified operator is Chuck Ishman, G Force engineering, 1630 Philadelphia Street, Unit 40, Indiana, Pa 15701.

One industrial user (brick maker).

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		William H. Mentzer, P.E. Environmental Engineering Specialist	April 15, 2019
X		Justin C. Dickey, P.E. Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.09
Latitude NHD	41° 7' 2.53"	Longitude NHD	-79° 11' 46.95"
Latitude DP	41° 7' 2.30"	Longitude DP	-79° 11' 47.77"
Quad Name	Summerville	Quad Code	1012
Wastewater:	Treated municipal sanitary sewer wastes		
Receiving Waters	Runaway Run	Stream Code	48477
NHD Com ID	123863567	RMI	0.1000
Drainage Area	3.5	Yield (cfs/mi ²)	0.061
Q ₇₋₁₀ Flow (cfs)	0.2	Q ₇₋₁₀ Basis	Redbank Creek@St Charles
Elevation (ft)	1159.67	Slope (ft/ft)	0.0013
Watershed No.	17-C	Chapter 93 Class.	CWF
Existing Use	statewide	Existing Use Qualifier	none
Exceptions to Use	none	Exceptions to Criteria	none
Comments	Runaway Run discharges to Redbank Creek at RMI 39.76. Confluence Elevation is 1152.34 ft and the basin drainage is 361.16 square miles		
Assessment Status	Impaired		
Impairment Causes	Metals, pH		
Impairment Sources	Acid Mine Drainage		
TMDL Status	pending	Name	Runaway Run
Background/Ambient Data		Data Source (secondary source 2009 Redbank TMDL)	
pH (SU)	4.00	Rte 28 Bridge over Runaway Run on February 4, 1998	
temperature (°C)	20	Assumed (CWF)	
total alkalinity	0 (2.0 in 2009)	Rte 28 Bridge over Runaway Run on February 4, 1998	
total calcium	104	Rte 28 Bridge over Runaway Run on February 4, 1998	
magnesium	50.1	Rte 28 Bridge over Runaway Run on February 4, 1998	
iron 01045A	7.16 (3.37 in 2009)	Rte 28 Bridge over Runaway Run on February 4, 1998	
manganese 01055A	8.08 (10.43 in 2009)	Rte 28 Bridge over Runaway Run on February 4, 1998	
aluminum 01105A	3.23	Rte 28 Bridge over Runaway Run on February 4, 1998	
total acidity hot	50 (57.05 in 2009)	Rte 28 Bridge over Runaway Run on February 4, 1998	
hardness (mg/L)	413	Rte 28 Bridge over Runaway Run on February 4, 1998	
specific conductance	820	Rte 28 Bridge over Runaway Run on February 4, 1998	
Other: BOD	1.8	WQN 820 (in 1993 for Redbank Creek)	
pH (SU)	6.73	WQN 820 (in 1993 for Redbank Creek)	
Other: BOD	1.8	WQN 820 (in 1993 for Redbank Creek)	
Nearest Downstream Public Water Supply Intake	Hawthorn Water Company		
PWS Waters	Redbank Creek	Flow at Intake (cfs)	
PWS RMI	28.04	Distance from Outfall (mi)	11.82

Changes Since Last Permit Issuance: none

Other Comments: none

Treatment Facility Summary					
Treatment Facility Name: Summerville Borough STP					
WQM Permit	Notarization	Application	Received	Amendment	Issuance
No	Date	Date	Date	No.	Date
3398402	Feb 12, 1998	Jan 23, 1998	Jan 26, 1998		6 Apr 1998
3398402	Dec 26, 2000		Jan 4, 2001	A1	6 Feb 2001
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)	
Sewage	secondary	SBR	UV	0.090	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal	
0.090	158	no requirements	Aerated holding	landfill	

Changes Since Last Permit Issuance: none

The design load rounded to the nearest 5-pounds is 160-PPD.

NPDES Permit

Design effluent: 25-mg/l 5 day-BOD, 30-mg/L TSS, and 3-mg/L ammonia. The original NPDES permit was for a Redbank Creek discharge. When built a Runaway Creek outfall was installed. WQPR has used Runaway Run as the receiving waters since 1998.

Planning

The official sewerage plan approval is dated December 2000 to address collection system changes later addressed on WQM permit amendment 1.

Changes Since Last Permit Issuance: None

Other Comments:

Treatment is with a two basin ICEAS sequencing batch reactor with UV light disinfection

WQM Amendment 1

Application dated November 15, 1999 and revised January 4, 2001. Permit for modifications, sewers and pump stations.

With 1996 Sewerage Conditions 1, 2, 3, 4, 5, 6, 7, 9, 12, 13, 14, 16, 17, 18, 20, 21, and 22; 1991 erosion control all; and Special Condition 1 holding Dan B. Slagle responsible for design. No treatment plant changes were proposed.

Pump station mean flow remained at 0.090-MGD based on 672 people and 259 EDU. Wetwell capacity was increased to 1269-gallon and 20-minute retention at 0.090-MGD using 200-gpm submersible pumps. The wet well 10-inch inlet has a coarse screen basket and the 6-inch force main prior to the treatment facility has a fine screen basket. The force main has diameter been increased from 4 to 6-inch.

A 60-kw generator is provided for emergency treatment operation.

WQM Permit

Permit for sanitary sewage collection and treatment.

With 1996 Sewerage Conditions 1, 2, 3, 4, 5, 6, 7, 8, 9, 19, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, and 22; 1991 erosion control all; and Special Condition 1 holding Dan B. Slagle responsible for design.

Design for 244 connections totaling 359 EDU and a 900 (673 people) person design population.

Treatment is a Sanitaire/ABJ (intermittent cycle extending aeration system [ICEAS]) sequencing batch reactor. {ICEAS is a continuous flow single basin system.}

Trojan UV light disinfection.

23 000-gallon aerated sludge holding tank with 18 to 30-day retention.

Sludge production is 1 274-gpd at 0.85 to 1.37 per cent solids

VSS loading is 21 PPD/100 cubic foot based on 90-PPD sludge and 70% volatile solids.

Domestic		861	people										
Industrial		39	people										
Total		900	people										
Year		2007				revised to				2012			
Runoff		24	hours										
Domestic	100	gpcd	0.090	MGD									
Maximum	Domestic		0.225	MGD									
Total Design	Average		0.090	MGD									
	Maximum monthly		0.169	MGD									
	Peak Hourly		0.225	MGD									
	Instantaneous		0.225	MGD									
Pump Station	submersible												
	duplex	160	gpm	or 230400-gpd		revised to				200-gpm		288000-gpd	
Outfall			8 inch	diameter									

Parameter	Year	Month	Mean MGD	Influent				#	Min	Effluent		#
				Mean	Max	Mean	Max			Mean	Max	
Annual Average Flow	Design		0.090									
Hydraulic Design Capacity			0.090									
Organic Design Capacity				158								
Annual Average	2017		0.0370									
	2016		0.0236									
	2015		0.0260									
Highest Monthly Average Flow		November	0.0900									
pH									6.85		7.03	208
TRC												
BOD5				36	44	195	201	24				
CBOD5									< 2	6.4	16.5	48
TSS				55	64	302	296	24	< 5	12.35	25	48
Nitrogen						17.5	21.3	24		80.07		
Phosphorus						0.14	0.35	24		> 0.97		
Fecal Coliform						< 10	< 0	24	< 10	5312.98	40469	48
UV Intensity									4.94			730

UV Intensity is in $\mu\text{w}/\text{sq-cm}$.

Nitrogen and phosphorus data is not consistent with other effluent data.

Chemical Use:

Hydrated lime for pH adjustment
Sludge production and disposal

304 dry tons sludge removed.

No outside sludge sources reported.

Sludge disposal sites reported were Punxsutawney Sewage (PA0020346 and Greentree Landfill (PA101397)

All sludge is landfill disposed.

Included is a 26R report for Glen-Gary Corporation, Hanley Plant. A 1 596 080-gallon waste source with a 7 to 8-SU pH is reported. 1 642 884-gallons were shipped the previous year.

The industrial waste flow is approximately 4373-gpd or 5% of the design flow.

2017 WLMR

Population 530

1 industrial user – Glen-Gery Corporation (brick maker)

Water and Creek Street Pump Station

Capacity 200-gpm

304-tons wet sludge removed to Greentree Landfill.

	Flow	Organic
Annual Average	0.037	41
Max Mon Ave	0.09	58
Max 3 Mon Ave	0.06	NA

No projected overloads

Compliance History

DMR Data for Outfall 001 (from March 1, 2018 to February 28, 2019)

Parameter	FEB-19	JAN-19	DEC-18	NOV-18	OCT-18	SEP-18	AUG-18	JUL-18	JUN-18	MAY-18	APR-18	MAR-18
Flow (MGD) Average Monthly	0.05	0.036	0.033	0.046	0.034	0.045	0.022	0.019	0.02	0.048	0.069	0.060
pH (S.U.) Minimum	6.5	6.4	6.6	6.5	6.2-	6.8	6.9	6.9	7.0	6.9	6.7	6.7
pH (S.U.) Maximum	6.9	6.9	7.0	6.9	7.1	7.2	7.2	7.3	7.4	7.5	7.2	6.9
CBOD5 (ppd) Ave Monthly	4	2	2	2	1	0.6	< 0.5	0.7	0.8	< 0.8	< 1	< 1
CBOD5 (ppd) Weekly Average	5	3	3	2	2	0.8	0.7	14	1.0	< 0.8	2	1
CBOD5 (mg/L) Average Monthly	8	11	8	5	6	2	< 3	4	5	< 2	< 2	< 2
CBOD5 (mg/L) Weekly Average	12	18	11	5	10	2	4	5	8	< 2	2	3
TSS (lbs/day) Average Monthly	8	< 5	4	7	3	< 2	2	< 2	3	2	< 4	2
TSS (lbs/day) Weekly Average	9	10	6	10	3	2	2	3	3	3	4	2
TSS (mg/L) Average Monthly	17	< 24	17	18	15	< 11	11	< 11	16	6	< 6	5
TSS (mg/L) Weekly Average	20	23.7	25	22	18	16	14	16	18	7	6	5
Fecal Coliform (#/100 ml) Geometric Mean	748	< 88	108	< 10	< 19	175	< 10	< 45	< 184	< 10	< 10	50
Fecal Coliform (#/100 ml) Instant Maximum	748	775	108	< 10	36	192	< 10	207	5091	< 10	< 10	57
UV Intensity (µw/cm²) Average Monthly	7.8	6.5	2.2	2.5	2.3	2.1	2	2.1	2.1	1.9	2.1	2.1
Total Nitrogen (mg/L) Average Monthly	12.2	17.6	15.1	11.5	15.8	11.38	7.08	16.66	30.5	10.22	9.17	7.72
Total Phosphorus (mg/L) Average Monthly	0.39	3.04	0.71	0.386	0.83	0.5	0.38	0.41	0.18	< 0.11	0.16	< 0.13

Summer median 7.1-SU annual median 6.9-SU

No Ammonia monitoring requirements in the NPDES permit.

Compliance History

Effluent Violations for Outfall 001, from: April 1, 2018 to: February 28, 2019

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	06/30/18	IMAX	5091	CFU/100 ml	1000	CFU/100 ml

Summary of Inspections: Last inspected October 27, 2016 with one SBR down for repair (actuator broke) and its replacement on order.

Other Comments: Last inspection was in 2016

Permit No. PA0222496

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.09</u>
Latitude <u>41° 7' 2.30"</u>	Longitude <u>-79° 11' 47.77"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4-mg/L	Daily minimum	BPJ	

Comments: Proposed is the 4.0-mg/L minimum daily BPJ DO requirement

Water Quality-Based Limitations

The receiving waters are abandoned mine drainage impacted without any water-quality based requirements. The basic TMDL for Redbank Creek is dated June 9, 2009 with a specific Runaway Run TMDL scheduled for 2015.

The Redbank Creek TMDL allows for further mining activities in the Runaway Run basin. The local public water supply, Hawthorne Water Company is listed in the Redbank Creek TMDL while the Summerville STP is not listed.

Based on sanitary sewage collection system as the waste source, reasonable potential use implies BOD, or CBOD, RSS, ammonia and DO requirements. As the receiving waters are mine drainage impaired no water quality limitations are presently proposed.

With stream recovery (attaining designated uses) the stream pH should approximate 6.5-SU as a default value while the background total aluminum, iron, and manganese ambient quality should fall to near zero. With stream recovery a 4.0-mg/L minimum daily DO and a 5/5-mg/L summer ammonia limitations are recommended. The annual current discharge pH median is 6.9-SU with a 7.1-SU summer median.

The following limitations were determined through water quality modeling (output files attached):

Discharge pH	Parameter	Limit			SBC	Model		
		Minimum	Mean	Maximum		Minimum	Mean	Maximum
		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
6.9	Ammonia		5.5	10.0			5.2	10.3
	DO	4.0				4.0		

Best Professional Judgment (BPJ) Limitations

Comments: the 4-mg/L DO limit is considered BPJ.

Anti-Backsliding

Not necessary

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
DO	XXX	XXXX	4.0	XXX	XXX	XXX	1/day	Grab
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
CBOD5	19	30	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	23	34	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
UV Intensity (µw/cm ²)	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection.