

Application Type	Renewal
Facility Type	Municipal
Major / Minor	Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No.	PA0222496
APS ID	1118656
Authorization ID	1493707

Applicant and Facility Information

Applicant Name	Summerville Borough Municipal Authority	Facility Name	Summerville Borough STP
Applicant Address	PO Box 278	Facility Address	Anderson Drive
	Summerville, PA 15864-0278		Summerville, PA 15864-0278
Applicant Contact	Howard Johnson	Facility Contact	Andy Wonderling
Applicant Phone	(814) 856-3210	Facility Phone	(814) 856-3210
Client ID	33297	Site ID	543483
Ch 94 Load Status	Not Overloaded	Municipality	Summerville Borough
Connection Status	No Limitations	County	Jefferson
Date Application Received	July 29, 2024	EPA Waived?	Yes
Date Application Accepted	July 29, 2024	If No, Reason	
Purpose of Application	NPDES Permit Renewal.		

Summary of Review

Summerville Borough Municipal Authority (SBMA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on January 22, 2020, and became effective on February 1, 2020. The permit expired on January 31, 2025, but the terms and conditions have been extended since that time.

Based on the review, it is recommended that the permit be drafted.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jinsu Kim Jinsu Kim / Environmental Engineering Specialist	September 4, 2025
X		Adam Olesnak Adam Olesnak, P.E. / Environmental Engineer Manager	September 4, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.09
Latitude	41° 7' 2.30"	Longitude DP	-79° 11' 47.77"
Quad Name	Summerville	Quad Code	1012
Wastewater Description: Sewage Effluent			
Receiving Waters	Runaway Run	Stream Code	48477
NHD Com ID	123863567	RMI	0.1000
Drainage Area	3.5	Yield (cfs/mi ²)	0.061
Q ₇₋₁₀ Flow (cfs)	0.2	Q ₇₋₁₀ Basis	Redbank Creek@St Charles
Elevation (ft)	1159.67	Slope (ft/ft)	0.0013
Watershed No.	17-C	Chapter 93 Class.	CWF
Existing Use	statewide	Existing Use Qualifier	none
Exceptions to Use	none	Exceptions to Criteria	none
Assessment Status	Impaired		
Cause(s) of Impairment	METALS, PH		
Source(s) of Impairment	ACID MINE DRAINAGE, ACID MINE DRAINAGE		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Hawthorn Water Company		
PWS Waters	Redbank Creek	Flow at Intake (cfs)	
PWS RMI	28.04	Distance from Outfall (mi)	11.82

Comments: The discharge is to Runaway Run at RMI 0.1. A drainage area upstream of the discharge point is estimated to be 3.5 sq.mi according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>. DEP's latest Integrated Water Quality Report finalized in 2024 indicates that Runaway Run is impaired for pH and metals as a result of acid mine drainage. A Total Maximum Daily Load (TMDL) has not been developed to address these impairments; therefore, no TMDL has been taken into consideration at this time. The fact sheet developed for the last permit renewal indicates that the nearest downstream water supply intake is Hawthorn Water Company located on Redbank Creek approximately 11 miles from the discharge point. Given the nature of discharge and distance, the discharge is not expected to adversely impact the water supply.

Treatment Facility Summary																																																																																															
Treatment Facility Name: Summerville Borough STP																																																																																															
WQM Permit No.	Issuance Date																																																																																														
3398402	02/15/2001																																																																																														
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)																																																																																											
Sewage	Secondary	Sequencing Batch Reactor	Ultraviolet	0.09																																																																																											
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal																																																																																											
0.09	160	Not Overloaded	Aerobic Digestion	Landfill																																																																																											
<p>Comments: SBMA operates a municipal wastewater treatment facility designed to treated 0.09 MGD of wastewater generated from Summerville Borough (100%). This facility is a Sequencing Batch Reactor (SBR) activated sludge treatment facility consisting of two (2) SBR tanks, UV disinfection, and outfall structure. An aerobic digester is available for sludge treatment processing. Any solids generated from this facility is removed by a sludge hauling company for disposal at a landfill. SBMA also receives industrial wastewater from one industrial business known as Glen-Gery Corporation Hanley Plant. (brick making company).</p>																																																																																															
Compliance History																																																																																															
Summary of DMRs:	A summary of past 12 month DMR data is presented on the next page.																																																																																														
Summary of Inspections:	11/03/2021: DEP conducted a routine inspection and noted that no significant violations were identified at the time of inspection.																																																																																														
Other Comments:	Since the last permit reissuance, the facility had a number of permit violations; these violations were as follows:																																																																																														
<table border="1"> <thead> <tr> <th>Date</th><th>Description</th><th>Parameters</th><th>Results</th><th>Limits</th><th>Units</th><th>SBC</th></tr> </thead> <tbody> <tr> <td>Jan-20</td><td>Other</td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Jan-20</td><td>Violation of permit condition</td><td>Total Suspended Solids</td><td>32</td><td>30 mg/L</td><td>Average Monthly</td><td></td></tr> <tr> <td>Jun-21</td><td>Violation of permit condition</td><td>Total Suspended Solids</td><td>32</td><td>30 mg/L</td><td>Average Monthly</td><td></td></tr> <tr> <td>May-21</td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Jan-23</td><td>Late DMR Submission</td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Jun-23</td><td>Other</td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Jun-23</td><td>Violation of permit condition</td><td>Total Suspended Solids</td><td>32</td><td>30 mg/L</td><td>Average Monthly</td><td></td></tr> <tr> <td>Oct-23</td><td>Late DMR Submission</td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Feb-25</td><td>Violation of permit condition</td><td>Carbonaceous Biochemical Oxygen Demand (CBOD5)</td><td>26</td><td>25 mg/L</td><td>Average Monthly</td><td></td></tr> <tr> <td>Feb-25</td><td>Violation of permit condition</td><td>Carbonaceous Biochemical Oxygen Demand (CBOD5)</td><td>49</td><td>40 mg/L</td><td>Weekly Average</td><td></td></tr> <tr> <td>Aug-25</td><td>Violation of permit condition</td><td>Total Suspended Solids</td><td>51</td><td>30 mg/L</td><td>Average Monthly</td><td></td></tr> <tr> <td>Aug-25</td><td>Violation of permit condition</td><td>Total Suspended Solids</td><td>72</td><td>45 mg/L</td><td>Weekly Average</td><td></td></tr> </tbody> </table> <p>DEP's database shows there are no open violations identified by PADEP NWRO Clean Water Program.</p>					Date	Description	Parameters	Results	Limits	Units	SBC	Jan-20	Other						Jan-20	Violation of permit condition	Total Suspended Solids	32	30 mg/L	Average Monthly		Jun-21	Violation of permit condition	Total Suspended Solids	32	30 mg/L	Average Monthly		May-21							Jan-23	Late DMR Submission						Jun-23	Other						Jun-23	Violation of permit condition	Total Suspended Solids	32	30 mg/L	Average Monthly		Oct-23	Late DMR Submission						Feb-25	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	26	25 mg/L	Average Monthly		Feb-25	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	49	40 mg/L	Weekly Average		Aug-25	Violation of permit condition	Total Suspended Solids	51	30 mg/L	Average Monthly		Aug-25	Violation of permit condition	Total Suspended Solids	72	45 mg/L	Weekly Average	
Date	Description	Parameters	Results	Limits	Units	SBC																																																																																									
Jan-20	Other																																																																																														
Jan-20	Violation of permit condition	Total Suspended Solids	32	30 mg/L	Average Monthly																																																																																										
Jun-21	Violation of permit condition	Total Suspended Solids	32	30 mg/L	Average Monthly																																																																																										
May-21																																																																																															
Jan-23	Late DMR Submission																																																																																														
Jun-23	Other																																																																																														
Jun-23	Violation of permit condition	Total Suspended Solids	32	30 mg/L	Average Monthly																																																																																										
Oct-23	Late DMR Submission																																																																																														
Feb-25	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	26	25 mg/L	Average Monthly																																																																																										
Feb-25	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	49	40 mg/L	Weekly Average																																																																																										
Aug-25	Violation of permit condition	Total Suspended Solids	51	30 mg/L	Average Monthly																																																																																										
Aug-25	Violation of permit condition	Total Suspended Solids	72	45 mg/L	Weekly Average																																																																																										

Effluent Data

DMR Data for Outfall 001 (from July 1, 2024 to June 30, 2025)

Parameter	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24
Flow (MGD) Average Monthly	0.37	0.039	0.043	0.039	0.057	0.049	0.039	0.032	0.027	0.028	0.025	0.023
pH (S.U.) Minimum	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.5	6.7
pH (S.U.) Maximum	6.8	6.8	6.8	6.7	6.8	6.7	6.7	6.7	6.8	6.6	6.7	6.8
DO (mg/L) Daily Minimum	5.08	4.95	5.1	5.42	5.26	5.09	5.42	5.75	5.87	5.85	5.71	5.35
CBOD5 (lbs/day) Average Monthly	2	5	6	3	6	10	5	1	1	1	< 0.5	1
CBOD5 (lbs/day) Weekly Average	2	8	6	3	7	20	6	1	1	2	< 0.5	1
CBOD5 (mg/L) Average Monthly	9	23	18	9	14	26	13	5	4	7	< 2	7
CBOD5 (mg/L) Weekly Average	12	36	22	9	14	49	18	5	5	9	< 2	8
BOD5 (mg/L) Raw Sewage Influent Average Monthly	157	151	1070	75	168	185	123	87	221	133	218	170
TSS (lbs/day) Average Monthly	6	3	3	4	5	6	6	4	1	3	3	< 1
TSS (lbs/day) Weekly Average	7	3	3	5	5	9	9	4	1	4	5	2
TSS (mg/L) Average Monthly	28	12	9	11	10	18	14	16	6	14	13	< 8
TSS (mg/L) Raw Sewage Influent Average Monthly	562	180	85	76	284	268	152	94	384	176	110	352
TSS (mg/L) Weekly Average	29	13	11	14	12	26	14	16	6	18	19	10
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	129	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	< 1	< 1	158	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10
UV Intensity (μw/cm ²) Average Monthly	5.9	6	6.1	6.8	6.5	7.6	8.3	9.7	10.3	10.1	10.8	11.2

NPDES Permit Fact Sheet
Summerville Borough STP

NPDES Permit No. PA0222496

Parameter	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24
Total Nitrogen (mg/L) Average Quarterly	21.5			13.1			12.34			21.26		
Ammonia (mg/L) Average Quarterly	19.6			12.6			18.04			2.87		
Total Phosphorus (mg/L) Average Quarterly	0.86			2.94			0.79			0.66		

Existing Effluent Limits and Monitoring Requirements

A table below summarizes effluent limits and monitoring requirements specified in the current NPDES permit.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
Dissolved Oxygen (DO)	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	19	30	XXX	25	40	50	2/month	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab 8-Hr
Total Suspended Solids	23	34	XXX	30	45	60	2/month	Composite
Total Suspended Solids Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ultraviolet light intensity (μ w/cm ²)	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured 8-Hr
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Composite
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.09	
Latitude	41° 7' 2.30"	Longitude	-79° 11' 47.77"	
Wastewater Description:	Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Since the facility utilizes UV disinfection TRC effluent standards are not applicable.

Water Quality-Based Limitations

CBOD5, NH3-N and Dissolved Oxygen (DO)

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's technical guidance no. 391-2000-007 describes the technical methods contained in the model for conducting wasteload allocation analyses and for determining recommended limits for point source discharges. DEP recently updated this model (ver. 1.1) to include new ammonia criteria that has been approved by US EPA as part of the 2017 Triennial Review. The model output indicates WQBELs for Ammonia-Nitrogen are required, and all other existing limits are still appropriate. The fact sheet developed for the last permit renewal also had the same results but for some reason, effluent limits were not included in the permit, but the permit instead included a quarterly monitoring requirement. It appears it was unintentionally excluded from the permit as there is no justification mentioned in the fact sheet as to why only monitoring requirement was included in the permit. It is recommended to include these limits as summer limits and a monthly sampling requirement is recommended for ammonia-nitrogen. For winter, effluent limits are developed using a multiplier of 3.0 based on DEP's technical guidance no. 391-2000-003. The instantaneous maximum effluent limits are developed using a multiplier of 2.0 based on DEP's technical guidance no. 391-2000-013. Imposing these effluent limits is supported by DEP's SOP no. BCW-PMT-033. The data reported in the DMR shows high effluent concentrations of ammonia-nitrogen; yet, these data are quarterly data; therefore it is unclear if the facility is able to achieve compliance with these limits.

Toxics

The application submitted for this permit renewal did not require sampling of toxics pollutants.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

A minimum of 4.0 mg/L for DO is an existing effluent limit and will remain unchanged in the permit to ensure that the facility continues to protect all aquatic life. This approach is consistent with DEP's SOP no. BPNPSM-PMT-033.

Additional Considerations

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Influent BOD & TSS Monitoring

As a result of negotiation with EPA, the existing influent monitoring reporting requirement for TSS and BOD5 will be maintained in the draft permit. This requirement has been consistently assigned to all municipal wastewater treatment facilities.

E. Coli Monitoring Requirement

DEP's SOP no. BPNPSM-PMT-033 recommends a quarterly routine monitoring of E. Coli for all sewage facilities that have design flow less than 0.1 MGD but greater than 0.05 MGD. A quarterly monitoring for E. Coli will therefore be included in the permit.

Ultraviolet Output Monitoring

DEP's SOP no. BPNPSM-PMT-033 recommends a routine monitoring of UV output when the UV system is used for disinfection in lieu of chlorine. Therefore, a continuation of UV disinfection output monitoring is recommended.

Total Nitrogen & Total Phosphorus

A continuation of nutrient monitoring is recommended. This approach is consistent with DEP's SOP no. BPNPSM-PMT-033. Since the facility has performed nutrient monitoring previously and the stream segment where the discharge is located is not impaired for nutrients, a quarterly sampling of nutrients is still acceptable.

Monitoring Frequency and Sample Type

Unless otherwise specified throughout this fact sheet, monitoring frequencies and sample types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

Mass Loading Limitations

All effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

Antidegradation Requirements

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

Class A Wild Trout Fishery

No Class A Wild Trout Fisheries are also impacted by this discharge.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
Dissolved Oxygen (DO)	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	19	30	XXX	25	40	50	2/month	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab 8-Hr
Total Suspended Solids	23	34	XXX	30	45	60	2/month	Composite
Total Suspended Solids Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia-Nitrogen May 1- Oct 31	3.8	XXX	XXX	5.0	XXX	10.0	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 – Apr 30	11.3	XXX	XXX	15.0	XXX	30.0	2/month	8-Hr Composite
Ultraviolet light intensity (μ w/cm ²)	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
E. Coli (No. / 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]


StreamStats Report

Region ID: PA

Workspace ID: PA20250904012458889000

Clicked Point (Latitude, Longitude): 41.11735, -79.19638

Time: 2025-09-03 21:25:19 -0400



 [Collapse All](#)

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	3.5	square miles
ELEV	Mean Basin Elevation	1439	feet
PRECIP	Mean Annual Precipitation	44	inches

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	3.5	square miles	2.33	1720
ELEV	Mean Basin Elevation	1439	feet	898	2700
PRECIP	Mean Annual Precipitation	44	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.359	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.528	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.153	ft ³ /s	54	54
30 Day 10 Year Low Flow	0.22	ft ³ /s	49	49
90 Day 10 Year Low Flow	0.326	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
17C		48477	RUNAWAY RUN		0.100	1159.00	3.50	0.00000	0.00 <input checked="" type="checkbox"/>		
Stream Data											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Summerville STP	PA0222496		0.0900	0.0900	0.0900	0.000	25.00	7.00		
Parameter Data											
	Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5			25.00	2.00	0.00	1.50				
	Dissolved Oxygen			4.00	8.24	0.00	0.00				
	NH3-N			25.00	0.00	0.00	0.70				

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
17C		48477	RUNAWAY RUN		0.000	1154.00	3.52	0.00000	0.00 <input checked="" type="checkbox"/>		
Stream Data											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
				0.0000	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data											
	Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5			25.00	2.00	0.00	1.50				
	Dissolved Oxygen			3.00	8.24	0.00	0.00				
	NH3-N			25.00	0.00	0.00	0.70				

