

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0222674
 APS ID 1086260
 Authorization ID 1435746

Applicant and Facility Information

Applicant Name	<u>McKean Township Sewer Authority</u>	Facility Name	<u>McKean Township Sewer Authority STP</u>
Applicant Address	<u>9231 Edinboro Road, PO Box 88</u> <u>Mc Kean, PA 16426-1845</u>	Facility Address	<u>Near Intersection of SR 832 and West Road</u> <u>McKean, PA 16426</u>
Applicant Contact	<u>Janice Dennis</u> <u>(secretary@mckeantownship.com)</u>	Facility Contact	<u>Janice Dennis</u> <u>(secretary@mckeantownship.com)</u>
Applicant Phone	<u>(814) 476-7414</u>	Facility Phone	<u>(814) 476-7414</u>
Client ID	<u>118541</u>	Site ID	<u>492215</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>McKean Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Erie</u>
Date Application Received	<u>March 30, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>April 14, 2023</u>	If No, Reason	<u>-</u>

Purpose of Application Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater from a municipal sewer system.

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The Permittee should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in effects for Client ID (118541) as of 1/18/2024.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	1/18/2024
X		Vacant / Environmental Engineer Manager	Okay to Draft JCD 1/22/2024

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.25</u>
Latitude	<u>42° 00' 10.00"</u>	Longitude	<u>-80° 12' 16.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Elk Creek (WWF, MF)</u>	Stream Code	<u>62491</u>
NHD Com ID	<u>123926245</u>	RMI	<u>17.85</u>
Drainage Area	<u>35.7</u>	Yield (cfs/mi ²)	<u>0.067</u>
Q ₇₋₁₀ Flow (cfs)	<u>2.39</u>	Q ₇₋₁₀ Basis	<u>calculated</u>
Elevation (ft)	<u>871</u>	Slope (ft/ft)	<u>0.005417</u>
Watershed No.	<u>15-A</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Pennsylvania - Canada International border</u>		
PWS Waters	<u>Lake Erie</u>	Flow at Intake (cfs)	<u>-</u>
PWS RMI	<u>-</u>	Distance from Outfall (mi)	<u>40.0</u>

Sludge use and disposal description and location(s): All sludge is hauled to the Chautauqua Landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.25 MGD of treated sewage from an existing Publicly Owned Treatment Works (POTW) in McKean Township, Erie County.

Treatment permitted under WQM Permit 2599409 consists of the following: A bar screen, grit removal, skimming / separators, dual oxidation ditches, alum addition for Phosphorus control, dual clarifiers, dual aerobic digesters, a belt press, liquid hypochloride disinfection with a contact tank, and post aeration.

1. Streamflow:

Brandy Run near Girard, PA Streamgage No. 4213075 (1988-2008)

Drainage Area:	<u>4.45</u>	sq. mi.	(USGS StreamStats)
Q ₇₋₁₀ :	<u>0.3</u>	cfs	(USGS StreamStats)
Yieldrate:	<u>0.067</u>	cfs/m	(Calculated)

Elk Creek at Outfall 001:

Drainage Area:	<u>35.7</u>	sq. mi.	(USGS StreamStats)
Yieldrate:	<u>0.067</u>	cfs/m	(Calculated above)
% of stream allocated:	<u>100%</u>	Basis:	<u>No nearby discharges</u>
Q ₇₋₁₀ :	<u>2.39</u>	cfs	(Calculated)

2. Wasteflow:

Maximum discharge: 0.25 MGD = 0.38 cfs

Runoff flow period: 24 hours Basis: Runoff flow for municipal STPs

The calculated stream flow (Q7-10) is greater than 3 times the permitted discharge flow. In accordance with the SOP, since this is an existing discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)
10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/quarter.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.05 MGD and less than 1 MGD.

e. Phosphorus

The Phosphorus limit of 1.0 mg/l for Lake Erie based on the 1969 International Joint Committee (IJC) agreement will be retained.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.9 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH₃-N concentration: 0.0 mg/l

Basis: Default value

Calculated NH₃-N Summer limits: 11.4 mg/l (monthly average)
22.8 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer NH₃-N limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. The calculated limits are less restrictive than in the previous permit. Based on eDMR data, the more restrictive limits are attainable so they will be retained with this renewal.

h. CBOD₅

Median discharge pH to be used: 7.9 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated CBOD5 limits above (see Attachment 1). The calculated limits are less restrictive than in the previous permit. Based on eDMR data, the more restrictive limits are attainable so they will be retained with this renewal. Per the SOP, the previous winter limits were removed and the previous summer limits were set year round.

i. Influent Total Suspended Solids and BOD₅

Monitoring for these two parameters will be retained as recommended in the SOP for POTWs, as authorized under Chapter 92a.61.

j. Dissolved Oxygen (DO)

The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. This limit is the same as the previous permit and will be retained.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

k. Disinfection

Ultraviolet (UV) light monitoring

Total Residual Chlorine (TRC) limits: 0.5 mg/l (monthly average)
1.6 mg/l (instantaneous maximum)

Basis: The technology-based TRC limits above were calculated using the Department's TRC Calc Spreadsheet (see Attachment 2). The limits are less restrictive than the previous NPDES Permit. Based on the eDMR data, the current limits are attainable, so they will be retained with this renewal.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

4. Industrial/Commercial users:

Business Name	Business Type	Average Flow (gpd)
Presque Isle Passage	Seasonal Campground	2995
Burger King	Restaurant	0
Howard Industries	Commercial	592
Schneider	Commercial	41
Urraro Oil Company	Gas Station	277
Exit 18 Shell	Gas Station	0
West Haven Holding Company	Seasonal Campground	3195
Hanisek	Commercial	66
Marp LTD, LLC Quality Inn	Hotel	1315
Hammel Green, LLC	Restaurant	22
Elk Creek Partnership	Restaurant	49
Highway Equipment	Commercial	55
KMB Leasing Co.	Industrial	101
Crystal Lakes Development	Industrial	66
McKean Realty Holding	Industrial	5
Peter's Heat Treat	Industrial	197
McKean Heavy Duty Trucks	Industrial	38
KOA Campground	Seasonal Campground	658
Beachwood Golf Course	Golf Course	279
FedEx	Industrial	589
Birkmire Trucking Company	Industrial	233
Plyer Entry Systems	Industrial	66

5. Reasonable Potential Analysis for Receiving Stream:

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

6. Reasonable Potential for Downstream Public Water Supply (PWS):

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate).

Nearest Downstream potable water supply (PWS): Pennsylvania - Canada International border

Distance downstream from the point of discharge: 40.0 miles (approximate)

Result: No limits or monitoring are necessary as significant dilution is available.

7. Flow Information:

This facility receives 100% of flow from the McKean Township. All the sewers are separate sewers.

8. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

9. Attachment List:

Attachment 1 - WQ Modeling Printouts

Attachment 2 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from December 1, 2022 to November 30, 2023)

Parameter	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22
Flow (MGD) Average Monthly	0.1289	0.094	0.088	0.152	0.161	0.131	0.166	0.184	0.245	0.197	0.271	0.178
Flow (MGD) Daily Maximum	0.174	0.135	0.121	0.246	0.226	0.204	0.422	0.380	0.410	0.321	0.429	0.389
pH (S.U.) Instantaneous Minimum	7.8	7.9	8.0	7.8	7.9	7.5	7.6	7.7	7.7	7.6	7.6	7.8
pH (S.U.) Instantaneous Maximum	8.3	8.3	8.3	8.3	8.2	8.1	8.2	8.2	8.1	8.1	8.1	8.1
DO (mg/L) Instantaneous Minimum	8.76	8.9	8.76	9.03	9.14	8.32	8.20	8.96	8.9	8.89	9.05	8.89
TRC (mg/L) Average Monthly	0.15	0.17	0.02	0.02	0.02	0.02	0.20	0.21	0.17	0.16	0.17	0.15
TRC (mg/L) Instantaneous Maximum	0.27	0.28	0.02	0.02	0.02	0.02	0.25	0.32	0.30	0.24	0.30	0.25
CBOD5 (lbs/day) Average Monthly	2.47	1.88	2.27	5.45	3.08	8.74	3.18	3.38	5.72	4.60	4.75	9.35
CBOD5 (lbs/day) Weekly Average	2.58	2.24	3.97	13.69	3.57	18.03	4.06	3.68	8.62	7.02	5.42	24.49
CBOD5 (mg/L) Average Monthly	2.3	2.4	3.1	4.30	2.3	8	2.3	2.2	2.80	2.8	2.1	6.3
CBOD5 (mg/L) Weekly Average	2.40	2.86	5.41	10.80	2.66	16.50	2.93	2.4	4.22	4.27	2.40	16.50
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	127	123	118	129	138	176	141	98	218	280	217	266
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	160	203	187	204	224	271	220	156	400	757	467	620
BOD5 (mg/L) Raw Sewage Influent Average Monthly	118	156	174	108	107	158	116	72	117	169	91	184
TSS (lbs/day) Average Monthly	8.27	3.52	3.59	5.16	7.11	10.27	7.48	11.97	22.88	14.46	16.0	10.99
TSS (lbs/day) Raw Sewage Influent Average Monthly	159	251	170	115	461	139	194	260	315	616	313	588

**NPDES Permit Fact Sheet
McKean Township Sewer Authority STP**

NPDES Permit No. PA0222674

TSS (lbs/day) Raw Sewage Influent Daily Maximum	243	481	308	242	1059	196	525	641	754	1751	687	1377
TSS (lbs/day) Weekly Average	16.12	4.70	4.40	9.82	11.41	17.64	13.15	16.88	44.95	21.36	20	22.27
TSS (mg/L) Average Monthly	7.7	4.5	4.9	4.1	5.3	9.4	5.4	7.8	11.2	8.8	6.9	7.4
TSS (mg/L) Raw Sewage Influent Average Monthly	142	497	253	91	383	122	166	165	170	370	128	403
TSS (mg/L) Weekly Average	15	6.0	6.0	7.5	8.5	16.15	9.5	11	22	13	9	15
Fecal Coliform (No./100 ml) Geometric Mean	104.1	18.9	21.4	6.2	3.8	5.3	59	69.5	30.2	97.1	42.8	169.1
Fecal Coliform (No./100 ml) Instantaneous Maximum	2419.6	145	365.4	35	9.8	20.3	2419.5	2420	1046.2	1986.3	2419.6	2416
Total Nitrogen (mg/L) Average Monthly	8.25	11.34	12.04	11.41	3.622	4.79	8.28	9.83	8.80	12.64	11.65	11.93
Ammonia (lbs/day) Average Monthly	0.10	0.23	0.44	0.12	0.40	3.39	1.80	0.31	< 0.20	< 0.17	0.23	< 0.15
Ammonia (mg/L) Average Monthly	0.1	0.3	0.60	0.1	0.30	3.1	1.3	0.2	< 0.1	< 0.1	< 0.1	< 0.1
Total Phosphorus (mg/L) Average Monthly	0.40	0.35	0.69	0.49	0.21	0.47	0.41	0.17	0.19	0.24	0.17	0.27

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.25	XXX	0.83	1/day	Grab
CBOD5	31.0	47.0	XXX	15.0	22.5	30	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
TSS	62.5	94.0	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Ammonia Nov 1 - Apr 30	18.7	XXX	XXX	9.0	XXX	18	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	6.2	XXX	XXX	3.0	XXX	6	1/week	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2	1/week	24-Hr Composite

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 92a.47. The limits for Total Suspended Solids and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for influent BOD5 and influent Total Suspended Solids is based on Chapter 92a.61. Monitoring for E. Coli is based on Chapter 92a.61. The limits for CBOD5 and Ammonia-Nitrogen are water quality-based on Chapter 93.7. The limits for Total Phosphorus are technology-based on the IJC agreement for discharges in the Lake Erie Basin. Monitoring for Total Nitrogen is based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
15		62491		ELK CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
21.870	Middleboro STP	PA0046418	0.100	CBOD5	25		
				NH3-N	15.42	30.84	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
17.850	McKean Twp	PA0222674	0.250	CBOD5	25		
				NH3-N	11.46	22.92	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
15	62491	ELK CREEK			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
21.870	0.100	25.000		7.010	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
18.939	0.553	34.267		0.134	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
4.53	0.356	1.69		1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.151	7.795	Tsviglou		5	
<u>Reach Travel Time (days)</u>	Subreach Results				
1.827	TravTime	CBOD5	NH3-N	D.O.	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.183	4.17	1.40	7.11	
	0.365	3.85	1.16	7.24	
	0.548	3.54	0.96	7.39	
	0.731	3.27	0.80	7.52	
	0.913	3.01	0.66	7.54	
	1.096	2.77	0.55	7.54	
	1.279	2.56	0.45	7.54	
	1.461	2.36	0.38	7.54	
	1.644	2.17	0.31	7.54	
	1.827	2.00	0.26	7.54	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
17.850	0.350	25.000		7.061	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
27.145	0.627	43.268		0.166	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
5.14	0.509	1.69		1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.056	5.550	Tsviglou		5	
<u>Reach Travel Time (days)</u>	Subreach Results				
1.473	TravTime	CBOD5	NH3-N	D.O.	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.147	4.68	1.45	6.59	
	0.295	4.25	1.25	6.53	
	0.442	3.87	1.07	6.63	
	0.589	3.52	0.92	6.78	
	0.736	3.21	0.79	6.95	
	0.884	2.92	0.68	7.11	
	1.031	2.65	0.59	7.25	
	1.178	2.42	0.50	7.38	
	1.325	2.20	0.43	7.50	
	1.473	2.00	0.37	7.54	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
15	62491	ELK CREEK	21.870	986.00	18.70	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.067	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Middleboro STP	PA0046418	0.1000	0.0000	0.0000	0.000	25.00	7.10

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
15	62491	ELK CREEK	17.850	871.00	34.22	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.067	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
McKean Twp	PA0222674	0.2500	0.0000	0.0000	0.000	25.00	7.90

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
15	62491	ELK CREEK	13.840	805.00	42.05	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.067	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
15		62491				ELK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
21.870	1.25	0.00	1.25	.1547	0.00542	.553	18.94	34.27	0.13	1.827	25.00	7.01
17.850	2.29	0.00	2.29	.5415	0.00312	.627	27.15	43.27	0.17	1.473	25.00	7.06
Q1-10 Flow												
21.870	0.80	0.00	0.80	.1547	0.00542	NA	NA	NA	0.11	2.268	25.00	7.01
17.850	1.47	0.00	1.47	.5415	0.00312	NA	NA	NA	0.14	1.786	25.00	7.09
Q30-10 Flow												
21.870	1.70	0.00	1.70	.1547	0.00542	NA	NA	NA	0.16	1.563	25.00	7.01
17.850	3.12	0.00	3.12	.5415	0.00312	NA	NA	NA	0.19	1.276	25.00	7.05

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
15	62491	ELK CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
21.870	Middleboro STP	10.93	50	10.93	50	0	0
17.850	McKean Twp	10.21	48.94	10.2	48.94	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
21.870	Middleboro STP	1.36	16.38	1.36	15.42	2	6
17.850	McKean Twp	1.34	12.17	1.34	11.46	2	6

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
21.87	Middleboro STP	25	25	15.42	15.42	4	4	0	0
17.85	McKean Twp	25	25	11.46	11.46	4	4	0	0

Attachment 2

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
2.39	= Q stream (cfs)			0.5	= CV Daily
0.25	= Q discharge (MGD)			0.5	= CV Hourly
30	= no. samples			1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream			1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge			15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value			720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			0	= Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii		WLA_afc = 1.990	1.3.2.iii	WLA_cfc = 1.933
PENTOXSD TRG	5.1a		LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b		LTA_afc = 0.742	5.1d	LTA_cfc = 1.124
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f		AML_MULT = 1.231		
PENTOXSD TRG	5.1g		AVG_MON_LIMIT (mg/l) = 0.500		BAT/BPJ
			INST_MAX_LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ \dots + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$				
LTA_afc	$wla_afc*LTAMULT_afc$				
WLA_cfc	$(.011/e(-k*CFC_tc) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ \dots + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$				
LTA_cfc	$wla_cfc*LTAMULT_cfc$				
AML_MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$				
AVG_MON_LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$				
INST_MAX_LIMIT	$1.5*(av_mon_limit/AML_MULT)/LTAMULT_afc$				