

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0222909  
APS ID 1088371  
Authorization ID 1439503

**Applicant and Facility Information**

Applicant Name	<u>Kinzua Warren Joint Authority</u>	Facility Name	<u>Kinzua Warren County WWTP</u>
Applicant Address	<u>119 Mead Boulevard</u> <u>Clarendon, PA 16313-1119</u>	Facility Address	<u>509 Kinzua Road</u> <u>Warren, PA 16365</u>
Applicant Contact	<u>Jeri Graham</u>	Facility Contact	<u>Jesse Crawford</u>
Applicant Phone	<u>(814) 726-7126</u>	Facility Phone	<u>(814) 726-7126</u>
Applicant Email	<u>kwcjauthority@gmail.com</u>		
Client ID	<u>44318</u>	Site ID	<u>522490</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Mead Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Warren</u>
Date Application Received	<u>May 3, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 24, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an Existing Discharge From a POTW</u>		

**Summary of Review**

No changes to discharge quantity or quality are being proposed as part of this renewal.

Act 14 – Proof of Notification was submitted and received.

SPECIAL CONDITIONS: NONE

The EPA waiver is in effect.

There are NO open violations in WMS for the subject Client ID (44318) as of October 6, 2023 [11/21/2023 CWY](#)

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Aeshah Shameseldin Aeshah Shameseldin / Civil Engineer Trainee	October 6, 2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	11/21/2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.3125</u>
Latitude	<u>41° 49' 25.3"</u>	Longitude	<u>-79° 6' 36.1"</u>
Quad Name	<u>Clarendon</u>	Quad Code	<u>41079G1</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Allegheny River (CWF)</u>	Stream Code	<u>42122</u>
NHD Com ID	<u>112375329</u>	RMI	<u>192.76</u>
Drainage Area	<u>2200</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.18</u>
Q <sub>7-10</sub> Flow (cfs)	<u>396</u>	Q <sub>7-10</sub> Basis	<u>Calculated</u>
Elevation (ft)	<u>1200</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>16-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>---</u>	Existing Use Qualifier	<u>---</u>
Exceptions to Use	<u>---</u>	Exceptions to Criteria	<u>---</u>
Assessment Status	<u>Not Assessed</u>		
Cause(s) of Impairment	<u>---</u>		
Source(s) of Impairment	<u>---</u>		
TMDL Status	<u>---</u>	Name	<u>---</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u>---</u>
Temperature (°F)	<u>20</u>	Default	<u>---</u>
Hardness (mg/L)	<u>100</u>	Default	<u>---</u>
Other:	<u>---</u>		<u>---</u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. – Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1376</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>98.5</u>

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Kinzua Warren County WWTP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6221401		06/28/2021		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary with Ammonia Reduction	Extended Aeration	Ultraviolet	0.3125
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.3125	550	Not Overloaded	Aerobic digester / sludge drying beds	Landfill

Changes Since Last Permit Issuance: None.

Other Comments: None.

**Compliance History**

**DMR Data for Outfall 001 (from July 1, 2022 to June 30, 2023)**

Parameter	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22
Flow (MGD) Average Monthly	0.095	0.108	0.107	0.148	0.125	0.156	0.128	0.141	0.112	0.118	0.107	0.112
Flow (MGD) Daily Maximum	0.123	0.152	0.192	0.179	0.319	0.405	0.182	0.562	0.193	0.255	0.147	0.194
pH (S.U.) Daily Minimum	6.03	6.04	6.02	6.06	0.01	6.0	6.05	6.01	6.18	6.44	6.09	6.04
pH (S.U.) Daily Maximum	7.03	6.98	7.1	6.85	6.86	6.92	7.1	7.47	7.12	7.36	7.53	7.98
DO (mg/L) Daily Minimum	6.7	7.38	6.49	6.07	7.57	5.68	7.44	6.3	5.92	5.83	5.23	5.87
CBOD5 (lbs/day) Average Monthly	4.0	< 4.0	< 4.0	8.0	6.0	11.0	< 4.0	< 5.0	< 4.0	< 6.0	< 5	< 4.0
CBOD5 (lbs/day) Weekly Average	8.0	7.0	< 4.0	12	13.0	27	4.0	8.0	< 4.0	< 9	9.0	< 5.0
CBOD5 (mg/L) Average Monthly	7.0	< 5.0	< 4.0	7.0	6.0	< 11.0	< 4.0	< 6.0	< 4.0	< 4.0	< 5.0	< 4.0
CBOD5 (mg/L) Weekly Average	10.0	9.0	4.0	10.0	11.0	26.0	5.0	9.0	< 4.0	< 4.0	10.0	< 4.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	234	240	198	236	205	204.0	313	246	210	350	261	265.0
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	285	303	210	275	215	267.0	350	315	260	455	271	296
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	279	278	231	225	215.0	189.0	332	267	246	260	288.0	281.0
TSS (lbs/day) Average Monthly	14.0	11.0	< 6.0	14.0	21.0	45.0	< 21.0	5.0	< 5.0	< 8.0	7.0	< 7.0
TSS (lbs/day) Raw Sewage Influent   Average Monthly	281	212	154	186	187	187.0	805	240	256	667	381	210.0
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	533	345	200	227	306	258.0	1949	271	416	1449	734	268.0

**NPDES Permit Fact Sheet  
Kinzua Warren County WWTP**

**NPDES Permit No. PA0222909**

TSS (lbs/day) Weekly Average	24.0	15.0	9.0	21.0	79.0	90	40.0	7.0	5.0	11.0	11	15.0
TSS (mg/L) Average Monthly	17.0	13.0	< 7.0	14.0	22.0	41.0	< 22.0	6.0	< 6.0	< 6.0	8.0	< 7.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	319	242	176	179	179.0	173.0	814	269	302	518	426.0	220.0
TSS (mg/L) Weekly Average	29.0	18.0	12.0	22.0	66.0	87.0	45.0	9.0	7.0	8.0	12.0	13.0
Fecal Coliform (No./100 ml) Geometric Mean	< 7.0	< 1.0	< 1.0	< 1.0	43	< 52.0	< 1.0	< 6.0	5.0	15	14	< 2.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 2420.0	5.0	1.0	< 1.0	2420	2420.0	5.0	148	11.0	65	96	10
Total Nitrogen (mg/L) Daily Maximum							< 1.25					
Ammonia (lbs/day) Average Monthly	< 7.0	< 0.04	< 0.3	0.3	0.4	3.0	< 0.3	< 0.03	< 0.3	2.0	0.4	< 0.3
Ammonia (mg/L) Average Monthly	< 0.3	< 0.3	< 0.3	0.3	0.44	2.98	< 0.3	< 0.3	< 0.3	0.77	0.49	< 0.3
Total Phosphorus (mg/L) Daily Maximum							5.87					

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.3125</u>
<b>Latitude</b> <u>41° 49' 25.3"</u>	<b>Longitude</b> <u>-79° 6' 36.1"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	§ 92a.61

Comments: TRC limit not applicable for this discharge because UV disinfection is utilized. *Daily monitoring of UV Intensity is being added to the permit in accordance with the Department's March 24, 2021 SOP "Establishing Effluent Limitations for Individual Sewage Permits". 11/21/2023 CWY*

**Water Quality-Based Limitations**

A "Reasonable Potential Analysis" determined the following parameters were candidates for limitations: CBOD<sub>5</sub>, Nitrogen, Ammonia, Phosphorus, and Dissolved Oxygen (DO).

CBOD<sub>5</sub>, Ammonia, and DO are evaluated using WQM 7.0 (See Attachment 1)

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	4	Daily Min.	WQM 7.0
CBOD <sub>5</sub>	25	Monthly Avg.	WQM 7.0
	50	IMAX	

Comments: Due to the discharge being directly to the Allegheny River, potential impacts to endangered mussel species were evaluated. Based on USFWS Recommendation, the following effluent limitations have been established for Ammonia-Nitrogen (See Attachment 2) *The calculated average monthly Ammonia-Nitrogen limit using WQM 7.0 is 25 mg/l. The more stringent limits established in previous permits are attainable and will be retained. Monitoring frequency is 1/week in accordance with Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations".*

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (05/01 – 10/31)	2.2	Monthly Average	USFWS Recommendation (See Attachment 2)
	4.4	IMAX	
Ammonia Nitrogen (11/01 – 04/30)	6.6	Monthly Average	USFWS Recommendation (See Attachment 2)
	13.2	IMAX	

**Best Professional Judgment (BPJ) Limitations**

Comments: A dissolved oxygen effluent limit of a minimum of 4.0 mg/l, and monitoring for total nitrogen, total phosphorus and raw sewage influent monitoring for BOD<sub>5</sub> and TSS are placed in the permit in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.”

**Anti-Backsliding**

No backsliding of limits is being proposed.

**Threatened and Endangered Mussel Species Concerns and Considerations**

*The USFWS has indicated in comment letters and email correspondence on other NPDES Permits, that to protect threatened and endangered mussel species, wastewater discharges containing ammonia-nitrogen (NH<sub>3</sub>-N), chloride (Cl<sup>-</sup>), dissolved nickel, dissolved zinc, and total copper where mussels or their habitat exist, can be no more than 1.9 mg/l, 78 mg/l, 7.3 ug/l, 13.18 ug/l, and 10 ug/l respectively. Therefore, the Department has considered all of these parameters in this evaluation.*

*Although the Allegheny River is known to contain state and federally listed threatened and endangered (T/E) mussel species, there have been no known populations of T/E species found in the segment of the Allegheny River between the outlet of the Kinzua Dam and the confluence with Conewango Creek. This has been confirmed by studies conducted by the Department as well as other agencies. The Department believes the reason for this is likely due to the Dam outflow patterns and colder water from the outflow. This section of the Allegheny River is also nutrient and sediment deprived because of the outflow from the Dam.*

Ammonia:

*The USFWS began informal consultation with the Rural Utilities Service (RUS) in 1994, based on concerns that this discharge could potentially affect federally listed endangered mussels that could exist in this section of stream. The USFWS had further discussions with RUS, the Authority, their consultant and the Department in the later part of 1994. A letter from the USFWS to the Authority on 12/1/1994 outlined conditions that the Authority would need to take in order for the service to concur with a “not likely to have adversely affect” determination. The Authority agreed to the conditions, and the USFWS formally ended the informal consultation, via a letter dated 11/26/1997 (see Attachment 2). The conditions were: 1) a summertime ammonia nitrogen limit of 2.2 mg/l, 2) the use of UV disinfection, and the discharge be above the low water mark in the stream. These ammonia limits have been written into previous permits, are attainable, and will be reimplemented with this renewal.*

Chloride, Dissolved Nickel, Dissolved Zinc, and Total Copper:

*Based on the prior recommendations of the USFWS and there being no known T/E species in the vicinity of the discharge, the Department does not expect this discharge to have an adverse impact on threatened or endangered mussels in the Allegheny River.*

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	65	104	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	78	117	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (µw/cm²)	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/day	Recorded
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	17	XXX	XXX	6.6	XXX	13.2	1/week	24-Hr Composite
Ammonia May 1 - Oct 31	5.7	XXX	XXX	2.2	XXX	4.4	1/week	24-Hr Composite



Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

**Outfall Location - eMap with Aerial Imagery**

**Legend**

Regulated Facilities and Related Information

Streams and Water Resources

Water Quality

Existing Use Streams

- Cold Water Fish
- Exceptional Value
- High Quality
- Trout Stocking
- Warm Water Fish
- Overlap

Designated Use Streams

- Cold Water Fish
- Exceptional Value
- High Quality
- Trout Stocking
- Warm Water Fish
- Overlap
- Missing from CH93

Boundaries

County Boundaries

Municipalities

**Designated Use Streams (1 of 3)**

Designated Use Gen ID: 100097  
GNIS Name:  
GNIS ID:  
ReachCode: 05010001002367  
COMID: 112375329  
Length Miles: 0.415  
Map Symbology: CWF  
Length Miles: 0.415  
Designated Use: 1  
DES Use ID: 1  
Use Description: CWF(COLD WATER FISHES)  
Migratory Fish: N  
HUC: 05010001  
Basin: Y  
Basin Narrative: This is a BASIN delineation. It includes ALL tributaries draining into the stream segment described below. The stream code listed below is that of the mainstem. The stream codes  
[Zoom to](#)

Locate Latitude and Longitude

Decimal Degrees  DD/MM/SS

Latitude: Degrees: 41 Minutes: 49 Seconds: 25.3  
Longitude: -79 6 36.1


Locate Close

Imagery: undefined; ESRI Streets: Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand), NGCC, (c) OpenStreetMap contributors, and the GIS User Community

**Drainage Area Location – StreamStats with Aerial Imagery**

StreamStats Report

Region ID:	PA
Workspace ID:	PA20231005133639870000
Clicked Point (Latitude, Longitude):	41.82432, -79.11104
Time:	2023-10-05 09:37:16 -0400



**+** Collapse All

**> Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	2200	square miles

**Attachment 1**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18A		42122		ALLEGHENY RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
192.760	Kinzua Warren	PA0222909	0.313	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18A	42122	ALLEGHENY RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
192.760	0.313	20.000	6.998	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
349.510	1.159	301.475	0.978	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.03	0.020	0.03	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.238	3.894	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.139	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.014	2.03	0.03	8.24
	0.028	2.03	0.03	8.24
	0.042	2.03	0.03	8.24
	0.055	2.03	0.03	8.24
	0.069	2.03	0.03	8.24
	0.083	2.02	0.03	8.24
	0.097	2.02	0.03	8.24
	0.111	2.02	0.03	8.24
	0.125	2.02	0.03	8.24
	0.139	2.02	0.03	8.24

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42122	ALLEGHENY RIVER	192.760	1182.00	2200.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.180	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Kinzua Warren	PA0222909	0.3130	0.0000	0.0000	0.000	20.00	6.30

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42122	ALLEGHENY RIVER	190.540	1172.00	2230.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.180	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Kinzua Warren	PA0222909	0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70



**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
18A	42122	ALLEGHENY RIVER	

---

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
192.760	Kinzua Warren	9.7	50	9.7	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
192.760	Kinzua Warren	1.92	25	1.92	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
192.76	Kinzua Warren	25	25	25	25	4	4	0	0

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18A		42122				ALLEGHENY RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
192.760	396.00	0.00	396.00	.4842	0.00085	1.159	349.51	301.48	0.98	0.139	20.00	7.00
<b>Q1-10 Flow</b>												
192.760	253.44	0.00	253.44	.4842	0.00085	NA	NA	NA	0.76	0.178	20.00	7.00
<b>Q30-10 Flow</b>												
192.760	538.56	0.00	538.56	.4842	0.00085	NA	NA	NA	1.16	0.117	20.00	7.00

Attachment 2



FACT SHEET  
ATTACHMENT B

RFB

United States Department of the Interior

FISH AND WILDLIFE SERVICE  
Suite 322  
315 S. Allen St.  
State College, Pennsylvania 16801

November 26, 1997

RECEIVED  
DEC 05 1997

Mr. Ervin B. Myers  
Rural Utilities Service  
1012 Water Street  
Meadville, PA 16335

NORTHWEST ENGINEERING INC

Dear Mr. Myers:

This is in response to your September 9, 1997, letter requesting that the Fish and Wildlife Service evaluate the proposed wastewater collection and treatment project of the Kinzua/Warren County Joint Authority. The treatment plant will discharge 500,000 gallons per day of municipal wastewater into the Allegheny River in Warren County. Informal consultation under Section 7(a)(2) of the Endangered Species Act of 1973 (87 Stat 884, as amended; 16 U.S.C. 1531 *et seq.*) began in 1994, based on concerns that the project could possibly affect federally listed endangered species, namely the clubshell mussel (*Pleurobema clava*) and the northern riffleshell mussel (*Epioblasma rangiana torulosa*). Discussions between your agency, the Pennsylvania Department of Environmental Protection (DEP), Lake Engineering (the Authority's consultant at the time), and the Service took place in the latter half of 1994.

In a letter dated December 1, 1994, the Service outlined steps that the Authority would need to take to enable the Service to concur with a "not likely to adversely affect" determination. Briefly, for the Service to concur, the plant would need to utilize ultraviolet (UV) light for disinfection rather than elemental chlorine, and water quality criteria for chemical constituents would need to be met at "end-of-pipe." We also recommended that a cursory mussel survey be conducted, since at that time there was flexibility regarding placement of the outfall structure, and we believed that suitable mussel habitat should be avoided if possible.

After receiving your September 9 letter, further discussions have taken place between your agency, DEP, Northwest Engineering, the Authority's current consultant, and the Service. We have also received a letter from the Authority dated October 21, 1997, in which they agreed to the measures outlined in our December 1, 1994, letter. We believe those measures will allow implementation and operation of the project without adversely affecting endangered species. Communications with Northwest Engineering indicate that, while an effluent concentration of 2.2 mg/L ammonia-nitrogen is attainable during summer conditions, this concentration is not attainable during colder weather, and concentrations in the range of 3 - 4 mg/L ammonia nitrogen will be discharged. We expect further information on this from Northwest Engineering, but do not believe that a winter effluent limitation that corresponds to a 2.2 mg/L summer effluent concentration will adversely affect endangered mussels in this case.

We also understand that a location for the treatment plant has been chosen and, therefore, there is little flexibility regarding the outfall location. Our past recommendation that a " cursory " mussel survey be conducted to minimize potential impacts by careful siting of the outfall no longer applies. The proposal calls for the outfall structure to be above the low water mark of the Allegheny River (H. Blumgren, Northwest Engineering, Inc. personal communication), so no mussel survey is needed.

---

We expect that construction and operation of the proposed collection and treatment systems, taking into account the Authority's commitment to the implementation of our recommendations, are not likely to adversely affect federally-listed endangered mussels. Therefore, this concludes informal consultation between our agencies pursuant to Section 7(a)(2) of the Endangered Species Act.

We appreciate your efforts, and those of the Authority, to conserve our Nation's rare species. Please contact Mark Hersh of this office (814-234-4090) if you have any questions regarding this matter.

Sincerely,



David Denmore  
Supervisor

cc: John Arway, PFBC  
Andy Shiels, PFBC  
Rich Kaintz, DEP, NWRO  
John Wester, K/WCJA  
✓ Hal Blumgren, Northwest Engineering  
ES:PAFO:CMH:nt/jg/11/26/97  
filename:myers.mh