

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0223018
APS ID 1000502
Authorization ID 1285735

Applicant and Facility Information

Applicant Name	<u>Farmington Township</u>	Facility Name	<u>Farmington Township STP</u>
Applicant Address	<u>596 Fairbanks Road</u> <u>Russell, PA 16345</u>	Facility Address	<u>595 Fairbanks Road</u> <u>Russell, PA 16345</u>
Applicant Contact	<u>Edward Beardsley</u>	Facility Contact	<u>Edward Beardsley</u>
Applicant Phone	<u>(724) 867-6981</u>	Facility Phone	<u>(724) 867-6981</u>
Client ID	<u>112070</u>	Site ID	<u>536121</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Farmington Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Warren County</u>
Date Application Received	<u>August 12, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 29, 2019</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an existing NPDES Permit for an existing discharge of treated sanitary wastewater from a municipal sewer system.</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.
A Part II Water Quality Management permit is not required at this time.
The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in efacts associated with the subject Client ID (112070) as of 11/3/2021.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	11/3/2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	11/4/2021

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.025</u>
Latitude	<u>41° 58' 14.30"</u>	Longitude	<u>-79° 14' 12.90"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Rollin Run (CWF)</u>	Stream Code	<u>56404</u>
NHD Com ID	<u>129446832</u>	RMI	<u>1.2</u>
Drainage Area	<u>1.23</u>	Yield (cfs/mi ²)	<u>0.07</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.086</u>	Q ₇₋₁₀ Basis	<u>calculated</u>
Elevation (ft)	<u>1518</u>	Slope (ft/ft)	<u>0.01149</u>
Watershed No.	<u>16-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>PA - NY state border</u>		
PWS Waters	<u>Kiantone Creek</u>	Flow at Intake (cfs)	<u>-</u>
PWS RMI	<u>-</u>	Distance from Outfall (mi)	<u>4.5</u>

Sludge use and disposal description and location(s): Sludge is not used, it is hauled to the Sugar Grove Area Sewer Authority where it is applied to the reed beds.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.025 MGD of treated sewage from an existing Publicly Owned Treatment Works (POTW) in Farmington Township, Warren County.

Permitted treatment (WQM Permit no. 6200408) consists of: Comminution, an 8,543 gallon aerated equalization tank, 3 aeration tanks totaling 26,000 gallons, a 5,847 gallon settling tank, a 10,625 gallon aerobic digestion tank, chlorination with a 2,800 gallon contact tank, dechlorination with a 690 gallon tank, a polishing clarifier, and post aeration.

1. Streamflow:

Jackson Run near North Warren, PA - USGS gage 03015280 (1964-1978):

Q ₇₋₁₀ :	<u>0.9</u>	cfs	(USGS StreamStats)
Drainage Area:	<u>12.8</u>	sq. mi.	(USGS StreamStats)
Yieldrate:	<u>0.07</u>	cfsm	calculated

Unnamed Tributary to the Kiantone Creek at Outfall 001:

Yieldrate:	<u>0.07</u>	cfsm	calculated above
Drainage Area:	<u>1.23</u>	sq. mi.	(USGS StreamStats)
Q ₇₋₁₀ :	<u>0.086</u>	cfs	calculated

% of stream allocated: 100% Basis: No nearby discharges

2. Wasteflow:

Maximum discharge: 0.025 MGD = 0.038 cfs

Runoff flow period: 24 hours Basis: Runoff flow for an STP with equalization

In accordance with the SOP, since there is greater than 3 parts stream flow (Q7-10) to 1 part effluent (design flow), the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30 mg/l as a monthly average and 60 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows less than 0.05 MGD.

e. Phosphorus

Limit not necessary

Basis: Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

Limit necessary due to:

Discharge to lake, pond, or impoundment

Discharge to stream

Discharge to a dry stream

Basis: N/A

f. Total Nitrogen

Limit not necessary

Basis: The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

Limit necessary due to:

Discharge to a lake, pond, or impoundment

Discharge to a stream

Discharge to a dry stream

Basis: N/A

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.6 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value

Calculated NH₃-N Summer limits: 6.7 mg/l (monthly average)
13.4 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 20.1 mg/l (monthly average)
40.2 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1). The winter limits are calculated as three times the summer limits. However, the previous limits are more restrictive and are attainable, so they will be retained.

h. CBOD₅

Median discharge pH to be used: 7.6 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

CBOD₅ Summer limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

CBOD₅ Winter limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 1), which are the same as in the previous permit. The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. Since the summer and winter limits are technology-based, per the SOP, the year-round limit of 25.0 mg/l monthly average and 50.0 mg/l instantaneous maximum will be retained with this renewal.

i. Influent Total Suspended Solids and BOD₅

Monitoring for these two parameters will be retained as recommended in the SOP for POTWs, as authorized under Chapter 92a.61.

j. Dissolved Oxygen (DO)

- 4.0 mg/l - minimum desired in effluent to protect all aquatic life
- 5.0 mg/l - desired in effluent for CWF, WWF, or TSF
- 6.0 mg/l - minimum required due to discharge falling under guidance document 391-2000-014
- 8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: A Dissolved Oxygen minimum of 4.0 mg/l was calculated by the WQ Model (see Attachment 1). The new limit will be added with this renewal per the SOP, based on Chapter 93.7, and under the authority of Chapter 92a.61.

The measurement frequency will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

k. Total Residual Chlorine (TRC)

No limit necessary

Basis: N/A

TRC limits: 0.3 mg/l (monthly average)
1.0 mg/l (instantaneous maximum)

Basis: The water quality-based limits for TRC above were calculated by the TRC Calc Spreadsheet (see Attachment 2). The calculated limits are more restrictive than the previous permit. Since the new more restrictive limits are attainable, a compliance schedule will not be added with this renewal.

The measurement frequency will be set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

4. **Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 by the Department's Toxics Management Spreadsheet since no parameters other than sewage are required to be sampled for flows less than 0.1 MGD.

Result: No reasonable potential was calculated, so no WQBELs are necessary for this renewal.

5. **Reasonable Potential for Downstream Public Water Supply (PWS):**

The Reasonable Potential Analysis does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since sample data was provided, mass-balance calculations were performed (see below).

Nearest Downstream potable water supply (PWS): PA - NY state border

Distance downstream from the point of discharge: 4.5 miles (approximate)

PWS Evaluation:

Stream flow (sf) at the potable water supply intake (PA-NY state border) = 1.16 cfs

Waste flow (wf) from the STP = 0.025 MGD = 0.038 cfs

Total flow = 1.198 cfs

Background Concentrations: No data available (assumed zero)

Mass balance for TDS at the potable water supply intake:

$$(sf @ PWS)(\text{bkrd. conc.}) + (wf)(x) = (\text{tot. flow})(\text{criteria})$$

$$(1.16 \text{ cfs})(0 \text{ mg/l}) + (0.038 \text{ cfs})(x) = (1.198 \text{ cfs})(500 \text{ mg/l})$$

$$x = 15,763 \text{ mg/l (renewal application maximum was 476 mg/l - ok)}$$

Mass balance for Chloride at the potable water supply intake:

$$(sf @ PWS)(\text{bkrd. conc.}) + (wf)(x) = (\text{tot. flow})(\text{criteria})$$

$$(1.16 \text{ cfs})(0 \text{ mg/l}) + (0.038 \text{ cfs})(x) = (1.198 \text{ cfs})(250 \text{ mg/l})$$

$x = 7,881 \text{ mg/l}$ (renewal application maximum was 131 mg/l - ok)

Mass balance for Bromide at the potable water supply intake:

$$(\text{sf @ PWS})(\text{bkrd. conc.}) + (\text{wf})(x) = (\text{tot. flow})(\text{criteria})$$
$$(1.16 \text{ cfs})(0 \text{ mg/l}) + (0.038 \text{ cfs})(x) = (1.198 \text{ cfs})(1 \text{ mg/l})$$

$x = 31.5 \text{ mg/l}$ (renewal application maximum was <0.4 mg/l - ok)

Bromide has been linked to the formation of disinfection byproducts at increased levels in public water systems. Where the concentration of Bromide in a discharge exceeds 1 mg/L, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Since the permitted discharge is less than 0.1 MGD, and the maximum reported sample data for Bromide was <2.0 mg/l, monitoring is not necessary with this renewal permit.

Mass balance for Sulfate at the potable water supply intake:

$$(\text{sf @ PWS})(\text{bkrd. conc.}) + (\text{wf})(x) = (\text{tot. flow})(\text{criteria})$$
$$(1.16 \text{ cfs})(0 \text{ mg/l}) + (0.038 \text{ cfs})(x) = (1.198 \text{ cfs})(250 \text{ mg/l})$$

$x = 7,881 \text{ mg/l}$ (renewal application maximum was 26.5 mg/l - ok)

- No limits necessary
 Limits needed

Basis: Significant dilution available.

6. Additional Information:

The Farmington Township STP receives 100% of its flow from the Farmington Township, which is a 100% separate sewer system.

7. Anti-Backsliding

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

8. Attachment List:

- Attachment 1 - WQ Modeling Printouts
- Attachment 2 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from October 1, 2020 to September 30, 2021)

Parameter	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20
Flow (MGD) Average Monthly	0.005	0.006	0.006	0.006	0.005	0.006	0.006	0.005	0.006	0.007	0.005	0.005
pH (S.U.) Minimum	7.6	7.1	7.2	7.4	7.5	6.5	7.3	7.3	7.6	7.6	7.9	7.8
pH (S.U.) Maximum	8.1	7.4	7.8	7.7	8.1	7.8	7.8	7.8	7.8	7.9	8.1	8.1
TRC (mg/L) Average Monthly	0.16	0.11	0.12	0.17	0.12	0.14	0.09	0.08	0.16	0.16	0.1	0.19
TRC (mg/L) Instantaneous Maximum	0.22	0.14	0.13	0.26	0.14	0.22	0.18	0.09	0.24	0.31	0.14	0.38
CBOD5 (lbs/day) Average Monthly	< 0.08	0.2	0.5	0.3	< 0.2	0.3	< 0.3	0.2	< 0.2	< 0.3	< 0.3	0.2
CBOD5 (lbs/day) Weekly Average	< 0.1	0.3	0.9	0.4	0.3	0.3	0.5	0.2	< 0.2	0.3	0.4	0.3
CBOD5 (mg/L) Average Monthly	< 2.2	3.85	5.39	6.31	< 5.49	6.71	< 4.26	3.73	< 3	4.41	< 4.73	4.81
CBOD5 (mg/L) Weekly Average	< 2.4	5.15	6.96	7.03	7.97	6.98	5.52	4.25	< 3	5.81	4.76	5.41
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	8	18	5.0	8	12	10	14	11	12	19	12	8
BOD5 (mg/L) Raw Sewage Influent Average Monthly	245	263	115.6	156	334	240	213.5	213	198.9	272	9	171
TSS (lbs/day) Average Monthly	< 0.1	0.3	0.7	0.3	0.4	0.4	0.2	0.2	0.2	1	0.7	0.3
TSS (lbs/day) Raw Sewage Influent Average Monthly	10	15	8.0	9	10	12	8	9	5	7	9	8
TSS (lbs/day) Weekly Average	0.1	0.4	1.0	1.0	0.4	0.6	0.3	0.3	0.3	2	1.0	0.3
TSS (mg/L) Average Monthly	< 3.5	4.7	9.6	6.4	11.6	9.1	3.2	5	3.2	15.6	9.2	6.5
TSS (mg/L) Raw Sewage Influent Average Monthly	326	227	168	184	259	292	126	187	87	106	128	173
TSS (mg/L) Weekly Average	< 4.5	6.4	10.0	22.8	13.2	14.5	4	6	4.8	28	15.2	6.8

Fecal Coliform (CFU/100 ml) Average Monthly	67	289	508	149	8							
Fecal Coliform (CFU/100 ml) Geometric Mean						101	6	75	15	311	647	52
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	866.4	2419.6	1379.2	149.2	8	353.6	8	2842	17.3	1498	960.6	126.2
Total Nitrogen (mg/L) Average Monthly	37.22	39.03	22.66	31.12	44.16	48.02	52.65	52.23	53.33	36.39	36.69	63.42
Ammonia (lbs/day) Average Monthly	< 0.003	0.007	< 0.008	< 0.005	0.004	< 0.01	0.007	< 0.005	< 0.006	< 0.007	< 0.007	< 0.005
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	0.1	< 0.319	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Total Phosphorus (mg/L) Average Monthly	8.99	7.64	4.89	5.48	5.4	7.27	7.27	6.86	5.8	4.68	0.3	6.98

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.33	XXX	1.0	1/day	Grab
CBOD5	5.0	8.0	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	6.0	9.0	XXX	30.0	45.0	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	2.5	XXX	XXX	13.5	XXX	27	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	0.9	XXX	XXX	4.5	XXX	9	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for CBOD5, Total Suspended Solids, and Fecal Coliforms are technology based on Chapter 92a.47. Monitoring for influent BOD5 and Total Suspended Solids is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16B		56404		Trib 56404 to Kiantone Creek			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.200	Farmington STP	PA0223018a	0.025	CBOD5	25		
				NH3-N	6.76	13.52	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
16B	56404	Trib 56404 to Kiantone Creek			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
1.200	0.025	21.550		7.115	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
5.089	0.361	14.098		0.068	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
9.13	1.038	2.10		0.789	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
6.928	24.467	Owens		6	
<u>Reach Travel Time (days)</u>	Subreach Results				
1.080	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.108	8.09	1.92	7.96	
	0.216	7.18	1.77	8.01	
	0.324	6.36	1.62	8.01	
	0.432	5.64	1.49	8.01	
	0.540	5.00	1.37	8.01	
	0.648	4.44	1.26	8.01	
	0.756	3.93	1.15	8.01	
	0.864	3.49	1.06	8.01	
	0.972	3.09	0.97	8.01	
	1.080	2.74	0.89	8.01	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16B	56404	Trib 56404 to Kiantone Creek	1.200	1518.00	1.23	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.070	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Farmington STP	PA0223018a	0.0250	0.0000	0.0000	0.000	25.00	7.60

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16B	56404	Trib 56404 to Kiantone Creek	0.000	1433.00	1.81	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.070	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
 16B 56404 Trib 56404 to Kiantone Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	1.200 Farmington STP	12.08	29.29	12.08	29.29	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	1.200 Farmington STP	1.68	6.76	1.68	6.76	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	1.20 Farmington STP	25	25	6.76	6.76	4	4	0	0

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16B		56404				Trib 56404 to Kiantone Creek						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1.200	0.09	0.00	0.09	.0387	0.01342	.361	5.09	14.1	0.07	1.080	21.55	7.11
Q1-10 Flow												
1.200	0.06	0.00	0.06	.0387	0.01342	NA	NA	NA	0.06	1.267	22.06	7.16
Q30-10 Flow												
1.200	0.12	0.00	0.12	.0387	0.01342	NA	NA	NA	0.08	0.953	21.24	7.09

Attachment 2

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.086	= Q stream (cfs)	0.5	= CV Daily	
0.025	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 0.728		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.271		5.1d
				WLA_cfc = 0.703
				LTAMULT_cfc = 0.581
				LTA_cfc = 0.408
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.334		AFC
		INST MAX LIMIT (mg/l) = 1.093		
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots$ $\dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots$ $\dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			