

Application Type
 Facility Type
 Major / Minor

Renewal
Municipal
Minor
**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

 Application No. **PA0223051**
 APS ID **1141915**
 Authorization ID **1534790**
Applicant and Facility Information

Applicant Name	<u>Connoquenessing Borough</u>	Facility Name	<u>Connoquenessing Borough STP</u>
Applicant Address	<u>PO Box 471</u>	Facility Address	<u>State Route 68</u>
	<u>Connoquenessing, PA 16027-0471</u>		<u>Connoquenessing, PA 16027</u>
Applicant Contact	<u>Dayna Walko</u>	Facility Contact	<u>Dayna Walko</u>
Applicant Phone	<u>(724) 789-9097</u>	Facility Phone	<u>(724) 789-9097</u>
Client ID	<u>141768</u>	Site ID	<u>531104</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Connoquenessing Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Butler</u>
Date Application Received	<u>July 22, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	<u>---</u>
Purpose of Application	<u>Renewal application for a Minor Sewage Facility – Sewage Treatment Plant (STP)</u>		

Summary of Review

On July 22, 2025, the Department received an application for reissuance of Individual Permit No. PA0223051 which is set to expire on January 31, 2026. There is one outfall (Outfall 001) which discharges into Tributary 35099 to Connoquenessing Creek (WWF).

Act 14 notifications were submitted and received.

The facility is currently in the eDMR system.

The facility was last inspected on March 23, 2023, by Bruce Leidy. No violations were noted.

There are no open violations in WMS for the Subject Client ID (141768) as of September 4, 2025.

Proposed Changes from previous permit:

- More Stringent Ammonia-Nitrogen limits (compliance schedule implemented)
- More stringent TRC limits (compliance schedule implemented)
- Addition of E. Coli monitoring limit
- Increased monitoring frequencies from 3/week to 1/day for DO, pH, and TRC

Approve	Deny	Signatures	Date
X		Carlee Wilson Carlee Wilson / Environmental Engineering Trainee	September 23, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	September 29, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.08
Latitude	40° 48' 39.69"	Longitude	-80° 0' 41.68"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Connoquenessing Creek (WWF)	Stream Code	35099
NHD Com ID	126218464	RMI	0.78
Drainage Area	0.2	Yield (cfs/mi ²)	0.0058
Q ₇₋₁₀ Flow (cfs)	0.00116	Q ₇₋₁₀ Basis	USGS - StreamStats
Elevation (ft)	-	Slope (ft/ft)	-
Watershed No.	20-C	Chapter 93 Class.	WWF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	-	Name	-
Background/Ambient Data			
pH (SU)	-	Data Source	
Temperature (°F)	-	-	
Hardness (mg/L)	-	-	
Other:	-	-	
Nearest Downstream Public Water Supply Intake			
PWS Waters	Beaver River	Flow at Intake (cfs)	561
PWS RMI	3.5	Distance from Outfall (mi)	42.0

Changes Since Last Permit Issuance: Q₇₋₁₀ Flow was updated using USGS StreamStats.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Treatment Facility Summary				
Treatment Facility Name: Connoquenessing Borough STP				
WQM Permit No.		Issuance Date		
1018405		8/08/2021		
WQG028302		6/13/2006		
1000407		10/31/2000		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia and Phosphorus	Activated Sludge	Hypochlorite	0.08
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.08	136	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None

Other Comments:

WQM Permit No. 1018405

This permit was issued on August 8, 2018, which approved the construction and operation of sewage facilities consisting of an 8-inch gravity sewer to serve Phase 3, a 6-inch force main sewer and a pump station with two 10 HP submersible sewage pumps to serve Phase 4-7.

WQM Permit No. 1000407

The treatment facility covered under WQM Permit No. 1000407 includes a communicator with bypass bar screen, two 44,830-gallon aeration tanks, two 7,187-gallon settling tanks, aluminum sulfate addition for phosphorous control to a 2,107-gallon mixing/flocculation tank, two 7,187-gallon phosphorous settling tanks, liquid sodium hypochlorite disinfection with a 2,505-gallon contact tank, and a 4,989-gallon tank for post aeration. Sludge handling consists of two 19,327-gallon aerobic digesters and a sludge bagging unit. This permit was issued on October 31, 2000.

Compliance History

DMR Data for Outfall 001 (from August 1, 2024, to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.034	0.033	0.041	0.046	0.041	0.054	0.039	0.039	0.032	0.024	0.022	0.026
Flow (MGD) Weekly Average	0.044	0.036	0.051	0.058	0.053	0.065	0.047	0.044	0.039	0.025	0.023	0.036
pH (S.U.) Daily Minimum	6.1	6.0	6.0	6.3	6.1	6.2	7.1	6.2	7.0	6.6	6.7	6.3
pH (S.U.) Daily Maximum	6.9	6.4	6.4	6.7	6.7	6.7	7.4	7.3	7.5	7.4	7.4	7.0
DO (mg/L) Daily Minimum	6.0	6.0	6.2	6.2	5.5	5.0	6.0	5.0	5.1	5.0	6.0	5.5
TRC (mg/L) Average Monthly	0.020	0.020	0.010	0.010	0.010	0.010	0.010	0.010	0.020	0.020	0.020	0.020
TRC (mg/L) Instantaneous Maximum	0.050	0.050	0.030	0.010	0.010	0.010	0.050	0.050	0.050	0.050	0.050	0.050
CBOD5 (lbs/day) Average Monthly	0.7	0.6	0.8	1.2	1.1	1.2	1.0	1.0	0.8	0.6	0.6	0.07
CBOD5 (lbs/day) Weekly Average	0.9	0.8	1.2	2.0	1.9	1.5	1.2	1.1	1.0	0.6	0.6	0.09
CBOD5 (mg/L) Average Monthly	2.5	2.0	2.2	3.2	3.3	2.6	3.0	3.0	3.0	3.0	3.0	3.0
CBOD5 (mg/L) Weekly Average	2.5	2.5	2.9	4.2	4.3	2.8	3.1	3.0	3.0	3.0	3.0	3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	54.2	76.0	57.4	108.1	72.5	72.5	69.9	65.3	115.3	55.6	33.0	36.2
BOD5 (mg/L) Raw Sewage Influent Average Monthly	191	276	168	282	212	161	215	201	432	278	180	167
TSS (lbs/day) Average Monthly	0.9	1.7	1.5	1.6	1.2	1.4	1.1	1.0	0.8	0.6	0.6	0.7
TSS (lbs/day) Raw Sewage Influent Average Monthly	50.8	53.9	38.9	42.0	52.3	80.2	91.4	54.0	46.7	34.4	48.3	19.6

NPDES Permit Fact Sheet
Connoquenessing Borough STP

NPDES Permit No. PA0223051

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
TSS (lbs/day) Weekly Average	1.1	2.7	2.1	1.7	1.5	1.9	1.6	1.0	1.0	0.7	0.6	0.9
TSS (mg/L) Average Monthly	3.0	6.0	4.5	3.5	3.0	3.0	3.5	3.0	3.0	3.0	3.0	3.0
TSS (mg/L) Raw Sewage Influent Average Monthly	179	196	114	110	153	178	281	166	175	172	263	90.5
TSS (mg/L) Weekly Average	3.0	9.0	5.0	4.0	3.5	3.5	4.0	3.0	3.0	3.5	3.0	3.0
Fecal Coliform (No./100 ml) Geometric Mean	13	214	4	49	235	135	3	3	3	2	1	1
Fecal Coliform (No./100 ml) Instantaneous Maximum	25	2420	9	2420	2420	260	5	5	5	3	1	1
Total Nitrogen (lbs/day) Average Monthly	6.3	0.9	2.1	7.7	2.7	6.6	5.3	7.3	5.5	1.8	1.9	2.9
Total Nitrogen (mg/L) Average Monthly	22.2	3.2	6.2	20.1	7.9	14.6	16.2	22.6	20.7	9.2	10.1	13.3
Ammonia (lbs/day) Average Monthly	0.2	0.2	0.2	0.03	1.4	2.1	1.5	0.5	0.13	0.1	0.2	0.1
Ammonia (mg/L) Average Monthly	0.7	0.9	0.5	0.6	4.1	4.6	4.6	1.4	0.5	0.6	1.3	0.4
Total Phosphorus (lbs/day) Average Monthly	0.4	0.3	0.3	0.8	0.3	0.6	0.5	0.5	0.3	0.4	0.4	0.3
Total Phosphorus (mg/L) Average Monthly	1.3	1.2	0.9	1.0	1.0	1.3	1.5	1.4	1.2	2.0	2.1	1.6
Total Copper (lbs/day) Average Monthly	0.001	0.001	0.001	0.001	< 0.001	0.001	< 0.001	0.001	0.001	0.001	0.001	0.001
Total Copper (lbs/day) Weekly Average	0.001	0.001	0.001	0.001	< 0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001
Total Copper (ug/L) Average Monthly	0.003	0.004	0.003	0.019	0.003	0.006	0.007	0.008	0.006	0.005	0.007	0.005
Total Copper (ug/L) Weekly Average	0.003	0.004	0.003	0.019	0.003	0.006	0.007	0.008	0.006	0.005	0.007	0.005
Total Lead (lbs/day) Average Monthly	0.001	0.001	0.001	0.001	< 0.001	0.001	< 0.001	< 0.001	0.001	0.001	0.001	0.001
Total Lead (lbs/day) Weekly Average	0.001	0.001	0.001	0.001	< 0.001	0.001	< 0.001	< 0.001	0.001	0.001	0.001	0.001

NPDES Permit Fact Sheet
Connoquenessing Borough STP

NPDES Permit No. PA0223051

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Total Lead (ug/L) Average Monthly	0.10	0.19	0.010	0.3	0.11	0.11	< 1.0	< 1.0	1.0	1.0	1.0	1.0
Total Lead (ug/L) Weekly Average	0.10	0.19	0.010	0.3	0.11	0.11	< 1.0	< 1.0	1.0	1.0	1.0	1.0
Total Zinc (lbs/day) Average Monthly	0.010	0.010	0.010	0.001	0.010	0.010	< 0.020	0.020	0.010	0.010	0.010	0.001
Total Zinc (lbs/day) Weekly Average	0.010	0.010	0.010	0.001	0.010	0.010	< 0.020	0.020	0.010	0.010	0.010	0.001
Total Zinc (ug/L) Average Monthly	30.5	32.5	33.6	10.9	23.9	38.0	56.9	91.5	52.9	35.2	42.6	41.4
Total Zinc (ug/L) Weekly Average	30.5	32.5	33.6	10.9	23.9	38.0	56.9	91.5	52.9	35.2	42.6	41.4

Compliance History

Effluent Violations for Outfall 001, from: September 1, 2024, To: July 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	06/30/25	Geo Mean	214	No./100 ml	200	No./100 ml
Fecal Coliform	06/30/25	IMAX	2420	No./100 ml	1000	No./100 ml
Total Phosphorus	09/30/24	Avg Mo	2.1	mg/L	2.0	mg/L
Total Zinc	12/31/24	Avg Mo	91.5	ug/L	82.6	ug/L

Comments: There have been 4 effluent violations in the past year. These violations are not considered to be chronic.

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 48' 40.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .08
Longitude -80° 0' 41.60"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Table 1. Minimum Technology and BPJ Standards				
Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Monitor	IMAX	-	92a.61
Total Phosphorous	Report	Average Monthly	-	92a.61
Total Nitrogen	Report	Average Monthly	-	92a.61

The above limits are minimum technology-based and BPJ standards for individual sewage permits which are found in the Department's *"Establishing Effluent Limitations for Individual Sewage Permits"* document (SOP. No. BCW-PMT-033). The limits for pH are technology-based on Chapter 93.7. The limits for Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus are based on Chapter 92a.61.

The current permit has sampling frequencies for pH, DO, and TRC as 3/week. However, as stated in Table 6-3 of the Department's *"Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits"* document (362-0400-001) the minimum monitoring frequencies for these parameters should be 1/day. It was acknowledged in the previous permit renewal on the fact sheet addendum that these sampling frequencies would increase with the next renewal - "Based on current DEP policy, the monitoring frequency for Dissolved Oxygen, pH, and Total Residual Chlorine can be set as 3/week, with the understanding that the testing frequency for Dissolved Oxygen, pH, and Total Residual Chlorine are proposed to be collected at a frequency of 1/day in the next NPDES Permit renewal."

Total Residual Chlorine

Using the Department's Total Residual Chlorine (TRC) Spreadsheet, it is proposed to establish more stringent limits of 0.01 mg/l (average monthly) and 0.033 mg/l (IMAX) for TRC in the permit (Attachment 5). Since the permittee does not demonstrate its ability to comply with these new limits at least 75% of the time, a compliance schedule has been implemented into the permit with a three-year timeline to provide time for the new limits to be attained (SOP No. BCW-PMT-002).

Total Phosphorus

The previous 2.0 mg/l limit based on Chapter 96.5 due to the discharge flowing to the Connoquenessing Creek, which is impaired for nutrients, will be retained.

Water Quality-Based Limitations

Table 2. Water Quality Modeling Results		
Parameter	Limit (mg/l)	SBC
CBOD5	25	Average Monthly
	50	IMAX
NH3-N	1.3	Average Monthly
	2.7	IMAX
DO	5.0	Daily Minimum

The above parameters were evaluated using water quality modeling (Attachment 6). This model is used to determine and/or establish WQBELs to protect water quality. In this evaluation, the model provided the above limits for CBOD5, Ammonia-Nitrogen and Dissolved Oxygen.

Carbonaceous Biological Oxygen Demand (CBOD5)

WQM 7.1 resulted in the limits above, which are the same from the previous NPDES permit, therefore there are no proposed changes to the CBOD5 limits.

Ammonia-Nitrogen (NH3-N)

Water Quality Modeling resulted in the above WQBELs for ammonia-nitrogen. These limits are more stringent than the current permit limits and therefore will be proposed into this permit renewal. According to eDMR data, the limits are achievable, but a compliance schedule has been added to provide time for the new limits to be attained. To calculate the winter limits, a seasonal multiplier of 3 is applied to the summer limits above.

Dissolved Oxygen (DO)

The Dissolved Oxygen daily minimum of 5.0 mg/l will be retained with this renewal. The technology-based minimum of 5.0 mg/l is recommended by the Water Quality Model (Attachment 6) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. The DO goal is 5.0 mg/l for WWF so this limit will protect water quality of the receiving stream.

Toxic Pollutants

Table 3. Toxics Management Spreadsheet Results		
Parameter	Limit (µg/l)	SBC
Total Lead	Report	Average Monthly
	Report	Daily Maximum
	Report	IMAX
Total Zinc	Report	Average Monthly
	Report	Daily Maximum
	Report	IMAX

Since sampling is conducted and limits exist for Total Copper, Total Lead, and Total Zinc, the long-term concentration averages from the permittee's eDMR data were used to run the Toxics Management Spreadsheet (TMS) to determine if more stringent limits are needed to protect water quality. This evaluation provided the above results (Table 3) which are less stringent than the limitations of the current permit. Therefore, the current permit limits will be retained into the next permit.

Anti-Backsliding

Table 3. Effluent Limitations in the Current Permit for Outfall 001

Parameter	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum	
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	3/week
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	3/week
TRC	XXX	XXX	XXX	0.020	XXX	0.065	3/week
CBOD5	29.1	46.7	XXX	25.0	40.0	50	2/month
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month
TSS	35.0	52.5	XXX	30.0	45.0	60	2/month
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month
Ammonia Nov 1 - Apr 30	3.6	XXX	XXX	5.4	XXX	10.8	2/month
Ammonia May 1 - Oct 31	1.2	XXX	XXX	1.8	XXX	3.6	2/month
Total Phosphorus	1.3	XXX	XXX	2.0	XXX	4	2/month
Total Copper (ug/L)	0.006	0.012	XXX	9.6	19.3	24.1	1/month
Total Lead (ug/L)	0.002	0.004	XXX	3.4	6.8	8.5	1/month
Total Zinc (ug/L)	0.055	0.110	XXX	82.6	165.2	206.5	1/month

Comments: More stringent limits are proposed for the highlighted items above. All other permit limitations, monitoring, requirements, and conditions will be retained into the next permit with the addition of E. Coli monitoring.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through End of Interim Period 1.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.020	XXX	0.065	1/day	Grab
CBOD5	29.1	46.7	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	35.0	52.5	XXX	30.0	45.0	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	3.6	XXX	XXX	5.4	XXX	10.8	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	1.2	XXX	XXX	1.8	XXX	3.6	2/month	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through End of Interim Period 1)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	1.3	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Copper (ug/L)	0.006	0.012	XXX	9.6	19.3	24.1	1/month	8-Hr Composite
Total Lead (ug/L)	0.002	0.004	XXX	3.4	6.8	8.5	1/month	8-Hr Composite
Total Zinc (ug/L)	0.055	0.110	XXX	82.6	165.2	206.5	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 – after disinfection

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: End of Interim Period 1 through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.010	XXX	0.033	1/day	Grab
CBOD5	29.1	46.7	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	35.0	52.5	XXX	30.0	45.0	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	2.6	XXX	XXX	3.9	XXX	8.1	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	0.8	XXX	XXX	1.3	XXX	2.7	2/month	8-Hr Composite


Outfall 001, Continued (from End of Interim Period 1 through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	1.3	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Copper (ug/L)	0.006	0.012	XXX	9.6	19.3	24.1	1/month	8-Hr Composite
Total Lead (ug/L)	0.002	0.004	XXX	3.4	6.8	8.5	1/month	8-Hr Composite
Total Zinc (ug/L)	0.055	0.110	XXX	82.6	165.2	206.5	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 – after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for influent BOD5 and Total Suspended Solids is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for Total Nitrogen, Total Copper, Total Lead, and Total Zinc is based on Chapter 92a.61. The limits for Total Phosphorus are technology-based on Chapter 96.5

Attachment 1
eMapPA – Receiving Stream Designated Use



Attachment 2
Google Earth – Aerial Site View



Attachment 3
USGS StreamStats (Outfall 001) – Drainage Area Details

StreamStats Report

Region ID:

PA

Workspace ID:


PA20250911143853245000

Clicked Point (Latitude, Longitude):

40.81118, -80.01184

Time:

2025-09-11 10:39:16 -0400



» Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.2	square miles	2.26	1400
ELEV	Mean Basin Elevation	1267	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0047	ft^3/s
30 Day 2 Year Low Flow	0.0098	ft^3/s
7 Day 10 Year Low Flow	0.00116	ft^3/s
30 Day 10 Year Low Flow	0.00283	ft^3/s
90 Day 10 Year Low Flow	0.00633	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.

Attachment 4
USGS StreamStats (Endpoint) – Drainage Area Details

StreamStats Report

Region ID:

PA

Workspace ID:


PA20250911144549947000

Clicked Point (Latitude, Longitude):

40.80582, -79.99939

Time:

2025-09-11 10:46:14 -0400



» Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.44	square miles	2.26	1400
ELEV	Mean Basin Elevation	1233	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0113	ft^3/s
30 Day 2 Year Low Flow	0.0226	ft^3/s
7 Day 10 Year Low Flow	0.00303	ft^3/s
30 Day 10 Year Low Flow	0.00692	ft^3/s
90 Day 10 Year Low Flow	0.0148	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.

Attachment 5
Total Residual Chlorine Spreadsheet

TRC EVALUATION																																			
<table border="1"> <tr><td>0.00116</td><td>= Q stream (cfs)</td><td>0.5</td><td>= CV Daily</td></tr> <tr><td>0.08</td><td>= Q discharge (MGD)</td><td>0.5</td><td>= CV Hourly</td></tr> <tr><td>30</td><td>= no. samples</td><td>1</td><td>= AFC_Partial Mix Factor</td></tr> <tr><td>0.3</td><td>= Chlorine Demand of Stream</td><td>1</td><td>= CFC_Partial Mix Factor</td></tr> <tr><td>0</td><td>= Chlorine Demand of Discharge</td><td>15</td><td>= AFC_Criteria Compliance Time (min)</td></tr> <tr><td>0.5</td><td>= BAT/BPJ Value</td><td>720</td><td>= CFC_Criteria Compliance Time (min)</td></tr> <tr><td></td><td>= %Factor of Safety (FOS)</td><td></td><td>=Decay Coefficient (K)</td></tr> </table>				0.00116	= Q stream (cfs)	0.5	= CV Daily	0.08	= Q discharge (MGD)	0.5	= CV Hourly	30	= no. samples	1	= AFC_Partial Mix Factor	0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		= %Factor of Safety (FOS)		=Decay Coefficient (K)				
0.00116	= Q stream (cfs)	0.5	= CV Daily																																
0.08	= Q discharge (MGD)	0.5	= CV Hourly																																
30	= no. samples	1	= AFC_Partial Mix Factor																																
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor																																
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)																																
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)																																
	= %Factor of Safety (FOS)		=Decay Coefficient (K)																																
Source	Reference	AFC Calculations		Reference	CFC Calculations																														
TRC	1.3.2.iii	WLA_afc = 0.022		1.3.2.iii	WLA_cfc = 0.014																														
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581																														
PENTOXSD TRG	5.1b	LTA_afc= 0.008		5.1d	LTA_cfc = 0.008																														
Effluent Limit Calculations																																			
PENTOXSD TRG	5.1f	AML MULT = 1.231																																	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.010			CFC																														
		INST MAX LIMIT (mg/l) = 0.033																																	
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$																																	
LTAMULT_afc		$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$																																	
LTA_afc		wla_afc*LTAMULT_afc																																	
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$																																	
LTAMULT_cfc		$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$																																	
LTA_cfc		wla_cfc*LTAMULT_cfc																																	
AML MULT		EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))																																	
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)																																	
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)																																	

Attachment 6
WQM 7.1 Model Results

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
		20C	35099	Trib 35099 of Connoquenessing Creek			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.780	Connoquenessing	PA	0.000	CBOD5	25		
				NH3-N	1.39	2.78	
				Dissolved Oxygen			5

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
		Trib 35099 of Connoquenessing Creek								
20C	35099	0.780	1213.00	0.20	0.00000	0.00	<input checked="" type="checkbox"/>			

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream Temp (°C)	pH
									Temp	pH		
Q7-10	0.006	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Connoquenessing	PA0223051	0.0000	0.0000	0.0800	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>		<u>Stream Name</u>							
20C			35099		Trib 35099 of Connoquenessing Creek							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
0.780	0.00	0.00	0.00	.1238	0.05059	.397	2.78	7.01	0.11	0.410	24.95	7.00
Q1-10 Flow												
0.780	0.00	0.00	0.00	.1238	0.05059	NA	NA	NA	0.11	0.411	24.97	7.00
Q30-10 Flow												
0.780	0.00	0.00	0.00	.1238	0.05059	NA	NA	NA	0.11	0.410	24.94	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
------------------	--------------------	--------------------

20C

35099

Trib 35099 of Connoquenessing Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.780	Connoquenessin	11.1	11.17	11.1	11.17	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.780	Connoquenessin	1.37	1.39	1.37	1.39	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.78	Connoquenessing	25	25	1.39	1.39	5	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	35099	Trib 35099 of Connoquenessing Creek		
<u>RMI</u> 0.780	<u>Total Discharge Flow (mgd)</u> 0.080	<u>Analysis Temperature (°C)</u> 24.954	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 2.782	<u>Reach Depth (ft)</u> 0.397	<u>Reach WDRatio</u> 7.012	<u>Reach Velocity (fps)</u> 0.113	
<u>Reach CBOD5 (mg/L)</u> 24.79	<u>Reach Kc (1/days)</u> 1.498	<u>Reach NH3-N (mg/L)</u> 1.38	<u>Reach Kn (1/days)</u> 1.025	
<u>Reach DO (mg/L)</u> 5.030	<u>Reach Kr (1/days)</u> 31.347	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 0.410	Subreach Results			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.041	22.94	1.32	5.77
	0.082	21.24	1.27	6.09
	0.123	19.66	1.21	6.30
	0.164	18.20	1.16	6.46
	0.205	16.85	1.12	6.60
	0.246	15.60	1.07	6.72
	0.287	14.44	1.03	6.84
	0.328	13.37	0.98	6.95
	0.369	12.37	0.94	7.05
	0.410	11.45	0.90	7.15

Attachment 7
Toxics Management Spreadsheet

Instructions	Discharge	Stream											
Facility: Connoquenessing STP NPDES Permit No.: PA0223051 Outfall No.: 001													
Evaluation Type: _____ Wastewater Description: _____													
Discharge Characteristics													
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)						
			AFC	CFC	THH	CRL	Q_{7-10}	Q_h					
0.08	100	7											
Discharge Pollutant			Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L											
	Chloride (PWS)	mg/L											
	Bromide	mg/L											
	Sulfate (PWS)	mg/L											
	Fluoride (PWS)	mg/L											
	Total Aluminum	$\mu\text{g/L}$											
	Total Antimony	$\mu\text{g/L}$											
	Total Arsenic	$\mu\text{g/L}$											
	Total Barium	$\mu\text{g/L}$											
	Total Beryllium	$\mu\text{g/L}$											
	Total Boron	$\mu\text{g/L}$											
	Total Cadmium	$\mu\text{g/L}$											
	Total Chromium (III)	$\mu\text{g/L}$											
	Hexavalent Chromium	$\mu\text{g/L}$											
	Total Cobalt	$\mu\text{g/L}$											
	Total Copper	$\mu\text{g/L}$	0.007										
Free Cyanide	$\mu\text{g/L}$											0.007	
Total Cyanide	$\mu\text{g/L}$											0.007	
Dissolved Iron	$\mu\text{g/L}$												
Total Iron	$\mu\text{g/L}$												
Total Lead	$\mu\text{g/L}$	0.6325											
Total Manganese	$\mu\text{g/L}$												
Total Mercury	$\mu\text{g/L}$												
Total Nickel	$\mu\text{g/L}$												
Total Phenols (Phenolics) (PWS)	$\mu\text{g/L}$											0.007	
Total Selenium	$\mu\text{g/L}$											0.007	
Total Silver	$\mu\text{g/L}$												
Total Thallium	$\mu\text{g/L}$												
Total Zinc	$\mu\text{g/L}$	46.5											
Total Molybdenum	$\mu\text{g/L}$												
Group 2													



Stream / Surface Water Information

Connoquenessing STP, NPDES Permit No. PA0223051, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: _____ No. Reaches to Model: 1

Statewide Criteria
 Great Lakes Criteria
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	035099	0.78	1213	0.2			Yes
End of Reach 1	035099	0.02	1010	0.44			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	0.78	0.0058										100	7		
End of Reach 1	0.02	0.0069													

Q_h

Location	RMI	LFY (cfs/mi ²)	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	0.78														
End of Reach 1	0.02														



Model Results

Connoquenessing STP, NPDES Permit No. PA0223051, Outfall 001

Instructions	Results	RETURN TO INPUTS	SAVE AS PDF	PRINT	<input checked="" type="radio"/> All	<input type="radio"/> Inputs	<input type="radio"/> Results	<input type="radio"/> Limits
--------------	---------	----------------------------------	-----------------------------	-----------------------	--------------------------------------	------------------------------	-------------------------------	------------------------------

Hydrodynamics

Wasteload Allocations

AFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	13.439	14.0	14.1	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	82.4	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	121	Chem Translator of 0.978 applied

CFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	8.956	9.33	9.42	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.517	3.18	3.21	Chem Translator of 0.791 applied
Total Zinc	0	0		0	118.139	120	121	Chem Translator of 0.986 applied

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	

Model Results

9/25/2025

Page 5

Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Lead	Report	Report	Report	Report	Report	µg/L	3.21	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	Report	Report	Report	Report	Report	µg/L	120	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., < Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Copper	9.42	µg/L	Discharge Conc ≤ 10% WQBEL

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment 6)
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment 7)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment 5)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]