

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0228095
APS ID 1020695
Authorization ID 1321999

Applicant and Facility Information

Applicant Name	<u>Tulpehocken Spring Water Co.</u>	Facility Name	<u>Tulpehocken Spring Water Co.</u>
Applicant Address	<u>750 Point Township Drive</u> <u>Northumberland, PA 17857-8789</u>	Facility Address	<u>750 Point Township Drive</u> <u>Northumberland, PA 17857-8789</u>
Applicant Contact	<u>Greg Miles</u>	Facility Contact	<u>Greg Miles</u>
Applicant Phone	<u>(800) 346-9284</u>	Facility Phone	<u>(800) 346-9284</u>
Client ID	<u>59009</u>	Site ID	<u>518639</u>
SIC Code	<u>2000</u>	Municipality	<u>Point Township</u>
SIC Description	<u>Food and Kindred Products</u>	County	<u>Northumberland</u>
Date Application Received	<u>July 28, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 5, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for the renewal of the existing Individual NPDES permit.</u>		

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

The discharge is distilled water that is used in the final stage of a bottle washing operation and all other process wash water goes to the sanitary sewer.

Approve	Deny	Signatures	Date
X		<i>Jonathan P. Peterman</i> Jonathan P. Peterman / Project Manager	March 30, 2021
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	March 31, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0027</u>
Latitude	<u>40° 54' 32.61"</u>	Longitude	<u>-76° 45' 51.12"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>IW Process Effluent without ELG</u>			
Receiving Waters	<u>Unnamed Stream</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>65643213</u>	RMI	<u>0.3</u>
Drainage Area	<u>8.44 mi^2 at Lithia Spring Creek</u>	Yield (cfs/mi^2)	<u>0.06</u>
Q7-10 Flow (cfs)	<u>0.5</u>	Q7-10 Basis	<u>Stream Gage (01554000)</u>
Elevation (ft)	<u>450</u>	Slope (ft/ft)	<u>n/a</u>
Watershed No.	<u>5-E</u>	Chapter 93 Class.	<u>TSF-MF</u>
Existing Use	<u>TSF-MF</u>	Existing Use Qualifier	<u>n/a</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Not Assessed (man-made canal)</u>		
Cause(s) of Impairment	<u>N/A</u>		
Source(s) of Impairment	<u>N/A</u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>PA American Water in Milton, PA</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>728</u>
PWS RMI	<u>10.5</u>	Distance from Outfall (mi)	<u>4</u>

Changes Since Last Permit Issuance: The Q7-10 was determined at the confluence of the canal with Lithia Spring Creek. The updated Q7-10 data was obtained from the updated stream gage information obtained from *Stuckey, M.H., and Roland, M.A., 2011, Selected Streamflow Statistics for Streamgage Locations In and Near Pennsylvania*. A comparative analysis was not conducted given that a stream gage (01554000) is located immediately downstream of the discharge location. The associated stream data is attached in Appendix A.

Other Comments: None.

Anti-Backsliding

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

Chesapeake Bay Requirements

This facility is classified as a "non-significant" IW given that the gross effluent discharges do not exceed 75 lbs/day of TN or 25 lbs/day of TP. The permittee will not be required to monitor and report TN and TP throughout the permit term in accordance with the Phase II WIP Chesapeake Bay Strategy for non-significant industrial waste facilities. Non-significant IW dischargers should receive monitoring requirements in permits if there is any possibility of a net increase in nutrients as a result of facility processes, and monitoring frequencies should be established using the general guidance in the Phase II WIP Supplement. It was determined that there is no potential that the associated facility processes could create a net increase in TP.

Existing Effluent Limitations and Monitoring Requirements

Outfall 001 - Existing Limits

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	2/month	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	2/month	Grab
Total Dissolved Solids	XXX	XXX	XXX	500	750 Daily Max	XXX	2/month	Grab
MBAS	XXX	XXX	XXX	Report Daily Max	XXX	0.5	2/month	Grab

The existing effluent limits for Outfall 001 were based on a design flow of 0.0027 MGD

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.0027</u>
Latitude <u>40° 54' 33.10"</u>	Longitude <u>-76° 45' 51.40"</u>
Wastewater Description: <u>IW Process Effluent without ELG</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l) (Average Monthly)	Limit (mg/l) (Daily Maximum)	Limit (mg/l) (Inst. Maximum)	Federal Regulation	State Regulation
pH	6-9 at all times	-		§133.102(c)	§95.2

Effluent Limits Guidelines (ELGs)

There are no ELGs associated with this facilities processes.

Water Quality-Based Limitations

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for toxics, the Department utilizes the Toxics Management Spreadsheet.

Toxics Management Spreadsheet

Toxics Management Spreadsheet is a single discharge wasteload allocation program for toxics that uses a mass-balance water quality analysis to determine recommended water quality-based effluent limits. The model incorporates consideration for mixing, first-order decay and other factors to computes a Wasteload Allocation (WLA) for each applicable criterion. Finally, the model determines a maximum water quality-based effluent limitation (WQBEL) for each parameter and outputs the more stringent of the WQBEL or the input concentration. The output of which is the recommends average monthly and maximum daily effluent limitations.

A "Reasonable Potential Analysis" (See Appendix B) determined that the following parameters were candidates for monitoring or limitations shown below:

Parameter	Effluent Limit (µg/l)	WQBEL (µg/l)	WQBEL Criterion	Permit Recommendation
Total Copper	870	1,815	AFC	Monitor

Comments: Monitoring for Total Copper will be required on an annual basis.

Best Professional Judgement (BPJ) Limitations

Comments: The existing limitations for total dissolved solids (TDS), total suspended solids (TSS), and methylene blue active substance (MBAS) were previously established as BPJ limitations.

Additional Considerations

None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001) and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

Outfall 001 - Proposed Limits

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	2/month	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	2/month	Grab
Total Dissolved Solids	XXX	XXX	XXX	500	750 Daily Max	XXX	2/month	Grab
MBAS	XXX	XXX	XXX	Report Daily Max	XXX	0.5	2/month	Grab
Total Copper (µg/l)	XXX	XXX	XXX	Report Annual Average	XXX	XXX	1/year	Grab

The proposed effluent limits for Outfall 001 were based on a design flow of 0.0027 MGD.

General Information

The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001)*, Chapter 5 - Specifying Effluent Limitations in NPDES Permits. The existing monitoring frequencies and sample types for these parameters generally correspond with the *Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001)* Table 6-4 and will remain.

Flow

Reporting of maximum daily flow and monthly average is appropriate for this type of facility and consistent with similar facility types.

pH

The existing permit limits for pH were implemented in accordance with 25 PA Code §95.2(1), which provide the basis of effluent limitations for pH, and shall remain.

Total Dissolved Solids, Total Suspended Solids, and MBAS

The existing limitations for total dissolved solids (TDS), total suspended solids (TSS), and methylene blue active substance (MBAS) were previously established as BPJ limitations.

Total Copper

Given that Total Copper was determined to be a pollutant of concern, monitoring will be required on an annual basis.

Other Comments: None.

Stormwater Requirements

The facility has a Standard Industrial Classification (SIC) code of 2089. The stormwater from the site is covered under a no exposure certificate.

Compliance History

Summary of Inspections -The last facility inspection was conducted on 2/4/2020 by the Department which revealed that there were no issues and the facility was operating normally.

WMS Query Summary – A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed no open violations.

Summary of e-DMR- A review of the e-DMR data over the previous year reveals no effluent violations listed in the compliance section below.

Compliance History

DMR Data for Outfall 001 (from February 1, 2020 to January 31, 2021)

Parameter	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20
Flow (MGD) Average Monthly	0.0012	0.0012	0.0012	0.0012	0.0014	0.0014	0.0014	0.0014	0.0015	0.0014	0.0014	0.0015
Flow (MGD) Daily Maximum	0.0013	0.0013	0.0013	0.0013	0.0016	0.0015	0.0016	0.0015	0.0016	0.0016	0.0016	0.0016
pH (S.U.) Minimum	6.8	6.8	6.8	6.8	6.8	6.8	6.7	6.8	6.7	6.9	6.7	6.8
pH (S.U.) Maximum	6.8	6.8	6.8	6.8	6.8	6.9	6.8	6.9	6.8	6.7	6.9	6.7
TSS (mg/L) Average Monthly	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5	< 5.0	2.5	< 5.0
TSS (mg/L) Weekly Average	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	5.0	< 5.0
Total Dissolved Solids (mg/L) Average Monthly	121	57	67	124	107	109	126	111	84	120	215	121
Total Dissolved Solids (mg/L) Daily Maximum	146	62	76	144	128	112	186	116	142	124	296	166
MBAS (mg/L) Daily Maximum	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05


Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment B)
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

APPENDIX A

Q7-10 ANALYSIS AND STREAM DATA

StreamStats Report

Region ID: PA
 Workspace ID: PA20210329181348284000
 Clicked Point (Latitude, Longitude): 40.90811, -76.76632
 Time: 2021-03-29 14:14:05 -0400



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	8.44	square miles
PRECIP	Mean Annual Precipitation	41	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	1.7	miles per square mile
ROCKDEP	Depth to rock	4.4	feet
CARBON	Percentage of area of carbonate rock	13.74	percent

General Disclaimers

The delineation point is in an exclusion area. undefined

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	8.44	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	1.7	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	13.74	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIl: Prediction Interval-Lower, Plu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	1.02	ft ³ /s	38	38
30 Day 2 Year Low Flow	1.36	ft ³ /s	33	33
7 Day 10 Year Low Flow	0.468	ft ³ /s	51	51
30 Day 10 Year Low Flow	0.631	ft ³ /s	46	46
90 Day 10 Year Low Flow	0.973	ft ³ /s	36	36


Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

StreamStats Report

Region ID: PA
 Workspace ID: PA20210330151846628000
 Clicked Point (Latitude, Longitude): 40.90510, -76.76484
 Time: 2021-03-30 11:19:02 -0400



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	8.92	square miles
PRECIP	Mean Annual Precipitation	41	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	1.64	miles per square mile
ROCKDEP	Depth to rock	4.4	feet
CARBON	Percentage of area of carbonate rock	13	percent

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	8.92	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	1.64	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	13	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIl: Prediction Interval-Lower, Plu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	1.11	ft ³ /s	38	38
30 Day 2 Year Low Flow	1.48	ft ³ /s	33	33
7 Day 10 Year Low Flow	0.512	ft ³ /s	51	51
30 Day 10 Year Low Flow	0.689	ft ³ /s	46	46
90 Day 10 Year Low Flow	1.06	ft ³ /s	36	36

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the

APPENDIX B

TOXICS MANAGEMENT SPREADSHEET



Discharge Information

Instructions Discharge Stream

Facility: Tulpehocken Spring Water Co. NPDES Permit No.: PA0228095 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Bottle water rinse water

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.0027	16	7						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	86								
	Chloride (PWS)	mg/L	2.4								
	Bromide	mg/L	< 0.6								
	Sulfate (PWS)	mg/L	4.1								
	Fluoride (PWS)	mg/L	< 0.2								
Group 2	Total Aluminum	µg/L	71								
	Total Antimony	µg/L	1								
	Total Arsenic	µg/L	< 1.5								
	Total Barium	µg/L	8.6								
	Total Beryllium	µg/L	< 0.5								
	Total Boron	µg/L	< 50								
	Total Cadmium	µg/L	< 0.2								
	Total Chromium (III)	µg/L	1								
	Hexavalent Chromium	µg/L	0.29								
	Total Cobalt	µg/L	< 2.5								
	Total Copper	µg/L	870								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	< 13								
	Dissolved Iron	µg/L	< 60								
	Total Iron	µg/L	19								
	Total Lead	µg/L	0.55								
	Total Manganese	µg/L	1.1								
	Total Mercury	µg/L	0.0014								
	Total Nickel	µg/L	1.6								
	Total Phenols (Phenolics) (PWS)	µg/L	3								
Total Selenium	µg/L	< 2									
Total Silver	µg/L	< 0.5									
Total Thallium	µg/L	< 0.5									
Total Zinc	µg/L	52									
Total Molybdenum	µg/L	< 1									
Acrolein	µg/L										
Acrylamide	µg/L										
Acrylonitrile	µg/L										
Benzene	µg/L										
Bromoform	µg/L										



Stream / Surface Water Information

Tulpehocken Spring Water Co., NPDES Permit No. PA0228095, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Lithia Spring Creek No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	027289	0.3	438	8.44			Yes
End of Reach 1	027289	0	428	8.92			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	0.3	0.1										100	7		
End of Reach 1	0	0.1													

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	0.3														
End of Reach 1	0														



Model Results

Tulpehocken Spring Water Co., NPDES Permit No. PA0228095, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 9.391

PMF: 1

Analysis Hardness (mg/l): 99.586

Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	152,298	
Total Antimony	0	0		0	1,100	1,100	223,370	
Total Arsenic	0	0		0	340	340	69,042	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	4,264,338	
Total Boron	0	0		0	8,100	8,100	1,644,816	
Total Cadmium	0	0		0	2,006	2.12	431	Chem Translator of 0.944 applied
Total Chromium (III)	0	0		0	567.832	1,797	364,893	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	3,309	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	19,291	
Total Copper	0	0		0	13.387	13.9	2,832	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	64.291	81.2	16,492	Chem Translator of 0.792 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	334	Chem Translator of 0.85 applied
Total Nickel	0	0		0	466.597	468	94,939	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	3.194	3.76	763	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	13,199	
Total Zinc	0	0		0	116.770	119	24,245	Chem Translator of 0.978 applied

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	44,674	
Total Arsenic	0	0		0	150	150	30,460	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	832,561	
Total Boron	0	0		0	1,600	1,600	324,902	
Total Cadmium	0	0		0	0.245	0.27	54.8	Chem Translator of 0.909 applied
Total Chromium (III)	0	0		0	73.863	85.9	17,441	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	2,111	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	3,858	
Total Copper	0	0		0	8.924	9.3	1,888	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	304,596	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.505	3.16	643	Chem Translator of 0.792 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	184	Chem Translator of 0.85 applied
Total Nickel	0	0		0	51.824	52.0	10,555	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	1,013	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	2,640	
Total Zinc	0	0		0	117.725	119	24,245	Chem Translator of 0.986 applied

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	1,137	
Total Arsenic	0	0		0	10	10.0	2,031	
Total Barium	0	0		0	2,400	2,400	487,353	
Total Boron	0	0		0	3,100	3,100	629,498	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	

Hexavalent Chromium	0	0		0	N/A	N/A	N/A
Total Cobalt	0	0		0	N/A	N/A	N/A
Total Copper	0	0		0	N/A	N/A	N/A
Dissolved Iron	0	0		0	300	300	60,919
Total Iron	0	0		0	N/A	N/A	N/A
Total Lead	0	0		0	N/A	N/A	N/A
Total Manganese	0	0		0	1,000	1,000	203,064
Total Mercury	0	0		0	0.050	0.05	10.2
Total Nickel	0	0		0	610	610	123,869
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A
Total Selenium	0	0		0	N/A	N/A	N/A
Total Silver	0	0		0	N/A	N/A	N/A
Total Thallium	0	0		0	0.24	0.24	48.7
Total Zinc	0	0		0	N/A	N/A	N/A

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	Report	Report	Report	Report	Report	µg/L	1,815	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	Discharge Conc < TQL
Total Aluminum	97,617	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	1,137	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	487,353	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	324,902	µg/L	Discharge Conc < TQL
Total Cadmium	54.8	µg/L	Discharge Conc < TQL
Total Chromium (III)	17,441	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	2,111	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	3,858	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	60,919	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	304,596	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	643	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	203,064	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	10.2	µg/L	Discharge Conc ≤ 10% WQBEL
Total Nickel	10,555	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	1,013	µg/L	Discharge Conc < TQL
Total Silver	489	µg/L	Discharge Conc ≤ 10% WQBEL
Total Thallium	48.7	µg/L	Discharge Conc < TQL
Total Zinc	15,540	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS