



Application Type	<u>Amendment, Major</u>
Facility Type	<u>Industrial</u>
Major / Minor	<u>Minor</u>

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No.	PA0228206 A-1
APS ID	1122577
Authorization ID	1501135

Applicant and Facility Information

Applicant Name	Clearfield Municipal Authority	Facility Name	Montgomery Run Water Treatment Facility
Applicant Address	107 E Market Street	Facility Address	1479 104th Cavalry Road
	Clearfield, PA 16830-2405		Clearfield, PA 16830
Applicant Contact	Richard Lopez	Facility Contact	
Applicant Phone	(814) 765-9609	Facility Phone	
Client ID	87622	Site ID	530691
SIC Code	4941	Municipality	Pike Township
SIC Description	Trans. & Utilities - Water Supply	County	Clearfield
Date Application Received	September 26, 2024	EPA Waived?	Yes
Date Application Accepted	October 10, 2024	If No, Reason	
Purpose of Application	Relocation of existing outfall and increase of design discharge flow.		

Summary of Review

The above applicant has submitted a NPDES amendment application for their existing facility located in Pike Township, Clearfield County. The facility is a potable Water Treatment Facility (WTF) that serves portions of Clearfield County. The existing potable WTF is a conventional filter system that is being replaced by a membrane system. This permit amendment is for the relocation of the existing outfall and to increase the design discharge flow of the WTF.

The existing discharge is pumped to an UNT of Montgomery Creek, just upgradient of the WTF. The application proposes to move the outfall to Montgomery Creek approximately 250 feet downstream of the existing location. Both streams are considered CWF-MF by the Department's Chapter 93 Regulations. In addition to relocating the discharge, the amendment application proposes to increase the design discharge flow from 0.018 MGD to 0.0375 MGD.

All applicable Department Standard Operating Procedures were followed during the review of this application, unless otherwise stated.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Chad A. Fabian</i> Chad A. Fabian / Project Manager	February 6, 2025
X		<i>Nicholas W. Hartranft, P.E.</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	February 7, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0375
Latitude	41° 1' 28"	Longitude	-78° 30' 5"
Wastewater Description:	Water Treatment filter backwash water		
Receiving Waters	Montgomery Creek (CWF)	Stream Code	26623
NHD Com ID	61830503	RMI	2.9
Drainage Area	12.4 mi ²	Yield (cfs/mi ²)	n/a
Q ₇₋₁₀ Flow (cfs)	1.55	Q ₇₋₁₀ Basis	Stream delineation
Elevation (ft)	1274	Slope (ft/ft)	n/a
Watershed No.	8-B	Chapter 93 Class.	CWF
Existing Use Exceptions to Use	Same	Existing Use Qualifier	n/a
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	Metals and pH		
Source(s) of Impairment	Acid Mine Drainage		
TMDL Status	Final	Name	Montgomery Creek
Nearest Downstream Public Water Supply Intake	PA American Water near Milton, PA approximately 160 miles downstream on the W. Branch Susquehanna River		

Changes Since Last Permit Issuance: The outfall has been moved approximately 250 feet downstream, therefore the drainage basin area has been adjusted from 11.7 mi² to 12.4 mi² (See attached Streamstats for drainage area). The discharge design flow has been increased from 0.018 MGD to 0.0375 MGD.

Other Comments:

The Q_{7,10} was recalculated since the discharge point has moved. During the most recent renewal, the Q_{7,10} was 1.46 cfs with a drainage basin area of 11.7 mi². Using a ratio (cfs/mi²) and the new drainage basin area of 12.4 mi², the new Q_{7,10} has been calculated to be 1.55 cfs.

Compliance History	
Summary of DMRs:	A review of the eDMR data shows no exceedances of effluent limits in the past 12 months.
Summary of Inspections:	The most recent inspection by the Department was conducted on 1/12/24. The only violations noted were minor TSS exceedances in April of 2023. The average monthly limitations for TSS is 30 mg/l, while the permittee reported 31.8. There are currently no open violations at the facility.

Development of Effluent Limitations

Technology Based Effluent Limitations

The Department's *Technology-Based Control Requirements for Water Treatment Plant Wastes* (DEP #362-2183-003, 1997) is a guidance that provides the following technology standards for discharges associated with Water Treatment Plants:

Parameter	Monthly Average (mg/L)	Daily Maximum (mg/L)
Suspended Solids	30.0	60.0
Iron (Total)	2.0	4.0
Aluminum (Total)	4.0	8.0
Manganese (Total)	1.0	2.0
pH (SU)	6.0 to 9.0 at all times	
Total Chlorine Residual	0.5	

Water Quality Based Effluent Limitations (WQBELs)

Total Residual Chlorine (TRC)

The Department's TRC evaluation spreadsheet was used to evaluate if the existing 0.5 mg/l monthly average technology based TRC limit. The attached model shows that the existing limitation is protective of water quality standards.

Toxics Screening Analysis

The Department's Toxic Management Spreadsheet (TMS) was used to determine reasonable potential (RP) and calculate water quality-based effluent limitations (WQBELs) for the discharge. The new design discharge flow of 0.0375 MGD and the new $Q_{7,10}$ of 1.55 cfs were used to evaluate the parameters that were sampled during the previous NPDES renewal to determine if any WQBELs applied. The attached model shows that no WQBELs are warranted for this discharge. The TMS did recommend monitoring for total aluminum.

Total Maximum Daily Loads

Stream assessments have determined that the Montgomery Creek watershed is affected by pollution from Acid Mine Drainage (AMD). This pollution has caused high levels of metals and low pH in the main stem of Montgomery Creek and its unnamed tributaries. To address this impairment, a Total Maximum Daily Load (TMDL) was prepared by the Susquehanna River Basin Commission (SRBC) for Montgomery Creek and approved by the EPA in 2003. The CMA WTF discharge was not identified as a source of metals in the watershed and was therefore not assigned waste-load allocations (WLAs) for the purposes of the TMDL.

In order to comply with the TMDL at a later issuance/renewal, the Department has established effluent limits for total aluminum, total iron and total manganese at the water quality criteria established in 25 PA Code Chapter 93:

Parameter	WQBEL	Guidance (mg/l)	WQ Criteria/Proposed Effluent Limit (mg/l)	Regulation
Total Aluminum	25.72	4.0	0.75	25 PA § 93.8c
Total Iron	80.25	2.0	1.50	25 PA § 93.7
Total Manganese	53.50	1.0	1.00	25 PA § 93.7

By assigning the water quality criteria as effluent limitations, the discharge cannot be expected to contribute to the impairment.

Anti-Back Sliding

This draft permit does not propose a relaxation in any of the existing effluent limitations.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
TSS	XXX	XXX	XXX	30.0	60.0	75	1/month	Grab
Total Aluminum	0.23	0.46 Daily Max	XXX	0.75	1.50	1.88	1/week	Grab
Total Iron	0.47	0.94 Daily Max	XXX	1.50	3.00	3.75	1/week	Grab
Total Manganese	0.31	0.62 Daily Max	XXX	1.00	2.00	2.5	1/week	Grab

Compliance Sampling Location: 001

Other Comments:

All of the above effluent limitations and monitoring frequencies are the same as in the existing permit, except the mass limits have been adjusted for a design discharge flow of 0.0375 MGD.

General Part C Conditions are proposed in the permit.

It is recommended that the permit be drafted as described above.

