

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0228249  
 APS ID 1066014  
 Authorization ID 1400648

**Applicant and Facility Information**

Applicant Name	<u>Eagle Creek LLC</u>	Facility Name	<u>Eagle Creek LLC WWTP</u>
Applicant Address	<u>1454 Martin Street</u> <u>State College, PA 16803-3065</u>	Facility Address	<u>Old SR 220 South of Unionville</u> <u>Julian, PA 16844</u>
Applicant Contact	<u>Scott Yocum</u>	Facility Contact	<u>Scott Yocum</u>
Applicant Phone	<u>(814) 234-4645</u>	Facility Phone	<u>(814) 231-8200</u>
Client ID	<u>285677</u>	Site ID	<u>493660</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Union Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Centre</u>
Date Application Received	<u>June 20, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 1, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an existing NPDES permit for the discharge of treated sewage.</u>		

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Derek S. Garner</i> Derek S. Garner / Project Manager	May 8, 2023
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 9, 2023

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.015</u>
Latitude	<u>40° 53' 59.77"</u>	Longitude	<u>-77° 52' 55.16"</u>
Quad Name	<u>Bear Knob</u>	Quad Code	<u>1122</u>
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Bald Eagle Creek</u>	Stream Code	<u>22412</u>
NHD Com ID	<u>67179272</u>	RMI	<u>35.3</u>
Drainage Area	<u>76.8</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.438</u>
Q <sub>7-10</sub> Flow (cfs)	<u>33.6</u>	Q <sub>7-10</sub> Basis	<u>Streamgage No. 01547200</u>
Elevation (ft)	<u>775</u>	Slope (ft/ft)	<u>n/a</u>
Watershed No.	<u>9-C</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u>n/a</u>	Existing Use Qualifier	<u>n/a</u>
Exceptions to Use	<u>n/a</u>	Exceptions to Criteria	<u>n/a</u>

Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>n/a</u>		
Source(s) of Impairment	<u>n/a</u>		
TMDL Status	<u>n/a</u>	Name	<u>n/a</u>

Nearest Downstream Public Water Supply Intake	<u>Pennsylvania American Water Company</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Flow at Intake (cfs)	<u>741.48</u>
PWS RMI	<u>10.64</u>	Distance from Outfall (mi)	<u>91.52</u>

**Treatment Facility Summary**

**Treatment Facility Name:** Eagle Creek LLC Wastewater Treatment Plant

Construction and operation of the facility is covered under Water Quality Management (WQM) Permit No. 1401402, issued May 2, 2001. The permit allows for a phased expansion of the facility to accommodate build-out of the serviced mobile home park. Phase I represents build-out of the mobile home park from initial development through the addition of 67 units. Phase II represents build-out of the mobile home park from 68 to 104 units proposed in the approved Act 537 Sewage Facilities Plan. Phase I is served by the construction of a 15,000 GPD treatment plant. The permit requires treatment units for an additional 15,000 GPD to be constructed prior to the start of Phase II. As of the date of this fact sheet there has been no discussion regarding additional treatment units or Phase II of the mobile home park.

WQM Permit No. 1401402 was amended on November 15, 2022 to approve installation and operation of a sodium bisulfite dechlorination system.

Existing treatment at the facility consists of:

- Aerated equalization tank
- Cromaglass CA-150 Unit
- Erosion Chlorinator
- Chlorine Contact Tank

<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Hypochlorite	0.015
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.015	38	Not Overloaded	Aerobic Digestion	Other WWTP

**Compliance History**

The following violations occurred during the existing permit's term:

Monitoring Period Begin Date	Monitoring Period End Date	Noncompliance Description	Noncompliance Category	Parameter	Sample Value	Violation Condition	Permit Value	Units	SBC
5/1/2019	5/31/2019	Sample collection less frequent than required	Other Violations	CBOD5					
5/1/2019	5/31/2019	Sample collection less frequent than required	Other Violations	Fecal Coliform					
5/1/2019	5/31/2019	Sample collection less frequent than required	Other Violations	Total Suspended Solids					
5/1/2019	5/31/2019	Violation of permit condition	Effluent	Fecal Coliform	14136	>	1000	CFU/100 ml	IMAX
5/1/2019	5/31/2019	Violation of permit condition	Effluent	Fecal Coliform	14136	>	200	CFU/100 ml	Geometric Mean
9/1/2019	9/30/2019	Late DMR Submission	Other Violations						
11/1/2019	11/30/2019	Late DMR Submission	Other Violations						
12/1/2019	12/31/2019	Sample collection less frequent than required	Other Violations						
3/1/2020	3/31/2020	Late DMR Submission	Other Violations						
6/1/2020	6/30/2020	Violation of permit condition	Effluent	Fecal Coliform	1102	>	1000	CFU/100 ml	IMAX
8/1/2020	8/31/2020	Late DMR Submission	Other Violations						
1/1/2021	1/31/2021	Late DMR Submission	Other Violations						
4/1/2021	4/30/2021	Late DMR Submission	Other Violations						
5/1/2021	5/31/2021	Late DMR Submission	Other Violations						
9/1/2022	9/30/2022	Violation of permit condition	Effluent	Fecal Coliform	2419.6	>	1000	CFU/100 ml	IMAX
9/1/2022	9/30/2022	Violation of permit condition	Effluent	Fecal Coliform	2420	>	200	CFU/100 ml	Geometric Mean
11/1/2022	11/30/2022	Late DMR Submission	Other Violations						
3/1/2023	3/31/2023	Late DMR Submission	Other Violations						

The Operations Section is aware of the abovementioned violations and has noted such in the most recent inspection reports.

The facility was most recently inspected by DEP on March 6, 2023. The inspection report indicates no impact was noted at the outfall.

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 54' 0.50"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.015  
Longitude -77° 52' 55.51"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

DEP models in-stream conditions to determine if water quality-based effluent limitations (WQBELs) are appropriate. A model was created using WQM 7.0 v1.0b to determine if the existing limits for CBOD<sub>5</sub>, ammonia-N and dissolved oxygen are appropriate or if more stringent limits are necessary.

The water quality model WQM 7.0 v1.0b is used to determine the WQBELs for dissolved oxygen, CBOD<sub>5</sub> and ammonia-n (NH<sub>3</sub>-N) based on a multiple-discharge analysis, if applicable. The model assumes complete and instantaneous mixing with the receiving surface water. The reach chosen to model the in-stream characteristics is appropriate as a recovery in dissolved oxygen levels is demonstrated. The modeling output is as follows:

Parameter	Discharge Conc. (mg/l)	Effluent Limitations		
		30 Day Average (mg/l)	Maximum (mg/l)	Minimum (mg/l)
CBOD <sub>5</sub>	25	25	-	-
NH <sub>3</sub> -N	25	25	50	-
Dissolved Oxygen	3	-	-	3

The input concentration for CBOD<sub>5</sub> is the technology-based concentration limit in the existing permit, and the input concentrations for ammonia-N and dissolved oxygen are the assumed default values for treated sewage. Based on the model output, the existing limits are protective of the receiving surface water.

An evaluation of the existing technology-based TRC limits indicates there are no water quality concerns.

All modeling input/output data is attached.

**Best Professional Judgment (BPJ) Limitations**

The existing permit contains a 2/month ammonia and daily dissolved oxygen reporting requirement help characterize the effluent. DEP recommends that these requirements remain in the permit.

An annual reporting requirement for E. Coli is proposed per the 2017 Triennial Review of Water Quality Standards, published in the PA Bulletin on July 11, 2020.

**Chesapeake Bay Considerations**

Per the Wastewater Supplement to Phase 3 of Pennsylvania’s Watershed Implementation Plan (WIP) the Eagle Creek LLC Wastewater Treatment Plant is considered a Phase 5 facility. The WIP requires all Phase 5 facilities to conduct, at a minimum, annual sampling for Total Nitrogen (TN) and Total Phosphorus (TP) if the facility has not completed two years’ worth of voluntary nutrient monitoring already. The facility sampled for the nitrogen series and total phosphorus from September 2006 to February 2010.

Monitoring Period	Total Nitrogen		Total Phosphorus	
	Mo Load (lbs)	Avg Mo Conc (mg/l)	Mo Load (lbs)	Avg Mo Conc (mg/l)
Jan-09	7.7	15.0	2.4	4.6
Feb-09	11.2	25.3	2.3	5.2
Mar-09	6.2	10.7	3.1	4.3
Apr-09	15.0	25.0	3.0	7.2
May-09	6.2	16.9	3.1	4.9
Jun-09	8.9	19.8	2.0	4.5
Jul-09	9.1	19.6	2.4	5.3
Aug-09	13.9	20.3	6.2	8.5
Sep-09	9.9	14.8	3.0	4.9
Oct-09	15.5	13.0	3.1	2.6
Nov-09	16.2	21.1	4.8	6.3
Dec-09	13.3	20.9	3.1	4.7
Jan-10	3.1	15.3	0.9	4.2
Feb-10	12.0	19.9	2.2	4.0
<b>AVG</b>	<b>10.6</b>	<b>18.4</b>	<b>3.0</b>	<b>5.1</b>

**Anti-Backsliding**

No limits or monitoring requirements are proposed to be made less stringent. Anti-backsliding should not impact the permit.

**Existing Effluent Limitations and Monitoring Requirements**

The existing effluent limitations and monitoring requirements are as follows:

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Weir
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Compliance Sampling Location: Outfall 001



### Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	22412	BALD EAGLE CREEK	<b>35.300</b>	775.00	76.80	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
<b>Q7-10</b>	0.438	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Eagle Creek LLC	PA0228249	0.0150	0.0150	0.0150	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	22412	BALD EAGLE CREEK	<b>34.800</b>	767.00	81.70	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
<b>Q7-10</b>	0.438	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
09C	22412	BALD EAGLE CREEK

RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
35.300	33.64	0.00	33.64	.0232	0.00303	.852	71.11	83.48	0.56	0.055	25.00	7.00
<b>Q1-10 Flow</b>												
35.300	31.96	0.00	31.96	.0232	0.00303	NA	NA	NA	0.54	0.057	25.00	7.00
<b>Q30-10 Flow</b>												
35.300	39.69	0.00	39.69	.0232	0.00303	NA	NA	NA	0.61	0.050	25.00	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.95	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.18	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
09C	22412	BALD EAGLE CREEK

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
35.300	Eagle Creek LLC	11.07	50	11.07	50	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
35.300	Eagle Creek LLC	1.37	25	1.37	25	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
35.30	Eagle Creek LLC	25	25	25	25	3	3	0	0

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
09C	22412	BALD EAGLE CREEK

---

<u>RMJ</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
35.300	0.015	25.000	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
71.115	0.852	83.477	0.556
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.02	0.012	0.02	1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.239	8.843	Tsivoglou	5
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>		

0.055

TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
0.005	2.02	0.02	7.54
0.011	2.02	0.02	7.54
0.016	2.02	0.02	7.54
0.022	2.02	0.02	7.54
0.027	2.02	0.02	7.54
0.033	2.01	0.02	7.54
0.038	2.01	0.02	7.54
0.044	2.01	0.02	7.54
0.049	2.01	0.02	7.54
0.055	2.01	0.02	7.54

---

---

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
09C		22412		BALD EAGLE CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
35.300	Eagle Creek LLC	PA0228249	0.015	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3



1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Input appropriate values in B4:B8 and E4:E7					
4	33.6	= Q stream (cfs)		0.5	= CV Daily	
5	0.015	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		0.032	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	=Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 461.919	1.3.2.iii	WLA_cfc = 14.421	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 172.122	5.1d	LTA_cfc = 8.384	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.500	BAT/BPJ		
18			INST_MAX_LIMIT (mg/l) = 1.635			
	WLA_afc	(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
	LTAMULT_afc	EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)				
	LTA_afc	wla_afc*LTAMULT_afc				
	WLA_cfc	(.011/e(-k*CFC_tc) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc) )... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
	LTAMULT_cfc	EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)				
	LTA_cfc	wla_cfc*LTAMULT_cfc				
	AML_MULT	EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))				
	AVG_MON_LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
	INST_MAX_LIMIT	1.5*(av_mon_limit/AML_MULT)/LTAMULT_afc				