

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0228478
APS ID 1059302
Authorization ID 1389301

Applicant and Facility Information

Applicant Name	<u>Milton Region Sewer Authority Northumberland County</u>	Facility Name	<u>East Chillisquaque Potts Grove STP Sewer System</u>
Applicant Address	<u>5585 State Route 405 Milton, PA 17847-7519</u>	Facility Address	<u>4842 State Route 642 Milton, PA 17847</u>
Applicant Contact	<u>Genie Bausinger</u>	Facility Contact	<u>Genie Bausinger</u>
Applicant Phone	<u>(570) 742-3424</u>	Facility Phone	<u>(570) 742-3424</u>
Client ID	<u>201704</u>	Site ID	<u>550434</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>East Chillisquaque Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Northumberland</u>
Date Application Received	<u>March 18, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 23, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit.</u>		

Summary of Review

The subject facility is a Publicly Owned Treatment Works (POTW) serving East Chillisquaque Township in the vicinity of the village of Potts Grove in Northumberland County. A map of the discharge location is attached (see Attachment A).

A map of the discharge location is attachments.

Sludge use and disposal description and location(s): The facility's digested sludge is transferred to other treatment plants for further processing. Per the application 0.673 dry tons were removed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	August 16, 2022
x		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	August 16, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.04</u>
Latitude	<u>40° 59' 31.43"</u>	Longitude	<u>-76° 46' 43.46"</u>
Quad Name	<u>Northumberland, PA</u>	Quad Code	<u></u>
Wastewater Description:	<u>Sewage Effluent</u>		
Receiving Waters	<u>Chillisquaque Creek (WWF)</u>	Stream Code	<u>18712</u>
NHD Com ID	<u>66919921</u>	RMI	<u>7.87</u>
Drainage Area	<u>51.3 mi²</u>	Yield (cfs/mi ²)	<u>0.212</u>
Q ₇₋₁₀ Flow (cfs)	<u>10.9</u>	Q ₇₋₁₀ Basis	<u>USGS Gage 01553700 – Chillisquaque Creek @ Washingtonville (1981- 2008)</u>
Elevation (ft)	<u>484</u>	Slope (ft/ft)	<u>0.00189</u>
Watershed No.	<u>10-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>SILTATION</u>		
Source(s) of Impairment	<u>AGRICULTURE</u>		
TMDL Status	<u>None</u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>Sunbury Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Distance from Outfall (mi)	<u>Approx. 15</u>

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics were determined for the previous review and remain adequate.

Other Comments:

No downstream water supply is expected to be affected by this discharge at this time with the limitations and the monitoring proposed.

The impairment by siltation to Chillisquaque Creek is specifically attributed to agriculture and the facility discharge consistently complies with its TSS limits. Therefore, no additional monitoring or limits will be applied to the discharge at this time to address the stream impairment.

Treatment Facility Summary				
Treatment Facility Name: Pottsgrove STP				
WQM Permit No.		Issuance Date		
4901405		3/27/07 – T1		
		1/3/02 – Original		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.04
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.04	91	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments: The treatment facility, as permitted under WQM No. 4901405 consists of comminution, extended aeration tank, two clarifiers, hypochlorite injection, chlorination, and aerobic digester.

Trucked-in Waste
The applicant has indicated in the application that the facility has received no hauled-in wastes in the past three years and does not expect to receive any hauled-in wastes over the next permit term.

Compliance History

DMR Data for Outfall 001 (from July 1, 2021 to June 30, 2022)

Parameter	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21
Flow (MGD) Average Monthly	0.012473	0.017842	0.019491	0.019628	0.020135	0.0158	0.014038	0.015315	0.014776	0.016552	0.01281	0.016316
Flow (MGD) Daily Maximum	0.016853	0.054757	0.035341	0.028159	0.032675	0.020472	0.022211	0.034148	0.043127	0.036837	0.025295	0.038547
pH (S.U.) Minimum	6.79	6.61	6.66	6.68	6.64	6.8	6.8	6.82	6.81	6.66	6.68	6.67
pH (S.U.) Maximum	7.12	7.13	7.04	7.06	7.01	7.12	7.35	7.32	7.32	7.28	7.17	7.06
DO (mg/L) Minimum	7.82	5.93	6.12	8.65	9.84	8.11	8.65	7.59	7.68	7.18	7.39	7.23
TRC (mg/L) Average Monthly	0.3	0.4	0.3	0.4	0.4	0.3	0.3	0.3	0.3	0.4	0.4	0.3
TRC (mg/L) Instantaneous Maximum	0.53	0.78	0.72	0.61	0.73	0.59	0.56	0.52	0.58	0.9	0.98	0.43
CBOD5 (lbs/day) Average Monthly	0.3	0.4	0.6	0.6	0.5	0.4	0.3	0.3	0.4	0.5	0.2	0.5
CBOD5 (lbs/day) Weekly Average	0.4	0.4	0.7	0.6	0.6	0.4	0.3	0.3	0.5	0.8	0.3	0.6
CBOD5 (mg/L) Average Monthly	3	3	4	4	4	3	3	3	4	4	3	3
CBOD5 (mg/L) Weekly Average	4	3	4	4	4	3	3	3	4	5	3	4
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	36	38	34	38	61	40	48	39	31	24	41	52
BOD5 (mg/L) Raw Sewage Influent Average Monthly	380	280	215	234	435	316	453	368	281	192	453	341
TSS (lbs/day) Average Monthly	0.7	0.6	0.3	1.0	1.0	< 0.3	0.4	< 0.4	0.6	< 0.7	< 0.2	1.0
TSS (lbs/day) Raw Sewage Influent Average Monthly	49	32	120	44	47	42	54	52	47	35	36	72
TSS (lbs/day) Weekly Average	1.0	0.7	0.4	1.0	1.0	0.4	0.5	0.7	0.9	1.3	< 0.2	1.3
TSS (mg/L) Average Monthly	8	4	2	8	7	< 3	4	< 4	5	< 5	< 2	6

**NPDES Permit Fact Sheet
East Chillisquaque Potts Grove STP Sewer System**

NPDES Permit No. PA0228478

TSS (mg/L) Raw Sewage Influent Average Monthly	521	239	826	275	329	330	505	485	434	274	395	595
TSS (mg/L) Weekly Average	13	5	2	9	10	3	5	6	7	8	< 2	7
Fecal Coliform (CFU/100 ml) Geometric Mean	118	19	4	13	99	14	127	15	104	7	144	113
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	119.8	90.9	18.3	30.9	144.5	62.4	365.4	25.6	140.1	53.7	1299.7	235.9
Total Nitrogen (lbs/day) Annual Average							< 3.53754					
Total Nitrogen (mg/L) Annual Average							< 37.57					
Ammonia (mg/L) Average Quarterly	E			0.1			0.07			0.22		
Ammonia (mg/L) Instantaneous Maximum	E			0.1			0.07			0.22		
Total Phosphorus (lbs/day) Annual Average							0.31290					
Total Phosphorus (mg/L) Annual Average							1.56					

Compliance History, Cont'd

Effluent Violations for Outfall 001, from: July 1, 2021 to: June 30, 2022

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	08/31/21	IMAX	1299.7	CFU/100 ml	1000	CFU/100 ml

Compliance History, Cont'd

Summary of Inspections:	The facility has been inspected annually by the Department over the past permit term. The most recent inspection on May 6, 2021 identified violations for failure to conduct sampling which was due to flooding at the plant.
Other Comments:	A query in WMS found no open violations in eFACTS for Milton Regional Sewer Authority

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	8.0	13.0	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	10.0	15.0	XXX	30	45	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report AnnI Avg	XXX	XXX	Report AnnI Avg	XXX	XXX	1/year	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report Avg Qrtly	XXX	Report	1/quarter	8-Hr Composite
Total Phosphorus	Report AnnI Avg	XXX	XXX	Report AnnI Avg	XXX	XXX	1/year	8-Hr Composite

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.04</u>
Latitude <u>40° 59' 31.40"</u>	Longitude <u>-76° 46' 43.50"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are existing in the facility permit and will remain unchanged in this permit renewal.

Water Quality-Based Limitations

CBOD5, DO, and NH3-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed for the discharge for the previous review and showed that the secondary treatment limits listed above for CBOD₅ are adequate to protect the receiving stream. See Attachment B.

TRC

The above Total Residual Chlorine limit from 92a.48(b)(2) is applicable to the facility. The Department uses a modeling spreadsheet to determine necessary WQBELs for TRC toxicity based on instream dilution. The attached modeling results from the previous review (See attachment C) show that the BAT limit of 0.5 mg/l is adequate to protect the receiving stream.

Toxics Management

No further "Reasonable Potential Analysis" was performed to determine additional parameters as candidates for limitations for this 0.04 MGD facility sewage treatment facility receiving no industrial influent.

Chesapeake Bay Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen (TN) and Total Phosphorus (TP) cap loads have been established for significant dischargers in Pennsylvania to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. The MRSA Potts Grove treatment plant is considered an existing Phase 5, insignificant Chesapeake Bay discharger per the Phase III Watershed Implementation Plan (WIP) and thus has received no Cap Loads. The existing permit included annual monitoring for TN and TP. The average TN was <29.54 mg/L and 4.15 lbs/day and the average TP was 3.65 mg/L and 0.543 lbs/day over the past permit term. Consistent with the Phase

III WIP the permittee has conducted adequate monitoring and no further monitoring for nutrients will be required at this time.

Best Professional Judgment (BPJ) Limitations

Comments: No BPJ limits are needed beyond the technology and water quality-based limits noted above.

Anti-Backsliding

No limitations have been made less stringent consistent with the anti-backsliding requirements of the Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	8.0	13.0	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	10.0	15.0	XXX	30	45	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia	XXX	XXX	XXX	Report Avg Qrtly	XXX	Report	1/quarter	8-Hr Composite
E. Coli	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab


Compliance Sampling Location: Outfall 001

Other Comments: As mentioned above Total Nitrogen and Total Phosphorus monitoring have been removed. In addition, E. Coli monitoring will now be included in the permit consistent with recent changes to Chapter 93 of the Department's regulations and Department policy. The existing quarterly monitoring for NH₃-N is less than twice per month as is typically required for a 0.04 MGD facility. However, given the consistently low levels of NH₃-N in the effluent (average <0.18 mg/L over the past permit term) the quarterly monitoring is adequate and will be kept.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Model



WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code				Stream Name						
10D		18712				CHILLISQUAQUE CREEK						
RMI	Stream Flow (els)	PWS With (els)	Net Stream Flow (els)	Disc Analysis Flow (els)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	WID Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
7.870	mas	0.00	mBB	.0619	0.00189	.755	46.57	61.7	0.31	0.079	20.03	7.00
Q1-10 Flow												
7.870	6.96	0.00	6.96	.0619	0.00189	NA	NA	NA	0.24	0.101	20.04	7.00
Q30-10 Flow												
7.870	14.79	0.00	14.79	.0619	0.00189	NA	NA	NA	0.37	0.066	20.02	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	
WLAMethod	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	
D.O. Saturation	90.00%	Use Balanced Technology	
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
10D	18712	CHILLISQUAQUE CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.870	Potts Grove	9.64	50	9.64	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.870	Potts Grove	1.91	25	1.91	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3wN</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
7.87	Potts Grove	25	25	25	25	3	3	0	a

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10D	18712	CHILLISQUAQUE CREEK

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
7.870	0.040	20.028	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
46.569	0.755	61.698	0.311
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.13	0.094	0.14	0.702
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/l)</u>
8.213	4.024	Tsivoglou	5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>		
0.079	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>
	(days)	(mg/L)	(mg/L)
			<u>D.O.</u>
			(mg/L)
	0.008	2.13	0.14
	0.016	2.13	0.14
	0.024	2.13	0.14
	0.031	2.12	0.14
	0.039	2.12	0.14
	0.047	2.12	0.14
	0.055	2.12	0.14
	0.063	2.12	0.14
	0.071	2.12	0.13
	0.079	2.11	0.13

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
10D		18712	CHILLISQUAQUE CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.870	Potts Grove	PA0228478	0.040	C8OD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
100	18712	CHILLISQUAQUE CREEK	7.870	484.00	51.30	0.00000	0.00	0

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Reh Trav Time	Reh Velocity	WO Ratio	Reh Width	Reh Depth	Tributary Temp	pH	Stream Temp	pH
	(efsm)	(efs)	(efs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.212	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Potts Grove	PA0228478	0.0400	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Cone (mg/L)	Trib Cone (mg/L)	Stream Cone (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10D	18712	CHILLISQUAQUE CREEK	7.470	480.00	52.00	0.00000	0.00	

Stream Data

Design Cond.	LFY (efsm)	Trib Flow (els)	Stream Flow (els)	Reh Trav Time (days)	Reh Velocity (fps)	WD Ratio	Reh Width (ft)	Reh Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	07-10	0.212	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
01-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Cone (mg/L)	Trib Cone (mg/L)	Stream Cone (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

TRC EVALUATION

Client	Date
10.9 = Q stream (cfs)	0.5 = CV Daily
0.04 = Q discharge (MGD)	0.5 = CV Hourly
30 = no. samples	1 = AFC Partial Mix Factor
0.3 = Chlorine Demand of Stream	1 = CFC Partial Mix Factor
0 = Chlorine Demand of Discharge	15 = AFC Criteria Compliance Time (min)
0.5 = BAT/BPJ Value	720 = CFC Criteria Compliance Time (min)
= % Factor of Safety (FOS)	0 = Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA _{afc} = 56.210	1.3.2.iii	WLA _{cfc} = 54.793
PENTOXSD TRG	5.1a	LTAMULT _{afc} = 0.373	5.1c	LTAMULT _{cfc} = 0.581
PENTOXSD TRG	5.1b	LTA _{afc} = 20.945	5.1d	LTA _{cfc} = 31.854
		WQBEL _{alc} = 25.781		WQBEL _{etc} = 39.209

Source	Effluent Limit Calculations		
PENTOXSD TRG	5.11	AMLMULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	

WLA _{afc}	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
LTAMULT _{afc}	$EXP((0.5 \cdot LN(cvhA2 + 1)) - 2.326 \cdot LN(cvhA2 + 1)A0.5)$
LTA _{afc}	$wla_afc \cdot LTAMULT_afc$
WLA_{cfc}	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$
LTAMULT _{cfc}	$EXP((0.5 \cdot LN(cvdA2 / no_samples + 1)) - 2.326 \cdot LN(cvdA2 / no_samples + 1)A0.5)$
LTA_{cfc}	$wla_cfc \cdot LTAMULT_cfc$
AML MULT	$EXP(2.326 \cdot LN((cvdA2 / no_samples + 1)A0.5) - 0.5 \cdot LN(cvdA2 / no_samples + 1))$
AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$