

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0228648
APS ID 992601
Authorization ID 1272240

Applicant and Facility Information

Applicant Name	<u>Jackson Township Municipal Authority Tioga County</u>	Facility Name	<u>Jackson Township Municipal Authority Millerton Sewer System STP</u>
Applicant Address	<u>585 Skyline Drive Lawrenceville, PA 16929-8737</u>	Facility Address	<u>30 Wisteria Way Millerton, PA 16936</u>
Applicant Contact	<u>Robert Rundell, Operator</u>	Facility Contact	<u>Robert Rundell, Operator</u>
Applicant Phone	<u>(570) 537-3300</u>	Facility Phone	<u>(570) 537-3300</u>
Client ID	<u>202790</u>	Site ID	<u>605302</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Jackson Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Tioga</u>
Date Application Received	<u>May 2, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 4, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES permit</u>		

Summary of Review

The Jackson Township Municipal Authority STP serves the area around the Village of Millerton in Jackson Township, Tioga County. A map of the discharge location is attached.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		Keith C. Allison / Project Manager	October 8, 2019
		Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.11</u>
Latitude	<u>41° 59' 12.43"</u>	Longitude	<u>-76° 55' 57.80"</u>
Quad Name	<u>Millerton, PA</u>	Quad Code	<u>0330</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Seeley Creek (Hammond Creek)</u>	Stream Code	<u>30951</u>
NHD Com ID	<u>48523484</u>	RMI	<u>2.05</u>
Drainage Area	<u>26.3 mi²</u>	Yield (cfs/mi ²)	<u>0.0614</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.6</u>	Q ₇₋₁₀ Basis	<u>USGS Gage 01516350, Tioga River near Mansfield (1978-2008)</u>
Elevation (ft)	<u>1155</u>	Slope (ft/ft)	<u>0.00887</u>
Watershed No.	<u>4-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Nearest Downstream Public Water Supply Intake	<u>PA-NY State Line</u>		
PWS Waters	<u>Seeley Creek</u>	Distance from Outfall (mi)	<u>2.13</u>

Changes Since Last Permit Issuance: None. The stream and drainage characteristics determined for the previous renewal remain valid and are unchanged here.

Other Comments: The receiving stream, Hammond Creek, is not specifically listed in Chapter 93.

No downstream water supply is expected to be affected by the discharge with the limitations and monitoring proposed. The Department considers the Pennsylvania-New York state line to be the nearest downstream water supply because there is no other nearer water supply intake.

Treatment Facility Summary				
Treatment Facility Name: Jackson Township Sewer System				
WQM Permit No.		Issuance Date		
5904402		9/21/04		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.11
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.22	186	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None

Other Comments: The treatment, as approved by WQM permit No. 5904402 consists of a pump station, comminutor, bar screen, flow equalization, two extended aeration basins, two clarifiers, chlorination with contact tank, dechlorination with contact tank, sludge holding and reed sludge drying beds.

Compliance History	
Summary of DMRs:	A review of the DMRs for the past year found the effluent violations listed in the table below.
Summary of Inspections:	The facility has been inspected by the Department approximately annually over the past permit term. The most recent inspection on June 30, 2019 by Brandon Shihinski, WQS identified no violations.

Effluent Violations for Outfall 001, from: September 1, 2018 To: August 31, 2019

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Ammonia	05/31/19	Avg Mo	6.8	lbs/day	5.5	lbs/day
Ammonia	05/31/19	Wkly Avg	8.4	lbs/day	8.3	lbs/day
Ammonia	05/31/19	Avg Mo	16.3	mg/L	6	mg/L
Ammonia	05/31/19	Wkly Avg	16.9	mg/L	9	mg/L

Other Comments: A WMS query found no open violations in eFACTS for the Jackson Township Municipal Authority.

Existing Effluent Limitations and Monitoring Requirements – Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	4.0	XXX	XXX	XXX	1/week	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.17	1/day	Grab
CBOD5 May 1 - Oct 31	18	28	XXX	20	30	40	2/month	8-Hr Composite
CBOD5 Nov 1 - Apr 30	23	37	XXX	25	40	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Suspended Solids	28	41	XXX	30	45	60	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	XXX	2/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	XXX	2/month	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	5.5	8.3	XXX	6	9	12	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	16.5	24.8	XXX	18	27	36	2/month	8-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	1/year	8-Hr Composite

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.11</u>
Latitude <u>41° 59' 13.00"</u>	Longitude <u>-76° 55' 58.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limit are applicable and already included in the existing NPDES permit.

Water Quality-Based Limitations

CBOD₅, NH₃-N & DO

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia nitrogen (NH₃-N) into free-flowing streams and rivers. The discharge has existing WQ-Based limits for CBOD₅ and NH₃-N. As conditions have not changed, modeling conducted for the previous review remains valid which shows that the existing limits are adequate to protect the receiving stream. See Attachment B.

Total Residual Chlorine

TRC modeling performed for the previous review remains valid and shows that the existing BAT limit of 0.5 mg/L is adequate to protect the receiving stream. See Attachment B. The facility has an existing TRC IMAX of 1.17 mg/L that will remain in the permit pursuant to anti-backsliding.

Toxics Management

No further "Reasonable Potential Analysis" was performed at this time to determine additional parameters as candidates for limitations or monitoring for this minor sewage treatment facility with no industrial dischargers.

Chesapeake Bay/Nutrient Requirements

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is considered a Phase 5 Chesapeake Bay sewage discharger, and as such requires no nutrient loading limits. Per a review of the facility DMRs over the past permit term the Total Nitrogen has averaged 20.1 mg/L and the Total Phosphorus has averaged 4.7 mg/L. Because the nutrients levels in the discharge have adequately been characterized at this time, existing annual Total Nitrogen and Total Phosphorus monitoring will be removed from this proposed draft permit.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limits are necessary for this discharge at this time beyond the technology and water quality-based limitations noted above.

Anti-Backsliding

No limitations were made less stringent consistent with the anti-degradation requirements of the Clean Water Act and 40 CFR 122.44(I).

Hauled in Waste

Per the application, the permittee has not accepted any hauled-in waste in the past three years and does not anticipate receiving any over the next permit term.

Biosolids/Sludge Disposal

Wasted sludge is disposed at the Northern Tier Solid Waste Authority Bradford County Landfill.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/week	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.17	1/day	Grab
CBOD5 Nov 1 - Apr 30	23	37	XXX	25	40	50	2/month	8-Hr Composite
CBOD5 May 1 - Oct 31	18	28	XXX	20	30	40	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	28	41	XXX	30	45	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	16.5	24.8	XXX	18	27	36	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	5.5	8.3	XXX	6	9	12	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: The above monitoring and limitations are unchanged from the existing permit with the exception of the removal of annual Total Nitrogen and Total Phosphorus monitoring as mentioned above.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment B)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment)
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment)
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits
<input type="checkbox"/>	Other:



Permit No. PA0228648

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04B	30951	HAMMOND CREEK	2.050	1155.00	26.30	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.061	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Jackson Twp	PA0228648	0.1100	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	20.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	6.00	0.00	0.00	0.70

Permit No. PA0228648

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
04B		30951				HAMMOND CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.050	1.61	0.00	1.61	.1702	0.00887	.581	20.69	35.6	0.15	0.844	20.48	7.00
Q1-10 Flow												
2.050	1.03	0.00	1.03	.1702	0.00887	NA	NA	NA	0.12	1.052	20.71	7.00
Q30-10 Flow												
2.050	2.20	0.00	2.20	.1702	0.00887	NA	NA	NA	0.17	0.721	20.36	7.00

Permit No. PA0228648

Permit No. PA0228648

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Permit No. PA0228648

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
 04B 30951 HAMMOND CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.050	Jackson Twp	9.19	12	9.19	12	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.050	Jackson Twp	1.87	6	1.87	6	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.05	Jackson Twp	20	20	6	6	3	3	0	0

Permit No. PA0228648

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
04B	30951	HAMMOND CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.050	0.110	20.477	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
20.688	0.581	35.595	0.148	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.72	0.540	0.57	0.726	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.743	12.654	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.844	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.084	3.55	0.54	8.17
	0.169	3.39	0.51	8.17
	0.253	3.23	0.48	8.17
	0.338	3.08	0.45	8.17
	0.422	2.94	0.42	8.17
	0.506	2.81	0.40	8.17
	0.591	2.68	0.37	8.17
	0.675	2.56	0.35	8.17
	0.759	2.44	0.33	8.17
	0.844	2.33	0.31	8.17

Permit No. PA0228648

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
04B		30951	HAMMOND CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.050	Jackson Twp	PA0228648	0.110	CBOD5	20		
				NH3-N	6	12	
				Dissolved Oxygen			3

Permit No. PA0228648

TRC EVALUATION					
Client			Date ...		
1.6	= Q stream (cfs)		0.5	= CV Daily	
0.11	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC Criteria Compliance Time (min)	
0.5	= BAT/BJ Value		720	= CFC Criteria Compliance Time (min)	
	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc =	3.018	1.3.2.iii	WLA_cfc = 2.935
PENTOXSD TRG	5.1a	LTAMULT_afc =	0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc =	1.125	5.1d	LTA_cfc = 1.706
		WQBEL_afc =	1.384		WQBEL_cfc = 2.100
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	$wla_afc \cdot LTAMULT_afc$				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	$wla_cfc \cdot LTAMULT_cfc$				
AML MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$				
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$				