

PA0231754, Sewage, SIC Code 4952, **Kailee N. Karycki**, 792 Brush Valley Road, Sunbury, PA 17801-7500. Facility Name: Karycki SFTF. This proposed facility will be located in Rockefeller Township, **Northumberland County**.

Description of Proposed Activity: The application is for a new NPDES permit for a new discharge of treated SRSTP Sewage.

The receiving stream(s), Unnamed Tributary of Susquehanna River (WWF, MF), is located in State Water Plan watershed 6-B and is classified for Warm Water Fishes and Migratory Fishes, aquatic life, water supply and recreation. The discharge is not expected to affect public water supplies.

The proposed effluent limits for Outfall 001 are based on a design flow of 0.0004 MGD.

<i>Parameters</i>	<i>Mass Units (lbs/day)</i>		<i>Concentrations (mg/L)</i>			
	<i>Average Monthly</i>	<i>Average Weekly</i>	<i>Minimum</i>	<i>Annual Average</i>	<i>Maximum</i>	<i>IMAX</i>
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX
Biochemical Oxygen Demand (BOD5)	XXX	XXX	XXX	10.0	XXX	20.0
Total Suspended Solids	XXX	XXX	XXX	10.0	XXX	20.0
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX

You may make an appointment to review the DEP files on this case by calling the File Review Coordinator at 570-327-3693.

The EPA Waiver is in effect