

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0232751  
APS ID 1036243  
Authorization ID 1349669

**Applicant and Facility Information**

Applicant Name	<u>Potter Township Centre County</u>	Facility Name	<u>Potters Mills Central Treatment System</u>
Applicant Address	<u>124 Short Road</u> <u>Spring Mills, PA 16875-9326</u>	Facility Address	<u>Rt 144</u> <u>Potters Mills, PA 16875</u>
Applicant Contact	<u>Dick Decker, Chairman</u>	Facility Contact	<u>Dave Boliek</u>
Applicant Phone	<u>(814) 364-9176</u>	Facility Phone	<u>(814) 364-9314</u>
Client ID	<u>35324</u>	Site ID	<u>814487</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Potter Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Centre</u>
Date Application Received	<u>April 13, 2021</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>April 16, 2021</u>	If No, Reason	<u>New Phase V Chesapeake Bay Discharge</u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

**Summary of Review**

The subject permit is a Publicly Owned Treatment Works (POTW) serving the Potters Mills area of Potter Township, Centre County.

A map indicating the discharge location is attached.

Sludge use and disposal description and location(s): Septage is either transferred to other facilities for further processing or beneficially used.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	June 22, 2021
✓		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	June 23, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.014</u>
Latitude	<u>40° 48' 44.16"</u>	Longitude	<u>-77° 38' 16.65"</u>
Quad Name	<u>Centre Hall, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Sinking Creek (CWF, MF)</u>	Stream Code	<u>18377</u>
NHD Com ID	<u>54970197</u>	RMI	<u>6.8</u>
Drainage Area	<u>19.1 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0770</u>
Q <sub>7-10</sub> Flow (cfs)	<u>1.47</u>	Q <sub>7-10</sub> Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1128.4</u>	Slope (ft/ft)	<u>0.00127</u>
Watershed No.	<u>6-A</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>PATHOGENS</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u></u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>Suez Water Pennsylvania</u>		
PWS Waters	<u>Susquehanna River</u>	Distance from Outfall (mi)	<u>Approx. 100</u>

Changes Since Last Permit Issuance: The above stream and drainage characteristics were determined for the previous review and remain adequate.

Other Comments:

The effluent is pumped approximately a mile northward along SR 144 to discharge to Sinking Creek. Potter Run is closer to the treatment facility, but it also has an existing use of HQ-CWF which would subject the discharge to the anti-degradation requirements of Chapter 93.

No downstream water supply is expected to be affected by this discharge at this time with the limitations and monitoring proposed.

The above-listed impairment from pathogens should not be exacerbated by this discharge which meets its fecal coliform limits which are equivalent to instream criteria. Also, malfunctioning septic systems, which were eliminated with the installation of this treatment facility, may have contributed to the impairment.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Potters Mills Central Treatment System				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
1416404		4/6/2017		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	STEP	Ultraviolet	0.014
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.014	35	Not Overloaded	None	Offsite

Changes Since Last Permit Issuance: Discharge began in November 2019.

Other Comments: The treatment facility, as permitted by WQM Permit No. 1416404, consists of an ORENCO Septic Tank Effluent Pump (STEP) system consisting of a septic tank with Biotube Filter serving each home or business discharging by pump to an ORENCO AdvanTex AX-MAX treatment plant followed by Ultraviolet Light Disinfection. The ORENCO AdvanTex Ax-Max plant is a recirculating fixed media filter system.

Hauled in Waste
Per the application the facility has not received any hauled in waste and is not expected to receive any over the next permit term.

Compliance History

DMR Data for Outfall 001 (from May 1, 2020 to April 30, 2021)

Parameter	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20
Flow (MGD) Average Monthly	0.00368	0.00344	0.00349	0.00333	0.00333	0.00325	0.00354	0.00359	0.00396	0.00328	0.00338	0.00376
Flow (MGD) Daily Maximum	0.00496	0.00460	0.00509	0.00552	0.00552	0.00456	0.00458	0.00491	0.00613	0.00408	0.00416	0.00691
pH (S.U.) Instantaneous Minimum	6.0	6.44	6.47	6.31	5.74	6.05	6.26	6.84	6.15	6.67	6.36	6.54
pH (S.U.) Instantaneous Maximum	6.8	6.94	6.73	6.76	6.85	6.65	7.21	7.2	7.24	7.11	6.92	6.96
DO (mg/L) Instantaneous Minimum	2.78	3.76	3.68	4.06	4.53	2.76	1.16	2.0	2.11	2.26	2.32	2.73
CBOD5 (lbs/day) Average Monthly	< 0.100	0.100	0.200	< 0.0900	< 0.10	< 0.070	2.90	0.090	0.10	0.0800	0.0800	0.100
CBOD5 (mg/L) Average Monthly	< 3.0	5.0	< 5.0	< 3.0	< 4.0	< 3.00	3.0	< 4.0	3.00	3.00	3.0	4.00
CBOD5 (mg/L) Instantaneous Maximum	4.0	7.0	6.0	< 3.0	5.0	< 3.0	3.0	4.0	3.00	3.00	3.0	4.00
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	5.0	8.0	6.0	6.0	6.0	7.0	< 162.0	8.0	8.0	7.0	8.0	227
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	5.0	8.0	7.0	7.0	7.0	7.0	< 202.0	9.0	10.0	8.0	14.0	292
BOD5 (mg/L) Raw Sewage Influent Average Monthly	143	273.0	163	180.0	217	282.0	< 5.0	297	294.0	262.0	330	227
TSS (lbs/day) Average Monthly	0.10	0.20	0.07	0.06	0.10	0.06	0.07	0.05	< 0.10	0.08	0.70	0.20
TSS (lbs/day) Raw Sewage Influent Average Monthly	1.0	1.0	1.0	1.0	1.0	1.0	< 1.0	1.0	1.0	1.0	2.0	42.0
TSS (lbs/day) Raw Sewage Influent Daily Maximum	1.0	1.0	1.0	1.0	1.0	1.0	2.0	2.0	1.0	1.0	3.0	53.0

**NPDES Permit Fact Sheet**  
**Potters Mills Central Treatment System**

**NPDES Permit No. PA0232751**

TSS (mg/L) Average Monthly	3.0	6.0	2.0	2.0	4.0	< 2.0	2.0	< 2.0	< 3.0	3.0	22.0	6.00
TSS (mg/L) Raw Sewage Influent Average Monthly	37.0	31	40.0	37.0	47.0	30.0	< 50	55.0	39.0	47.0	95.0	42.0
TSS (mg/L) Instantaneous Maximum	2.0	6.0	2.0	2.0	5.0	3.0	2.0	< 2.0	< 4.0	4.0	22.0	11.00
Fecal Coliform (No./100 ml) Geometric Mean	< 4.0	5.0	< 3.0	< 1.0	< 2.0	< 2.0	< 4.0	< 4.0	< 4.0	4.0	8.00	< 4.00
Fecal Coliform (No./100 ml) Instantaneous Maximum	14.6	6.3	6.30	1.0	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	4.0	16.40	< 4.00
UV Intensity (µw/cm²) Instantaneous Minimum	73.0	72.0	75.0	78.0	78.0	81.0	81.0	80.0	75.0	75	81	77.0
Nitrate-Nitrite (mg/L) Average Monthly	47.756	32.25	< 48.63	< 53.70	< 54.2	53.03	44.39	< 29.05	< 24.76	< 27.36	< 16.517	38.75
Nitrate-Nitrite (lbs) Total Monthly	< 46.0	29.0	< 47.0	< 51.0	< 44	39.0	< 41	< 22.0	< 28.0	< 22	< 15.0	33.0
Total Nitrogen (mg/L) Average Monthly	< 50.17	36.01	< 49.88	< 2.0	< 56.8	< 53.87	< 45.49	< 29.65	< 25.57	< 28.06	< 20.397	40.706
Total Nitrogen (lbs) Effluent Net Total Monthly	< 48.0	33.0	< 48	< 53.0	< 46.0	< 39.4	< 41.0	< 23.0	< 29.0	< 22.0	< 18.0	35.00
Total Nitrogen (lbs) Total Monthly	< 48.0	33.0	< 48.0	< 53.0	< 46.0	< 39.0	< 41.0	< 23.0	< 29.0	< 22	< 18.0	35.0
Total Nitrogen (lbs) Effluent Net Total Annual												
Total Nitrogen (lbs) Total Annual												
Ammonia (lbs/day) Average Monthly	2.0	0.1	1.0	0.03	0.06	< 0.6	0.30	0.02	0.40	< 0.01	< 0.6	1.934
Ammonia (mg/L) Average Monthly	2.325	3.633	1.251	0.934	0.686	< 0.838	0.33	0.60	0.354	< 0.5	< 0.72	1.934
Ammonia (lbs) Total Monthly	2.0	3.0	1.0	0.90	0.60	< 0.6	0.30	0.50	0.40	< 0.40	0.60	2.00
Ammonia (lbs) Total Annual												
TKN (mg/L) Average Monthly	< 1.387	3.75	< 0.50	< 1.838	2.60	< 0.50	< 0.50	< 0.5	< 0.81	< 0.50	< 3.878	1.753

**NPDES Permit Fact Sheet  
Potters Mills Central Treatment System**

**NPDES Permit No. PA0232751**

TKN (lbs) Total Monthly	< 1.0	3.0	< 0.50	< 2.0	2.0	< 0.40	< 0.40	< 0.40	< 0.90	< 0.40	3.0	2.00
Total Phosphorus (mg/L) Average Monthly	8.52	8.52	5.74	6.10	6.32	6.5	7.0	6.67	6.56	6.95	5.74	4.08
Total Phosphorus (lbs) Effluent Net Total Monthly	8.0	8.0	6.0	6.0	5.0	5.0	6.0	5.0	7.0	6.00	5.0	4.00
Total Phosphorus (lbs) Total Monthly	8.0	8.0	6.0	6.0	5.0	5.0	6.0	5.0	7.00	6.00	5.0	4.00
Total Phosphorus (lbs) Effluent Net Total Annual								48.0				
Total Phosphorus (lbs) Total Annual								48.0				

**Compliance History, Cont'd**

<b>Summary of Inspections:</b>		The facility has been inspected by the Department since beginning operation in November 2019. The most recent Chesapeake Bay inspection on February 18, 2021 identified the failure to meet the phosphorus cap load. A routine partial inspection on July 27, 2020 identified the failure to take samples as required by the permit.
<b>Other Comments:</b>		A query in WMS found two open violations for Potter Township, Centre County in eFACTS: <ul style="list-style-type: none"> <li>• Violation ID No. 889734 for Violation of NPDES effluent limits, 7/28/20 and</li> <li>• Violation ID No. 889735 for Failure to monitor pollutants as required by the NPDES Permit.</li> </ul>

**Existing Effluent Limitations and Monitoring Requirements**

The limitations and Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instantaneous Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	2.91	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Total Suspended Solids	3.50	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report	XXX	1/year	Grab
Ultraviolet light intensity (µw/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Calculation
Ammonia-Nitrogen	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab

Compliance Sampling Location: Outfall 001

Existing Effluent Limitations and Monitoring Requirements								
Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	2/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Net Total Nitrogen	Report	0	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	0	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

The permittee is authorized to use 975 lbs/year as Total Nitrogen (TN) Offsets toward compliance with the Annual Net TN mass load limitation (Cap Load), in accordance with Part C of the permit. These offsets may be applied through the Compliance Year or during the Truing Period. The application of Offsets must be reported to DEP as described in Part C. The offsets are authorized for the following pollutant load reduction activities.

- Connection of 39 EDUs to the public sewer system after January 1, 2003, in which 25 lbs/year of TN offsets are granted per EDU



**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.014</u>
<b>Latitude</b> <u>40° 48' 44.35"</u>	<b>Longitude</b> <u>-77° 38' 17.86"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

Comments: The above limitations are applicable and are included in the existing permit. In addition to the Fecal Coliform limitations listed above the permit will include e. coli bacteria monitoring consistent with current Department policy and recent changes to Chapter 93 of the Department's regulations.

**Water Quality-Based Limitations**

**DO, CBOD5 and NH3-N**

The Department uses the WQM7.0 model to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. The model incorporates recent changes to the NH<sub>3</sub>-N criteria in 25 PA Code §93. WQM7.0 modeling was performed of the discharge to the Sinking Creek and showed that no limitations are necessary beyond the technology-based secondary treatment limits listed above (see Attachment B). Due to minimum DO levels in the discharge being less than the typical assumption of 3 mg/L, the DO input into the model was 2.0 mg/L. The existing DO and ammonia monitoring will continue.

**Toxics Management**

No additional reasonable potential analysis will be evaluated for this minor POTW with no significant industrial users.

**Best Professional Judgment (BPJ) Limitations**

Comments: None needed besides the above technology and water quality-based limits.

**Chesapeake Bay/Nutrient Requirements**

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant and new dischargers in Pennsylvania in order to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. As a 0.014 MGD facility which was first permitted in 2016, the Potters Mills treatment facility is considered a new non-significant Phase 5, Significant Chesapeake Bay discharger. Nutrient cap loadings of 0 pounds for both Total Nitrogen and Total Phosphorus have previously been established for this discharge consistent with the Phase III Watershed Implementation Plan.

The discharge's cap loadings as well as the actual Total Nitrogen and Total Phosphorus loadings for the past cycle are listed in the table below. The permittee has failed to meet the TP cap load. Consistent with the Phase III WIP and a February 3, 2021 amendment to this NPDE Permit, the facility is afforded 975 lbs of TN Offsets which are listed specifically in the NPDES Permit as TN Offsets available to the Township for compliance with the Cap Load.

<b>Nutrient</b>	<b>Total Nitrogen</b>	<b>Total Phosphorus</b>
<b>Nutrient Cap Loads for PA0114821</b>	0	0
<b>10/1/19 – 9/30/20 Total Loadings</b>	<330	48.0
<b>Offsets Applied</b>	330	--
<b>10/1/18 – 9/30/19 Net Loadings</b>	0	48.0

**Anti-Backsliding**

No proposed limitations were made less stringent consistent with the anti-degradation requirements of the Clean Water Act and 40 CFR 122.44(l).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instantaneous Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	2.91	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Total Suspended Solids	3.50	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report	XXX	1/year	Grab
Ultraviolet light intensity (µw/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Calculation
Ammonia-Nitrogen	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab

Compliance Sampling Location: Outfall 001

Other Comments: The above limitations and monitoring are unchanged from the existing permit except for the inclusion of e. coli monitoring as mentioned above.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	Grab
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	2/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/month	Grab
Net Total Nitrogen	XXX	0 <sup>(3)</sup>	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	XXX	0	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

The permittee is authorized to use 975 lbs/year as Total Nitrogen (TN) Offsets toward compliance with the Annual Net TN mass load limitation (Cap Load), in accordance with Part C. These offsets may be applied through the Compliance Year or during the Truing Period. The application of Offsets must be reported to DEP as described in Part C. The offsets are authorized for the following pollutant load reduction activities.



- Connection of 39 EDUs to the public sewer system after January 1, 2003, in which 25 lbs/year of TN offsets are granted per EDU

Comments: Monthly reporting of Net Total Nitrogen and Net Total Phosphorus loads have been removed consistent with current standard Chesapeake Bay nutrient monitoring requirements.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 8/23/13
<input type="checkbox"/>	Other: [redacted]

Attachment:

- A. Discharge Location Map
- B. WQM7.0 Model



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
06A	18377	SINKING CREEK	6.810	1128.40	19.10	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.077	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Potter Twp	PA0232751	0.0140	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	2.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70



### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
06A	18377	SINKING CREEK	5.560	1120.00	21.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.077	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
06A		18377		SINKING CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
6.810	1.47	0.00	1.47	.0217	0.00127	.577	21.08	36.52	0.12	0.623	20.07	7.00
<b>Q1-10 Flow</b>												
6.810	0.94	0.00	0.94	.0217	0.00127	NA	NA	NA	0.10	0.796	20.11	7.00
<b>Q30-10 Flow</b>												
6.810	2.00	0.00	2.00	.0217	0.00127	NA	NA	NA	0.15	0.525	20.05	7.00

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>					
06A		18377		SINKING CREEK					
<b>NH3-N Acute Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
6.810	Potter Twp	16.6	50	16.6	50	0	0		
<b>NH3-N Chronic Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
6.810	Potter Twp	1.88	25	1.88	25	0	0		
<b>Dissolved Oxygen Allocations</b>									
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
6.81	Potter Twp	25	25	25	25	2	2	0	0

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
06A	18377	SINKING CREEK	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
6.810	0.014	20.073	7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
21.081	0.577	36.520	0.123
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.33	0.159	0.36	0.704
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.152	1.486	Tsivoglou	6
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>		
0.623	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
		<u>D.O. (mg/L)</u>	
	0.062	2.31	0.35
	0.125	2.29	0.33
	0.187	2.27	0.32
	0.249	2.24	0.30
	0.311	2.22	0.29
	0.374	2.20	0.28
	0.436	2.18	0.27
	0.498	2.16	0.26
	0.561	2.13	0.24
	0.623	2.11	0.23

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
06A	18377	SINKING CREEK	
<u>RMI</u>	<u>Name</u>	<u>Permit Number</u>	<u>Disc Flow (mgd)</u>
6.810	Potter Twp	PA0232751	0.014
		<u>Parameter</u>	<u>Eff. Limit 30-day Ave. (mg/L)</u>
		CBOD5	25
		NH3-N	25
		Dissolved Oxygen	50
			<u>Eff. Limit Maximum (mg/L)</u>
			2
			<u>Eff. Limit Minimum (mg/L)</u>