

Application Type	<u>Renewal</u>
Wastewater Type	<u>Sewage</u>
Facility Type	<u>SRSTP</u>

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No.	PA0233749
APS ID	1107932
Authorization ID	1474076

Applicant, Facility and Project Information


Applicant Name	<u>Jeffrey L Freezer</u>	Facility Name	<u>Jeffrey Freezer Subdivision</u>
Applicant Address	<u>151 Mahaffey Hollow Road Ext</u>	Facility Address	<u>151 Mahaffey Hollow Road Ext</u>
	<u>Linden, PA 17744-7793</u>		<u>Linden, PA 17744-7793</u>
Applicant Contact	<u>Jeffrey Freezer</u>	Facility Contact	<u>Jeffrey Freezer</u>
Applicant Phone	<u>(570) 323-6057</u>	Facility Phone	<u>(570) 323-6057</u>
Client ID	<u>268711</u>	Site ID	<u>711168</u>
SIC Code	<u>4952</u>	Municipality	<u>Woodward Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Lycoming</u>
Date Application Received	<u>February 22, 2024</u>	WQM Required	
Date Application Accepted	<u>March 7, 2024</u>	WQM App. No.	
Project Description	Application for a renewal of an individual NPDES permit for the discharge of treated sewage from a SRSTP.		

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This permit is for the discharge from an existing single residence sewage treatment plant (SRSTP) serving a three-bedroom home. The treatment plant replaced an existing malfunctioning onlot septic system.

An individual Single Residence permit is required due to the use of an alternative design that is not covered in the *Small Flow Treatment Facilities Design Manual* (Document 362-0300-002.) The Premier Tech Aqua Ecoflo Coco Biofilter Ecoflo STB-650 PR can be used in PAG-04 applications. However, this older model is a STB-650 fiberglass units which is not acceptable for a general permit.

Approve	Deny	Signatures	Date
X		 Jonathan P. Peterman / Project Manager	February 18, 2025
X		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	February 18, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.0004
Latitude	4° 15' 31.76"	Longitude	-77° 8' 14.40"
Quad Name	SALLADASBURG	Quad Code	0828
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Quenshukeny Run (WWF, MF)	Stream Code	20970
NHD Com ID	66915689	RMI	0.6600
Drainage Area	-	Yield (cfs/mi ²)	-
Q ₇₋₁₀ Flow (cfs)	-	Q ₇₋₁₀ Basis	-
Elevation (ft)	-	Slope (ft/ft)	-
Watershed No.	10-A	Chapter 93 Class.	WWF, MF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	N/A		
Source(s) of Impairment	N/A		
TMDL Status	N/A	Name	N/A
Nearest Downstream Public Water Supply Intake	PA American Water White Deer		
West Branch of Susquehanna			
PWS Waters	River	Flow at Intake (cfs)	682
PWS RMI	10.5	Distance from Outfall (mi)	36

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary				
Treatment Facility Name: Jeffrey Freezer Subdivision				
Waste Type	Degree of Treatment	Process Type	Disinfection	Design Flow (MGD)
Sewage	Tertiary	ECOFLOW Peat Filter	Ultraviolet	0.0004
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0004	--	Not Overloaded	None.	Other WWTP.

Treatment System Components:

- One (1) 1,000-Gallon Septic Tank.
- One (1) EFT-080 Effluent filter.
- One (1) 500 GPD Peat Bio-filter (Premier-Tech Model STB-650).
- One (1) UV Disinfection system.
- One (1) Outfall 001.

Changes Since Last Permit Issuance: N/A.

Other Comments: WQM permit 4108402 was issued on 3/2/2009 for the original construction.

Existing Effluent Limitations and Monitoring Requirements

Existing Limits – Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200 Daily Max	XXX	XXX	1/year	Grab

*The existing effluent limits for Outfall 001 were based on a design flow of 0.0004 MGD.

Chesapeake Bay Requirements

Facilities that are designed based on a flow of less than 2,000 GPD (400 GPD design flow for this facility) are not a part of Pennsylvania's Chesapeake Bay Tributary Strategy. Accordingly, it is not practicable to require the permittee to perform nutrient monitoring.

Anti-Backsliding

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
CBOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

*The proposed effluent limits for Outfall 001 were based on a design flow of 0.0004 MGD.

Development of Effluent Limitations and Monitoring Frequencies

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	10	Average Monthly	125.3(a)(2)(i)	DEP SFTF Design Manual (Document 362-0300-002)
	20	IMAX		
Total Suspended Solids	10	Average Monthly	125.3(a)(2)(i)	DEP SFTF Design Manual (Document 362-0300-002)
	20	IMAX		
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform	200 / 100 ml	Geo Mean	-	92a.47(a)(4)

CBOD₅ (10 mg/L) and TSS (10mg/L) are technology-based limits stipulated in the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001). The fecal coliform limits correspond with 25 PA Code § 92a.47 (a)(4). pH monitoring is not required for SRSTPs. The treatment design utilizes UV disinfection. No monitoring is required for UV disinfection systems at SRSTPs.

All of the monitoring frequencies sample types correspond with the policies and procedures stipulated in the SOP in lieu of the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001).

Compliance History

WMS Query Summary - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed that there were no unresolved violations.